


Dorota Szmajda-Kuberczyk  
tłumacz przysięgły języka angielskiego  
Rybie, ul. Kasztanowa 33, 05-090 Raszyn  
tel. 501 123 253



POŚWIADCZONE TŁUMACZENIE Z JĘZYKA ANGIELSKIEGO

[Dokument źródłowy, przedstawiony w formie elektronicznej, składa się z 35 numerowanych arkuszy. Na życzenie Klienta przetłumaczono strony jak niżej. Tekst w nawiasach kwadratowych pochodzi od tłumacza.] -----

[nagłówek (na każdym arkuszu oprócz 1)]: logo · **DUŃSKI INSTYTUT TECHNOLOGICZNY** [ang. Danish Technological Institute] · numer strony w formacie [nr strony] z 35 · 300-KLAB-24-026-3 -----

[stopka (na każdym arkuszu)]: logo ilac-MRA · logo DANAK · Test Reg. nr. 300 -----

[arkusz 1]: -----

logo · **DUŃSKI INSTYTUT TECHNOLOGICZNY** [ang. Danish Technological Institute] · Teknologiparken · Kongsvang Allé 29, DK-8000 Aarhus C · +45 72 20 20 00 · [Info@teknologisk.dk](mailto:Info@teknologisk.dk) · [www.teknologisk.dk](http://www.teknologisk.dk) -----  
Strona 1 z 35 -----

Inicjały: PRES/RTHI -----

Nr akt: 249417 -----

Załączniki: 1 -----

**RAPORT Z BADAŃ** -----

Nr raportu: 300-KLAB-24-026-3 -----

**Klient:** -----

Firma: GUANGDONG PHNIX ECO-ENERGY SOLUTION LTD. -----

Adres: No. 3 Tianyuan Road, Dagang Town, Nansha District, Guangzhou -----

Miasto: Guangdong, 511470, Chiny -----

Tel. + 86 020-39067523 -----

**Element:** -----

Marka: PHNIX -----

Typ: pompa ciepła powietrze-woda (monoblok) -----

Model: PASRW040S-BP-PS-B -----

Nr serii: B082209290005 -----

Rok produkcji: nie dotyczy -----

**Marka:** -----



Marka: Cooper & Hunter -----

Typ: pompa ciepła powietrze-woda (monoblok) -----

Model: CH-HP12-UIMPRM-P -----

Daty: element badany: od kwietnia do czerwca 2024 r. -----

Procedura: zob. cel z wykazem norm (strona 2). -----

Uwagi: jednostka została dostarczona przez klienta. Instalacji oraz ustawień testowych dokonano zgodnie z instrukcjami producenta. -----

Warunki: niniejsze badanie zostało przeprowadzone w ramach akredytacji zgodnie z wymogami międzynarodowymi (ISO/IEC 17025:2017) oraz zgodnie z Ogólnymi Warunkami Duńskiego Instytutu Technologicznego. Wyniki badania odnoszą się wyłącznie do badanego urządzenia. Niniejszy raport z badań może być przytaczany w formie wyciągu wyłącznie po uzyskaniu pisemnej zgody Duńskiego Instytutu Technologicznego. -----

Klient nie może wymieniać ani powoływać się na Duński Instytut Technologiczny ani na pracowników Duńskiego Instytutu Technologicznego w celach marketingowych lub reklamowych bez każdorazowej pisemnej zgody Duńskiego Instytutu Technologicznego. -----

Dział/Ośrodek: Duński Instytut Technologiczny · Energia i Klimat · Laboratorium Pomp Ciepła, Aarhus -----

Data: 06 sierpnia 2024 r. -----

Podpis: -----

Preben Eskerod -----

B.TecMan & MarEng -----

Współpraca: -----

Rasmus Thisgaard -----

B.TecMan & MarEng -----

DOKUMENT PODPISANY CYFROWO -----


06 sierpnia 2024 r. -----

Duński Instytut Technologiczny -----

[arkusz 8]: -----

Wyniki badań SCOP w niskiej temperaturze – dla średniej sezonu grzewczego (A) – EN 14825 -----

|                              |                   |
|------------------------------|-------------------|
| Model (jednostka zewnętrzna) | PASRW040S-BP-PS-B |
|------------------------------|-------------------|



|  |   |
|--|---|
| Pompa ciepła powietrze-woda monoblok     | T |
| Niskotemperaturowa pompa ciepła          | N |
| Wyposażona w dodatkowy ogrzewacz         | N |
| Wielofunkcyjny ogrzewacz z pompą ciepła  | N |
| Obliczenie SCOP wykonane jako odwracalne | T |

|  |                    |           |
|--|--------------------|-----------|
| Znamionowa moc cieplna <sup>1)</sup>                     | P <sub>RATED</sub> | 8,73 [kW] |
| Sezonowa efektywność energetyczna ogrzewania pomieszczeń | η <sub>S</sub>     | 178,6 [%] |

|   |  |  |     |  |
|---|--|--|-----|--|
| Zmierzona wydajność grzewcza przy częściowym obciążeniu w temperaturze zewnętrznej T <sub>j</sub> | Klimat umiarkowany - Zastosowanie w niskiej temperaturze | T <sub>i</sub> = 15°C<br>T <sub>i</sub> = -7°C<br>T <sub>i</sub> = 2°C<br>T <sub>i</sub> = 7°C<br>T <sub>i</sub> = 12°C<br>T <sub>j</sub> = temperatura dwuwartościowa<br>T <sub>i</sub> = granica działania | Pdh | - [kW]<br>7,94 [kW]<br>5,20 [kW]<br>3,64 [kW]<br>4,21 [kW]<br>7,94 [kW]<br>8,73 [kW] |
|---|--|--|-----|--|

|   |  |  |      |   |
|---|--|--|------|---|
| Zmierzony współczynnik wydajności w temperaturze zewnętrznej T <sub>j</sub> | Klimat umiarkowany - Zastosowanie w niskiej temperaturze | T <sub>i</sub> = 15°C<br>T <sub>i</sub> = -7°C<br>T <sub>i</sub> = 2°C<br>T <sub>i</sub> = 7°C<br>T <sub>i</sub> = 12°C<br>T <sub>j</sub> = temperatura dwuwartościowa<br>T <sub>i</sub> = granica działania | COPd | - [-]<br>3,29 [-]<br>4,22 [-]<br>5,74 [-]<br>8,15 [-]<br>3,29 [-]<br>2,91 [-] |
|---|--|--|------|---|

|                               |           |          |
|-------------------------------|-----------|----------|
| Temperatura dwuwartościowa    | Tbivalent | -7 [°C]  |
| Graniczna temperatura robocza | TOL       | -10 [°C] |
| robocza                       | WTOL      | - [°C]   |
| Współczynnik strat            | Cdh       | 0,95 [-] |

|   |  |   |  |
|---|--|---|--|
| Pobór mocy w trybach innych niż aktywny | Tryb wyłączenia<br>Tryb wyłączonego termostatu<br>Tryb gotowości<br>Tryb włączonej grzalki karteru | P <sub>OFF</sub><br>P <sub>TO</sub><br>P <sub>SB</sub><br>P <sub>CK</sub> | 0,020 [kW]<br>0,024 [kW]<br>0,020 [kW]<br>0,020 [kW] |
| Ogrzewacz dodatkowy <sup>1)</sup>       | Znamionowa moc cieplna<br>Rodzaj energii zasilania   | P <sub>SUP</sub>  | 0,00 [kW]<br>elektryczna                             |

|              |  |   |
|--------------|--|---|
| Inne pozycje | Regulacja wydajności<br>Regulacja przepływu wody<br>Natężenie przepływu wody<br>Roczne zużycie energii | zmienna<br>stała<br>1700 [l/h]<br>Q <sub>HE</sub> |
|              |  | 3973 [kWh]  |


W przypadku ogrzewaczy pomieszczeń z pompą ciepła i wielofunkcyjnych ogrzewaczy z pompą ciepła znamionowa moc cieplna (Prated) jest równa obciążeniu obliczeniowemu dla trybu ogrzewania (Pdesignh), a znamionowa moc grzewcza ogrzewacza dodatkowego (Psup), jest równa dodatkowej wydajności grzewczej (sup(T<sub>j</sub>)).

Do obliczenia SCOP użyto wartości P<sub>CK</sub> - P<sub>SB</sub>. Zob. „SCOP – dokładne obliczenie”.

[arkusz 9]: -----

Wyniki badań SCOP w średniej temperaturze – dla średniej sezonu

grzewczego (A) – EN 14825 -----



|  |                   |  |
|--|-------------------|--|
| Model (jednostka zewnętrzna)           | PASRW040S-BP-PS-B |  |
| Pompa ciepła powietrze-woda monoblok   | T                 |  |
| Niskotemperaturowa pompa ciepła        | N                 |  |
| Wyposażona w dodatkową grzałkę         | N                 |  |
| Kombinowana grzałka z pompą ciepła     | N                 |  |
| Obliczenie SCOP wykonane jako odwrotne | T                 |  |

|  |                    |           |
|--|--------------------|-----------|
| Znamionowa moc cieplna <sup>1)</sup>                     | P <sub>RATED</sub> | 9,51 [kW] |
| Sezonowa efektywność energetyczna ogrzewania pomieszczeń | $\eta_S$           | 129,3 [%] |
|  | SCOP               | 3,31 [-]  |

|   |                      |  |     |  |
|---|----------------------|--|-----|--|
| Zmierzona wydajność grzewcza przy częściowym obciążeniu w temperaturze zewnętrznej T <sub>j</sub> | Klimat umiarkowany - | T <sub>j</sub> = 15°C<br>T <sub>j</sub> = -7°C<br>T <sub>j</sub> = 2°C<br>T <sub>j</sub> = 7°C<br>T <sub>j</sub> = 12°C<br>T <sub>j</sub> = temperatura dwuwartościowa<br>T <sub>j</sub> = granica działania | Pdh | - [kW]<br>8,61 [kW]<br>5,55 [kW]<br>3,63 [kW]<br>4,11 [kW]<br>8,61 [kW]<br>8,45 [kW] |
|---|----------------------|--|-----|--|

|   |                      |  |      |   |
|---|----------------------|--|------|---|
| Zmierzony współczynnik wydajności w temperaturze zewnętrznej T <sub>j</sub> | Klimat umiarkowany - | T <sub>j</sub> = 15°C<br>T <sub>j</sub> = -7°C<br>T <sub>j</sub> = 2°C<br>T <sub>j</sub> = 7°C<br>T <sub>j</sub> = 12°C<br>T <sub>j</sub> = temperatura dwuwartościowa<br>T <sub>j</sub> = granica działania | COPd | - [-]<br>2,24 [-]<br>3,27 [-]<br>3,84 [-]<br>5,87 [-]<br>2,24 [-]<br>2,11 [-] |
|---|----------------------|--|------|---|

|                               |           |          |
|-------------------------------|-----------|----------|
| Temperatura dwuwartościowa    | Tbivalent | -7 [°C]  |
| Graniczna temperatura robocza | TOL       | -10 [°C] |
| Współczynnik strat            | WTOL      | - [°C]   |
|                               | Cdh       | 0,97 [-] |

|   |  |   |  |
|---|--|---|--|
| Pobór mocy w trybach innych niż aktywny | Tryb wyłączenia<br>Tryb wyłączonego termostatu<br>Tryb gotowości<br>Tryb włączonej grzałki karteru | P <sub>OFF</sub><br>P <sub>TO</sub><br>P <sub>SB</sub><br>P <sub>CK</sub> | 0,020 [kW]<br>0,024 [kW]<br>0,020 [kW]<br>0,020 [kW] |
| Ogrzewacz dodatkowy <sup>1)</sup>       | Znamionowa moc cieplna<br>Rodzaj energii zasilania   | P <sub>SUP</sub>  | 1,06 [kW]<br>elektryczna                             |

|              |   |  |
|--------------|---|--|
| Inne pozycje | Regulacja wydajności<br>Regulacja przepływu wody<br>Natężenie przepływu wody<br>Rocznne zużycie energii Q <sub>HE</sub> | zmienna<br>stała<br>1050 (l/h)<br>5942 [kWh] |
|--------------|---|--|

|   |
|---|
| W przypadku ogrzewaczy pomieszczeń z pompą cieplą i wielofunkcyjnych ogrzewaczy z pompą ciepłą znamionowa moc cieplna (Prated) jest równa obciążeniu obliczeniowemu dla trybu ogrzewania (Pdesignh), a znamionowa moc grzewcza ogrzewacza dodatkowego (Psup), jest równa dodatkowej wydajności grzewczej (sup(Tj)).<br>Do obliczenia SCOP użyto wartości P <sub>CK</sub> - P <sub>SB</sub> . Zob. „SCOP – dokładne obliczenie”. |
|---|

[arkusz 10]: -----

Wyniki badań dla warunków znamionowych znormalizowanych – EN  
14511

| Nr | Warunki badania | Wydajność grzewcza [kW] | COP   |
|----|-----------------|-------------------------|-------|
| 1  | A7/W35          | 10,119                  | 4,637 |
| 2  | A7/W55          | 9,647                   | 2,930 |



BB

Wyniki badań dla rozruchu i działania – EN 14511-4

| Nr        | Warunki badania<br>Wlot powietrze/woda [C°] | Walidacja badania |
|-----------|---|-------------------|
| rozruch   | A-25/W9                                     | pozytywna         |
| działanie | A-25/W50                                    | pozytywna         |

Wyniki badań przy zamknięciu przepływu czynnika przekazującego  
ciepło po stronie skraplacza – EN 14511-4

| Nr | Wymiennik ciepła | Walidacja badania |
|----|------------------|-------------------|
| 1  | wewnętrzny       | pozytywna         |
| 2  | zewnętrzny       | pozytywna         |

Wyniki badań przy całkowej awarii zasilania energią elektryczną – EN  
14511-4

| Nr | Walidacja badania |
|----|-------------------|
| 1  | pozytywna         |

[arkusz 11]: -----

Wyniki pomiaru mocy akustycznej – EN 12102-1

| Nr             | Warunki badania | Poziom mocy akustycznej LW(A)<br>[dB re 1pW] | Niepewność $\sigma_{tot}$<br>[dB] |
|----------------|-----------------|--|-----------------------------------|
| 1 <sup>E</sup> | A7/W55          | 54,3   | 1,6                               |

E) Oznaczenie ErP -----

Poziom mocy akustycznej odniesionej do A jest oznaczony dla mierzonego zakresu częstotliwości od 100 Hz do 10 kHz. W celu obliczenia niepewności zob. Załącznik 1.

Pomiary mocy akustycznej wykonuje Kamalathasan Arumugam (KAMA) we współpracy z Patrickiem Gilbertem (PGL), Duński Instytut Technologiczny.

[arkusz 35]: -----

Załącznik 2 – Upoważnienie-----

Upoważnienie -----

[ang. Authorization Letter] -----

Niniejsza deklaracja zgodności zostaje wydana na wyjątkową odpowiedzialność:

Nazwa producenta: Guangdong PHNIX ECO-Energy Solution LTD -----  
Adres producenta: No. 3 Tianyuan Road, Dagang Town, Nansha District  
Guangzhou Guangdong, 511470 Chiny -----  
Oświadczamy, iż poniższy produkty, pompy ciepła, który wyprodukowaliśmy  
dla firmy COOPER AND HUNTER OVERSEAS LP, są identyczne jak nasze  
poniższe modele: -----

|                     |                   |
|---------------------|-------------------|
| Model Cooper&Hunter | CH-HP12-UIMPRM-P  |
| Model PHNIX         | PASRW040S-BP-PS-B |

Nazwa [firma] Cooper&Hunter: COOPER AND HUNTER OVERSEAS LP ---  
Nazwa marki Cooper&Hunter: Cooper&Hunter -----  
Adres Cooper&Hunter: SUITE 201, 45B WEST WILMOT STREET,  
RICHMOND HILL, ON L4B2P3 KANADA -----  
Uwaga: Niniejsza deklaracja traci ważność w przypadku wprowadzenia zmian  
technologicznych lub funkcjonalnych bez zgody producenta. -----  
Data: 24 maja 2024 r. -----  
Podmiot upoważniony: Guangdong PHNIX ECO-Energy Solution LTD -----  
[-], nieczytelny podpis -----  
[Odcisk pieczęci o treści]: W imieniu Guangdong PHNIX ECO-Energy  
Solution LTD · [-], nieczytelny podpis · Podpis osoby upoważnionej -----

[koniec tłumaczenia]

Ja, Dorota Szmajda-Kuberczyk, tłumacz przysięgły języka angielskiego  
wpisana na liste tłumaczy przysięgłych Ministra Sprawiedliwości pod  
numerem TP/2161/05, stwierdzam zgodność powyższego tłumaczenia z  
dokumentem w języku angielskim (dokument elektroniczny pdf, którego  
wydruk, opatrzony pieczęcią i podpisem tłumacza, załączono do  
niniejszego).

Rybki, 08.08.2024 r.  
Nr Repertorium: 544/24



Dorota Gide

# TEST REPORT

Report no.:  
300-KLAB-24-026-3



DANISH  
TECHNOLOGICAL  
INSTITUTE

Teknologiparken  
Kongsvang Allé 29  
DK-8000 Aarhus C  
+45 72 20 20 00  
Info@teknologisk.dk  
www.teknologisk.dk

Page 1 of 35  
Init: PRES/RTHI  
File no.: 249401  
Enclosures: 1

**Customer:** Company: Guangdong PHNIX ECO-Energy Solution LTD  
Address: No. 3 Tianyuan Road, Dagang Town, Nansha District  
City: Guangzhou Guangdong, 511470 China  
Tel.: +86 020-39067523

**Component:** Brand: PHNIX  
Type: Air to water heat pump (monobloc)  
Model: PASRW040S-BP-PS-B  
Series no.: B082209290005  
Prod. year: N/A

**Brand name:** Brand: Cooper&Hunter  
Type: Air to water heat pump (mono block)  
Model: CH-HP12-UIMPRM-P

**Dates:** Component tested: April-June 2024

**Procedure:** See objective (page 2) for list of standards.

**Remarks:** The unit was delivered by the customer. The installation and test settings were done according to the manufacturer's instructions. All tests are done with enabled defrost mode.

**Terms:** This test was conducted under accreditation in accordance with international requirements (ISO/IEC 17025:2017) and in accordance with the General Terms and Conditions of Danish Technological Institute. The test results solely apply to the tested item. This test report may be quoted in extract only if Danish Technological Institute has granted its written consent.

The customer may not mention or refer to Danish Technological Institute or Danish Technological Institute's employees for advertising or marketing purposes unless Danish Technological Institute has granted its written consent in each case.

**Division/Centre:** Danish Technological Institute  
Energy and Climate  
Heat Pump Laboratory, Aarhus

**Date:** 2024.08.06

**Test Engineer:**  
Preben Eskerod  
B.TecMan & MarEng

**Co-reader:**  
Rasmus Thisgaard  
B.TecMan & MarEng



DIGITALLY SIGNED DOCUMENT

6 August 2024

DANISH TECHNOLOGICAL INSTITUTE



Test Reg. nr. 300



DANISH  
TECHNOLOGICAL  
INSTITUTE

Page 8 of 35  
300-KLAB-24-026-3

## Test results

### Test results of SCOP test at low temperature - heating season average (A) – EN 14825

|   |  |                                      |                  |            |
|---|--|--------------------------------------|------------------|------------|
| Model (Outdoor)   |  | PASRW040S-BP-PS-B                    |                  |            |
| Air-to-water heat pump mono bloc  |  | Y                                    |                  |            |
| Low-temperature heat pump   |  | N                                    |                  |            |
| Equipped with supplementary heater  |  | N                                    |                  |            |
| Heat pump combination heater  |  | N                                    |                  |            |
| SCOP calculation done as reversible   |  | Y                                    |                  |            |
| Rated heat output <sup>1)</sup>   |  | P <sub>rated</sub>                   | 8.73 [kW]        |            |
| Seasonal space heating energy efficiency  |  | η <sub>s</sub>                       | 178.6 [%]        |            |
|   |  | SCOP                                 | 4.54 [-]         |            |
| Measured capacity for heating for part load at outdoor temperature T <sub>j</sub> | Average Climate<br>- Low temperature application | T <sub>j</sub> =-15 °C               | P <sub>dh</sub>  | - [kW]     |
|   |  | T <sub>j</sub> =-7 °C                | P <sub>dh</sub>  | 7.94 [kW]  |
|   |  | T <sub>j</sub> =2 °C                 | P <sub>dh</sub>  | 5.20 [kW]  |
|   |  | T <sub>j</sub> =7 °C                 | P <sub>dh</sub>  | 3.64 [kW]  |
|   |  | T <sub>j</sub> =12 °C                | P <sub>dh</sub>  | 4.21 [kW]  |
|   |  | T <sub>j</sub> =bivalent temperature | P <sub>dh</sub>  | 7.94 [kW]  |
|   |  | T <sub>j</sub> =operation limit      | P <sub>dh</sub>  | 8.73 [kW]  |
|   |  |                                      |                  |            |
| Measured coefficient of performance at outdoor temperature T <sub>j</sub>         | Average Climate<br>- Low temperature application | T <sub>j</sub> =-15 °C               | COP <sub>d</sub> | - [-]      |
|   |  | T <sub>j</sub> =-7 °C                | COP <sub>d</sub> | 3.29 [-]   |
|   |  | T <sub>j</sub> =2 °C                 | COP <sub>d</sub> | 4.22 [-]   |
|   |  | T <sub>j</sub> =7 °C                 | COP <sub>d</sub> | 5.74 [-]   |
|   |  | T <sub>j</sub> =12 °C                | COP <sub>d</sub> | 8.15 [-]   |
|   |  | T <sub>j</sub> =bivalent temperature | COP <sub>d</sub> | 3.29 [-]   |
|   |  | T <sub>j</sub> =operation limit      | COP <sub>d</sub> | 2.91 [-]   |
|   |  |                                      |                  |            |
| Bivalent temperature  |  | T <sub>bivalent</sub>                | -7 [°C]          |            |
| Operation limit temperatures  |  | TOL                                  | -10 [°C]         |            |
|   |  | WTOL                                 | - [°C]           |            |
| Degradation coefficient   |  | Cdh                                  | 0.95 [-]         |            |
| Power consumption in modes other than active mode                                 |  | Off mode                             | P <sub>OFF</sub> | 0.020 [kW] |
|   |  | Thermostat-off mode                  | P <sub>TO</sub>  | 0.024 [kW] |
|   |  | Standby mode                         | P <sub>SB</sub>  | 0.020 [kW] |
|   |  | Crankcase heater mode <sup>2)</sup>  | P <sub>CK</sub>  | 0.020 [kW] |
|   |  | Rated heat output                    | P <sub>SUP</sub> | 0.00 [kW]  |
| Supplementary heater <sup>1)</sup>  |  | Type of energy input                 | Electrical       |            |
| Other items   |  | Capacity control                     | Variable         |            |
|   |  | Water flow control                   | Fixed            |            |
|   |  | Water flow rate                      | 1700 [l/h]       |            |
|   |  | Annual energy consumption            | Q <sub>HE</sub>  | 3973 [kWh] |

<sup>1)</sup>For heat pump space heaters and heat pump combination heaters, the rated heat output, P<sub>rated</sub>, is equal to the design load for heating, P<sub>designh</sub>, and the rated heat output of a supplementary heater, P<sub>sup</sub>, is equal to the supplementary capacity for heating, sup(T<sub>j</sub>).

<sup>2)</sup>For SCOP calculation the value PCK - PSB is used. See section "SCOP - detailed calculation"



DANISH  
TECHNOLOGICAL  
INSTITUTE

Page 9 of 35  
300-KLAB-24-026-3

## Test results of SCOP test at medium temperature - heating season average (A) - EN 14825

|  |   |                                   |            |           |
|--|---|-----------------------------------|------------|-----------|
| <b>Model (Outdoor)</b>   | PASRW040S-BP-PS-B                                   |                                   |            |           |
| Air-to-water heat pump mono bloc   | Y   |                                   |            |           |
| Low-temperature heat pump  | N   |                                   |            |           |
| Equipped with supplementary heater   | N   |                                   |            |           |
| Heat pump combination heater   | N   |                                   |            |           |
| SCOP calculation done as reversible  | Y   |                                   |            |           |
| <b>Rated heat output<sup>1)</sup></b>  | $P_{rated}$   | 9.51 [kW]                         |            |           |
| <b>Seasonal space heating energy efficiency</b>  | $\eta_s$  | 129.3 [%]                         |            |           |
|  | SCOP  | 3.31 [-]                          |            |           |
| <b>Measured capacity for heating for part load at outdoor temperature <math>T_j</math></b> | Average Climate<br>- Medium temperature application | $T_j=-15\text{ }^\circ\text{C}$   | Pdh        | - [kW]    |
|  |   | $T_j=-7\text{ }^\circ\text{C}$    | Pdh        | 8.61 [kW] |
|  |   | $T_j=2\text{ }^\circ\text{C}$     | Pdh        | 5.55 [kW] |
|  |   | $T_j=7\text{ }^\circ\text{C}$     | Pdh        | 3.63 [kW] |
|  |   | $T_j=12\text{ }^\circ\text{C}$    | Pdh        | 4.11 [kW] |
|  |   | $T_j=\text{bivalent temperature}$ | Pdh        | 8.61 [kW] |
|  |   | $T_j=\text{operation limit}$      | Pdh        | 8.45 [kW] |
| <b>Measured coefficient of performance at outdoor temperature <math>T_j</math></b>         | Average Climate<br>- Medium temperature application | $T_j=-15\text{ }^\circ\text{C}$   | COPd       | - [-]     |
|  |   | $T_j=-7\text{ }^\circ\text{C}$    | COPd       | 2.24 [-]  |
|  |   | $T_j=2\text{ }^\circ\text{C}$     | COPd       | 3.27 [-]  |
|  |   | $T_j=7\text{ }^\circ\text{C}$     | COPd       | 3.84 [-]  |
|  |   | $T_j=12\text{ }^\circ\text{C}$    | COPd       | 5.87 [-]  |
|  |   | $T_j=\text{bivalent temperature}$ | COPd       | 2.24 [-]  |
|  |   | $T_j=\text{operation limit}$      | COPd       | 2.11 [-]  |
| <b>Bivalent temperature</b>  | Tbivalent   |                                   |            | -7 [°C]   |
| <b>Operation limit temperatures</b>  | TOL   |                                   |            | -10 [°C]  |
| <b>Degradation coefficient</b>   | WTOL  |                                   |            | - [°C]    |
| <b>Power consumption in modes other than active mode</b>                                   | Off mode  | $P_{off}$                         | 0.020 [kW] |           |
|  | Thermostat-off mode                                 | $P_{TO}$                          | 0.024 [kW] |           |
|  | Standby mode  | $P_{SB}$                          | 0.020 [kW] |           |
|  | Crankcase heater mode <sup>2)</sup>                 | $P_{CK}$                          | 0.020 [kW] |           |
| <b>Supplementary heater<sup>1)</sup></b>   | Rated heat output                                   | $P_{SUP}$                         | 1.06 [kW]  |           |
|  | Type of energy input                                |                                   | Electrical |           |
| <b>Other items</b>   | Capacity control                                    |                                   | Variable   |           |
|  | Water flow control                                  |                                   | Fixed      |           |
|  | Water flow rate                                     |                                   | 1050 [l/h] |           |
|  | Annual energy consumption                           | $Q_{HE}$                          | 5942 [kWh] |           |

<sup>1)</sup>For heat pump space heaters and heat pump combination heaters, the rated heat output,  $P_{rated}$ , is equal to the design load for heating,  $P_{designh}$ , and the rated heat output of a supplementary heater,  $P_{sup}$ , is equal to the supplementary capacity for heating,  $sup(T_j)$ .

<sup>2)</sup>For SCOP calculation the value  $P_{CK} - PSB$  is used. See section "SCOP - detailed calculation".



DANAK  
Test Reg. nr. 300



DANISH  
TECHNOLOGICAL  
INSTITUTE

Page 10 of 35  
300-KLAB-24-026-3

### Test results of standard rating test – EN 14511

| N <sup>#</sup> | Test conditions | Heating capacity [kW] | COP   |
|----------------|-----------------|-----------------------|-------|
| 1              | A7/W35          | 10.119                | 4.637 |
| 2              | A7/W55          | 9.647                 | 2.930 |

### Test results for starting and operating test - EN 14511-4

| N <sup>#</sup> | Test conditions<br>air/water inlet [°C] | Test validation |
|----------------|---|-----------------|
| Starting       | A-25/W9                                 | Passed          |
| Operating      | A-25/W50                                | Passed          |

### Test results for shutting off the heat transfer medium – EN 14511-4

| N <sup>#</sup> | Heat exchanger | Test validation |
|----------------|----------------|-----------------|
| 1              | Indoor         | Passed          |
| 2              | Outdoor        | Passed          |

### Test results for complete power supply failure – EN 14511-4

| N <sup>#</sup> | Test validation |
|----------------|-----------------|
| 1              | Passed          |





DANISH  
TECHNOLOGICAL  
INSTITUTE

Page 11 of 35  
300-KLAB-24-026-3

## Test results of sound power measurements – EN 12102-1

| N <sup>#</sup> | Test conditions | Sound power level LW(A)<br>[dB re 1pW] | Uncertainty $\sigma_{tot}$<br>[dB] |
|----------------|-----------------|--|------------------------------------|
| 1 <sup>E</sup> | A7/W55          | 54.3                                   | 1.6                                |

E) ErP labelling

The A-weighted total sound power level is determined for the measured frequency range from 100 Hz to 10 kHz. For the calculation of uncertainty, see appendix 1.

The sound power measurements are carried out by Kamalathan Arumugam (KAMA) and co-read by Patrick Glibert (PGL), Danish Technological Institute.



DANISH  
TECHNOLOGICAL  
INSTITUTE

Page 35 of 35  
300-KLAB-24-026-3

## Appendix 2 Authorization Letter

### Authorization Letter

This declaration of conformity is issued under the sole responsibility of

Manufacturer's Name: Guangdong PHNIX ECO-Energy Solution LTD

Manufacturer's Address: No. 3 Tianyuan Road, Dagang Town, Nansha District  
Guangzhou Guangdong, 511470 China

We declare that the following Heat pump product we produced for COOPER  
AND HUNTER OVERSEAS LP are identical to our following models

|                     |                   |
|---------------------|-------------------|
| Cooper&Hunter model | CH-HP12-UIMPRM-P  |
| PHNIX model         | PASRW040S-BP-PS-B |

Cooper&Hunter company name: COOPER AND HUNTER OVERSEAS LP


Cooper&Hunter brand /-mark: Cooper&Hunter

Cooper&Hunter address: SUITE 201, 45B WEST WILMOT STREET,  
RICHMOND HILL, ON L4B2P3 CANADA

Note: This declaration becomes invalid if technical or operational modifications  
are introduced without the manufacturer's consent.

For and on behalf of  
GUANGDONG PHNIX ECO-ENERGY SOLUTION LTD.  
广东芬尼克兹节能设备有限公司

Date: 24 May 2024



Authorised party: Guangdong PHNIX ECO-Energy Solution LTD  
Authorized Signature(s)



# TEST REPORT

Report no.:  
300-KLAB-24-026-3



DANISH  
TECHNOLOGICAL  
INSTITUTE

Teknologiparken  
Kongsvang Allé 29  
DK-8000 Aarhus C  
+45 72 20 20 00  
Info@teknologisk.dk  
www.teknologisk.dk

Page 1 of 35  
Init: PRES/RTHI  
File no.: 249401  
Enclosures: 1

**Customer:** Company: Guangdong PHNIX ECO-Energy Solution LTD  
Address: No. 3 Tianyuan Road, Dagang Town, Nansha District  
City: Guangzhou Guangdong, 511470 China  
Tel.: +86 020-39067523

**Component:** Brand: PHNIX  
Type: Air to water heat pump (monobloc)  
Model: PASRW040S-BP-PS-B  
Series no.: B082209290005  
Prod. year: N/A

**Brand name:** Brand: Cooper&Hunter  
Type: Air to water heat pump (mono block)  
Model: CH-HP12-UIMPRM-P

**Dates:** Component tested: April-June 2024

**Procedure:** See objective (page 2) for list of standards.

**Remarks:** The unit was delivered by the customer. The installation and test settings were done according to the manufacturer's instructions. All tests are done with enabled defrost mode.

**Terms:** This test was conducted under accreditation in accordance with international requirements (ISO/IEC 17025:2017) and in accordance with the General Terms and Conditions of Danish Technological Institute. The test results solely apply to the tested item. This test report may be quoted in extract only if Danish Technological Institute has granted its written consent.

The customer may not mention or refer to Danish Technological Institute or Danish Technological Institute's employees for advertising or marketing purposes unless Danish Technological Institute has granted its written consent in each case.

**Division/Centre:** Danish Technological Institute  
Energy and Climate  
Heat Pump Laboratory, Aarhus

**Date:** 2024.08.06

**Test Engineer:**  
Preben Eskerod  
B.TecMan & MarEng

**Co-reader:**  
Rasmus Thisgaard  
B.TecMan & MarEng



DANAK  
Test Reg. nr. 300



## Objective

The objective of this report is to document the following:

The Seasonal Coefficient of Performance (SCOP) at low and medium temperature application for average climate according to EN 14825:2022.

In order to calculate the SCOP, tests were carried out at the part load conditions stated in the tables on page 4 and 5.

COP test standard rating conditions A7/W35 and A7/W55 according to EN 14511:2022.

Operating requirements according to EN 14511-4:2022

- 4.2.1 Starting and operating tests
- 4.5 Shutting off the heat transfer medium flows
- 4.6 Complete power supply failure

Sound power measurements according to EN 12102-1:2022.



## Contents:

|  |           |
|--|-----------|
| <b>Test conditions .....</b>   | <b>4</b>  |
| SCOP test conditions for low temperature – EN 14825 .....  | 4         |
| SCOP test conditions for medium temperature – EN 14825 .....                                     | 5         |
| Test conditions for standard rating condition - EN14511 .....                                    | 6         |
| Test conditions for operating requirements – EN 14511-4 .....                                    | 6         |
| Test conditions for shutting off the heat transfer medium – EN 14511-4 .....                     | 6         |
| Test conditions for complete power supply failure – EN 14511-4.....                              | 7         |
| Test conditions for sound power measurements – EN 12102-1 .....                                  | 7         |
| <b>Test results.....</b>   | <b>8</b>  |
| Test results of SCOP test at low temperature - heating season average (A) – EN 14825 .....       | 8         |
| Test results of SCOP test at medium temperature - heating season average (A) – EN 14825 .....    | 9         |
| Test results of standard rating test – EN 14511 .....  | 10        |
| Test results for starting and operating test - EN 14511-4.....                                   | 10        |
| Test results for shutting off the heat transfer medium – EN 14511-4.....                         | 10        |
| Test results for complete power supply failure – EN 14511-4.....                                 | 10        |
| Test results of sound power measurements – EN 12102-1 .....                                      | 11        |
| <b>Photo .....</b>   | <b>12</b> |
| <b>SCOP - detailed calculation .....</b>   | <b>14</b> |
| Detailed SCOP calculation of low temperature and average climate conditions – EN 14825.....      | 14        |
| Detailed SCOP calculation of medium temperature and average climate conditions – EN 14825 .....  | 16        |
| <b>Detailed test results .....</b>   | <b>18</b> |
| Detailed SCOP test results - low temperature application and average climate – EN 14825 .....    | 18        |
| Detailed SCOP test results - medium temperature application and average climate – EN 14825 ..... | 23        |
| Test results of standard rating condition - EN14511 .....  | 28        |
| Detailed test results of sound power measurement – Test N#1 .....                                | 30        |
| <b>Appendix 1 Sound power measurement.....</b>   | <b>31</b> |
| <b>Appendix 2 Authorization Letter .....</b>   | <b>35</b> |



## Test conditions

### SCOP test conditions for low temperature – EN 14825

Part load conditions for reference SCOP and reference SCOPon calculation of air to water units for low temperature application for the reference heating season;  
“A” = average, “W” = warmer, and “C” = colder.

| Condition | Part Load Ratio<br>in %                    |     |     |    | Outdoor heat<br>exchanger              |             | Indoor heat exchanger |                                    |                             |                             |
|-----------|--|-----|-----|----|--|-------------|-----------------------|------------------------------------|-----------------------------|-----------------------------|
|           |  |     |     |    | Inlet dry (wet) bulb<br>temperature °C |             | Fixed<br>outlet<br>°C | Variable outlet <sup>d</sup><br>°C |                             |                             |
|           | Formula                                    | A   | W   | C  | Outdoor<br>air                         | Exhaust air | All<br>climates       | A                                  | W                           | C                           |
| A         | $(-7 - 16) / (T_{designh} - 16)$           | 88  | n/a | 61 | -7(-8)                                 | 20(12)      | <sup>a</sup> / 35     | <sup>a</sup> / 34                  | n/a                         | <sup>a</sup> / 30           |
| B         | $(+2 - 16) / (T_{designh} - 16)$           | 54  | 100 | 37 | 2(1)                                   | 20(12)      | <sup>a</sup> / 35     | <sup>a</sup> / 30                  | <sup>a</sup> / 35           | <sup>a</sup> / 27           |
| C         | $(+7 - 16) / (T_{designh} - 16)$           | 35  | 64  | 24 | 7(6)                                   | 20(12)      | <sup>a</sup> / 35     | <sup>a</sup> / 27                  | <sup>a</sup> / 31           | <sup>a</sup> / 25           |
| D         | $(+12 - 16) / (T_{designh} - 16)$          | 15  | 29  | 11 | 12(11)                                 | 20(12)      | <sup>a</sup> / 35     | <sup>a</sup> / 24                  | <sup>a</sup> / 26           | <sup>a</sup> / 24           |
| E         | $(TOL - 16) / (T_{designh} - 16)$          |     |     |    | TOL                                    | 20(12)      | <sup>a</sup> / 35     | <sup>a</sup> / <sup>b</sup>        | <sup>a</sup> / <sup>b</sup> | <sup>a</sup> / <sup>b</sup> |
| F         | $(T_{bivalent} - 16) / (T_{designh} - 16)$ |     |     |    | T <sub>bivalent</sub>                  | 20(12)      | <sup>a</sup> / 35     | <sup>a</sup> / <sup>c</sup>        | <sup>a</sup> / <sup>c</sup> | <sup>a</sup> / <sup>c</sup> |
| G         | $(-15 - 16) / (T_{designh} - 16)$          | n/a | n/a | 82 | -15                                    | 20(12)      | <sup>a</sup> / 35     | n/a                                | n/a                         | <sup>a</sup> / 32           |

<sup>a</sup> With the water flow rate as determined at the standard rating conditions given in EN 14511-2 at 30/35 conditions for units with a fixed water flow rate, and with a fixed delta T of 5 K for units with a variable flow rate. If the resulting flow rate is below the minimum flow rate then this minimum flow rate is used with the outlet temperature.

<sup>b</sup> Variable outlet shall be calculated by interpolation from T<sub>designh</sub> and the temperature which is closest to the TOL.

<sup>c</sup> Variable outlet shall be calculated by interpolation between the upper and lower temperatures which are closest to the bivalent temperature.

<sup>d</sup> If the variable outlet temperature is below the minimum of the operation range of the unit, this minimum should be considered.

## Additional information

| Climate | T <sub>designh</sub> [°C] | T <sub>bivalent</sub> [°C] | TOL [°C] | Outlet<br>temperature | Flow rate |
|---------|---------------------------|----------------------------|----------|-----------------------|-----------|
| Average | -10                       | -7                         | -10      | Variable              | Fixed     |



## SCOP test conditions for medium temperature – EN 14825

Part load conditions for reference SCOP and reference SCOPon calculation of air to water units for medium temperature application for the reference heating season;  
"A" = average, "W" = warmer, and "C" = colder.

| Condition | Part Load Ratio<br>in %                    |     |     |    | Outdoor heat<br>exchanger              |             | Indoor heat exchanger |                                    |                             |                             |
|-----------|--|-----|-----|----|--|-------------|-----------------------|------------------------------------|-----------------------------|-----------------------------|
|           |  |     |     |    | Inlet dry (wet) bulb<br>temperature °C |             | Fixed<br>outlet<br>°C | Variable outlet <sup>d</sup><br>°C |                             |                             |
|           | Formula                                    | A   | W   | C  | Outdoor<br>air                         | Exhaust air | All<br>climates       | A                                  | W                           | C                           |
| A         | $(-7 - 16) / (T_{designh} - 16)$           | 88  | n/a | 61 | -7(-8)                                 | 20(12)      | <sup>a</sup> / 55     | <sup>a</sup> / 52                  | n/a                         | <sup>a</sup> / 44           |
| B         | $(+2 - 16) / (T_{designh} - 16)$           | 54  | 100 | 37 | 2(1)                                   | 20(12)      | <sup>a</sup> / 55     | <sup>a</sup> / 42                  | <sup>a</sup> / 55           | <sup>a</sup> / 37           |
| C         | $(+7 - 16) / (T_{designh} - 16)$           | 35  | 64  | 24 | 7(6)                                   | 20(12)      | <sup>a</sup> / 55     | <sup>a</sup> / 36                  | <sup>a</sup> / 46           | <sup>a</sup> / 32           |
| D         | $(+12 - 16) / (T_{designh} - 16)$          | 15  | 29  | 11 | 12(11)                                 | 20(12)      | <sup>a</sup> / 55     | <sup>a</sup> / 30                  | <sup>a</sup> / 34           | <sup>a</sup> / 28           |
| E         | $(TOL - 16) / (T_{designh} - 16)$          |     |     |    | TOL                                    | 20(12)      | <sup>a</sup> / 55     | <sup>a</sup> / <sup>b</sup>        | <sup>a</sup> / <sup>b</sup> | <sup>a</sup> / <sup>b</sup> |
| F         | $(T_{bivalent} - 16) / (T_{designh} - 16)$ |     |     |    | T <sub>bivalent</sub>                  | 20(12)      | <sup>a</sup> / 55     | <sup>a</sup> / <sup>c</sup>        | <sup>a</sup> / <sup>c</sup> | <sup>a</sup> / <sup>c</sup> |
| G         | $(-15 - 16) / (T_{designh} - 16)$          | n/a | n/a | 82 | -15                                    | 20(12)      | <sup>a</sup> / 55     | n/a                                | n/a                         | <sup>a</sup> / 49           |

<sup>a</sup> With the water flow rate as determined at the standard rating conditions given in EN 14511-2 at 47/55 conditions for units with a fixed water flow rate, and with a fixed delta T of 8 K for units with a variable flow rate. If the resulting flow rate is below the minimum flow rate then this minimum flow rate is used with the outlet temperature.

<sup>b</sup> Variable outlet shall be calculated by interpolation  $T_{designh}$  and the temperature which is closest to the TOL.

<sup>c</sup> Variable outlet shall be calculated by interpolation between the upper and lower temperatures which are closest to the bivalent temperature.

<sup>d</sup> If the variable outlet temperature is below the minimum of the operation range of the unit, this minimum should be considered.

## Additional information

| Climate | $T_{designh}$ [°C] | $T_{bivalent}$ [°C] | TOL [°C] | Outlet<br>temperature | Flow rate |
|---------|--------------------|---------------------|----------|-----------------------|-----------|
| Average | -10                | -7                  | -10      | Variable              | Fixed     |



## Test conditions for standard rating condition - EN14511

| N# | Heat source                     |                                 | Heat sink              |                         |
|----|---------------------------------|---------------------------------|------------------------|-------------------------|
|    | Inlet dry bulb temperature (°C) | Inlet wet bulb temperature (°C) | Inlet temperature (°C) | Outlet temperature (°C) |
| 1  | 7                               | 6                               | 30                     | 35                      |
| 2  | 7                               | 6                               | 47                     | 55                      |

## Test conditions for operating requirements – EN 14511-4

| N# | Heat source                     |                                 | Heat sink              | Water flow rate at indoor heat exchanger | Test      |
|----|---------------------------------|---------------------------------|------------------------|--|-----------|
|    | Inlet dry bulb temperature (°C) | Inlet wet bulb temperature (°C) | Inlet temperature (°C) |  |           |
| 1  | -25                             | -                               | 9                      | 850 L/h                                  | Starting  |
| 2  | -25                             | -                               | 50                     | 850 L/h                                  | Operating |

## Test conditions for shutting off the heat transfer medium – EN 14511-4

| N# | Heat source                     |                                 | Heat sink              |                         | Heat exchanger |
|----|---------------------------------|---------------------------------|------------------------|-------------------------|----------------|
|    | Inlet dry bulb temperature (°C) | Inlet wet bulb temperature (°C) | Inlet temperature (°C) | Outlet temperature (°C) |                |
| 1  | 7                               | 6                               | 30                     | 35                      | Indoor         |
| 2  | 7                               | 6                               | 30                     | 35                      | Outdoor        |



## Test conditions for complete power supply failure – EN 14511-4

| N <sup>#</sup> | Heat source                     |                                 | Heat sink              |                         |
|----------------|---------------------------------|---------------------------------|------------------------|-------------------------|
|                | Inlet dry bulb temperature (°C) | Inlet wet bulb temperature (°C) | Inlet temperature (°C) | Outlet temperature (°C) |
| 1              | 7                               | 6                               | 30                     | 35                      |

## Test conditions for sound power measurements – EN 12102-1

| N <sup>#</sup> | Test condition                                  |   | Heat pump setting     |                               |                       |                  |
|----------------|---|---|-----------------------|-------------------------------|-----------------------|------------------|
|                | Outdoor heat exchanger (dry bulb/wet bulb) (°C) | Indoor heat exchanger (inlet/outlet) (°C) | Compressor speed (Hz) | Fan speed Motor speed 1 (rpm) | Heating capacity (kW) | Power input (kW) |
| 1 <sup>E</sup> | 7/6   | 47/55                                     | 33                    | 325                           | 3.73                  | 1.62             |

E) ErP labelling



## Test results

### Test results of SCOP test at low temperature - heating season average (A) – EN 14825

| Model (Outdoor)   |  | PASRW040S-BP-PS-B                    |                  |           |  |
|---|--|--------------------------------------|------------------|-----------|--|
| <b>Air-to-water heat pump mono bloc</b>   |  | Y                                    |                  |           |  |
| <b>Low-temperature heat pump</b>  |  | N                                    |                  |           |  |
| <b>Equipped with supplementary heater</b>   |  | N                                    |                  |           |  |
| <b>Heat pump combination heater</b>   |  | N                                    |                  |           |  |
| <b>SCOP calculation done as reversible</b>  |  | Y                                    |                  |           |  |
| <b>Rated heat output<sup>1)</sup></b>   |  | P <sub>rated</sub>                   | 8.73 [kW]        |           |  |
| <b>Seasonal space heating energy efficiency</b>   |  | $\eta_s$                             | 178.6 [%]        |           |  |
|   |  | SCOP                                 | 4.54 [-]         |           |  |
| <b>Measured capacity for heating for part load at outdoor temperature T<sub>j</sub></b> | Average Climate<br>- Low temperature application | T <sub>j</sub> =-15 °C               | P <sub>dh</sub>  | - [kW]    |  |
|   |  | T <sub>j</sub> =-7 °C                | P <sub>dh</sub>  | 7.94 [kW] |  |
|   |  | T <sub>j</sub> =2 °C                 | P <sub>dh</sub>  | 5.20 [kW] |  |
|   |  | T <sub>j</sub> =7 °C                 | P <sub>dh</sub>  | 3.64 [kW] |  |
|   |  | T <sub>j</sub> =12 °C                | P <sub>dh</sub>  | 4.21 [kW] |  |
|   |  | T <sub>j</sub> =bivalent temperature | P <sub>dh</sub>  | 7.94 [kW] |  |
|   |  | T <sub>j</sub> =operation limit      | P <sub>dh</sub>  | 8.73 [kW] |  |
|   |  |                                      |                  |           |  |
| <b>Measured coefficient of performance at outdoor temperature T<sub>j</sub></b>         | Average Climate<br>- Low temperature application | T <sub>j</sub> =-15 °C               | COP <sub>d</sub> | - [-]     |  |
|   |  | T <sub>j</sub> =-7 °C                | COP <sub>d</sub> | 3.29 [-]  |  |
|   |  | T <sub>j</sub> =2 °C                 | COP <sub>d</sub> | 4.22 [-]  |  |
|   |  | T <sub>j</sub> =7 °C                 | COP <sub>d</sub> | 5.74 [-]  |  |
|   |  | T <sub>j</sub> =12 °C                | COP <sub>d</sub> | 8.15 [-]  |  |
|   |  | T <sub>j</sub> =bivalent temperature | COP <sub>d</sub> | 3.29 [-]  |  |
|   |  | T <sub>j</sub> =operation limit      | COP <sub>d</sub> | 2.91 [-]  |  |
|   |  |                                      |                  |           |  |
| <b>Bivalent temperature</b>   |  | Tbivalent                            | -7 [°C]          |           |  |
| <b>Operation limit temperatures</b>   |  | TOL                                  | -10 [°C]         |           |  |
| <b>Degradation coefficient</b>  |  | WTOL                                 | - [°C]           |           |  |
|   |  | Cdh                                  | 0.95 [-]         |           |  |
| <b>Power consumption in modes other than active mode</b>                                | Off mode   | P <sub>OFF</sub>                     | 0.020 [kW]       |           |  |
|   | Thermostat-off mode                              | P <sub>TO</sub>                      | 0.024 [kW]       |           |  |
|   | Standby mode                                     | P <sub>SB</sub>                      | 0.020 [kW]       |           |  |
|   | Crankcase heater mode <sup>2)</sup>              | P <sub>CK</sub>                      | 0.020 [kW]       |           |  |
| <b>Supplementary heater<sup>1)</sup></b>  | Rated heat output                                | P <sub>SUP</sub>                     | 0.00 [kW]        |           |  |
|   | Type of energy input                             |                                      | Electrical       |           |  |
| <b>Other items</b>  | Capacity control                                 |                                      | Variable         |           |  |
|   | Water flow control                               |                                      | Fixed            |           |  |
|   | Water flow rate                                  |                                      | 1700 [l/h]       |           |  |
|   | Annual energy consumption                        | Q <sub>HE</sub>                      | 3973 [kWh]       |           |  |

<sup>1)</sup>For heat pump space heaters and heat pump combination heaters, the rated heat output, P<sub>rated</sub>, is equal to the design load for heating, P<sub>designh</sub>, and the rated heat output of a supplementary heater, P<sub>sup</sub>, is equal to the supplementary capacity for heating, sup(T<sub>j</sub>).

<sup>2)</sup> For SCOP calculation the value PCK - PSB is used. See section "SCOP - detailed calculation"



## Test results of SCOP test at medium temperature - heating season average (A) – EN 14825

|   |  |   |  |  |
|---|--|---|--|--|
| <b>Model (Outdoor)</b>  | PASRW040S-BP-PS-B                                |   |  |  |
| Air-to-water heat pump mono bloc  | Y  |   |  |  |
| Low-temperature heat pump   | N  |   |  |  |
| Equipped with supplementary heater  | N  |   |  |  |
| Heat pump combination heater  | N  |   |  |  |
| SCOP calculation done as reversible   | Y  |   |  |  |
| <b>Rated heat output<sup>1)</sup></b>   | $P_{rated}$                                      | 9.51 [kW]   |  |  |
| <b>Seasonal space heating energy efficiency</b>   | $\eta_s$   | 129.3 [%]   |  |  |
|   | SCOP   | 3.31 [-]  |  |  |
| <b>Measured capacity for heating for part load at outdoor temperature T<sub>j</sub></b> | Average Climate - Medium temperature application | T <sub>j</sub> =-15 °C<br>T <sub>j</sub> =-7 °C<br>T <sub>j</sub> =2 °C<br>T <sub>j</sub> =7 °C<br>T <sub>j</sub> =12 °C<br>T <sub>j</sub> =bivalent temperature<br>T <sub>j</sub> =operation limit | P <sub>dh</sub><br>P <sub>dh</sub><br>P <sub>dh</sub><br>P <sub>dh</sub><br>P <sub>dh</sub><br>P <sub>dh</sub><br>P <sub>dh</sub>        | - [kW]<br>8.61 [kW]<br>5.55 [kW]<br>3.63 [kW]<br>4.11 [kW]<br>8.61 [kW]<br>8.45 [kW] |
| <b>Measured coefficient of performance at outdoor temperature T<sub>j</sub></b>         | Average Climate - Medium temperature application | T <sub>j</sub> =-15 °C<br>T <sub>j</sub> =-7 °C<br>T <sub>j</sub> =2 °C<br>T <sub>j</sub> =7 °C<br>T <sub>j</sub> =12 °C<br>T <sub>j</sub> =bivalent temperature<br>T <sub>j</sub> =operation limit | COP <sub>d</sub><br>COP <sub>d</sub><br>COP <sub>d</sub><br>COP <sub>d</sub><br>COP <sub>d</sub><br>COP <sub>d</sub><br>COP <sub>d</sub> | - [-]<br>2.24 [-]<br>3.27 [-]<br>3.84 [-]<br>5.87 [-]<br>2.24 [-]<br>2.11 [-]        |
| Bivalent temperature<br>Operation limit<br>temperatures<br>Degradation coefficient      |  | Tbivalent<br>TOL<br>WTOL<br>Cd <sub>h</sub>   | -7 [°C]<br>-10 [°C]<br>- [°C]<br>0.97 [-]  |  |
| <b>Power consumption in modes other than active mode</b>                                |  | Off mode<br>Thermostat-off mode<br>Standby mode<br>Crankcase heater mode <sup>2)</sup>  | P <sub>OFF</sub><br>P <sub>TO</sub><br>P <sub>SB</sub><br>P <sub>CK</sub>  | 0.020 [kW]<br>0.024 [kW]<br>0.020 [kW]<br>0.020 [kW]                                 |
| <b>Supplementary heater<sup>1)</sup></b>  |  | Rated heat output<br>Type of energy input   | P <sub>SUP</sub><br>Electrical   | 1.06 [kW]<br>Electrical  |
| <b>Other items</b>  |  | Capacity control<br>Water flow control<br>Water flow rate<br>Annual energy consumption  | Q <sub>HE</sub>  | Variable<br>Fixed<br>1050 [l/h]<br>5942 [kWh]  |

<sup>1)</sup>For heat pump space heaters and heat pump combination heaters, the rated heat output, Prated, is equal to the design load for heating, P<sub>designh</sub>, and the rated heat output of a supplementary heater, Psup, is equal to the supplementary capacity for heating, sup(T<sub>j</sub>).

<sup>2)</sup>For SCOP calculation the value PCK - PSB is used. See section "SCOP - detailed calculation"



### Test results of standard rating test – EN 14511

| N# | Test conditions | Heating capacity [kW] | COP   |
|----|-----------------|-----------------------|-------|
| 1  | A7/W35          | 10.119                | 4.637 |
| 2  | A7/W55          | 9.647                 | 2.930 |

### Test results for starting and operating test - EN 14511-4

| N#        | Test conditions<br>air/water inlet [°C] | Test validation |
|-----------|---|-----------------|
| Starting  | A-25/W9                                 | Passed          |
| Operating | A-25/W50                                | Passed          |

### Test results for shutting off the heat transfer medium – EN 14511-4

| N# | Heat exchanger | Test validation |
|----|----------------|-----------------|
| 1  | Indoor         | Passed          |
| 2  | Outdoor        | Passed          |

### Test results for complete power supply failure – EN 14511-4

| N# | Test validation |
|----|-----------------|
| 1  | Passed          |



## Test results of sound power measurements – EN 12102-1

| N <sup>#</sup> | Test conditions | Sound power level LW(A)<br>[dB re 1pW] | Uncertainty $\sigma_{tot}$<br>[dB] |
|----------------|-----------------|--|------------------------------------|
| 1 <sup>E</sup> | A7/W55          | 54.3                                   | 1.6                                |

E) ErP labelling

The A-weighted total sound power level is determined for the measured frequency range from 100 Hz to 10 kHz. For the calculation of uncertainty, see appendix 1.

The sound power measurements are carried out by Kamalathasan Arumugam (KAMA) and co-read by Patrick Glibert (PGL), Danish Technological Institute.



DANISH  
TECHNOLOGICAL  
INSTITUTE

Page 12 of 35  
300-KLAB-24-026-3

## Photo

### Unit




DANAK  
Test Reg. nr. 300



DANISH  
TECHNOLOGICAL  
INSTITUTE

Page 13 of 35  
300-KLAB-24-026-3

### Rating plate



DANAK  
Test Reg. nr. 300



## SCOP - detailed calculation

### Detailed SCOP calculation of low temperature and average climate conditions – EN 14825

#### Calculation of reference SCOP

$$SCOP = \frac{P_{designh} \times H_{he}}{P_{designh} \times H_{he} + H_{TO} \times P_{TO} + H_{SB} \times P_{SB} + H_{CK} \times P_{CK} + H_{OFF} \times P_{OFF}}$$

Where

$P_{design}$  =

Heating load of the building at design temperature, kW

$H_{he}$  =

Number of equivalent heating hours, 2066 h

$H_{TO}, H_{SB}, H_{CK}, H_{OFF}$  =

Number of hours for which the unit is considered to work in thermostat off mode, standby mode, crankcase heater mode and off mode, h, respectively

$P_{TO}, P_{SB}, P_{CK}, P_{OFF}$  =

Electricity consumption during thermostat off mode, standby mode, crankcase heater mode and off mode, kW, respectively

#### Data for SCOP

|         | Outdoor temperature [°C] | Part load ratio [%] | Part load [kW] | Declared capacity [kW] | Declared COP [-] | cdh [-] | CR [-] | COPbin [-] |
|---------|--------------------------|---------------------|----------------|------------------------|------------------|---------|--------|------------|
| A       | -7                       | 88                  | 7.72           | 7.94                   | 3.29             | 0.99    | 1.00   | 3.29       |
| B       | 2                        | 54                  | 4.70           | 5.20                   | 4.22             | 0.98    | 1.00   | 4.22       |
| C       | 7                        | 35                  | 3.02           | 3.64                   | 5.74             | 0.96    | 0.83   | 5.70       |
| D       | 12                       | 15                  | 1.34           | 4.21                   | 8.15             | 0.95    | 0.32   | 7.42       |
| E       | -10                      | 100                 | 8.73           | 8.73                   | 2.91             | 0.99    | 1.00   | 2.91       |
| F - BIV | -7                       | 88                  | 7.72           | 7.94                   | 3.29             | 0.99    | 1.00   | 3.29       |

#### Energy consumption for thermostat off, standby, off mode, crankcase heater mode

|                  | Hours [h] | Power input [kW] | Applied to SCOP calculation [kW] | Energy consumption [kWh] |
|------------------|-----------|------------------|----------------------------------|--------------------------|
| Off mode         | 0         | 0.01952          | 0.01952                          | 0                        |
| Thermostat off   | 178       | 0.02394          | 0.02394                          | 4.26132                  |
| Standby          | 0         | 0.01952          | 0.01952                          | 0                        |
| Crankcase heater | 178       | 0.01963          | 0.00011                          | 0.01958                  |



Calculation Bin for SCOP<sub>on</sub>

|                    | <b>Bin</b><br>[-] | <b>Outdoor<br/>temperature</b><br>[°C] | <b>Hours</b><br>[h] | <b>Heat load</b><br>[kW] | <b>Heat load<br/>covered by<br/>heat pump</b><br>[kW] | <b>Electrical<br/>back up<br/>heater</b><br>[kW] | <b>backup<br/>heater<br/>energy input</b><br>[kWh] | <b>COP<sub>bin</sub></b><br>[-] | <b>Annual<br/>heating<br/>demand</b><br>[kWh] | <b>Annual<br/>energy<br/>input</b><br>[kWh] | <b>Net annual<br/>heating<br/>capacity</b><br>[kWh] | <b>Net annual<br/>power<br/>input</b><br>[kWh] |
|--------------------|-------------------|--|---------------------|--------------------------|---|--|--|---------------------------------|---|---|---|--|
| <b>E</b>           | 21                | -10                                    | 1                   | 8.73                     | 8.73  | 0.00   | 0.00   | 2.91                            | 8.73  | 3.00  | 8.73  | 3.00   |
|                    | 22                | -9                                     | 25                  | 8.39                     | 8.39  | 0.00   | 0.00   | 3.03                            | 209.86  | 69.17                                       | 209.86  | 69.17  |
|                    | 23                | -8                                     | 23                  | 8.06                     | 8.06  | 0.00   | 0.00   | 3.16                            | 185.34  | 58.63                                       | 185.34  | 58.63  |
| <b>A / F - BIV</b> | 24                | -7                                     | 24                  | 7.72                     | 7.72  | 0.00   | 0.00   | 3.29                            | 185.34  | 56.35                                       | 185.34  | 56.35  |
|                    | 25                | -6                                     | 27                  | 7.39                     | 7.39  | 0.00   | 0.00   | 3.39                            | 199.45  | 58.80                                       | 199.45  | 58.80  |
|                    | 26                | -5                                     | 68                  | 7.05                     | 7.05  | 0.00   | 0.00   | 3.49                            | 479.48  | 137.19                                      | 479.48  | 137.19   |
|                    | 27                | -4                                     | 91                  | 6.72                     | 6.72  | 0.00   | 0.00   | 3.60                            | 611.10  | 169.85                                      | 611.10  | 169.85   |
|                    | 28                | -3                                     | 89                  | 6.38                     | 6.38  | 0.00   | 0.00   | 3.70                            | 567.79  | 153.42                                      | 567.79  | 153.42   |
|                    | 29                | -2                                     | 165                 | 6.04                     | 6.04  | 0.00   | 0.00   | 3.80                            | 997.23  | 262.16                                      | 997.23  | 262.16   |
|                    | 30                | -1                                     | 173                 | 5.71                     | 5.71  | 0.00   | 0.00   | 3.91                            | 987.50  | 252.76                                      | 987.50  | 252.76   |
|                    | 31                | 0                                      | 240                 | 5.37                     | 5.37  | 0.00   | 0.00   | 4.01                            | 1289.35                                       | 321.55                                      | 1289.35   | 321.55   |
|                    | 32                | 1                                      | 280                 | 5.04                     | 5.04  | 0.00   | 0.00   | 4.11                            | 1410.23                                       | 342.89                                      | 1410.23   | 342.89   |
| <b>B</b>           | 33                | 2                                      | 320                 | 4.70                     | 4.70  | 0.00   | 0.00   | 4.22                            | 1504.25                                       | 356.82                                      | 1504.25   | 356.82   |
|                    | 34                | 3                                      | 357                 | 4.37                     | 4.37  | 0.00   | 0.00   | 4.51                            | 1558.31                                       | 345.32                                      | 1558.31   | 345.32   |
|                    | 35                | 4                                      | 356                 | 4.03                     | 4.03  | 0.00   | 0.00   | 4.81                            | 1434.41                                       | 298.25                                      | 1434.41   | 298.25   |
|                    | 36                | 5                                      | 303                 | 3.69                     | 3.69  | 0.00   | 0.00   | 5.11                            | 1119.12                                       | 219.17                                      | 1119.12   | 219.17   |
|                    | 37                | 6                                      | 330                 | 3.36                     | 3.36  | 0.00   | 0.00   | 5.40                            | 1108.04                                       | 205.08                                      | 1108.04   | 205.08   |
| <b>C</b>           | 38                | 7                                      | 326                 | 3.02                     | 3.02  | 0.00   | 0.00   | 5.70                            | 985.15  | 172.84                                      | 985.15  | 172.84   |
|                    | 39                | 8                                      | 348                 | 2.69                     | 2.69  | 0.00   | 0.00   | 6.04                            | 934.78  | 154.67                                      | 934.78  | 154.67   |
|                    | 40                | 9                                      | 335                 | 2.35                     | 2.35  | 0.00   | 0.00   | 6.39                            | 787.38  | 123.26                                      | 787.38  | 123.26   |
|                    | 41                | 10                                     | 315                 | 2.01                     | 2.01  | 0.00   | 0.00   | 6.73                            | 634.60  | 94.27                                       | 634.60  | 94.27  |
|                    | 42                | 11                                     | 215                 | 1.68                     | 1.68  | 0.00   | 0.00   | 7.08                            | 360.95  | 51.01                                       | 360.95  | 51.01  |
| <b>D</b>           | 43                | 12                                     | 169                 | 1.34                     | 1.34  | 0.00   | 0.00   | 7.42                            | 226.98  | 30.59                                       | 226.98  | 30.59  |
|                    | 44                | 13                                     | 151                 | 1.01                     | 1.01  | 0.00   | 0.00   | 7.76                            | 152.10  | 19.59                                       | 152.10  | 19.59  |
|                    | 45                | 14                                     | 105                 | 0.67                     | 0.67  | 0.00   | 0.00   | 8.11                            | 70.51   | 8.70  | 70.51   | 8.70   |
|                    | 46                | 15                                     | 74                  | 0.34                     | 0.34  | 0.00   | 0.00   | 8.45                            | 24.85   | 2.94  | 24.85   | 2.94   |

|                          |          |                           |          |         |
|--------------------------|----------|---------------------------|----------|---------|
| <b>SUM</b>               | 18032.82 | 3968.29                   | 18032.82 | 3968.29 |
| <b>SCOP<sub>on</sub></b> | 4.54     | <b>SCOP<sub>net</sub></b> | 4.54     |         |



## Detailed SCOP calculation of medium temperature and average climate conditions – EN 14825

### Calculation of reference SCOP

$$SCOP = \frac{P_{designh} \times H_{he}}{SCOP_{on} + H_{TO} \times P_{TO} + H_{SB} \times P_{SB} + H_{CK} \times P_{CK} + H_{OFF} \times P_{OFF}}$$

Where

$P_{design}$  =

Heating load of the building at design temperature, kW

$H_{he}$  =

Number of equivalent heating hours, 2066 h

$H_{TO}, H_{SB}, H_{CK}, H_{OFF}$  =

Number of hours for which the unit is considered to work in thermostat off mode, standby mode, crankcase heater mode and off mode, h, respectively

$P_{TO}, P_{SB}, P_{CK}, P_{OFF}$  =

Electricity consumption during thermostat off mode, standby mode, crankcase heater mode and off mode, kW, respectively

### Data for SCOP

|         | Outdoor temperature [°C] | Part load ratio [%] | Part load [kW] | Declared capacity [kW] | Declared COP [-] | cdh [-] | CR [-] | COPbin [-] |
|---------|--------------------------|---------------------|----------------|------------------------|------------------|---------|--------|------------|
| A       | -7                       | 88                  | 8.41           | 8.61                   | 2.24             | 0.99    | 1.00   | 2.24       |
| B       | 2                        | 54                  | 5.12           | 5.55                   | 3.27             | 0.99    | 1.00   | 3.27       |
| C       | 7                        | 35                  | 3.29           | 3.63                   | 3.84             | 0.97    | 1.00   | 3.84       |
| D       | 12                       | 15                  | 1.46           | 4.11                   | 5.87             | 0.97    | 0.36   | 5.53       |
| E       | -10                      | 100                 | 9.51           | 8.45                   | 2.11             | 0.99    | 1.00   | 2.11       |
| F - BIV | -7                       | 88                  | 8.41           | 8.61                   | 2.24             | 0.99    | 1.00   | 2.24       |

### Energy consumption for thermostat off, standby, off mode, crankcase heater mode

|                  | Hours [h] | Power input [kW] | Applied to SCOP calculation [kW] | Energy consumption [kWh] |
|------------------|-----------|------------------|----------------------------------|--------------------------|
| Off mode         | 0         | 0.01952          | 0.01952                          | 0                        |
| Thermostat off   | 178       | 0.02394          | 0.02394                          | 4.26132                  |
| Standby          | 0         | 0.01952          | 0.01952                          | 0                        |
| Crankcase heater | 178       | 0.01963          | 0.00011                          | 0.01958                  |



## Calculation Bin for SCOP<sub>on</sub>

| Bin<br>[-]  | Outdoor<br>temperature<br>[°C] | Hours<br>[h] | Heat load<br>[kW] | Heat load<br>covered by<br>heat pump<br>[kW] | Electrical<br>back up<br>heater<br>[kW] | backup<br>heater<br>energy input<br>[kWh] | COP <sub>bin</sub><br>[-] | Annual<br>heating<br>demand<br>[kWh] | Annual<br>energy<br>input<br>[kWh] | Net annual<br>heating<br>capacity<br>[kWh] | Net annual<br>power<br>input<br>[kWh] |        |
|-------------|--------------------------------|--------------|-------------------|--|---|---|---------------------------|--------------------------------------|------------------------------------|--|---------------------------------------|--------|
| E           | 21                             | -10          | 1                 | 9.51   | 8.45                                    | 1.06                                      | 1.06                      | 2.11                                 | 9.51                               | 5.06                                       | 8.45                                  | 4.00   |
|             | 22                             | -9           | 25                | 9.14   | 8.44                                    | 0.71                                      | 17.64                     | 2.16                                 | 228.61                             | 115.52                                     | 210.97                                | 97.88  |
|             | 23                             | -8           | 23                | 8.78   | 8.43                                    | 0.35                                      | 8.11                      | 2.20                                 | 201.90                             | 96.35                                      | 193.79                                | 88.23  |
| A / F - BIV | 24                             | -7           | 24                | 8.41   | 8.41                                    | 0.00                                      | 0.00                      | 2.24                                 | 201.90                             | 90.25                                      | 201.90                                | 90.25  |
|             | 25                             | -6           | 27                | 8.05   | 8.05                                    | 0.00                                      | 0.00                      | 2.35                                 | 217.27                             | 92.39                                      | 217.27                                | 92.39  |
|             | 26                             | -5           | 68                | 7.68   | 7.68                                    | 0.00                                      | 0.00                      | 2.47                                 | 522.32                             | 211.81                                     | 522.32                                | 211.81 |
|             | 27                             | -4           | 91                | 7.32   | 7.32                                    | 0.00                                      | 0.00                      | 2.58                                 | 665.70                             | 257.98                                     | 665.70                                | 257.98 |
|             | 28                             | -3           | 89                | 6.95   | 6.95                                    | 0.00                                      | 0.00                      | 2.69                                 | 618.52                             | 229.52                                     | 618.52                                | 229.52 |
|             | 29                             | -2           | 165               | 6.58   | 6.58                                    | 0.00                                      | 0.00                      | 2.81                                 | 1086.33                            | 386.71                                     | 1086.33                               | 386.71 |
|             | 30                             | -1           | 173               | 6.22   | 6.22                                    | 0.00                                      | 0.00                      | 2.92                                 | 1075.73                            | 367.95                                     | 1075.73                               | 367.95 |
|             | 31                             | 0            | 240               | 5.85   | 5.85                                    | 0.00                                      | 0.00                      | 3.04                                 | 1404.55                            | 462.33                                     | 1404.55                               | 462.33 |
|             | 32                             | 1            | 280               | 5.49   | 5.49                                    | 0.00                                      | 0.00                      | 3.15                                 | 1536.23                            | 487.33                                     | 1536.23                               | 487.33 |
| B           | 33                             | 2            | 320               | 5.12   | 5.12                                    | 0.00                                      | 0.00                      | 3.27                                 | 1638.65                            | 501.61                                     | 1638.65                               | 501.61 |
|             | 34                             | 3            | 357               | 4.76   | 4.76                                    | 0.00                                      | 0.00                      | 3.38                                 | 1697.54                            | 502.03                                     | 1697.54                               | 502.03 |
|             | 35                             | 4            | 356               | 4.39   | 4.39                                    | 0.00                                      | 0.00                      | 3.50                                 | 1562.57                            | 446.97                                     | 1562.57                               | 446.97 |
|             | 36                             | 5            | 303               | 4.02   | 4.02                                    | 0.00                                      | 0.00                      | 3.61                                 | 1219.11                            | 337.66                                     | 1219.11                               | 337.66 |
|             | 37                             | 6            | 330               | 3.66   | 3.66                                    | 0.00                                      | 0.00                      | 3.73                                 | 1207.04                            | 324.03                                     | 1207.04                               | 324.03 |
| C           | 38                             | 7            | 326               | 3.29   | 3.29                                    | 0.00                                      | 0.00                      | 3.84                                 | 1073.17                            | 279.50                                     | 1073.17                               | 279.50 |
|             | 39                             | 8            | 348               | 2.93   | 2.93                                    | 0.00                                      | 0.00                      | 4.18                                 | 1018.30                            | 243.80                                     | 1018.30                               | 243.80 |
|             | 40                             | 9            | 335               | 2.56   | 2.56                                    | 0.00                                      | 0.00                      | 4.51                                 | 857.73                             | 190.01                                     | 857.73                                | 190.01 |
|             | 41                             | 10           | 315               | 2.19   | 2.19                                    | 0.00                                      | 0.00                      | 4.85                                 | 691.30                             | 142.50                                     | 691.30                                | 142.50 |
|             | 42                             | 11           | 215               | 1.83   | 1.83                                    | 0.00                                      | 0.00                      | 5.19                                 | 393.20                             | 75.78                                      | 393.20                                | 75.78  |
| D           | 43                             | 12           | 169               | 1.46   | 1.46                                    | 0.00                                      | 0.00                      | 5.53                                 | 247.26                             | 44.75                                      | 247.26                                | 44.75  |
|             | 44                             | 13           | 151               | 1.10   | 1.10                                    | 0.00                                      | 0.00                      | 5.86                                 | 165.69                             | 28.26                                      | 165.69                                | 28.26  |
|             | 45                             | 14           | 105               | 0.73   | 0.73                                    | 0.00                                      | 0.00                      | 6.20                                 | 76.81                              | 12.39                                      | 76.81                                 | 12.39  |
|             | 46                             | 15           | 74                | 0.37   | 0.37                                    | 0.00                                      | 0.00                      | 6.54                                 | 27.07                              | 4.14                                       | 27.07                                 | 4.14   |



## Detailed test results

### Detailed SCOP test results - low temperature application and average climate – EN 14825

| Detailed result for 'EN14825:2022' Average Low (A and F) A -7 /W34                  |              |                               |  |
|---|--------------|-------------------------------|--|
| Tested according to:  |              | EN14511:2022 and EN14825:2022 |  |
| Climate zone:   |              | Average                       |  |
| Temperature application:  |              | Low                           |  |
| Condition name:   |              | A and F                       |  |
| Condition temperature:  | °C           | -7                            |  |
| Part load:  | %            | 88%                           |  |
| Chosen Tbivalent  | °C           | -7                            |  |
| Tdesign   | °C           | -10                           |  |
| Pdesign   | kW           | 9.94                          |  |
| Heating demand:   | kW           | 8.80                          |  |
| CR:   | -            | 1.0                           |  |
| Minimum flow reached:   | -            | No                            |  |
| Measurement type:   | Steady State |                               |  |
| Integrated liquid pump:   | Yes          |                               |  |
| Integrated liquid pump able to generate a positive ext. static pressure difference: | Yes          |                               |  |
| Included corrections (Final result)   |              |                               |  |
| Heating capacity  | kW           | 7.937                         |  |
| COP   | -            | 3.289                         |  |
| Power consumption   | kW           | 2.413                         |  |
| Measured  |              |                               |  |
| Heating capacity  | kW           | 7.998                         |  |
| COP   | -            | 3.192                         |  |
| Power consumption   | kW           | 2.505                         |  |
| During heating  |              |                               |  |
| Air_inlet temperature dry bulb  | °C           | -7.01                         |  |
| Air temperature wet bulb  | °C           | -8.07                         |  |
| Water_inlet temperature   | °C           | 29.99                         |  |
| water_outlet temperature  | °C           | 34.08                         |  |
| Water_outlet temperature (Time averaged)  | °C           | 34.08                         |  |
| Circulation pump  |              |                               |  |
| Measured external static pressure difference, liquid pump                           | Pa           | 65829                         |  |
| Calculated Hydraulic power  | W            | 31                            |  |
| Calculated global efficiency  | η            | 0.34                          |  |
| Calculated Capacity correction  | W            | 60                            |  |
| Calculated Power correction   | W            | 91                            |  |
| Water Flow  | m³/s         | 0.000471                      |  |



| <b>Detailed result for 'EN14825:2022' Average Low (B) A 2 /W30</b>                  |                               |          |
|---|-------------------------------|----------|
| Tested according to:  | EN14511:2022 and EN14825:2022 |          |
| Climate zone:   | Average                       |          |
| Temperature application:  | Low                           |          |
| Condition name:   | B                             |          |
| Condition temperature:  | °C 2                          |          |
| Part load:  | % 54%                         |          |
| Chosen Tbivalent  | °C -7                         |          |
| Tdesign   | °C -10                        |          |
| Pdesign   | kW 8.73                       |          |
| Heating demand:   | kW 4.70                       |          |
| CR:   | - 1.0                         |          |
| Minimum flow reached:   | - No                          |          |
| Measurement type:   | Steady State                  |          |
| Integrated liquid pump:   | Yes                           |          |
| Integrated liquid pump able to generate a positive ext. static pressure difference: | Yes                           |          |
| <b>Included corrections (Final result)</b>  |                               |          |
| Heating capacity  | kW                            | 5.205    |
| COP   | -                             | 4.216    |
| Power consumption   | kW                            | 1.235    |
| <b>Measured</b>   |                               |          |
| Heating capacity  | kW                            | 5.267    |
| COP   | -                             | 3.961    |
| Power consumption   | kW                            | 1.330    |
| <b>During heating</b>   |                               |          |
| Air_inlet temperature dry bulb  | °C                            | 2.02     |
| Air temperature wet bulb  | °C                            | 1.00     |
| Water_inlet temperature   | °C                            | 27.58    |
| water_outlet temperature  | °C                            | 30.27    |
| Water_outlet temperature (Time averaged)  | °C                            | 30.27    |
| <b>Circulation pump</b>   |                               |          |
| Measured external static pressure difference, liquid pump                           | Pa                            | 69180    |
| Calculated Hydraulic power  | W                             | 33       |
| Calculated global efficiency  | η                             | 0.34     |
| Calculated Capacity correction  | W                             | 62       |
| Calculated Power correction   | W                             | 95       |
| Water Flow  | m³/s                          | 0.000471 |



**Detailed result for 'EN14825:2022' Average Low (C) A 7 /W27**

|   |                               |              |  |
|---|-------------------------------|--------------|--|
| Tested according to:  | EN14511:2022 and EN14825:2022 |              |  |
| Climate zone:   | Average                       |              |  |
| Temperature application:  | Low                           |              |  |
| Condition name:   | C                             |              |  |
| Condition temperature:  | °C 7                          |              |  |
| Part load:  | % 35%                         |              |  |
| Chosen Tbivalent  | °C -7                         |              |  |
| Tdesign   | °C -10                        |              |  |
| Pdesign   | kW 8.73                       |              |  |
| Heating demand:   | kW 3.02                       |              |  |
| CR:   | - 0.8                         |              |  |
| Minimum flow reached:   | - No                          |              |  |
| Measurement type:   | Steady State                  |              |  |
| Integrated liquid pump:   | Yes                           |              |  |
| Integrated liquid pump able to generate a positive ext. static pressure difference: | Yes                           |              |  |
| <b>Included corrections (Final result)</b>  |                               |              |  |
| Heating capacity  | kW                            | <b>3.636</b> |  |
| COP   | -                             | <b>5.744</b> |  |
| Power consumption   | kW                            | <b>0.633</b> |  |
| <b>Measured</b>   |                               |              |  |
| Heating capacity  | kW                            | 3.700        |  |
| COP   | -                             | 5.066        |  |
| Power consumption   | kW                            | 0.730        |  |
| <b>During heating</b>   |                               |              |  |
| Air_inlet temperature dry bulb  | °C                            | 6.98         |  |
| Air temperature wet bulb  | °C                            | 6.01         |  |
| Water_inlet temperature   | °C                            | 25.49        |  |
| water_outlet temperature  | °C                            | 27.37        |  |
| Water_outlet temperature (Time averaged)  | °C                            | <b>27.06</b> |  |
| <b>Circulation pump</b>   |                               |              |  |
| Measured external static pressure difference, liquid pump                           | Pa                            | 71399        |  |
| Calculated Hydraulic power  | W                             | 34           |  |
| Calculated global efficiency  | η                             | 0.35         |  |
| Calculated Capacity correction  | W                             | 64           |  |
| Calculated Power correction   | W                             | 97           |  |
| Water Flow  | m³/s                          | 0.000471     |  |



| <b>Detailed result for 'EN14825:2022' Average Low (D) A 12 /W24</b>                 |                               |          |
|---|-------------------------------|----------|
| Tested according to:  | EN14511:2022 and EN14825:2022 |          |
| Climate zone:   | Average                       |          |
| Temperature application:  | Low                           |          |
| Condition name:   | D                             |          |
| Condition temperature:  | °C                            | 12       |
| Part load:  | %                             | 15%      |
| Chosen Tbivalent  | °C                            | -7       |
| Tdesign   | °C                            | -10      |
| Pdesign   | kW                            | 8.73     |
| Heating demand:   | kW                            | 1.34     |
| CR:   | -                             | 0.3      |
| Minimum flow reached:   | -                             | No       |
| Measurement type:   | Steady State                  |          |
| Integrated liquid pump:   | Yes                           |          |
| Integrated liquid pump able to generate a positive ext. static pressure difference: | Yes                           |          |
| Included corrections (Final result)   |                               |          |
| Heating capacity  | kW                            | 4.212    |
| COP   | -                             | 8.154    |
| Power consumption   | kW                            | 0.517    |
| Measured  |                               |          |
| Heating capacity  | kW                            | 4.273    |
| COP   | -                             | 7.021    |
| Power consumption   | kW                            | 0.609    |
| During heating  |                               |          |
| Air_inlet temperature dry bulb  | °C                            | 12.01    |
| Air temperature wet bulb  | °C                            | 11.01    |
| Water_inlet temperature   | °C                            | 23.25    |
| water_outlet temperature  | °C                            | 25.42    |
| Water_outlet temperature (Time averaged)  | °C                            | 23.94    |
| Circulation pump  |                               |          |
| Measured external static pressure difference, liquid pump                           | Pa                            | 66504    |
| Calculated Hydraulic power  | W                             | 31       |
| Calculated global efficiency  | η                             | 0.34     |
| Calculated Capacity correction  | W                             | 61       |
| Calculated Power correction   | W                             | 92       |
| Water Flow  | m³/s                          | 0.000471 |



**Detailed result for 'EN14825:2022' Average Low (E) A -10 /W35**

|   |                               |  |  |
|---|-------------------------------|--|--|
| Tested according to:  | EN14511:2022 and EN14825:2022 |  |  |
| Climate zone:   | Average                       |  |  |
| Temperature application:  | Low                           |  |  |
| Condition name:   | E                             |  |  |
| Condition temperature:  | °C -10                        |  |  |
| Part load:  | % 100%                        |  |  |
| Chosen Tbivalent  | °C -7                         |  |  |
| Tdesign   | °C -10                        |  |  |
| Pdesign   | kW 8.73                       |  |  |
| Heating demand:   | kW 8.73                       |  |  |
| CR:   | - 1.0                         |  |  |
| Minimum flow reached:   | - No                          |  |  |
| Measurement type:   | Steady State                  |  |  |
| Integrated liquid pump:   | Yes                           |  |  |
| Integrated liquid pump able to generate a positive ext. static pressure difference: | Yes                           |  |  |
| <b>Included corrections (Final result)</b>  |                               |  |  |
| Heating capacity  | kW 8.732                      |  |  |
| COP   | - 2.906                       |  |  |
| Power consumption   | kW 3.005                      |  |  |
| <b>Measured</b>   |                               |  |  |
| Heating capacity  | kW 8.793                      |  |  |
| COP   | - 2.839                       |  |  |
| Power consumption   | kW 3.097                      |  |  |
| <b>During heating</b>   |                               |  |  |
| Air_inlet temperature dry bulb  | °C -10.00                     |  |  |
| Air temperature wet bulb  | °C -11.01                     |  |  |
| Water_inlet temperature   | °C 30.73                      |  |  |
| water_outlet temperature  | °C 35.22                      |  |  |
| Water_outlet temperature (Time averaged)  | °C 35.22                      |  |  |
| <b>Circulation pump</b>   |                               |  |  |
| Measured external static pressure difference, liquid pump                           | Pa 66101                      |  |  |
| Calculated Hydraulic power  | W 31                          |  |  |
| Calculated global efficiency  | η 0.34                        |  |  |
| Calculated Capacity correction  | W 61                          |  |  |
| Calculated Power correction   | W 92                          |  |  |
| Water Flow  | m³/s 0.000471                 |  |  |



## Detailed SCOP test results - medium temperature application and average climate – EN 14825

| Detailed result for 'EN14825:2022' Average Medium (A and F) A -7/W52                |                               |          |  |  |  |
|---|-------------------------------|----------|--|--|--|
| Tested according to:  | EN14511:2022 and EN14825:2022 |          |  |  |  |
| Climate zone:   | Average                       |          |  |  |  |
| Temperature application:  | Medium                        |          |  |  |  |
| Condition name:   | A and F                       |          |  |  |  |
| Condition temperature:  | °C                            | -7       |  |  |  |
| Part load:  | %                             | 88%      |  |  |  |
| Chosen Tbivalent  | °C                            | -7       |  |  |  |
| Tdesign   | °C                            | -10      |  |  |  |
| Pdesign   | kW                            | 9.51     |  |  |  |
| Heating demand:   | kW                            | 8.41     |  |  |  |
| CR:   | -                             | 1.0      |  |  |  |
| Minimum flow reached:   | -                             | No       |  |  |  |
| Measurement type:   | Steady State                  |          |  |  |  |
| Integrated liquid pump:   | Yes                           |          |  |  |  |
| Integrated liquid pump able to generate a positive ext. static pressure difference: | Yes                           |          |  |  |  |
| Included corrections (Final result)   |                               |          |  |  |  |
| Heating capacity  | kW                            | 8.609    |  |  |  |
| COP   | -                             | 2.237    |  |  |  |
| Power consumption   | kW                            | 3.848    |  |  |  |
| Measured  |                               |          |  |  |  |
| Heating capacity  | kW                            | 8.660    |  |  |  |
| COP   | -                             | 2.207    |  |  |  |
| Power consumption   | kW                            | 3.923    |  |  |  |
| During heating  |                               |          |  |  |  |
| Air_inlet temperature dry bulb  | °C                            | -7.01    |  |  |  |
| Air temperature wet bulb  | °C                            | -8.01    |  |  |  |
| Water_inlet temperature   | °C                            | 45.00    |  |  |  |
| water_outlet temperature  | °C                            | 52.21    |  |  |  |
| Water_outlet temperature (Time averaged)  | °C                            | 52.21    |  |  |  |
| Circulation pump  |                               |          |  |  |  |
| Measured external static pressure difference, liquid pump                           | Pa                            | 80829    |  |  |  |
| Calculated Hydraulic power  | W                             | 24       |  |  |  |
| Calculated global efficiency  | η                             | 0.31     |  |  |  |
| Calculated Capacity correction  | W                             | 51       |  |  |  |
| Calculated Power correction   | W                             | 75       |  |  |  |
| Water Flow  | m³/s                          | 0.000291 |  |  |  |



**Detailed result for 'EN14825:2022' Average Medium (B) A 2 /W42**

|  |                               |          |  |
|--|-------------------------------|----------|--|
| Tested according to:   | EN14511:2022 and EN14825:2022 |          |  |
| Climate zone:  | Average                       |          |  |
| Temperature application:   | Medium                        |          |  |
| Condition name:  | B                             |          |  |
| Condition temperature:   | °C                            | 2        |  |
| Part load:   | %                             | 54%      |  |
| Chosen Tbivalent   | °C                            | -7       |  |
| Tdesign  | °C                            | -10      |  |
| Pdesign  | kW                            | 9.51     |  |
| Heating demand:  | kW                            | 5.12     |  |
| CR:  | -                             | 1.0      |  |
| Minimum flow reached:  | -                             | No       |  |
| Measurement type:  | Steady State                  |          |  |
| Integrated liquid pump:  | Yes                           |          |  |
| Integrated liquid pump able to generate a positve ext. static pressure difference: | Yes                           |          |  |
| <b>Included corrections (Final result)</b>   |                               |          |  |
| Heating capacity   | kW                            | 5.547    |  |
| COP  | -                             | 3.267    |  |
| Power consumption  | kW                            | 1.698    |  |
| <b>Measured</b>  |                               |          |  |
| Heating capacity   | kW                            | 5.596    |  |
| COP  | -                             | 3.162    |  |
| Power consumption  | kW                            | 1.770    |  |
| <b>During heating</b>  |                               |          |  |
| Air_inlet temperature dry bulb   | °C                            | 2.01     |  |
| Air temperature wet bulb   | °C                            | 1.00     |  |
| Water_inlet temperature  | °C                            | 37.47    |  |
| water_outlet temperature   | °C                            | 42.12    |  |
| Water_outlet temperature (Time averaged)   | °C                            | 42.12    |  |
| <b>Circulation pump</b>  |                               |          |  |
| Measured external static pressure difference, liquid pump                          | Pa                            | 76142    |  |
| Calculated Hydraulic power   | W                             | 22       |  |
| Calculated global efficiency   | η                             | 0.31     |  |
| Calculated Capacity correction   | W                             | 49       |  |
| Calculated Power correction  | W                             | 72       |  |
| Water Flow   | m³/s                          | 0.000291 |  |



**Detailed result for 'EN14825:2022' Average Medium (C) A 7 /W36**

|   |                               |          |  |
|---|-------------------------------|----------|--|
| Tested according to:  | EN14511:2022 and EN14825:2022 |          |  |
| Climate zone:   | Average Medium                |          |  |
| Temperature application:  | Medium                        |          |  |
| Condition name:   |                               | C        |  |
| Condition temperature:  | °C                            | 7        |  |
| Part load:  | %                             | 35%      |  |
| Chosen Tbivalent  | °C                            | -7       |  |
| Tdesign   | °C                            | -10      |  |
| Pdesign   | kW                            | 9.51     |  |
| Heating demand:   | kW                            | 3.29     |  |
| CR:   | -                             | 1.0      |  |
| Minimum flow reached:   | -                             | No       |  |
| Measurement type:   | Steady State                  |          |  |
| Integrated liquid pump:   | Yes                           |          |  |
| Integrated liquid pump able to generate a positive ext. static pressure difference: | Yes                           |          |  |
| <b>Included corrections (Final result)</b>  |                               |          |  |
| Heating capacity  | kW                            | 3.631    |  |
| COP   | -                             | 3.840    |  |
| Power consumption   | kW                            | 0.946    |  |
| <b>Measured</b>   |                               |          |  |
| Heating capacity  | kW                            | 3.682    |  |
| COP   | -                             | 3.611    |  |
| Power consumption   | kW                            | 1.020    |  |
| <b>During heating</b>   |                               |          |  |
| Air_inlet temperature dry bulb  | °C                            | 7.01     |  |
| Air temperature wet bulb  | °C                            | 6.02     |  |
| Water_inlet temperature   | °C                            | 33.22    |  |
| water_outlet temperature  | °C                            | 36.26    |  |
| Water_outlet temperature (Time averaged)  | °C                            | 36.26    |  |
| <b>Circulation pump</b>   |                               |          |  |
| Measured external static pressure difference, liquid pump                           | Pa                            | 79737    |  |
| Calculated Hydraulic power  | W                             | 23       |  |
| Calculated global efficiency  | η                             | 0.31     |  |
| Calculated Capacity correction  | W                             | 51       |  |
| Calculated Power correction   | W                             | 74       |  |
| Water Flow  | m³/s                          | 0.000291 |  |



**Detailed result for 'EN14825:2022' Average Medium (D) A 12/W30**

|   |                               |          |  |
|---|-------------------------------|----------|--|
| Tested according to:  | EN14511:2022 and EN14825:2022 |          |  |
| Climate zone:   | Average                       |          |  |
| Temperature application:  | Medium                        |          |  |
| Condition name:   | D                             |          |  |
| Condition temperature:  | °C                            | 12       |  |
| Part load:  | %                             | 15%      |  |
| Chosen Tbivalent  | °C                            | -7       |  |
| Tdesign   | °C                            | -10      |  |
| Pdesign   | kW                            | 9.51     |  |
| Heating demand:   | kW                            | 1.46     |  |
| CR:   | -                             | 0.4      |  |
| Minimum flow reached:   | -                             | No       |  |
| Measurement type:   | Steady State                  |          |  |
| Integrated liquid pump:   | Yes                           |          |  |
| Integrated liquid pump able to generate a positive ext. static pressure difference: | Yes                           |          |  |
| <b>Included corrections (Final result)</b>  |                               |          |  |
| Heating capacity  | kW                            | 4.107    |  |
| COP   | -                             | 5.867    |  |
| Power consumption   | kW                            | 0.700    |  |
| <b>Measured</b>   |                               |          |  |
| Heating capacity  | kW                            | 4.159    |  |
| COP   | -                             | 5.357    |  |
| Power consumption   | kW                            | 0.776    |  |
| <b>During heating</b>   |                               |          |  |
| Air_inlet temperature dry bulb  | °C                            | 11.99    |  |
| Air temperature wet bulb  | °C                            | 11.00    |  |
| Water_inlet temperature   | °C                            | 28.78    |  |
| water_outlet temperature  | °C                            | 32.22    |  |
| Water_outlet temperature (Time averaged)  | °C                            | 30.01    |  |
| <b>Circulation pump</b>   |                               |          |  |
| Measured external static pressure difference, liquid pump                           | Pa                            | 82846    |  |
| Calculated Hydraulic power  | W                             | 24       |  |
| Calculated global efficiency  | η                             | 0.32     |  |
| Calculated Capacity correction  | W                             | 52       |  |
| Calculated Power correction   | W                             | 76       |  |
| Water Flow  | m³/s                          | 0.000291 |  |



**Detailed result for 'EN14825:2022' Average Medium (E) A -10 /W55**

|   |                               |          |  |
|---|-------------------------------|----------|--|
| Tested according to:  | EN14511:2022 and EN14825:2022 |          |  |
| Climate zone:   | Average                       |          |  |
| Temperature application:  | Medium                        |          |  |
| Condition name:   | E                             |          |  |
| Condition temperature:  | °C                            | -10      |  |
| Part load:  | %                             | 100%     |  |
| Chosen Tbivalent  | °C                            | -7       |  |
| Tdesign   | °C                            | -10      |  |
| Pdesign   | kW                            | 9.51     |  |
| Heating demand:   | kW                            | 9.51     |  |
| CR:   | -                             | 1.0      |  |
| Minimum flow reached:   | -                             | No       |  |
| Measurement type:   | Steady State                  |          |  |
| Integrated liquid pump:   | Yes                           |          |  |
| Integrated liquid pump able to generate a positive ext. static pressure difference: | Yes                           |          |  |
| <b>Included corrections (Final result)</b>  |                               |          |  |
| Heating capacity  | kW                            | 8.452    |  |
| COP   | -                             | 2.115    |  |
| Power consumption   | kW                            | 3.997    |  |
| <b>Measured</b>   |                               |          |  |
| Heating capacity  | kW                            | 8.503    |  |
| COP   | -                             | 2.088    |  |
| Power consumption   | kW                            | 4.072    |  |
| <b>During heating</b>   |                               |          |  |
| Air_inlet temperature dry bulb  | °C                            | -10.01   |  |
| Air temperature wet bulb  | °C                            | -11.01   |  |
| Water_inlet temperature   | °C                            | 47.99    |  |
| water_outlet temperature  | °C                            | 55.08    |  |
| Water_outlet temperature (Time averaged)  | °C                            | 55.08    |  |
| <b>Circulation pump</b>   |                               |          |  |
| Measured external static pressure difference, liquid pump                           | Pa                            | 80491    |  |
| Calculated Hydraulic power  | W                             | 23       |  |
| Calculated global efficiency  | η                             | 0.31     |  |
| Calculated Capacity correction  | W                             | 51       |  |
| Calculated Power correction   | W                             | 74       |  |
| Water Flow  | m³/s                          | 0.000291 |  |



## Test results of standard rating condition - EN14511

| <b>Detailed result for 'EN14511:2022' A7/W35</b>    |      |              |
|---|------|--------------|
| Tested according to:                                |      | EN14511:2022 |
| Minimum flow reached:                               |      | No           |
| Measurement type:                                   |      | Steady State |
| Integrated circulation pump:                        |      | Yes          |
| <b>Included corrections (Final result)</b>          |      |              |
| Heating capacity                                    | kW   | 10.119       |
| COP   | -    | 4.637        |
| Power consumption                                   | kW   | 2.182        |
| <b>Measured</b>                                     |      |              |
| Heating capacity                                    | kW   | 10.179       |
| COP   | -    | 4.477        |
| Power consumption                                   | kW   | 2.273        |
| <b>During heating</b>                               |      |              |
| Air temperature dry bulb                            | °C   | 7.01         |
| Air temperature wet bulb                            | °C   | 5.99         |
| Inlet temperature                                   | °C   | 30.02        |
| Outlet temperature                                  | °C   | 35.08        |
| <b>Circulation pump</b>                             |      |              |
| Measured: Static differential pressure, liquid pump | Pa   | 63674        |
| Calculated Hydraulic power                          | W    | 31           |
| Calculated global efficiency                        | η    | 0.34         |
| Calculated Capacity correction                      | W    | 60           |
| Calculated Power correction                         | W    | 91           |
| Water Flow  | m³/s | 0.000485     |



| <b>Detailed result for 'EN14511:2022' A7/W55</b>    |      |              |
|---|------|--------------|
| Tested according to:                                |      | EN14511:2022 |
| Minimum flow reached:                               |      | No           |
| Measurement type:                                   |      | Steady State |
| Integrated circulation pump:                        |      | Yes          |
| <b>Included corrections (Final result)</b>          |      |              |
| Heating capacity                                    | kW   | 9.647        |
| COP   | -    | 2.930        |
| Power consumption                                   | kW   | 3.292        |
| <b>Measured</b>                                     |      |              |
| Heating capacity                                    | kW   | 9.699        |
| COP   | -    | 2.880        |
| Power consumption                                   | kW   | 3.367        |
| <b>During heating</b>                               |      |              |
| Air temperature dry bulb                            | °C   | 7.00         |
| Air temperature wet bulb                            | °C   | 6.02         |
| Inlet temperature                                   | °C   | 47.00        |
| Outlet temperature                                  | °C   | 55.09        |
| <b>Circulation pump</b>                             |      |              |
| Measured: Static differential pressure, liquid pump | Pa   | 81062        |
| Calculated Hydraulic power                          | W    | 24           |
| Calculated global efficiency                        | η    | 0.32         |
| Calculated Capacity correction                      | W    | 51           |
| Calculated Power correction                         | W    | 75           |
| Water Flow  | m³/s | 0.000291     |



## Detailed test results of sound power measurement – Test N#1

| ilac-MRA   |  | DANAK                      |                                | Sound power levels according to ISO<br>3743-1:2010 |             | TEKNOLOGISK<br>INSTITUT   |  |     |      |                   |     |      |  |     |      |  |     |      |      |     |      |  |     |      |  |     |      |      |     |      |  |     |      |  |      |      |      |      |      |  |      |      |  |      |      |      |      |      |  |      |      |  |      |      |      |      |      |  |      |      |  |      |      |      |       |      |  |  |  |  |  |  |  |
|--|--|----------------------------|--------------------------------|--|-------------|---------------------------|--|-----|------|-------------------|-----|------|--|-----|------|--|-----|------|------|-----|------|--|-----|------|--|-----|------|------|-----|------|--|-----|------|--|------|------|------|------|------|--|------|------|--|------|------|------|------|------|--|------|------|--|------|------|------|------|------|--|------|------|--|------|------|------|-------|------|--|--|--|--|--|--|--|
| Engineering method for small, movable sources in reverberant fields - Comparison method for hard-walled test rooms   |  |                            |                                |  |             |                           |  |     |      |                   |     |      |  |     |      |  |     |      |      |     |      |  |     |      |  |     |      |      |     |      |  |     |      |  |      |      |      |      |      |  |      |      |  |      |      |      |      |      |  |      |      |  |      |      |      |      |      |  |      |      |  |      |      |      |       |      |  |  |  |  |  |  |  |
| Client:  | GUANGDONG PHNIX ECO-ENERGY SOLUTION LTD.   |                            |                                | Date of test:                                      | 14-06-2024  |                           |  |     |      |                   |     |      |  |     |      |  |     |      |      |     |      |  |     |      |  |     |      |      |     |      |  |     |      |  |      |      |      |      |      |  |      |      |  |      |      |      |      |      |  |      |      |  |      |      |      |      |      |  |      |      |  |      |      |      |       |      |  |  |  |  |  |  |  |
| Object:  | Type: Mono air to water heat pump, Model: PASRW040S-BP-PS-B  |                            |                                |  |             |                           |  |     |      |                   |     |      |  |     |      |  |     |      |      |     |      |  |     |      |  |     |      |      |     |      |  |     |      |  |      |      |      |      |      |  |      |      |  |      |      |      |      |      |  |      |      |  |      |      |      |      |      |  |      |      |  |      |      |      |       |      |  |  |  |  |  |  |  |
| Mounting conditions:   | The outdoor unit is mounted on the supporting metal support frame using four pieces of spring mounts vibration isolators and placed on four pieces of concrete tiles (50x50x5 cm). All of these are placed in a water drop dry on two pieces of heavy concrete tiles (90x90x10cm) laying on a vibration damping mat on the floor. The noise radiated by the outdoor unit has been measured in Test room 2. |                            |                                |  |             |                           |  |     |      |                   |     |      |  |     |      |  |     |      |      |     |      |  |     |      |  |     |      |      |     |      |  |     |      |  |      |      |      |      |      |  |      |      |  |      |      |      |      |      |  |      |      |  |      |      |      |      |      |  |      |      |  |      |      |      |       |      |  |  |  |  |  |  |  |
| Operating conditions:  | A7/W55, Compressor speed: 33[Hz], Speed-fan motor 1: 325[rpm], Heating capacity: 3.73 [kW], Power_input: 1.62 [kW], Water flow rate: 1050 [l/h] and dP_water: 800 [mbar]   |                            |                                |  |             |                           |  |     |      |                   |     |      |  |     |      |  |     |      |      |     |      |  |     |      |  |     |      |      |     |      |  |     |      |  |      |      |      |      |      |  |      |      |  |      |      |      |      |      |  |      |      |  |      |      |      |      |      |  |      |      |  |      |      |      |       |      |  |  |  |  |  |  |  |
| Static pressure:   | 1010 hPa   |                            |                                | Reference box:                                     |             |                           |  |     |      |                   |     |      |  |     |      |  |     |      |      |     |      |  |     |      |  |     |      |      |     |      |  |     |      |  |      |      |      |      |      |  |      |      |  |      |      |      |      |      |  |      |      |  |      |      |      |      |      |  |      |      |  |      |      |      |       |      |  |  |  |  |  |  |  |
| Air temperature:   | 7,0 °C   |                            |                                | L1:  | 1,3 m       |                           |  |     |      |                   |     |      |  |     |      |  |     |      |      |     |      |  |     |      |  |     |      |      |     |      |  |     |      |  |      |      |      |      |      |  |      |      |  |      |      |      |      |      |  |      |      |  |      |      |      |      |      |  |      |      |  |      |      |      |       |      |  |  |  |  |  |  |  |
| Relative air humidity:   | 84,0 %   |                            |                                | L2:  | 0,5 m       |                           |  |     |      |                   |     |      |  |     |      |  |     |      |      |     |      |  |     |      |  |     |      |      |     |      |  |     |      |  |      |      |      |      |      |  |      |      |  |      |      |      |      |      |  |      |      |  |      |      |      |      |      |  |      |      |  |      |      |      |       |      |  |  |  |  |  |  |  |
| Test room volume:  | 102,8 m <sup>3</sup>   | Room:                      | Room 2                         | L3:  | 0,9 m       |                           |  |     |      |                   |     |      |  |     |      |  |     |      |      |     |      |  |     |      |  |     |      |      |     |      |  |     |      |  |      |      |      |      |      |  |      |      |  |      |      |      |      |      |  |      |      |  |      |      |      |      |      |  |      |      |  |      |      |      |       |      |  |  |  |  |  |  |  |
| Area, S, of test room:   | 138,9 m <sup>2</sup>   | Volume: 0,6 m <sup>3</sup> |                                |  |             |                           |  |     |      |                   |     |      |  |     |      |  |     |      |      |     |      |  |     |      |  |     |      |      |     |      |  |     |      |  |      |      |      |      |      |  |      |      |  |      |      |      |      |      |  |      |      |  |      |      |      |      |      |  |      |      |  |      |      |      |       |      |  |  |  |  |  |  |  |
| <table border="1"><thead><tr><th>Frequency f [Hz]</th><th>L<sub>w</sub> 1/3 octave [dB]</th><th>1/1 oct [dB]</th></tr></thead><tbody><tr><td>100</td><td>57,4</td><td></td></tr><tr><td>125</td><td>61,1</td><td>62,9<sup>2</sup></td></tr><tr><td>160</td><td>49,9</td><td></td></tr><tr><td>200</td><td>52,0</td><td></td></tr><tr><td>250</td><td>52,4</td><td>56,0</td></tr><tr><td>315</td><td>48,2</td><td></td></tr><tr><td>400</td><td>49,5</td><td></td></tr><tr><td>500</td><td>46,7</td><td>52,5</td></tr><tr><td>630</td><td>46,2</td><td></td></tr><tr><td>800</td><td>41,9</td><td></td></tr><tr><td>1000</td><td>41,0</td><td>45,7</td></tr><tr><td>1250</td><td>39,7</td><td></td></tr><tr><td>1600</td><td>35,6</td><td></td></tr><tr><td>2000</td><td>35,1</td><td>39,4</td></tr><tr><td>2500</td><td>32,6</td><td></td></tr><tr><td>3150</td><td>32,3</td><td></td></tr><tr><td>4000</td><td>33,4</td><td>44,1</td></tr><tr><td>5000</td><td>43,4</td><td></td></tr><tr><td>6300</td><td>34,6</td><td></td></tr><tr><td>8000</td><td>39,3</td><td>45,2</td></tr><tr><td>10000</td><td>43,4</td><td></td></tr></tbody></table> |  | Frequency f [Hz]           | L <sub>w</sub> 1/3 octave [dB] | 1/1 oct [dB]                                       | 100         | 57,4                      |  | 125 | 61,1 | 62,9 <sup>2</sup> | 160 | 49,9 |  | 200 | 52,0 |  | 250 | 52,4 | 56,0 | 315 | 48,2 |  | 400 | 49,5 |  | 500 | 46,7 | 52,5 | 630 | 46,2 |  | 800 | 41,9 |  | 1000 | 41,0 | 45,7 | 1250 | 39,7 |  | 1600 | 35,6 |  | 2000 | 35,1 | 39,4 | 2500 | 32,6 |  | 3150 | 32,3 |  | 4000 | 33,4 | 44,1 | 5000 | 43,4 |  | 6300 | 34,6 |  | 8000 | 39,3 | 45,2 | 10000 | 43,4 |  |  |  |  |  |  |  |
| Frequency f [Hz]   | L <sub>w</sub> 1/3 octave [dB]   | 1/1 oct [dB]               |                                |  |             |                           |  |     |      |                   |     |      |  |     |      |  |     |      |      |     |      |  |     |      |  |     |      |      |     |      |  |     |      |  |      |      |      |      |      |  |      |      |  |      |      |      |      |      |  |      |      |  |      |      |      |      |      |  |      |      |  |      |      |      |       |      |  |  |  |  |  |  |  |
| 100  | 57,4   |                            |                                |  |             |                           |  |     |      |                   |     |      |  |     |      |  |     |      |      |     |      |  |     |      |  |     |      |      |     |      |  |     |      |  |      |      |      |      |      |  |      |      |  |      |      |      |      |      |  |      |      |  |      |      |      |      |      |  |      |      |  |      |      |      |       |      |  |  |  |  |  |  |  |
| 125  | 61,1   | 62,9 <sup>2</sup>          |                                |  |             |                           |  |     |      |                   |     |      |  |     |      |  |     |      |      |     |      |  |     |      |  |     |      |      |     |      |  |     |      |  |      |      |      |      |      |  |      |      |  |      |      |      |      |      |  |      |      |  |      |      |      |      |      |  |      |      |  |      |      |      |       |      |  |  |  |  |  |  |  |
| 160  | 49,9   |                            |                                |  |             |                           |  |     |      |                   |     |      |  |     |      |  |     |      |      |     |      |  |     |      |  |     |      |      |     |      |  |     |      |  |      |      |      |      |      |  |      |      |  |      |      |      |      |      |  |      |      |  |      |      |      |      |      |  |      |      |  |      |      |      |       |      |  |  |  |  |  |  |  |
| 200  | 52,0   |                            |                                |  |             |                           |  |     |      |                   |     |      |  |     |      |  |     |      |      |     |      |  |     |      |  |     |      |      |     |      |  |     |      |  |      |      |      |      |      |  |      |      |  |      |      |      |      |      |  |      |      |  |      |      |      |      |      |  |      |      |  |      |      |      |       |      |  |  |  |  |  |  |  |
| 250  | 52,4   | 56,0                       |                                |  |             |                           |  |     |      |                   |     |      |  |     |      |  |     |      |      |     |      |  |     |      |  |     |      |      |     |      |  |     |      |  |      |      |      |      |      |  |      |      |  |      |      |      |      |      |  |      |      |  |      |      |      |      |      |  |      |      |  |      |      |      |       |      |  |  |  |  |  |  |  |
| 315  | 48,2   |                            |                                |  |             |                           |  |     |      |                   |     |      |  |     |      |  |     |      |      |     |      |  |     |      |  |     |      |      |     |      |  |     |      |  |      |      |      |      |      |  |      |      |  |      |      |      |      |      |  |      |      |  |      |      |      |      |      |  |      |      |  |      |      |      |       |      |  |  |  |  |  |  |  |
| 400  | 49,5   |                            |                                |  |             |                           |  |     |      |                   |     |      |  |     |      |  |     |      |      |     |      |  |     |      |  |     |      |      |     |      |  |     |      |  |      |      |      |      |      |  |      |      |  |      |      |      |      |      |  |      |      |  |      |      |      |      |      |  |      |      |  |      |      |      |       |      |  |  |  |  |  |  |  |
| 500  | 46,7   | 52,5                       |                                |  |             |                           |  |     |      |                   |     |      |  |     |      |  |     |      |      |     |      |  |     |      |  |     |      |      |     |      |  |     |      |  |      |      |      |      |      |  |      |      |  |      |      |      |      |      |  |      |      |  |      |      |      |      |      |  |      |      |  |      |      |      |       |      |  |  |  |  |  |  |  |
| 630  | 46,2   |                            |                                |  |             |                           |  |     |      |                   |     |      |  |     |      |  |     |      |      |     |      |  |     |      |  |     |      |      |     |      |  |     |      |  |      |      |      |      |      |  |      |      |  |      |      |      |      |      |  |      |      |  |      |      |      |      |      |  |      |      |  |      |      |      |       |      |  |  |  |  |  |  |  |
| 800  | 41,9   |                            |                                |  |             |                           |  |     |      |                   |     |      |  |     |      |  |     |      |      |     |      |  |     |      |  |     |      |      |     |      |  |     |      |  |      |      |      |      |      |  |      |      |  |      |      |      |      |      |  |      |      |  |      |      |      |      |      |  |      |      |  |      |      |      |       |      |  |  |  |  |  |  |  |
| 1000   | 41,0   | 45,7                       |                                |  |             |                           |  |     |      |                   |     |      |  |     |      |  |     |      |      |     |      |  |     |      |  |     |      |      |     |      |  |     |      |  |      |      |      |      |      |  |      |      |  |      |      |      |      |      |  |      |      |  |      |      |      |      |      |  |      |      |  |      |      |      |       |      |  |  |  |  |  |  |  |
| 1250   | 39,7   |                            |                                |  |             |                           |  |     |      |                   |     |      |  |     |      |  |     |      |      |     |      |  |     |      |  |     |      |      |     |      |  |     |      |  |      |      |      |      |      |  |      |      |  |      |      |      |      |      |  |      |      |  |      |      |      |      |      |  |      |      |  |      |      |      |       |      |  |  |  |  |  |  |  |
| 1600   | 35,6   |                            |                                |  |             |                           |  |     |      |                   |     |      |  |     |      |  |     |      |      |     |      |  |     |      |  |     |      |      |     |      |  |     |      |  |      |      |      |      |      |  |      |      |  |      |      |      |      |      |  |      |      |  |      |      |      |      |      |  |      |      |  |      |      |      |       |      |  |  |  |  |  |  |  |
| 2000   | 35,1   | 39,4                       |                                |  |             |                           |  |     |      |                   |     |      |  |     |      |  |     |      |      |     |      |  |     |      |  |     |      |      |     |      |  |     |      |  |      |      |      |      |      |  |      |      |  |      |      |      |      |      |  |      |      |  |      |      |      |      |      |  |      |      |  |      |      |      |       |      |  |  |  |  |  |  |  |
| 2500   | 32,6   |                            |                                |  |             |                           |  |     |      |                   |     |      |  |     |      |  |     |      |      |     |      |  |     |      |  |     |      |      |     |      |  |     |      |  |      |      |      |      |      |  |      |      |  |      |      |      |      |      |  |      |      |  |      |      |      |      |      |  |      |      |  |      |      |      |       |      |  |  |  |  |  |  |  |
| 3150   | 32,3   |                            |                                |  |             |                           |  |     |      |                   |     |      |  |     |      |  |     |      |      |     |      |  |     |      |  |     |      |      |     |      |  |     |      |  |      |      |      |      |      |  |      |      |  |      |      |      |      |      |  |      |      |  |      |      |      |      |      |  |      |      |  |      |      |      |       |      |  |  |  |  |  |  |  |
| 4000   | 33,4   | 44,1                       |                                |  |             |                           |  |     |      |                   |     |      |  |     |      |  |     |      |      |     |      |  |     |      |  |     |      |      |     |      |  |     |      |  |      |      |      |      |      |  |      |      |  |      |      |      |      |      |  |      |      |  |      |      |      |      |      |  |      |      |  |      |      |      |       |      |  |  |  |  |  |  |  |
| 5000   | 43,4   |                            |                                |  |             |                           |  |     |      |                   |     |      |  |     |      |  |     |      |      |     |      |  |     |      |  |     |      |      |     |      |  |     |      |  |      |      |      |      |      |  |      |      |  |      |      |      |      |      |  |      |      |  |      |      |      |      |      |  |      |      |  |      |      |      |       |      |  |  |  |  |  |  |  |
| 6300   | 34,6   |                            |                                |  |             |                           |  |     |      |                   |     |      |  |     |      |  |     |      |      |     |      |  |     |      |  |     |      |      |     |      |  |     |      |  |      |      |      |      |      |  |      |      |  |      |      |      |      |      |  |      |      |  |      |      |      |      |      |  |      |      |  |      |      |      |       |      |  |  |  |  |  |  |  |
| 8000   | 39,3   | 45,2                       |                                |  |             |                           |  |     |      |                   |     |      |  |     |      |  |     |      |      |     |      |  |     |      |  |     |      |      |     |      |  |     |      |  |      |      |      |      |      |  |      |      |  |      |      |      |      |      |  |      |      |  |      |      |      |      |      |  |      |      |  |      |      |      |       |      |  |  |  |  |  |  |  |
| 10000  | 43,4   |                            |                                |  |             |                           |  |     |      |                   |     |      |  |     |      |  |     |      |      |     |      |  |     |      |  |     |      |      |     |      |  |     |      |  |      |      |      |      |      |  |      |      |  |      |      |      |      |      |  |      |      |  |      |      |      |      |      |  |      |      |  |      |      |      |       |      |  |  |  |  |  |  |  |
| <sup>2</sup> Correction  |  |                            |                                |  |             |                           |  |     |      |                   |     |      |  |     |      |  |     |      |      |     |      |  |     |      |  |     |      |      |     |      |  |     |      |  |      |      |      |      |      |  |      |      |  |      |      |      |      |      |  |      |      |  |      |      |      |      |      |  |      |      |  |      |      |      |       |      |  |  |  |  |  |  |  |
| Sound power level L <sub>w</sub> (A):  |  | 54,3 dB [re 1pW]           |                                |  | Uncertainty | σ <sub>tot</sub> : 1,6 dB |  |     |      |                   |     |      |  |     |      |  |     |      |      |     |      |  |     |      |  |     |      |      |     |      |  |     |      |  |      |      |      |      |      |  |      |      |  |      |      |      |      |      |  |      |      |  |      |      |      |      |      |  |      |      |  |      |      |      |       |      |  |  |  |  |  |  |  |
| Name of test institute:  | DTI  |                            |                                | Date: 14-06-2024                                   |             |                           |  |     |      |                   |     |      |  |     |      |  |     |      |      |     |      |  |     |      |  |     |      |      |     |      |  |     |      |  |      |      |      |      |      |  |      |      |  |      |      |      |      |      |  |      |      |  |      |      |      |      |      |  |      |      |  |      |      |      |       |      |  |  |  |  |  |  |  |
| No. of test report:  | 300-KLAB-24-026  |                            |                                |  |             |                           |  |     |      |                   |     |      |  |     |      |  |     |      |      |     |      |  |     |      |  |     |      |      |     |      |  |     |      |  |      |      |      |      |      |  |      |      |  |      |      |      |      |      |  |      |      |  |      |      |      |      |      |  |      |      |  |      |      |      |       |      |  |  |  |  |  |  |  |
| Measurements are in full conformity with ISO 3743-1  |  |                            |                                |  |             |                           |  |     |      |                   |     |      |  |     |      |  |     |      |      |     |      |  |     |      |  |     |      |      |     |      |  |     |      |  |      |      |      |      |      |  |      |      |  |      |      |      |      |      |  |      |      |  |      |      |      |      |      |  |      |      |  |      |      |      |       |      |  |  |  |  |  |  |  |



## Appendix 1 Sound power measurement

### Unit specification

Type of unit: Mono air to water heat pump

Manufacturer: PHNIX

Size of the heat pump: 0.5x1.3x0.9 m (W x L x H)

Year of production: N/A.


### Operating conditions and environment

The operating conditions of the unit under test fulfill the requirements for Class A.

The acoustic test chamber is a hard walled reverberant room (103 m<sup>3</sup>) and equipped with relevant sound diffusing reflector panels. The acoustical test chamber fulfills the requirements of ISO3743-1 accuracy grade 2 (Engineering grade).

The measurements of the average sound pressure levels in 1/3 octave frequency bands are carried out using three microphones in the test chamber. During the measurements, the microphones are traversed up and down for one meter in the arc of a quarter circle.

The picture below shows the installation of the unit under test, position of microphones, sound diffusing reflector panels and the reference sound source.





## Measurement instruments

| <b>Id nr.</b> | <b>Manufacturer</b> | <b>Description</b>                                     | <b>Calibration company</b> |
|---------------|---------------------|--|----------------------------|
| 100864        | GRAS                | Gras 40AE_26CA, ½" free field microphone, Room 1       | Norsonic A/S, Norway       |
| 100865        | GRAS                | Gras 40AE_26CA, ½" free field microphone, Room 1       | Norsonic A/S, Norway       |
| 100866        | GRAS                | Gras 40AE_26CA, ½" free field microphone, Room 1       | Norsonic A/S, Norway       |
| 100867*       | GRAS                | Gras 40AE_26CA, ½" free field microphone, Room 2       | Norsonic A/S, Norway       |
| 100868*       | GRAS                | Gras 40AE_26CA, ½" free field microphone, Room 2       | Norsonic A/S, Norway       |
| 100869*       | GRAS                | Gras 40AE_26CA, ½" free field microphone, Room 2       | Norsonic A/S, Norway       |
| 100870        | GRAS                | Gras 40AE_26CA, ½" free field microphone, Roof monitor | Norsonic A/S, Norway       |
| 100873*       | Brüel & Kjær        | Acoustical calibrator, Brüel & Kjær 4231               | Element Metech,<br>Denmark |
| 100859        | Norsonic            | Reference sound source, Norsonic Nor278<br>Room 1      | RISE, Sweden               |
| 100872*       | Norsonic            | Reference sound source, Norsonic Nor278<br>Room 2      | RISE, Sweden               |
| 100620*       | Norsonic            | Multi-channel measurement system<br>Nor850             | Norsonic A/S, Norway       |

\*Instruments are used for the actual measurements for the calculation of the test results.

The other instruments are used for control measurements.

All microphones are equipped with windshields.



## Test Procedure

The measurements of the emitted sound power level from the heat pump are carried out according to the following standard:

- DS/EN 14511:2022
- EN 12102-1:2022
- ISO/EN 3743-1:2010

The basic acoustic measurement standard DS/EN 3743-1 is a comparison method using a calibrated reference sound source. Two series of sound pressure measurements are made under exactly the same acoustic conditions, e.g., the same microphone positions, temperature and air humidity. The calibrated sound power levels are known for the reference sound source at each frequency band, and they are used in the estimation of the acoustical correction factor for the calculation of the sound power emitted from the unit under test. The background noise levels are measured and used for relevant corrections.

The final total A-weighted sound power level is based on measurements and calculations in 1/3-octave levels, which then are summed into 1/1-octave levels. The A-weighted total sound power level is determined for the measured frequency range from 100 Hz to 10 kHz.

The actual microphone positions and correction values are saved in data files linked to the complete project documentation according to the DANAk-accreditation.

The complete measurement system is documented and regularly calibrated according to DANAk.

The detailed description of the measurement method is given in Danish in the quality database system "QA Web" at Danish Technological Institute, which is accessible by DANAk.



## Measurement uncertainty

The uncertainty of sound power level in decibel is determined in accordance with ISO 3743-1, equation 22  $\sigma_{tot} = \sqrt{\sigma_{RO}^2 + \sigma_{omc}^2}$  where:

- $\sigma_{RO}$  is the standard deviation of the reproducibility of the method and
- $\sigma_{omc}$  is the standard deviation describing the uncertainty associated with the instability of the operating and mounting conditions for the particular noise source under test.

$\sigma_{RO}$  expresses the uncertainty in test results delivered by the different accredited test laboratories due to different instrumentation and implementation of measurement procedure as well different radiation characteristic of the noise source under test.

$\sigma_{omc}$  expresses the uncertainty associated with the instability of the operating and mounting conditions for the particular noise source under test. The mounting and installation conditions in two DTI acoustical test chambers are well defined in the test procedure. Possible instability of the operating conditions is monitored and assessed prior to each noise test.

The test uncertainty  $\sigma_{omc}$  is calculated according to ISO3743-1 Annex C formula C.1 and is typically below 1.0dB, however in the report rounded up to the nearest 0.5dB or 1.0dB increment. As per Table C.1 (Accuracy grade 2) the uncertainty  $\sigma_{RO}$  is set to 1.5.

The expanded uncertainty U is calculated according to ISO 3743-1 equation 23:  
 $U = k \sigma_{tot}$  where  $k = 2$  for 95% confidence.

EXAMPLE:  $\sigma_{tot}: \sqrt{1.5^2 + 0.5^2} = 1.6 \text{ dB}$  and  $U(95\%) = 3.2 \text{ dB}$

Note: The expanded uncertainty does not include the standard deviation of production which is used in ISO4871 for the purpose of making noise declaration for batches of machines.



DANISH  
TECHNOLOGICAL  
INSTITUTE

Page 35 of 35  
300-KLAB-24-026-3

## Appendix 2 Authorization Letter

### Authorization Letter

This declaration of conformity is issued under the sole responsibility of

Manufacturer's Name: Guangdong PHNIX ECO-Energy Solution LTD

Manufacturer's Address: No. 3 Tianyuan Road, Dagang Town, Nansha District  
Guangzhou Guangdong, 511470 China

We declare that the following Heat pump product we produced for COOPER  
AND HUNTER OVERSEAS LP are identical to our following models

|                     |                   |
|---------------------|-------------------|
| Cooper&Hunter model | CH-HP12-UIMPRM-P  |
| PHNIX model         | PASRW040S-BP-PS-B |

Cooper&Hunter company name: COOPER AND HUNTER OVERSEAS LP

Cooper&Hunter brand /-mark: Cooper&Hunter

Cooper&Hunter address: SUITE 201, 45B WEST WILMOT STREET,  
RICHMOND HILL, ON L4B2P3 CANADA

Note: This declaration becomes invalid if technical or operational modifications  
are introduced without the manufacturer's consent.

*For and on behalf of*  
GUANGDONG PHNIX ECO-ENERGY SOLUTION LTD.  
广东芬尼克兹节能设备有限公司

Date: 24 May 2024



Authorised party: Guangdong PHNIX ECO-Energy Solution LTD

Authorized Signature(s)



 DANAK  
Test Reg. nr. 300

## OŚWIADCZENIE

|           |  |                            |
|-----------|--|----------------------------|
| Producent | Cooper&Hunter  | oświadcza, iż pompy ciepła |
| 1)        | CH-HP12UIMPRM-P<br>Oznaczenie/typ/identyfikator modelu |                            |
| 2)        | CH-HP08UIMPRK-P<br>Oznaczenie/typ/identyfikator modelu |                            |
| 3)        | Oznaczenie/typ/identyfikator modelu                    |                            |
| 4)        | Oznaczenie/typ/identyfikator modelu                    |                            |
| 5)        | Oznaczenie/typ/identyfikator modelu                    |                            |

Należą do jednego podtypu w danym typoszeregu i spełniają łącznie następujące warunki:

- identyczna konstrukcja obiegu chłodniczego, ten sam czynnik chłodniczy/roboczy;
- ten sam producent, typ i liczba sprężarek;
- ten sam typ elementu rozprężnego;
- ten sam typ skraplacza;
- ten sam typ parownika;
- ten sam typ procesu odszraniania;
- ten sam sterownik i zasada sterowania wydajnością;
- ten sam producent, typ i liczba wentylatorów parownika (w przypadku powietrznych pomp ciepła) i zasada sterowania wydajnością (stała, zmienna lub stopniowana regulacja prędkości obrotowej);
- urządzenia z i bez zaworu czterodrogowego nie mogą być zaliczone do tego samego typoszeregu.

12.08.2024

Miejscowość, data

Jarosław Siszewski  
ERKUD Sp. z o.o.  
ul. Borynowa 7  
82-310 Gdynia  
NIP 578-316-52-22  
REGON 0000000007210

Podpis osoby upoważnionej