

Prüfbedingung  
Test condition

Verbrauch (Consumption)

A12 / Wxx-30 D

Prüfnummer  
Test number

LW-694-24-53

Messgrößen Measured variables	Einheit Unit	Mittelwert Mean value	abs. Fehler absolute error	rel. Fehler relative error
1 Pto	W	15.9	± 0.3	± 2.00%
2 Psb	W	9.8	± 0.2	± 2.00%
3 Poff	W	9.8	± 0.2	± 2.00%
4 Pck	W	-	± -	± -
5 Prüfdauer (test duration)	hh:mm:ss	2:02:10		
Prüfbeginn (beginning of test)	hh:mm:ss	12:21:40	11.12.2024	2024-12-11
Prüfende (end of test)	hh:mm:ss	14:23:50	11.12.2024	2024-12-11

6 Bemerkung (remark)

7 Prüfer (supervisor)C. Schaible

Prüfnorm (test standard)

EN 14825

passed