



Testing Laboratory 1045.1 accredited by the Czech Accreditation Institute pursuant to
ČSN EN ISO/IEC 17025:2018

Strojírenský zkušební ústav, s.p. Zkušební laboratoř
(Engineering Test Institute, Public Enterprise, Testing Laboratory)
Hudcova 424/56b, Medlánky, 621 00 Brno

Page 1 of 14



TEST REPORT

39-17622/H

Product: Outdoor Air/Water Heat pump - monobloc

Type designation: AirKompakt P1522

Customer: Kołton Spółka komandytowa
ul. Sosnowa 2
34-480 Jabłonka
POLAND

Manufacturer: Kołton Spółka komandytowa
ul. Sosnowa 2
34-480 Jabłonka
POLAND

Report issue date: 2024-04-09

Distribution list: 1 copy to the Customer
1 copy to the Engineering Test Institute

This document may be copied in its entirety without written consent of the Engineering Test Institute. Partial copies are subject to approval. The results of the tests and verifications shall relate only to the products tested as received or presented. The testing laboratory is not responsible for the data provided by the customer specified in the report.

SP-2021-000012_1_12


I. Description of product tested

The Heat pump **AirKompakt P1522** supplied by the company **Kořton Spółka komandytowa** is structurally adapted to operate in air/water system. Device is designed as monobloc placed outdoor and indoor display module. Refrigerant R290 is used with charge of 2.2 kg. Power supply is a three-phase. Heat pump is reversible and is working with variable flow rate.

Main components of the outdoor unit **AirKompakt P1522**:

- Serial number 23PC15030010204
- Cubic shape with dimensions 1400 × 600 × 1190 mm (W × D × H)
- Frame and casing made of varnished steel sheets
- Cubic-shaped evaporator, 4 rows, dimensions 990 × 100 × 1070 mm (W × D × H), spacing 2.5 mm
- Plate condenser with dimensions 165 × 230 × 560 mm (W × D × H) including insulation
- Compressor Emerson Copeland Scroll ZH13KCU TFMN 524
- Refrigerant R290 (2.2 kg)
- Electric expansion valve Carel E²V
- 4-way reversing valve Sanhua International Europe, SHF-20D-47-O2 + coil
- Refrigerant accumulator
- Axial fan Ø57 cm, Ziehl-Abegg SE ZN063-6IL.BD.V5D8
- Pressure sensors
- Temperature sensors
- Refrigerant pipes
- Air vent
- Sightglass
- Safety valve
- Flow switch
- Biflow filter drier
- Electrical cabinet


Scheme:



Photodocumentation:



Heat pump **AirKompakt P1522** – outdoor unit
– Front view –




Heat pump **AirKompakt P1522** – outdoor unit
– Back view –

– Not recognised –

KOLTON CE				
0090				
<table border="0" style="width: 100%;"> <tr> <td style="width: 33%;">Kolon sp. s.r.o. Kornančytova ul. Soosova 2 34-400 Jablonka www.kolton.pl</td> <td style="width: 33%; text-align: center;">Bioso Servis pumpy ciepła Servis sterownika</td> <td style="width: 33%; text-align: right;">Kontakt 18 264 26 67 608 432 909, 476 060 601 33 875 93 80</td> </tr> </table>		Kolon sp. s.r.o. Kornančytova ul. Soosova 2 34-400 Jablonka www.kolton.pl	Bioso Servis pumpy ciepła Servis sterownika	Kontakt 18 264 26 67 608 432 909, 476 060 601 33 875 93 80
Kolon sp. s.r.o. Kornančytova ul. Soosova 2 34-400 Jablonka www.kolton.pl	Bioso Servis pumpy ciepła Servis sterownika	Kontakt 18 264 26 67 608 432 909, 476 060 601 33 875 93 80		
Typ Model/ Model	AIRKOMPAKT P1522			
Rok produkcji Production year/ Baujahr	2022			
Numer fabryczny Serial number/ Identifikationsnummer	Z3PC15030010204			
Zasilanie elektryczne Power supply/ Elektrische Versorgung	400 V; 3 ~; 50 Hz;			
Maksymalny prąd pracy Max. operation current/ Maximaler Arbeitsstrom	16,4 A			
Stopień ochrony IP IP code/ IP-Bewertung	IP 24			
Poziom mocy akustycznej Sound power level/ Schalleistungspegel	68 dB			
Moc grzewcza (A7/W35) Heating capacity/ Heizleistung	15,46 kW			
Moc elektryczna (A7/W35) Rated power/ Elektrische Leistungsaufnahme	3,67 kW			
COP A7/W35	4,14			
Czynnik chłodniczy/ilość Refrigerant/Refrigerant	R290 / 2,20 kg			
Max. ciśnienie robocze obiegu chłodniczego Max. working pressure of refrigerant/ Max. Kältemitteldruck	26 bar			
Max. ciśnienie robocze obiegu grzewczego Max. working pressure/ Max. Arbeitsdruck	2,5 bar			
Max. temp. zasilania Max water temperature/ Max. Wassertemperatur	65°C			
Pojemność wodna Heat pump capacity/Wärmepumpenleistung	6 L			
Masa Weight/ Gewicht	220 kg			
<p>UWAGA! Service tylko dla wykwalifikowanego personelu! WARNING! Service only for qualified in hydrocarbon refrigerant (HC) staff! ACHTUNG! Service nur für qualifizierte Mitarbeiter mit Kohlenwasserstoffkältemittel (HC)!</p>				

Heat pump **AirKompakt P1522** – outdoor unit
– Compressor label –

Heat pump **AirKompakt P1522** – outdoor unit
– Label –



Heat pump **AirKompakt P1522** – outdoor unit
– Without cover –

II. Sample tested

SZU reg. no.	Product name	Date of submission
1212.24.39742.001	AirKompakt P1522	2024-03-26

The visual inspection, tests and verification were carried out by Ing. Antonín Kolbábek, Ph.D. at the test station of SZU.

The tests were performed using measuring and testing equipment with valid calibration.

Test objective:	Heating and cooling equipment
Exact name of the test procedure:	2.136* - Measurement of noise characteristics
Test method:	ČSN EN 12102-1:2023; ČSN ISO 9614-2:1997
Sample tested:	Air/Water Heat pump AirKompakt P1522
Measuring equipment used:	see Chapter III
Place of test:	Engineering Test Institute, Hudcova 424/56b, 621 00 Brno, CZ

Measurement uncertainty:

Measured quantity	Unit	Uncertainty of measurement	Evaluation
Liquid			
- temperature difference (dT)	[K]	± 0.15 K	fulfilled
- temperature inlet/outlet	[°C]	± 0.15 K	fulfilled
- volume flow	[m ³ /s]	± 1 %	fulfilled
- static pressure difference	[kPa]	± 1 kPa ($\Delta p \leq 20$ kPa) or ± 5 % ($\Delta p > 20$ kPa)	fulfilled
Air			
- dry bulb temperature	[°C]	± 0.2 K	fulfilled
- wet bulb temperature	[°C]	± 0.4 K	fulfilled
- volume flow	[m ³ /s]	± 5 %	not applied
- static pressure difference	[Pa]	± 5 Pa ($\Delta p \leq 100$ Pa) or ± 5 % ($\Delta p > 100$ Pa)	not applied
Refrigerant			
- pressure at compressor outlet	[kPa]	± 1 %	not applied
- temperature	[°C]	± 0.5 K	not applied
Concentration (in volume)			
- heat transfer medium	[%]	± 2	not applied
Electrical quantities			
- electric power	[W]	± 1 %	fulfilled
- voltage	[V]	± 0.5 %	fulfilled
- current	[A]	± 0.5 %	fulfilled
- electric energy	[kWh]	± 1 %	not applied
Compressor rotational speed	[min ⁻¹]	± 0.5 %	not applied
The heating or cooling capacities measured on the liquid side shall be determined within a maximum uncertainty of 5 % independent of the individual uncertainties of measurement including the uncertainties on the properties of fluids.			fulfilled

Note:

Comment to abbreviated marking: e.g. A7/W55

A (air) 7 (input source air temperature in °C) / W (water), 55 (output heating water temperature in °C)


a) Measurement surface

Tested samples were surrounded by a cuboid-shape measuring surface set at the distance d [m].

Test Sample: Air/Water Heat pump AirKompakt P1522			
Distance from the test sample	d	[m]	0.20
Height of measurement surface	h	[m]	1.37
Width of measurement surface	w	[m]	1.80
Depth of measurement surface	l	[m]	0.96
Total measurement surface area	S	[m ²]	9.29
Minimal measuring time per surface	t_M	[s]	90.00

Sketch of measurement surface (not to scale):

Air/Water Heat pump **AirKompakt P1522**
– Outdoor unit –



b) Acoustic environment

The testing sample was placed inside a climate chamber (with dimensions shown below); sound absorbing panels were mounted on the walls and the ceiling of the chamber. The outdoor unit was placed in the middle of the chamber, at a sufficient distance from the surrounding walls, and was rotated by about $5 \pm 10^\circ$.

Climate-acoustic chamber <i>(corresponds to free field over a reflecting plane)</i>			
Width of testing room	l_1	[m]	6.95
Length of testing room	l_2	[m]	4.25
Height of testing room	l_3	[m]	4.50

c) Measured and calculated data – General overview:

Test sample			Air/Water Heat pump AirKompakt P1522
The measured values are in accordance with ČSN EN 12102-1:2023			YES
The measured values are in accordance with ČSN EN ISO 9614-2:1997			YES
Operation mode			Heating
Specification of the assessment condition			A7/W55*
Type of HP capacity regulation			FIXED
Fan speed settings			AUTO
Date of testing (YYYY-MM-DD)			2024-04-04
Reference air temperature	t_{amb}	[°C]	7.0
Relative humidity of air	RH	[%]	83.0
Ambient pressure	p_{amb}	[hPa]	984.2
Overall sound power level (linear)	L_W	[dB]	80.8 ± 1.5
Overall A-weighted sound power level	L_{WA}	[dB(A)]	63.1 ± 1.5
Accuracy class			Engineering (grade 2)

* Comment to abbreviated marking: i.e. A7/W55
 A (water), 7 (input source liquid temperature in °C) / W (water), 55 (outlet heating water temperature in °C)

1A) Measurement results – octave bands

Air/Water Heat pump AirKompakt P1522 ; Outdoor unit at A7/W55 / ON/OFF /	Engineering (Grade 2)
--	----------------------------------

f _m [Hz]	Criterion 1			Criterion 2		Criterion 3	All criteria passed?	L _w [dB]	L _{WA} [dB(A)]	U [dB]	Evaluation
	L _d	F _{pl}	L _d > F _{pl}	F _{+/-}	F _{+/-} ≤ 3	L _{w(1)} -L _{w(2)} ≤ 5					
125	20.6	8.9	YES	0.9	YES	YES	YES	71.9	53.9	± 3.0	c
250	21.3	3.2	YES	0.0	YES	YES	YES	64.2	55.4	± 2.0	passed
500	22.2	3.5	YES	0.0	YES	YES	YES	61.0	57.6	± 1.5	passed
1000	21.1	3.3	YES	0.0	YES	YES	YES	57.9	57.7	± 1.5	passed
2000	21.0	3.2	YES	0.0	YES	YES	YES	52.1	53.2	± 1.5	c
4000	20.5	3.5	YES	0.0	YES	YES	YES	46.2	47.2	± 1.5	passed
8000 ^{*)}	20.4	4.1	YES	0.0	YES	YES	YES	40.5	40.4	± 2.5	c
Total								80.8	63.1	± 1.5	


^{*)} Due to the sound intensity method limitations, the frequency of 6300 Hz was measured only.

Legend:

- passed* Third frequency bands with this description are significant for calculation of A-weighted total sound power level L_{WA}. Required accuracy class is fulfilled in this band.
- not passed* Third frequency bands with this description are significant for calculation of A-weighted total sound power level L_{WA}. Required accuracy class is not fulfilled in this band.
- c* Third frequency bands with this description are not significant for calculating of A-weighted total sound power level L_{WA}. These bands are evaluated in calculating of L_{WA}.
- nc* Third frequency bands with this description are not significant for calculating of A-weighted total sound power level L_{WA}. These bands are not evaluated in calculating of L_{WA}.

Spectrum of Sound power level L_W – octave bands

Air/Water Heat pump AirKompakt P1522 ; Outdoor unit at A7/W55 / ON/OFF /	Engineering (Grade 2)
--	----------------------------------



1B) Measurement results – one-third octave bands

Air/Water Heat pump AirKompakt P1522 ; Outdoor unit at A7/W55 / ON/OFF /	Engineering (Grade 2)
--	----------------------------------


f _m [Hz]	Criterion 1			Criterion 2		Criterion 3	All criteria passed?	L _w [dB]	L _{WA} [dB(A)]	U [dB]	Evaluation
	L _d	F _{pl}	L _d > F _{pl}	F _{+/-}	F _{+/-} ≤ 3	L _{w(1)} -L _{w(2)} ≤ 5					
100	21.1	3.5	YES	0.0	YES	YES	YES	71.4	52.3	± 3.0	passed
125	20.6	8.9	YES	0.9	YES	YES	YES	56.8	40.7	± 3.0	c
160	21.3	3.6	YES	0.9	YES	YES	YES	61.5	48.1	± 3.0	passed
200	21.3	3.5	YES	0.0	YES	YES	YES	60.7	49.8	± 2.0	passed
250	21.3	3.2	YES	0.0	YES	YES	YES	58.9	50.3	± 2.0	passed
315	21.4	3.5	YES	0.0	YES	YES	YES	58.3	51.7	± 2.0	passed
400	21.9	3.5	YES	0.0	YES	YES	YES	57.0	52.2	± 1.5	passed
500	22.2	3.5	YES	0.0	YES	YES	YES	56.1	52.9	± 1.5	passed
630	21.8	3.4	YES	0.0	YES	YES	YES	55.4	53.5	± 1.5	passed
800	21.5	3.4	YES	0.0	YES	YES	YES	54.8	54.0	± 1.5	passed
1000	21.1	3.3	YES	0.0	YES	YES	YES	52.9	52.9	± 1.5	passed
1250	21.8	3.4	YES	0.0	YES	YES	YES	50.9	51.5	± 1.5	passed
1600	21.8	3.4	YES	0.0	YES	YES	YES	49.0	50.0	± 1.5	passed
2000	21.0	3.2	YES	0.0	YES	YES	YES	46.8	48.0	± 1.5	passed
2500	20.6	3.0	YES	0.0	YES	YES	YES	45.3	46.6	± 1.5	passed
3150	20.6	2.7	YES	0.0	YES	YES	YES	42.2	43.4	± 1.5	c
4000	20.5	3.5	YES	0.0	YES	YES	YES	41.9	42.9	± 1.5	c
5000	20.3	3.5	YES	0.0	YES	YES	YES	39.7	40.2	± 1.5	c
6300	20.4	4.1	YES	0.0	YES	YES	YES	35.8	35.7	± 2.5	c
Total								80.8	63.1	± 1.5	

Legend:

- passed* Third frequency bands with this description are significant for calculation of A-weighted total sound power level L_{WA}. Required accuracy class is fulfilled in this band.
- not passed* Third frequency bands with this description are significant for calculation of A-weighted total sound power level L_{WA}. Required accuracy class is not fulfilled in this band.
- c* Third frequency bands with this description are not significant for calculating of A-weighted total sound power level L_{WA}. These bands are evaluated in calculating of L_{WA}.
- nc* Third frequency bands with this description are not significant for calculating of A-weighted total sound power level L_{WA}. These bands are not evaluated in calculating of L_{WA}.

Spectrum of Sound power level L_w – one-third octave bands

Air/Water Heat pump AirKompakt P1522 ; Outdoor unit at A7/W55 / ON/OFF /	Engineering (Grade 2)
--	----------------------------------



Tested by: Ing. Antonín Kolbábek, Ph.D.

Date: 2024-04-04

Signed: 

Reviewed and approved by: Ing. Petr Lindovský

Date: 2024-04-09

Signed: 

V. A list of referenced documents

- Order of 2024-03-20 (Order reg. no. B-81825, received on 2024-03-20)
- Contract B-81825/39
- ČSN EN 12102-1:2023 - Air conditioners, liquid chilling packages, heat pumps, process chillers and dehumidifiers with electrically driven compressors - Determination of the sound power level - Part 1: Air conditioners, liquid chilling packages, heat pumps for space heating and cooling, dehumidifiers and process chillers
- ČSN EN 14511-2:2023 - Air conditioners, liquid chilling packages and heat pumps for space heating and cooling and process chillers, with electrically driven compressors - Part 2: Test conditions
- ČSN EN 14511-3:2023 - Air conditioners, liquid chilling packages and heat pumps for space heating and cooling and process chillers, with electrically driven compressors - Part 3: Test methods
- ČSN EN 14825:2023 - Air conditioners, liquid chilling packages and heat pumps, with electrically driven compressors, for space heating and cooling, commercial and process cooling - Testing and rating at part load conditions and calculation of seasonal performance
- Background of the SZU task no. 39-17622
- Record measurement file 39-17622-H.zip

Test Report compiled by: Ing. Ondrej Bilkovič



Test Report approved by: Ing. Antonín Kolbábek, Ph.D.
Hydraulic and Pressure Equipment Manager

– End of Test Report –



Testing Laboratory 1045.1 accredited by the Czech Accreditation Institute pursuant to
ČSN EN ISO/IEC 17025:2018

Strojírenský zkušební ústav, s.p. Zkušební laboratoř
(Engineering Test Institute, Public Enterprise, Testing Laboratory)
Hudcova 424/56b, Medlánky, 621 00 Brno

Page 1 of 34



TEST REPORT

39-17622/T

Product: Outdoor Air/Water Heat pump - monobloc

Type designation: AirKompakt P1522

Customer: Kořton Spółka komandytowa
ul. Sosnowa 2
34-480 Jabłonka
POLAND

Manufacturer: Kořton Spółka komandytowa
ul. Sosnowa 2
34-480 Jabłonka
POLAND

Report issue date: 2024-04-09

Distribution list: 1 copy to the Customer
1 copy to the Engineering Test Institute

This document may be copied in its entirety without written consent of the Engineering Test Institute. Partial copies are subject to approval. The results of the tests and verifications shall relate only to the products tested as received or presented. The testing laboratory is not responsible for the data provided by the customer specified in the report.

SP-2021-000012_1_12


I. Description of product tested

The Heat pump **AirKompakt P1522** supplied by the company **Kořton Spółka komandytowa** is structurally adapted to operate in air/water system. Device is designed as monobloc placed outdoor and indoor display module. Refrigerant R290 is used with charge of 2.2 kg. Power supply is a three-phase. Heat pump is reversible and is working with variable flow rate.

Main components of the outdoor unit **AirKompakt P1522**:

- Serial number 23PC15030010204
- Cubic shape with dimensions 1400 × 600 × 1190 mm (W × D × H)
- Frame and casing made of varnished steel sheets
- Cubic-shaped evaporator, 4 rows, dimensions 990 × 100 × 1070 mm (W × D × H), spacing 2.5 mm
- Plate condenser with dimensions 165 × 230 × 560 mm (W × D × H) including insulation
- Compressor Emerson Copeland Scroll ZH13KCU TFMN 524
- Refrigerant R290 (2.2 kg)
- Electric expansion valve Carel E²V
- 4-way reversing valve Sanhua International Europe, SHF-20D-47-O2 + coil
- Refrigerant accumulator
- Axial fan Ø57 cm, Ziehl-Abegg SE ZN063-6IL.BD.V5D8
- Pressure sensors
- Temperature sensors
- Refrigerant pipes
- Air vent
- Sightglass
- Safety valve
- Flow switch
- Biflow filter drier
- Electrical cabinet


Scheme:



Photodocumentation:



Heat pump **AirKompakt P1522** – outdoor unit
– Front view –



Heat pump **AirKompakt P1522** – outdoor unit
– Back view –

– Not recognised –

KOLTON CE	
0090	
Kolton sp. s.r.o. Nortanadytova ul. Sosnovova 2 34-480 Jablonka www.kolton.pl	Büro Servis pumpy ciepła Servis sterownika 33 875 93 80
Kontakt: 18 284 26 57 600 432 600, 576 980 901 33 875 93 80	
Typ Model/ Model	AIRKOMPAKT P1522
Rok produkcji Production year/Erzeuger	2022
Numer fabryczny Serial number/Seriennummer	23PC1500010204
Zasilanie elektryczne Power supply/ Elektrische Versorgung	400 V; 3 ~; 50 Hz;
Maksymalny prąd pracy Max. operation current/ Maximaler Arbeitsstrom	16,4 A
Stopień ochrony IP IP code/ IP-Bewertung	IP 24
Poziom mocy akustycznej Sound power level/ Schalleistungspegel	68 dB
Moc grzewcza (A7/W35) Heating capacity/ Heizleistung	15,18 kW
Moc elektryczna (A7/W35) Rated power/ Elektrische Leistungsaufnahme	3,67 kW
COP A7/W35	4,14
Czynnik chłodniczy/Ilość Refrigerant/ Kältemittel	R290 / 2,20 kg
Max. ciśnienie robocze obiegu chłodniczego Max. working pressure of refrigerant/ Max. Kältemitteldruck	26 bar
Max. ciśnienie robocze obiegu grzewczego Max. working pressure/ Max. Arbeitsdruck	2,5 bar
Max. temp. zasilania Max. water temperature of Max. Wassertemperatur	65°C
Pojemność wodna Max. pump capacity/Wärmepumpenvolumen	6 L
Masa Weight/ Gewicht	220 kg
UWAGA! Serwis tylko dla wykwalifikowanego personelu! WARNING! Service only for qualified in hydrocarbon refrigerant (HC) staff! ACHTUNG! Service nur für qualifizierte Mitarbeiter mit Kohlenwasserstoffkältemittel (HC)!	

Heat pump **AirKompakt P1522** – outdoor unit
– Compressor label –

Heat pump **AirKompakt P1522** – outdoor unit
– Label –



Heat pump **AirKompakt P1522** – outdoor unit
– Without cover –

II. Sample tested

SZU reg. no.	Product name	Date of submission
1212.24.39742.001	AirKompakt P1522	2024-03-26

The visual inspection, tests and verification were carried out by Ing. Tomáš Sedláček at the test station of SZU. The tests were performed using measuring and testing equipment with valid calibration.

III. Measuring and test equipment:

No.	Description:	Inventory number:
1.	Electrical energy meter	E3.1
2.	Digital watt meter	1.2.3 ENERGIE ANALYZATOR_3
3.	Flow meter Krohne Optiflux	8.1.6 TECH_K3_V_DN50_SEK
4.	Barometer	2.4 MAR18_1_PB
5.	Differential pressure gauge	14.2.2 MAR18_3_dP_2
6.	Temperature-humidity meter HF532	14.1.1 K3_VLHKOST_1
7.	Temperature-humidity meter HF532	14.1.3 K3_VLHKOST_2
8.	Thermometers	14.4 MAR18_T

IV. Methods, results of tests and verifications

No.	Test objective	Requirement	Method of test	Documentation	Test evaluation/ verification *
1.	Rating conditions	-	ČSN EN 14511-2:2023 ČSN EN 14511-3:2023	Page No. 7	x
2.	Seasonal performance tests and SCOP calculation – Low temperature application	-	ČSN EN 14511-3:2023 ČSN EN 14825:2023	Page No. 8-14	x
3.	Seasonal performance tests and SCOP calculation – Medium temperature application	-	ČSN EN 14511-3:2023 ČSN EN 14825:2023	Page No. 15-21	x

*) **Evaluation / statement of conformity:**

+ Requirement fulfilled

- Requirement not fulfilled

0 Not applicable

x Not evaluated

Measured quantity	Unit	Uncertainty measurement	of	Evaluation
Liquid				
- temperature difference (dT)	[K]	± 0.15 K		fulfilled
- temperature inlet/outlet	[°C]	± 0.15 K		fulfilled
- volume flow	[m ³ /s]	± 1 %		fulfilled
- static pressure difference	[kPa]	± 1 kPa ($\Delta p \leq 20$ kPa) or ± 5 % ($\Delta p > 20$ kPa)		fulfilled
Air				
- dry bulb temperature	[°C]	± 0.2 K		fulfilled
- wet bulb temperature	[°C]	± 0.4 K		fulfilled
- volume flow	[m ³ /s]	± 5 %		not applied
- static pressure difference	[Pa]	± 5 Pa ($\Delta p \leq 100$ Pa) or ± 5 % ($\Delta p > 100$ Pa)		not applied
Refrigerant				
- pressure at compressor outlet	[kPa]	± 1 %		not applied
- temperature	[°C]	± 0.5 K		not applied
Concentration (in volume)				
- heat transfer medium	[%]	± 2		not related
Electrical quantities				
- electric power	[W]	± 1 %		fulfilled
- voltage	[V]	± 0.5 %		fulfilled
- current	[A]	± 0.5 %		fulfilled
- electric energy	[kWh]	± 1 %		not applied
Compressor rotational speed	[min ⁻¹]	± 0.5 %		not applied
The heating or cooling capacities measured on the liquid side shall be determined within a maximum uncertainty of 5 % independent of the individual uncertainties of measurement including the uncertainties on the properties of fluids.				fulfilled

Note:

The stated extended measurement uncertainties are calculated as a factor of the measurement uncertainty and the extension coefficient $k=2$, corresponding to the coverage certainty of 95% as regards standard classification.

If a statement of conformity is provided, the decision rule pursuant to ILAC-G8:09/2019, Art. 4.2.1 - binary statement for the simple acceptance rule shall apply.

Comment to abbreviated marking: e.g. A7/W35

A (air) 7 (input air, dry-bulb temperature in °C) / W (water), 35 (output heating water temperature in °C)

Test objective:	Rating conditions
Exact name of the test procedure:	1.37* - Tests of leakage, pressure resistance, thermal and technical parameters, combustion efficiency, safety functions
Test method:	ČSN EN 14511-2:2023, ČSN EN 14511-3:2023
Sample tested:	Heat pump AirKompakt P1522
Measuring equipment used:	see Chapter III

Specification of the assessment condition		A7/W35	A7/W55
Date of testing		2024-03-26	2024-03-27
Transient test procedure	YES / NO	NO	NO
Average defrost time of 1 cycle	[min]	–	–
Average time of 1 cycle	[min]	–	–
Calculation time	[min]	70.0	70.0
Output heating water – temperature calculation	[°C]	35.00	54.98
Input heating water – temperature calculation	[°C]	30.01	47.01
Output heating water temperature	[°C]	35.00	54.98
Input heating water temperature	[°C]	30.01	47.01
Air temperature – dry bulb temperature	[°C]	7.00	7.00
Air temperature – wet bulb temperature	[°C]	6.01	6.00
Relative humidity	[%]	87.02	87.00
Barometric pressure	[kPa]	96.965	96.468
Ambient temperature	[°C]	7.02	7.02
Secondary circuit pressure difference	[kPa]	-20.251	-6.997
Efficiency of the secondary liquid pump	[-]	0.275	0.154
Volume flow rate of heating water	[m ³ ·h ⁻¹]	2.7941	1.6780
Density of heating water	[kg·m ⁻³]	993.9	985.8
Specific heat capacity of heating water	[kJ·kg ⁻¹ ·K ⁻¹]	4.175	4.178
Voltage	[V]	402.48	401.14
Total current	[A]	21.44	25.60
Overall power input	[kW]	3.416	4.753
Capacity correction of sec. liquid pump	[W]	-41.337	-17.891
Power input correction of sec. liquid pump	[W]	-57.06	-21.15
Heating capacity – heating water	[kW]	16.076	15.314
Corrected heating capacity – heating water	[kW]	16.117	15.332
Uncertainty of corrected heating capacity	[kW]	± 0.281	± 0.175
Effective electric power input	[kW]	3.473	4.775
COP	[-]	4.640	3.211
Uncertainty of COP	[-]	± 0.082	± 0.037
Control settings	[-]	–	–
Circulation pump settings – heating water	[-]	–	–

Test objective:	Seasonal performance tests and SCOP calculation – Low temperature application
Exact name of the test procedure:	1.37* - Tests of leakage, pressure resistance, thermal and technical parameters, combustion efficiency, safety functions
Test method:	ČSN EN 14511-3:2023, ČSN EN 14825:2023
Sample tested:	Heat pump AirKompakt P1522
Measuring equipment used:	see Chapter III

Design		Air / water – monobloc			
Conditions specification according to ČSN 14825:2023	to EN	Temperature application		Low (ref. water temperature 35 °C)	
		Reference heating season		Average	
		Outlet water temperature - indoor heat exchanger		Variable	
		Compressor speed control		Fixed	
		Water flow rate – primary circuit		–	
		Water flow rate – secondary circuit		Variable	
Seasonal space heating efficiency	Heating	Average	η_s	161.6	%
		Warmer	η_s	–	%
		Colder	η_s	–	%
Seasonal efficiency according to ČSN 14825:2023	Heating	Average	SCOP	4.12	–
		Warmer	SCOP	–	–
		Colder	SCOP	–	–

Function	Cooling			Yes	
	Heating	Yes	Reference heating season	Average	Yes
				Warmer	–
				Colder	–

Full heating load	Cooling		$P_{designc}$	–	kW
	Heating	Average	$P_{designh}$	12.45	kW
		Warmer	$P_{designh}$	–	kW
		Colder	$P_{designh}$	–	kW

Bivalent temperatures	Heating	Average	$T_{bivalent}$	-7	°C
		Warmer	$T_{bivalent}$	–	°C
		Colder	$T_{bivalent}$	–	°C

Operation temperatures limit	Heating	Average	TOL	-10	°C
		Warmer	TOL	–	°C
		Colder	TOL	–	°C

Seasonal power consumption according to ČSN EN 14825:2023	Cooling		Q_{CE}	–	kWh
	Heating	Average	Q_{HE}	6252	kWh
		Warmer	Q_{HE}	–	kWh
		Colder	Q_{HE}	–	kWh
Modes other than „active mode“		Off mode	P_{OFF}	17.7	W
		Thermostat off mode	P_{TO}	17.7	W
		Standby mode	P_{SB}	17.7	W
		Crankcase heater mode	P_{CK}	0.0	W

Calculation of SCOP according to ČSN EN 14825:2023:

Number of hours used for calculation of reference SCOP (Annex B – Table B. 2, B. 3)

- For reversible heat pumps and reference heating season „A“ = average

H _{HE}	2066	[h]
H _{TO}	178	[h]
H _{SB}	0	[h]
H _{CK}	178	[h]
H _{OFF}	0	[h]

Measured data:

P _{TO}	0.0177	[kW]
P _{SB}	0.0177	[kW]
P _{CK}	0.0000	[kW]
P _{OFF}	0.0177	[kW]
P _{designh}	12.45	[kW]
SCOP _{ON}	4.12	[-]

Coefficient and correction:

F(1)	3	[%]
F(2)	0	[%]
CC	2.5	[-]

Calculation of SCOP:

7.3 Calculation of the reference annual heating demand (Q_H)

$$Q_H = P_{designh} \cdot H_{HE} \quad [kWh]$$

$$Q_H = 12.45 \cdot 2066 = 25730 \quad [kWh]$$

7.4 Calculation of the annual electricity consumption (Q_{HE})

$$Q_{HE} = Q_H / SCOP_{on} + H_{TO} \cdot P_{TO} + H_{SB} \cdot P_{SB} + H_{CK} \cdot P_{CK} + H_{OFF} \cdot P_{OFF} \quad [kWh]$$

$$Q_{HE} = 25730 / 4.12 + 178 \cdot 0.0177 + 0 \cdot 0.0177 + 178 \cdot 0 + 0 \cdot 0.0177 = 6252 \quad [kWh]$$

7.2 General formula for calculation of reference SCOP

$$SCOP = Q_H / Q_{HE} \quad [-]$$

$$SCOP = 25730 / 6252 = 4.12 \quad [-]$$

7.1 Calculation of the seasonal space heating efficiency η_s

$$\Sigma F(i) = F(1) + F(2) \quad [-]$$

$$\Sigma F = 0.03 + 0 = 0.03 \quad [-]$$

$$\eta_s = 1 / CC \cdot SCOP - \Sigma F(i) \quad [-]$$

$$\eta_s / A = (1 / 2.5) \cdot 4.12 - 0.03 = \underline{1.616} \quad [-]$$

Temperature level		Low (reference water temperature 35 °C)		
Reference heating season		„A“ = average ($T_{designh} = -10\text{ °C}$)		
Assessment condition		A, T _{biv} (F)	B	C
Specification of the assessment condition		A-7/W34	A2/W32.38	A7/W30.69
Date of testing		2024-03-27	2024-04-02	2024-04-03
Transient test procedure	YES / NO	NO	YES	NO
Average defrost time of 1 cycle	[min]	–	3.8	–
Average time of 1 cycle	[min]	–	76.9	–
Calculation time	[min]	70.0	153.9	70.0
Output heating water – temperature calculation	[°C]	34.04	31.80	30.67
Input heating water – temperature calculation	[°C]	29.06	27.39	25.71
Output heating water temperature	[°C]	34.04	32.35	30.67
Input heating water temperature	[°C]	29.06	27.39	25.71
Air temperature – dry bulb temperature	[°C]	-6.98	2.01	7.00
Air temperature – wet bulb temperature	[°C]	-8.01	0.99	6.01
Relative humidity	[%]	74.83	83.59	86.98
Barometric pressure	[kPa]	96.202	97.617	97.895
Ambient temperature	[°C]	-7.02	2.02	7.02
Secondary circuit pressure difference	[kPa]	-13.574	-16.047	-21.918
Efficiency of the secondary liquid pump	[-]	0.202	0.240	0.286
Volume flow rate of heating water	[m ³ ·h ⁻¹]	1.9111	2.4802	2.8745
Density of heating water	[kg·m ⁻³]	994.3	994.9	995.3
Specific heat capacity of heating water	[kJ·kg ⁻¹ ·K ⁻¹]	4.175	4.176	4.177
Voltage	[V]	400.03	401.49	398.83
Total current	[A]	21.05	20.90	20.57
Overall power input	[kW]	3.321	3.241	3.169
Capacity correction of sec. liquid pump	[W]	-28.508	-35.007	-43.605
Power input correction of sec. liquid pump	[W]	-35.71	-46.07	-61.11
Heating capacity – heating water	[kW]	10.989	12.702	16.470
Corrected heating capacity – heating water	[kW]	11.017	12.737	16.513
Uncertainty of corrected heating capacity	[kW]	± 0.193	± 0.249	± 0.290
Effective electric power input	[kW]	3.356	3.287	3.230
COP	[-]	3.283	3.875	5.112
Uncertainty of COP	[-]	± 0.058	± 0.076	± 0.091
Control settings	[-]	–	–	–
Circulation pump settings – heating water	[-]	–	–	–

Temperature level		Low (reference water temperature 35 °C)	
Reference heating season		„A“ = average ($T_{designh} = -10\text{ °C}$)	
Assessment condition		D	TOL (E)
Specification of the assessment condition		A12/W28.5	A-10/W35
Date of testing		2024-04-03	2024-03-28
Transient test procedure	YES / NO	NO	NO
Average defrost time of 1 cycle	[min]	–	–
Average time of 1 cycle	[min]	–	–
Calculation time	[min]	70.0	70.0
Output heating water – temperature calculation	[°C]	28.44	34.99
Input heating water – temperature calculation	[°C]	23.49	30.01
Output heating water temperature	[°C]	28.44	34.99
Input heating water temperature	[°C]	23.49	30.01
Air temperature – dry bulb temperature	[°C]	12.00	-10.00
Air temperature – wet bulb temperature	[°C]	11.00	-11.03
Relative humidity	[%]	88.99	69.34
Barometric pressure	[kPa]	98.020	96.386
Ambient temperature	[°C]	12.02	-10.01
Secondary circuit pressure difference	[kPa]	-29.410	-7.819
Efficiency of the secondary liquid pump	[-]	0.329	0.160
Volume flow rate of heating water	[m ³ ·h ⁻¹]	3.3440	1.7308
Density of heating water	[kg·m ⁻³]	995.9	994.0
Specific heat capacity of heating water	[kJ·kg ⁻¹ ·K ⁻¹]	4.178	4.175
Voltage	[V]	401.72	401.85
Total current	[A]	20.44	21.10
Overall power input	[kW]	3.086	3.321
Capacity correction of sec. liquid pump	[W]	-55.755	-19.655
Power input correction of sec. liquid pump	[W]	-83.07	-23.42
Heating capacity – heating water	[kW]	19.139	9.937
Corrected heating capacity – heating water	[kW]	19.195	9.956
Uncertainty of corrected heating capacity	[kW]	± 0.338	± 0.174
Effective electric power input	[kW]	3.169	3.344
COP	[-]	6.058	2.977
Uncertainty of COP	[-]	± 0.108	± 0.052
Control settings	[-]	–	–
Circulation pump settings – heating water	[-]	–	–

Data for SCOP calculation

- Low temperature application (reference water temperature 35 °C)
- Reference heating season „A“ – average

	Outdoor heat exchanger	Indoor heat exchanger	Part load ratio	Part load	DC Declared capacity	COPd at declared capacity	Cdh degradation coefficient	CR	COPbin (Tj)	Eff. power input of compressor off state
	Outdoor air inlet	Outlet water temperature								
	[°C]	[°C]	[%]	[kW]	[kW]	[-]	[-]	[-]	[-]	[kW]
A	-7	34.00	88.46	11.02	11.017	3.283	0.900	1.00	3.283	–
B	2	32.37	53.85	6.71	12.737	3.875	0.995	0.53	3.856	0.0177
C	7	30.69	34.62	4.31	16.513	5.112	0.995	0.26	5.034	0.0177
D	12	28.50	15.38	1.92	19.195	6.058	0.994	0.10	5.767	0.0177
TOL (E)	-10	35.00	100.00	12.45	9.956	2.977	0.900	1.25	2.977	–
Tbiv (F)	-7	34.00	88.46	11.02	11.017	3.283	0.900	1.00	3.283	–

Adaption of water temperature – according to ČSN EN 14825:2023, Annex E

- Low temperature application (reference water temperature 35 °C)
- Reference season „A“ – average
- Condition D
- Variable water flow rate – secondary circuit

General formulas and derivation:

$$t_{\text{outlet, average}} = t_{\text{inlet, capacity test}} + (t_{\text{outlet, capacity test}} - t_{\text{inlet, capacity test}}) \cdot \text{CR} \quad [^{\circ}\text{C}]$$

$$t_{\text{outlet, average}} = t_{\text{inlet, capacity test}} + (\Delta t) \cdot \text{CR} \quad [^{\circ}\text{C}]$$

$$t_{\text{outlet, average}} = t_{\text{outlet, capacity test}} - \Delta t + \Delta t \cdot \text{CR} \quad [^{\circ}\text{C}]$$

$$t_{\text{outlet, capacity test}} = t_{\text{outlet, average}} + \Delta t - \Delta t \cdot \text{CR} \quad [^{\circ}\text{C}]$$

For variable flow:

$$\Delta t = 5$$

$$\text{CR} \cdot \Delta t = \text{Part load} / \text{Declared capacity} \cdot 5$$

$$t_{\text{outlet, capacity test, variable flow}} = t_{\text{outlet, average}} + 5 - \text{Part load} / \text{Declared capacity} \cdot 5$$

Measured data:

$t_{\text{outlet, average}}$	24.00	[°C]
Declared capacity	19.195	[kW]
Declared capacity standard rating condition A7/W35	-	[kW]
Part load	1.92	[kW]

Calculation of water temperature

$$t_{\text{outlet, capacity test, variable flow}} = 24 + 5 - 1.92 / 19.195 \cdot 5 = \mathbf{28.5} \quad [^{\circ}\text{C}]$$

Calculation SCOP, SCOP_{on}, SCOP_{net}


- Low temperature application (reference water temperature 35 °C)
- Reference heating season „A“ – average

Bin	Outdoor temp. (dry bulb)	Hours	Part load ratio	Heat load	Capacity of HP	Heat load covered by heat pump	Resistive heat elbu (Tj)	Annual resistive heat	COPbin (Tj)	Annual heating demand	Annual power input including electric back up heating	Net annual heating capacity	Net annual power input without electric back up heating
j	Tj	hj		Ph(Tj)			elbu(Tj)	hj x elbu(Tj)	COPbin (Tj)	hj x Ph(Tj)		hj x (Ph(Tj) - elbu(Tj))	
[-]	[°C]	[h]	[%]	[kW]	[kW]	[kW]	[kW]	[kWh]	[-]	[kWh]	[kWh]	[kWh]	[kWh]
TOL (E)	21	-10	1	100.00	9.96	9.96	2.50	2.50	2.98	12	6	10	3
	22	-9	25	96.15	10.31	10.31	1.67	41.63	3.08	299	125	258	84
	23	-8	23	92.31	10.66	10.66	0.83	19.15	3.18	264	96	245	77
A, Tbiv (F)	24	-7	24	88.46	11.02	11.02	0.00	0.00	3.28	264	81	264	81
	25	-6	27	84.62	11.21	10.54	0.00	0.00	3.35	285	85	285	85
	26	-5	68	80.77	11.40	10.06	0.00	0.00	3.41	684	201	684	201
	27	-4	91	76.92	11.59	9.58	0.00	0.00	3.47	872	251	872	251
	28	-3	89	73.08	11.78	9.10	0.00	0.00	3.54	810	229	810	229
	29	-2	165	69.23	11.97	8.62	0.00	0.00	3.60	1423	395	1423	395
	30	-1	173	65.38	12.16	8.14	0.00	0.00	3.67	1409	384	1409	384
	31	0	240	61.54	12.35	7.66	0.00	0.00	3.73	1839	493	1839	493
	32	1	280	57.69	12.55	7.19	0.00	0.00	3.79	2012	530	2012	530
B	33	2	320	53.85	12.74	6.71	0.00	0.00	3.86	2146	556	2146	556
	34	3	357	50.00	13.49	6.23	0.00	0.00	4.09	2223	543	2223	543
	35	4	356	46.15	14.25	5.75	0.00	0.00	4.33	2046	473	2046	473
	36	5	303	42.31	15.00	5.27	0.00	0.00	4.56	1597	350	1597	350
	37	6	330	38.46	15.76	4.79	0.00	0.00	4.80	1581	329	1581	329
C	38	7	326	34.62	16.51	4.31	0.00	0.00	5.03	1405	279	1405	279
	39	8	348	30.77	17.05	3.83	0.00	0.00	5.18	1334	257	1334	257
	40	9	335	26.92	17.59	3.35	0.00	0.00	5.33	1123	211	1123	211
	41	10	315	23.08	18.12	2.87	0.00	0.00	5.47	905	165	905	165
	42	11	215	19.23	18.66	2.40	0.00	0.00	5.62	515	92	515	92
D	43	12	169	15.38	19.20	1.92	0.00	0.00	5.77	324	56	324	56
	44	13	151	11.54	19.73	1.44	0.00	0.00	5.91	217	37	217	37
	45	14	105	7.69	20.27	0.96	0.00	0.00	6.06	101	17	101	17
	46	15	74	3.85	20.80	0.48	0.00	0.00	6.21	35	6	35	6
	Σ		4910						Σ	25725	6248	25662	6185

SCOP _{on}	4.12	SCOP _{net}	4.15
		SCOP	4.12

Part load performance diagram

- Low temperature application (reference water temperature 35 °C)
- Reference heating season „A“ – average



Test objective:	Seasonal performance tests and SCOP calculation – Medium temperature application
Exact name of the test procedure:	1.37* - Tests of leakage, pressure resistance, thermal and technical parameters, combustion efficiency, safety functions
Test method:	ČSN EN 14511-3:2023, ČSN EN 14825:2023
Sample tested:	Heat pump AirKompakt P1522
Measuring equipment used:	see Chapter III

Design		Air / water – monobloc			
Conditions specification according to ČSN 14825:2023	to EN	Temperature application		Medium (ref. water temperature 55 °C)	
		Reference heating season		Average	
		Outlet water temperature - indoor heat exchanger		Variable	
		Compressor speed control		Fixed	
		Water flow rate – primary circuit		–	
		Water flow rate – secondary circuit		Variable	
Seasonal space heating efficiency	Heating	Average	η_s	128.4	%
		Warmer	η_s	–	%
		Colder	η_s	–	%
Seasonal efficiency according to ČSN 14825:2023	Heating	Average	SCOP	3.28	–
		Warmer	SCOP	–	–
		Colder	SCOP	–	–

Function	Cooling			Yes	
	Heating	Yes	Reference heating season	Average	Yes
				Warmer	–
				Colder	–

Full heating load	Cooling		$P_{designc}$	–	kW
	Heating	Average	$P_{designh}$	11.96	kW
		Warmer	$P_{designh}$	–	kW
		Colder	$P_{designh}$	–	kW

Bivalent temperatures	Heating	Average	$T_{bivalent}$	-7	°C
		Warmer	$T_{bivalent}$	–	°C
		Colder	$T_{bivalent}$	–	°C

Operation temperatures limit	Heating	Average	TOL	-10	°C
		Warmer	TOL	–	°C
		Colder	TOL	–	°C

Seasonal consumption according to ČSN EN 14825:2023	Cooling		Q_{CE}	–	kWh
	Heating	Average	Q_{HE}	7521	kWh
		Warmer	Q_{HE}	–	kWh
		Colder	Q_{HE}	–	kWh
Modes other than „active mode“		Off mode	P_{OFF}	17.7	W
		Thermostat off mode	P_{TO}	17.7	W
		Standby mode	P_{SB}	17.7	W
		Crankcase heater mode	P_{CK}	0.0	W

Calculation of SCOP according to ČSN EN 14825:2023:

Number of hours used for calculation of reference SCOP (Annex B – Table B. 2, B. 3)

- For reversible heat pumps and reference heating season „A“ = average

H _{HE}	2066	[h]
H _{TO}	178	[h]
H _{SB}	0	[h]
H _{CK}	178	[h]
H _{OFF}	0	[h]

Measured data:

P _{TO}	0.0177	[kW]
P _{SB}	0.0177	[kW]
P _{CK}	0.0000	[kW]
P _{OFF}	0.0177	[kW]
P _{designh}	11.96	[kW]
SCOP _{ON}	3.29	[-]

Coefficient and correction:

F(1)	3	[%]
F(2)	0	[%]
CC	2.5	[-]

Calculation of SCOP:

7.3 Calculation of the reference annual heating demand (Q_H)

$$Q_H = P_{designh} \cdot H_{HE} \quad [kWh]$$

$$Q_H = 11.96 \cdot 2066 = 24700 \quad [kWh]$$

7.4 Calculation of the annual electricity consumption (Q_{HE})

$$Q_{HE} = Q_H / SCOP_{on} + H_{TO} \cdot P_{TO} + H_{SB} \cdot P_{SB} + H_{CK} \cdot P_{CK} + H_{OFF} \cdot P_{OFF} \quad [kWh]$$

$$Q_{HE} = 24700 / 3.29 + 178 \cdot 0.0177 + 0 \cdot 0.0177 + 178 \cdot 0 + 0 \cdot 0.0177 = 7521 \quad [kWh]$$

7.2 General formula for calculation of reference SCOP

$$SCOP = Q_H / Q_{HE} \quad [-]$$

$$SCOP = 24700 / 7521 = 3.28 \quad [-]$$

7.1 Calculation of the seasonal space heating efficiency η_s

$$\Sigma F(i) = F(1) + F(2) \quad [-]$$

$$\Sigma F = 0.03 + 0 = 0.03 \quad [-]$$

$$\eta_s = 1 / CC \cdot SCOP - \Sigma F(i) \quad [-]$$

$$\eta_s / A = (1 / 2.5) \cdot 3.28 - 0.03 = \underline{1.284} \quad [-]$$

Temperature level		Medium (reference water temperature 55 °C)		
Reference heating season		„A“ = average ($T_{designh} = -10\text{ °C}$)		
Assessment condition		A, T _{biv} (F)	B	C
Specification of the assessment condition		A-7/W52	A2/W45.79	A7/W41.96
Date of testing		2024-03-27	2024-03-28	2024-04-02
Transient test procedure	YES / NO	NO	YES	NO
Average defrost time of 1 cycle	[min]	–	4.1	–
Average time of 1 cycle	[min]	–	86.0	–
Calculation time	[min]	70.0	86.0	70.0
Output heating water – temperature calculation	[°C]	51.99	45.01	41.98
Input heating water – temperature calculation	[°C]	44.01	37.91	33.99
Output heating water temperature	[°C]	51.99	45.81	41.98
Input heating water temperature	[°C]	44.01	37.84	33.99
Air temperature – dry bulb temperature	[°C]	-7.01	2.02	7.00
Air temperature – wet bulb temperature	[°C]	-8.03	0.99	6.01
Relative humidity	[%]	74.84	83.61	87.11
Barometric pressure	[kPa]	96.295	96.605	97.741
Ambient temperature	[°C]	-7.02	2.02	7.02
Secondary circuit pressure difference	[kPa]	-3.054	-14.339	-7.978
Efficiency of the secondary liquid pump	[-]	0.125	0.187	0.163
Volume flow rate of heating water	[m ³ ·h ⁻¹]	1.1550	1.4933	1.7691
Density of heating water	[kg·m ⁻³]	987.3	990.2	991.5
Specific heat capacity of heating water	[kJ·kg ⁻¹ ·K ⁻¹]	4.177	4.175	4.175
Voltage	[V]	401.62	398.74	402.34
Total current	[A]	24.00	23.05	22.66
Overall power input	[kW]	4.273	3.984	3.827
Capacity correction of sec. liquid pump	[W]	-6.870	-23.421	-20.201
Power input correction of sec. liquid pump	[W]	-7.85	-29.45	-24.12
Heating capacity – heating water	[kW]	10.569	12.208	16.244
Corrected heating capacity – heating water	[kW]	10.576	12.231	16.264
Uncertainty of corrected heating capacity	[kW]	± 0.121	± 0.154	± 0.185
Effective electric power input	[kW]	4.281	4.013	3.851
COP	[-]	2.470	3.047	4.223
Uncertainty of COP	[-]	± 0.028	± 0.039	± 0.048
Control settings	[-]	–	–	–
Circulation pump settings – heating water	[-]	–	–	–

Temperature level		Medium (reference water temperature 55 °C)	
Reference heating season		„A“ = average ($T_{designh} = -10\text{ °C}$)	
Assessment condition		D	TOL (E)
Specification of the assessment condition		A12/W37.22	A-10/W55
Date of testing		2024-04-02	2024-03-28
Transient test procedure	YES / NO	NO	NO
Average defrost time of 1 cycle	[min]	–	–
Average time of 1 cycle	[min]	–	–
Calculation time	[min]	70.0	70.0
Output heating water – temperature calculation	[°C]	37.25	55.01
Input heating water – temperature calculation	[°C]	29.24	47.01
Output heating water temperature	[°C]	37.25	55.01
Input heating water temperature	[°C]	29.24	47.01
Air temperature – dry bulb temperature	[°C]	12.00	-10.00
Air temperature – wet bulb temperature	[°C]	11.00	-11.03
Relative humidity	[%]	88.97	69.06
Barometric pressure	[kPa]	97.801	96.510
Ambient temperature	[°C]	12.02	-10.01
Secondary circuit pressure difference	[kPa]	-10.840	-4.988
Efficiency of the secondary liquid pump	[-]	0.189	0.131
Volume flow rate of heating water	[m ³ ·h ⁻¹]	2.0346	1.0676
Density of heating water	[kg·m ⁻³]	993.2	985.9
Specific heat capacity of heating water	[kJ·kg ⁻¹ ·K ⁻¹]	4.175	4.178
Voltage	[V]	402.98	401.71
Total current	[A]	21.73	24.30
Overall power input	[kW]	3.521	4.362
Capacity correction of sec. liquid pump	[W]	-26.230	-9.791
Power input correction of sec. liquid pump	[W]	-32.36	-11.27
Heating capacity – heating water	[kW]	18.756	9.775
Corrected heating capacity – heating water	[kW]	18.782	9.785
Uncertainty of corrected heating capacity	[kW]	± 0.214	± 0.111
Effective electric power input	[kW]	3.553	4.373
COP	[-]	5.286	2.238
Uncertainty of COP	[-]	± 0.061	± 0.026
Control settings	[-]	–	–
Circulation pump settings – heating water	[-]	–	–

Data for SCOP calculation

- Medium temperature application (reference water temperature 55 °C)
- Reference heating season „A“ – average

	Outdoor heat exchanger	Indoor heat exchanger	Part load ratio	Part load	DC Declared capacity	COP _d at declared capacity	C _{dh} degradation coefficient	CR	COP _{bin} (T _j)	Eff. power input of compressor off state
	Outdoor air inlet	Outlet water temperature								
	[°C]	[°C]	[%]	[kW]	[kW]	[-]	[-]	[-]	[-]	[kW]
A	-7	52.00	88.46	10.58	10.576	2.470	0.900	1.00	2.470	–
B	2	45.79	53.85	6.44	12.231	3.047	0.996	0.53	3.035	0.0177
C	7	41.96	34.62	4.14	16.264	4.223	0.995	0.25	4.167	0.0177
D	12	37.22	15.38	1.84	18.782	5.286	0.995	0.10	5.054	0.0177
TOL (E)	-10	55.00	100.00	11.96	9.785	2.238	0.900	1.22	2.238	–
T_{biv} (F)	-7	52.00	88.46	10.58	10.576	2.470	0.900	1.00	2.470	–

Adaption of water temperature – according to ČSN EN 14825:2023, Annex E

- Medium temperature application (reference water temperature 55 °C)
- Reference season „A“ – average
- Condition D
- Variable water flow rate – secondary circuit

General formulas and derivation:

$$t_{\text{outlet, average}} = t_{\text{inlet, capacity test}} + (t_{\text{outlet, capacity test}} - t_{\text{inlet, capacity test}}) \cdot CR \quad [^{\circ}\text{C}]$$

$$t_{\text{outlet, average}} = t_{\text{inlet, capacity test}} + (\Delta t) \cdot CR \quad [^{\circ}\text{C}]$$

$$t_{\text{outlet, average}} = t_{\text{outlet, capacity test}} - \Delta t + \Delta t \cdot CR \quad [^{\circ}\text{C}]$$

$$t_{\text{outlet, capacity test}} = t_{\text{outlet, average}} + \Delta t - \Delta t \cdot CR \quad [^{\circ}\text{C}]$$

For variable flow:

$$\Delta t = 8$$

$$CR \cdot \Delta t = \text{Part load} / \text{Declared capacity} \cdot 8$$

$$t_{\text{outlet, capacity test, variable flow}} = t_{\text{outlet, average}} + 8 - \text{Part load} / \text{Declared capacity} \cdot 8$$

Measured data:

t _{outlet, average}	30.00	[°C]
Declared capacity	18.782	[kW]
Declared capacity standard rating condition A7/W55	-	[kW]
Part load	1.84	[kW]

Calculation of water temperature

$$t_{\text{outlet, capacity test, variable flow}} = 30 + 8 - 1.84 / 18.782 \cdot 8 = \underline{\underline{37.22}} \quad [^{\circ}\text{C}]$$

Calculation SCOP, SCOP_{on}, SCOP_{net}


- Medium temperature application (reference water temperature 55 °C)
- Reference heating season „A“ – average

Bin	Outdoor temp. (dry bulb)	Hours	Part load ratio	Heat load	Capacity of HP	Heat load covered by heat pump	Resistive heat elbu (Tj)	Annual resistive heat	COPbin (Tj)	Annual heating demand	Annual power input including electric back up heating	Net annual heating capacity	Net annual power input without electric back up heating	
j	Tj	hj		Ph(Tj)			elbu(Tj)	hj x elbu(Tj)	COPbin (Tj)	hj x Ph(Tj)		hj x (Ph(Tj) - elbu(Tj))		
[-]	[°C]	[h]	[%]	[kW]	[kW]	[kW]	[kW]	[kWh]	[-]	[kWh]	[kWh]	[kWh]	[kWh]	
TOL (E)	21	-10	1	1	100.00	11.96	9.79	9.79	2.17	2.17	2.24	12	7	10
	22	-9	25	25	96.15	11.50	10.05	10.05	1.45	36.17	2.32	287	145	251
	23	-8	23	23	92.31	11.04	10.31	10.31	0.72	16.64	2.39	254	116	237
A, T_{biv} (F)	24	-7	24	24	88.46	10.58	10.58	10.58	0.00	0.00	2.47	254	103	254
	25	-6	27	27	84.62	10.12	10.76	10.12	0.00	0.00	2.53	273	108	273
	26	-5	68	68	80.77	9.66	10.94	9.66	0.00	0.00	2.60	657	253	657
	27	-4	91	91	76.92	9.20	11.13	9.20	0.00	0.00	2.66	837	315	837
	28	-3	89	89	73.08	8.74	11.31	8.74	0.00	0.00	2.72	778	286	778
	29	-2	165	165	69.23	8.28	11.50	8.28	0.00	0.00	2.78	1366	491	1366
	30	-1	173	173	65.38	7.82	11.68	7.82	0.00	0.00	2.85	1352	475	1352
	31	0	240	240	61.54	7.36	11.86	7.36	0.00	0.00	2.91	1766	607	1766
	32	1	280	280	57.69	6.90	12.05	6.90	0.00	0.00	2.97	1931	650	1931
B	33	2	320	320	53.85	6.44	12.23	6.44	0.00	0.00	3.03	2060	679	2060
	34	3	357	357	50.00	5.98	13.04	5.98	0.00	0.00	3.26	2134	654	2134
	35	4	356	356	46.15	5.52	13.84	5.52	0.00	0.00	3.49	1964	563	1964
	36	5	303	303	42.31	5.06	14.65	5.06	0.00	0.00	3.71	1533	413	1533
	37	6	330	330	38.46	4.60	15.46	4.60	0.00	0.00	3.94	1517	385	1517
C	38	7	326	326	34.62	4.14	16.26	4.14	0.00	0.00	4.17	1349	324	1349
	39	8	348	348	30.77	3.68	16.77	3.68	0.00	0.00	4.34	1280	295	1280
	40	9	335	335	26.92	3.22	17.27	3.22	0.00	0.00	4.52	1078	238	1078
	41	10	315	315	23.08	2.76	17.77	2.76	0.00	0.00	4.70	869	185	869
	42	11	215	215	19.23	2.30	18.28	2.30	0.00	0.00	4.88	494	101	494
D	43	12	169	169	15.38	1.84	18.78	1.84	0.00	0.00	5.05	311	62	311
	44	13	151	151	11.54	1.38	19.29	1.38	0.00	0.00	5.23	208	40	208
	45	14	105	105	7.69	0.92	19.79	0.92	0.00	0.00	5.41	97	18	97
	46	15	74	74	3.85	0.46	20.29	0.46	0.00	0.00	5.59	34	6	34
	Σ		4910						Σ	24695	7516	24640	7461	

SCOP _{on}	3.29	SCOP _{net}	3.30
		SCOP	3.28

Part load performance diagram

- Medium temperature application (reference water temperature 55 °C)
- Reference heating season „A“ – average



Tested by: Ing. Tomáš Sedláček

Date: 2024-04-09

Signed: Sedláček

Reviewed and approved by: Ing. Michal Faltýnek



Date: 2024-04-09

Signed: Faltýnek



V. Graphs

1. Rating conditions

A7/W35





A7/W55





2. Seasonal performance tests and SCOP calculation – Low temperature application



A-7/W34





A2/W32.28





A7/W30.69



A12/W28.5





A-10/W35





3. Seasonal performance tests and SCOP calculation – Medium temperature application



A-7/W52





A2/W45.79





A7/W41.96



A12/W37.22



A-10/W55



VI. A list of referenced documents

- Order B-81825 of 2024-03-20 (Order reg. no. B-81825, received on 2024-03-20)
- Contract B-81825
- ČSN EN 14511-2:2023 - Air conditioners, liquid chilling packages and heat pumps for space heating and cooling and process chillers, with electrically driven compressors - Part 2: Test conditions
- ČSN EN 14511-3:2023 - Air conditioners, liquid chilling packages and heat pumps for space heating and cooling a process chillers with electrically driven compressors - Part 3: Test methods
- ČSN EN 14825:2023 - Air conditioners, liquid chilling packages and heat pumps, with electrically driven compressors, for space heating and cooling - Testing and rating at part load conditions and calculation of
- Background of the task 39-17622
- Record measurement file 39-17622

Test Report compiled by: Ing. Tomáš Sedláček



Test Report approved by: Ing. Mario Jankola
Heating Equipment and Construction Products Manager

– End of Test Report –



Strojirenský zkušební ústav, s.p., Brno, Česká republika
Engineering Test Institute, Public Enterprise, Brno, Czech Republic

TEST CERTIFICATE

Number **O-B-00604-24**

Customer Kořton Spółka komandytowa
ul. Sosnowa 2
34-480 Jabłonka
POLAND

Product Outdoor Air/Water Heat pump - monobloc

Type designation / Trade mark **Airkompakt p1522**

Test methods ČSN EN 14511-3:2023, ČSN EN 12102-1:2023

Basis of certificate
Test reports:
39-17622/T of 2024-04-09
39-17622/H of 2024-04-09
Technical documents of Kořton Spółka komandytowa

Temperature application
LOW TEMPERATURE,
(Reference water temperature 35 °C)
MEDIUM TEMPERATURE
(Reference water temperature 55 °C)

Results:

Temperature conditions*	A7/W35	A7/W55
Corrected heating capacity [kW]	16.117	15.332
Effective electric power input [kW]	3.473	4.775
Coefficient of performance [-]	4.640	3.211

(*) Comment to abbreviated marking: e.g. A7/W35

A (air), 7 (input air – dry bulb temperature in °C) / W (water), 35 (output heating (cooling) water temperature in °C).





Sound power level at temperature condition A7/W55:

Outdoor Air/Water Heat pump - monobloc

Airkompakt p1522

Sound power level

LWA 63.1 ± 1.5 dB(A)

Accuracy class

Engineering (grade 2)

(*) Comment to abbreviated marking: e.g. A7/W55

A (air), 7 (input air – dry bulb temperature in °C) / W (water), 55 (output heating (cooling) water temperature in °C).

Specification of conditions:

Compressor speed control	Fixed	Heating water volume flow rate (indoor heat exchanger)	Variable
Outlet water temperature (indoor heat exchanger)	Variable	Source liquid volume flow rate (outdoor heat exchanger)	-
Function	Reversible		

Engineering Test Institute, Public Enterprise, confirms by this Test Certificate that the testing of the product in question was performed with the results as stated above. Engineering Test Institute, Public Enterprise, is an accredited Testing Laboratory 1045.1.

Brno, 2024-04-10

Ing. Mario Jankola

Heating Equipment and Construction Products Manager

- END OF TEST CERTIFICATE -





Strojirenský zkušební ústav, s.p., Brno, Česká republika
Engineering Test Institute, Public Enterprise, Brno, Czech Republic

TEST CERTIFICATE

Number **O-B-00605-24**

Customer Kolton Spółka komandytowa
ul. Sosnowa 2
34-480 Jabłonka
POLAND

Product Outdoor Air/Water Heat pump - monobloc

Type designation / Trademark **Airkompakt p1522**

Test methods ČSN EN 14511-3:2023, ČSN EN 14825:2023, ČSN EN 12102-1:2023

Basis of certificate Test reports:
39-17622/T of 2024-04-09
39-17622/H of 2024-04-09
Technical documents of Kolton Spółka komandytowa

Reference heating season „A” = average
(Reference design temperature $T_{designh} = -10\text{ °C}$)

Results:

LOW TEMPERATURE
(Reference water temperature 35 °C)

MEDIUM TEMPERATURE
(Reference water temperature 55 °C)

12.45	$P_{designh}$ [kW] ... Full load heating				11.96
4.12	SCOP [-] ... Seasonal coefficient of performance				3.28
Outdoor temperature T_j [°C]	Heating declared capacity P_{dh} [kW]	Coefficient of performance at the declared capacity COP_d [-]	Outdoor temperature T_j [°C]	Heating declared capacity P_{dh} [kW]	Coefficient of performance at the declared capacity COP_d [-]
$T_j = -7$	11.017	3.283	$T_j = -7$	10.576	2.470
$T_j = +2$	12.737	3.875	$T_j = +2$	12.231	3.047
$T_j = +7$	16.513	5.112	$T_j = +7$	16.264	4.223
$T_j = +12$	19.195	6.058	$T_j = +12$	18.782	5.286
$T_j = TOL = -10$	9.956	2.977	$T_j = TOL = -10$	9.785	2.238
$T_j = T_{bivalent} = -7$	11.017	3.283	$T_j = T_{bivalent} = -7$	10.576	2.470





LOW TEMPERATURE

(Reference water temperature 35 °C)

MEDIUM TEMPERATURE

(Reference water temperature 55 °C)

Power consumption in modes other than „active mode“:

17.7	Off mode	P _{OFF}	[W]	17.7
17.7	Thermostat off mode	P _{TO}	[W]	17.7
17.7	Standby mode	P _{SB}	[W]	17.7
0	Crankcase heater mode	P _{CK}	[W]	0

Annual electricity consumption for heating according to:

6252	ČSN EN 14825:2023	Q _{HE}	[kWh]	7521
------	-------------------	-----------------	-------	------

Seasonal Space heating energy efficiency

161.6	ČSN EN 14825:2023	η _s	[%]	128.4
-------	-------------------	----------------	-----	-------

Liquid flow rate in outdoor heating exchanger:

–	Source liquid	Min/Max	[m ³ /h]	–
---	---------------	---------	---------------------	---

Liquid flow rate in indoor heating exchanger:

1.731/3.344	Heating water	Min/Max	[m ³ /h]	1.068/2.035
-------------	---------------	---------	---------------------	-------------

Sound power level at condition A7W55*:

Airkompakt p1522

L_{WA} 63.1 ± 1.5 dB(A)

Accuracy class 2 (Engineering)

(*) Comment to abbreviated marking A7W55:

„A“ air, „7“ inlet temperature (dry-bulb temperature) in °C, „W“ water, „55“ outlet temperature in °C.

Specification of conditions:

Compressor speed control	Fixed	Heating water volume flow rate (indoor heat exchanger)	Variable
Outlet water temperature (indoor heat exchanger)	Variable	Source liquid volume flow rate (outdoor heat exchanger)	–
Function	Reversible		

Engineering Test Institute, Public Enterprise, confirms by this Test Certificate that the testing of the product in question was performed with the results as stated above. Engineering Test Institute, Public Enterprise, is an accredited Testing Laboratory 1045.1.

Brno, 2024-04-10

Ing. Mario Jankola

Heating Equipment and Construction Products Manager

– END OF TEST CERTIFICATE –





Strojirenský zkušební ústav, s.p., Brno, Česká republika
Engineering Test Institute, Public Enterprise, Brno, Czech Republic

TEST CERTIFICATE

Number **O-B-00606-24**

Customer **Kolton Spółka komandytowa**
ul. Sosnowa 2
34-480 Jabłonka
POLAND

Product **Outdoor Air/Water Heat pump - monobloc**

Type designation / Trade mark
Airkompakt p0916
Airkompakt p1118
Airkompakt p1522
Airkompakt p1926

Test methods **ČSN EN 14511-3:2023, ČSN EN 14825:2023, ČSN EN 12102-1:2023**

Basis of certificate
Test reports:
39-17622/T of 2024-04-09
39-17622/H of 2024-04-09
Technical documents of Kolton Spółka komandytowa

Temperature application
LOW TEMPERATURE,
(Reference water temperature 35 °C)
MEDIUM TEMPERATURE
(Reference water temperature 55 °C)

Specification of conditions:

Compressor speed control	Fixed	Heating water volume flow rate (indoor heat exchanger)	Variable
Outlet water temperature (indoor heat exchanger)	Variable	Source liquid volume flow rate (outdoor heat exch.)	-
Function	Reversible		



O-B-00606-24, page 1 (2)

Strojirenský zkušební ústav, s.p., Hudcova 424/56b, 621 00 Brno, Česká republika
Engineering Test Institute, public enterprise, Hudcova 424/56b, 621 00 Brno, Czech Republic

www.szutest.cz



**Results:**

Model names		Airkompakt p0916 (Tested)	Airkompakt p1118 (Not tested)	Airkompakt p1522 (Tested)	Airkompakt p1926 (Not tested)	
Temperature condition*						
A7/W35	Corrected heating capacity	[kW]	9.062	11.200	16.117	19.650
	Effective power input	[kW]	1.950	2.599	3.473	4.226
	Coefficient of performance	[-]	4.647	4.310	4.640	4.650
	Control settings	[-]	-	-	-	-
A7/W55	Corrected heating capacity	[kW]	8.428	11.200	15.332	17.400
	Effective power input	[kW]	2.678	3.478	4.775	5.918
	Coefficient of performance	[-]	3.148	3.220	3.221	2.940
	Control settings	[-]	-	-	-	-
A2/W35	Corrected heating capacity	[kW]	6.996 (Not tested)	9.400	13.500 (Not tested)	14.400
	Effective power input	[kW]	1.911 (Not tested)	2.473	3.562 (Not tested)	3.891
	Coefficient of performance	[-]	3.660 (Not tested)	3.800	3.790 (Not tested)	3.700
	Control settings	[-]	-	-	-	-

Sound power level at condition A7/W55*:

LWA	[dB(A)]	62.9 ± 1.5	66.0 ± 1.5	63.1 ± 1.5	69.0 ± 1.5
------------	---------	------------	------------	------------	------------

Accuracy class

Engineering (2)

(*) Comment to abbreviated marking e.g. A7W55:

„A“ air, „7“ inlet temperature (dry-bulb temperature) in °C, „W“ water, „55“ outlet temperature in °C.

(Tested) This test sample was tested at the Testing Laboratory.

(Not tested) The technical data were declared by the Manufacturer according to the model range specifications and were not tested by the Testing Laboratory.

Engineering Test Institute, Public Enterprise, confirms by this Test Certificate that the testing of the product in question was performed with the results as stated above. Engineering Test Institute, Public Enterprise, is an accredited Testing Laboratory 1045.1.

Test certificate **invalidates** and replaces the **O-B-01502-22 rev.1** from 2022-09-30.

Brno, 2024-04-10

Ing. Mario Jankola

Heating Equipment and Construction Products Manager

- END OF TEST CERTIFICATE -





Strojirenský zkušební ústav, s.p., Brno, Česká republika
Engineering Test Institute, Public Enterprise, Brno, Czech Republic

TEST CERTIFICATE

Number **O-B-00629-24**

Customer Kořton Spółka komandytowa
ul. Sosnowa 2
34-480 Jabłonka
POLAND

Product Outdoor Air/Water Heat pump - monobloc

Type designation / Trademark **Airkompakt p0916**
Airkompakt p1118
Airkompakt p1522
Airkompakt p1926

Test methods ČSN EN 14511-3:2023, ČSN EN 14825:2023

Basis of certificate Test reports:
39-17622/T of 2024-04-09
39-17622/H of 2024-04-09
Technical documents of Kořton Spółka komandytowa

Temperature application **LOW TEMPERATURE**
(Reference water temperature 35 °C)

Reference heating season **„A“ = average / „W“ = warmer / „C“ = colder**
(Reference design conditions for heating $T_{designh} = -10\text{ °C} / +2\text{ °C} / -22\text{ °C}$)

Specification of conditions:

Compressor speed control	Fixed	Heating water volume flow rate (indoor heat exchanger)	Variable
Outlet water temperature (indoor heat exchanger)	Variable	Source liquid volume flow rate (outdoor heat exchanger)	-
Function	Reversible		



O-B-00629-24, page 1 (2)

Strojirenský zkušební ústav, s.p., Hudcova 424/56b, 621 00 Brno, Česká republika
Engineering Test Institute, public enterprise, Hudcova 424/56b, 621 00 Brno, Czech Republic

www.szutest.cz



**Results:****Low temperature application**
(Reference water temperature 35 °C)

Model names		Airkompakt p0916 (Tested)	Airkompakt p1118 (Not tested)	Airkompakt p1522 (Tested)	Airkompakt p1926 (Not tested)	
Full load heating	$P_{designh}$ [kW]	A	6.20	8.59	12.45	14.58
		W	7.00	9.40	13.50 (Not tested)	14.40
		C	5.65	7.97	9.68 (Not tested)	12.38
Bivalent temperature	$T_{bivalent}$ [°C]	A	-7	-7	-7	-7
		W	2	2	2	2
		C	-15	-15	-15	-15
Seasonal coefficient of performance	SCOP [-]	A	4.00	4.05	4.12	4.08
		W	5.00 (Not tested)	5.16	4.96 (Not tested)	5.13
		C	3.54 (Not tested)	3.61	3.55 (Not tested)	3.53
Seasonal Space heating energy efficiency	η_s [%]	A	157.2	159.1	161.6	160.2
		W	196.9 (Not tested)	203.3	195.3 (Not tested)	202.3
		C	138.7 (Not tested)	141.2	139.1 (Not tested)	138.3

(Tested) This test sample was tested at the Testing Laboratory.

(Not tested) The technical data were declared by the Manufacturer according to the model range specifications and were not tested by the Testing Laboratory.

Engineering Test Institute, Public Enterprise, confirms by this Test Certificate that the testing of the product in question was performed with the results as stated above. Engineering Test Institute, Public Enterprise, is an accredited Testing Laboratory 1045.1.

Test certificate invalidates and replaces the O-B-01500-22 rev.1 from 2022-09-30.

Brno, 2024-04-11


Ing. Mario Jankola

Heating Equipment and Construction Products Manager

- END OF TEST CERTIFICATE -





Strojirenský zkušební ústav, s.p., Brno, Česká republika
Engineering Test Institute, Public Enterprise, Brno, Czech Republic

TEST CERTIFICATE

Number **O-B-00630-24**

Customer

Kolton Spółka komandytowa
ul. Sosnowa 2
34-480 Jablonka
POLAND

Product

Outdoor Air/Water Heat pump - monobloc

Type designation / Trademark

Airkompakt p0916
Airkompakt p1118
Airkompakt p1522
Airkompakt p1926

Test methods

ČSN EN 14511-3:2023, ČSN EN 14825:2023

Basis of certificate

Test reports:
39-17622/T of 2024-04-09
39-17622/H of 2024-04-09
Technical documents of Kolton Spółka komandytowa

Temperature application

MEDIUM TEMPERATURE
(Reference water temperature 55 °C)

Reference heating season

„A“ = average / „W“ = warmer / „C“ = colder
(Reference design conditions for heating $T_{design} = -10\text{ °C} / +2\text{ °C} / -22\text{ °C}$)

Specification of conditions:

Compressor speed control	Fixed	Heating water volume flow rate (indoor heat exchanger)	Variable
Outlet water temperature (indoor heat exchanger)	Variable	Source liquid volume flow rate (outdoor heat exchanger)	-
Function	Reversible		



O-B-00630-24, page 1 (2)

Strojirenský zkušební ústav, s.p., Hudcova 424/56b, 621 00 Brno, Česká republika
Engineering Test Institute, public enterprise, Hudcova 424/56b, 621 00 Brno, Czech Republic

www.szutest.cz





Results:

Medium temperature application
(Reference water temperature 55 °C)

Model names		Airkompakt p0916 (Tested)	Airkompakt p1118 (Not tested)	Airkompakt p1522 (Tested)	Airkompakt p1926 (Not tested)	
Full load heating	$P_{designh}$ [kW]	A	6.28	8.59	11.96	13.90
		W	6.52	8.90	11.60 (Not tested)	14.40
		C	5.29	7.72	9.68 (Not tested)	12.38
Bivalent temperature	$T_{bivalent}$ [°C]	A	-7	-7	-7	-7
		W	2	2	2	2
		C	-15	-15	-15	-15
Seasonal coefficient of performance	SCOP [-]	A	3.25	3.39	3.28	3.35
		W	4.03 (Not tested)	4.07	4.13 (Not tested)	4.10
		C	2.82 (Not tested)	2.97	2.93 (Not tested)	2.94
Seasonal Space heating energy efficiency	η_s [%]	A	127.0	132.8	128.4	131.2
		W	158.4 (Not tested)	159.8	162.4 (Not tested)	161.1
		C	109.8 (Not tested)	116.0	114.2 (Not tested)	114.5

(Tested) This test sample was tested at the Testing Laboratory.

(Not tested) The technical data were declared by the Manufacturer according to the model range specifications and were not tested by the Testing Laboratory.

Engineering Test Institute, Public Enterprise, confirms by this Test Certificate that the testing of the product in question was performed with the results as stated above. Engineering Test Institute, Public Enterprise, is an accredited Testing Laboratory 1045.1.

Test certificate **invalidates** and replaces the **O-B-01501-22 rev.1** from 2022-09-30.

Brno, 2024-04-11

Ing. Mario Jankola

Heating Equipment and Construction Products Manager

- END OF TEST CERTIFICATE -



Tłumaczenie przysięgłe z jęz. angielskiego na jęz. polski

Instytut Testów Inżynieryjnych, Przedsiębiorstwo Publiczne, Brno, Republika Czeska

CERTYFIKAT TESTÓW

Numer: O-B-00604-24

Klient KOŁTON SPÓŁKA KOMANDYTOWA
ul. Sosnowa 2
34-480 Jablonka
POLSKA

Produkt Zewnętrzna pompa ciepła typu powietrze/woda – monoblok

Oznaczenie typu/
znak towarowy **Airkompakt p1522**

Metody testowe ČSN EN 14511-3:2023, ČSN EN 12102-1:2023
Raporty z testów:
Podstawa certyfikatu 39-17622/T z 2024-04-09
39-17622/H z 2024-04-09
Dokumentacja techniczna KOŁTON SPÓŁKA KOMANDYTOWA

Zastosowana temp. **NISKA TEMPERATURA**
(Referencyjna temperatura wody 35°C)
ŚREDNIA TEMPERATURA
(Referencyjna temperatura wody 55°C)

Wyniki:

Warunki temperaturowe*	A7/W35	A7/W55
Skorygowana wydajność grzewcza [kW]	16,117	15,332
Efektywny pobór mocy elektrycznej [kW]	3,473	4,775
Współczynnik efektywności [-]	4,640	3,211
Ustawienia sprężarki [-]	-	-

(*) Komentarz do skróconego oznaczenia: np. A7/W35

A (powietrze), 7 (powietrze wejściowe - temperatura termometru suchego w °C) / W (woda),

35 (wyjściowa temperatura wody grzewczej (chłodzącej) w °C)

[okrągła pieczęć]

O-B-00604-24, strona 1 (2)

[Hologram]

Instytut Testów Inżynieryjnych, Przedsiębiorstwo Publiczne,

Hudcova 424/56b, 621 00 Brno, Republika Czeska

www.szutest.cz



Poziom mocy akustycznej w warunkach temperaturowych A7/W55*:

Zewnętrzna pompa ciepła typu powietrze/woda – monoblok

Airkompakt p1522

Poziom mocy akustycznej

 $L_{WA} 63,1 \pm 1,5$ dB(A)

Klasa dokładności

Inżynieria (klasa 2)

() Komentarz do skróconego oznaczenia: np. A7/W55**A (powietrze), 7 (powietrze wejściowe - temperatura termometru suchego w °C)/ W (woda),**55 (wyjściowa temperatura wody grzewczej (chłodzącej) w °C)***Specyfikacja warunków:**

Sterowanie prędkością sprężarki	Stałe	Przepływ objętościowy wody grzewczej (wewnętrzny wymiennik ciepła)	Zmienny
Temperatura wody na wylocie (wewnętrzny wymiennik ciepła)	Zmienna	Objętość przepływu cieczy źródłowej (zewnętrzny wymiennik ciepła)	-
Funkcja	Odwracalna		

Instytut Testów Inżynieryjnych, Przedsiębiorstwo Publiczne, potwierdza niniejszym Certyfikatem Testów, że badanie danego produktu zostało przeprowadzone z wynikami podanymi powyżej. Instytut Testów Inżynieryjnych, Przedsiębiorstwo Publiczne, jest akredytowanym Laboratorium Badawczym 1045.1.

Brno, 10.04.2024 r.

[nieczytelny podpis]

Ing. Mario Jankola

Kierownik Stacji Badań Urządzeń Ciepłych i Przyjaznych Środowisku

- KONIEC CERTYFIKATU TESTÓW -

[okrągła pieczęć]

O-B-00604-24, strona 2 (2)

Instytut Testów Inżynieryjnych, Przedsiębiorstwo Publiczne,

Hudcova 424/56b, 621 00 Brno, Republika Czeska

www.szutest.cz

Nr rep. 759/24

Stwierdzam zgodność powyższego przekładu z okazanym dokumentem

Tytułem wynagrodzenia pobrano -

Augustów, dnia: 13.04.2024 r.

Tłumacz przysięgły języka angielskiego – mgr Piotr Szlauzys (nr TP/4453/05)



Tłumaczenie przysięgłe z jęz. angielskiego na jęz. polski

Instytut Testów Inżynieryjnych, Przedsiębiorstwo Publiczne, Brno, Republika Czeska

CERTYFIKAT TESTÓW

Numer: O-B-00605-24

Klient KOŁTON SPÓŁKA KOMANDYTOWA
ul. Sosnowa 2
34-480 Jabłonka
POLSKA

Produkt Zewnętrzna pompa ciepła typu powietrze/woda – monoblok

Oznaczenie typu/
znak towarowy **Airkompakt p1522**

Metody testowe ČSN EN 14511-3:2023, ČSN EN 14825:2023; ČSN EN 12102-1:2023,
Raporty z testów:
Podstawa certyfikatu 39-17622/T z 2024-04-09
39-17622/H z 2024-04-09
Dokumentacja techniczna KOŁTON SPÓŁKA KOMANDYTOWA

Referencyjny sezon grzewczy **„A” = umiarkowany**
(Referencyjna temperatura projektowa $T_{designh} = -10\text{ °C}$)

Wyniki:

NISKA TEMPERATURA

(Referencyjna temperatura wody 35°C)

ŚREDNIA TEMPERATURA

(Referencyjna temperatura wody 55°C)

12,45	$P_{designh}$ [kW] ... Znamionowa moc cieplna				11,96
4,12	SCOP [-] ... Sezonowy współczynnik efektywności				3,28
Temperatura zewnętrzna	Deklarowana wydajność grzewcza	Współczynnik efektywności przy deklarowanej wydajności	Temperatura zewnętrzna	Deklarowana wydajność grzewcza	Współczynnik efektywności przy deklarowanej wydajności
T_j [°C]	P_{dh} [kW]	COP_d [-]	T_j [°C]	P_{dh} [kW]	COP_d [-]
$T_j = -7$	11,017	3,283	$T_j = -7$	10,576	2,470
$T_j = +2$	12,737	3,875	$T_j = +2$	12,231	3,047
$T_j = +7$	16,513	5,112	$T_j = +7$	16,264	4,223
$T_j = +12$	19,195	6,058	$T_j = +12$	18,782	5,286
$T_j = TOL = -10$	9,956	2,977	$T_j = TOL = -10$	9,785	2,238
$T_j = T_{bivalent} = -7$	11,017	3,283	$T_j = T_{bivalent} = -7$	10,576	2,470

[okrągła pieczęć]

O-B-00605-24, strona 1 (2)

Instytut Testów Inżynieryjnych, Przedsiębiorstwo Publiczne,
Hudcova 424/56b, 621 00 Brno, Republika Czeska

www.szutest.cz

[Hologram]



NISKA TEMPERATURA
(Referencyjna temperatura wody 35°C)

ŚREDNIA TEMPERATURA
(Referencyjna temperatura wody 55°C)

Pobór mocy w trybach innych niż „tryb aktywny”

17,7	Tryb wyłączony P _{OFF} [W]	17,7
17,7	Tryb wyłączonego termostatu P _{TO} [W]	17,7
17,7	Tryb czuwania P _{SB} [W]	17,7
0	Tryb grzałki karteru P _{CK} [W]	0

Roczne zużycie energii elektrycznej na ogrzewanie według:

6252	ČSN EN 14825:2023 Q _{HE} [kWh]	7521
------	---	------

Sezonowa efektywność energetyczna ogrzewania pomieszczeń

161,6	ČSN EN 14825:2023 η _s [%]	128,4
-------	--------------------------------------	-------

Nateżenie przepływu cieczy w zewnętrznym wymienniku ciepła:

-	Źródło cieczy	Min./Maks. [m ³ /h]	-
---	---------------	--------------------------------	---

Nateżenie przepływu cieczy w wewnętrznym wymienniku ciepła:

1,731/3,344	Woda grzewcza	Min./Maks. [m ³ /h]	1,068/2,035
-------------	---------------	--------------------------------	-------------

Poziom mocy akustycznej w warunku A7W55*:

Airkompakt p1522 L_{WA} 63,1±1,5 dB(A) Klasa dokładności 2 (inżynieria)

-zewnętrzna jednostka-

(*) *Komentarz do skróconego oznaczenia:*

„A” powietrze, „7” = temperatura na wlocie (temperatura termometru suchego) w °C, „W” woda, „55” temperatura na wylocie w °C.

Specyfikacja warunków:

Sterowanie prędkością sprężarki	Stałe	Przepływ objętościowy wody grzewczej (wewnętrzny wymiennik ciepła)	Zmienny
Temperatura wody na wylocie (wewnętrzny wymiennik ciepła)	Zmienna	Objętość przepływu cieczy źródłowej (zewnętrzny wymiennik ciepła)	-
Funkcja	Odwracalna		

Instytut Testów Inżynieryjnych, Przedsiębiorstwo Publiczne, potwierdza niniejszym Certyfikatem Testów, że badanie danego produktu zostało przeprowadzone z wynikami podanymi powyżej. Instytut Testów Inżynieryjnych, Przedsiębiorstwo Publiczne, jest akredytowanym Laboratorium Badawczym 1045.1.

Brno, 10.04.2024 r.

[nieczytelny podpis]

Ing. Mario Jankola

Kierownik Stacji Badań Urządzeń Ciepłych i Przyjaznych Środowisku

- KONIEC CERTYFIKATU TESTÓW -

[okrągła pieczęć]

O-B-00605-24, strona 2 (2)

Instytut Testów Inżynieryjnych, Przedsiębiorstwo Publiczne,
Hudcova 424/56b, 621 00 Brno, Republika Czeska
www.szutest.cz

Nr rep. 760/24

Stwierdzam zgodność powyższego przekładu z okazanym dokumentem

Tytułem wynagrodzenia pobrano -

Augustów, dnia: 13.04.2024 r.

Tłumacz przysięgły języka angielskiego – mgr Piotr Szlauzys (nr TP/4453/05)



Tłumaczenie przysięgłe z jęz. angielskiego na jęz. polski

Instytut Testów Inżynieryjnych, Przedsiębiorstwo Publiczne, Brno, Republika Czeska

CERTYFIKAT TESTÓW

Numer: O-B-00606-24

Klient	KOŁTON SPÓŁKA KOMANDYTOWA ul. Sosnowa 2 34-480 Jabłonka POLSKA
Produkt	Zewnętrzna pompa ciepła typu powietrze/woda – monoblok
Oznaczenie typu/ znak towarowy	Airkompakt p0916 Airkompakt p1118 Airkompakt p1522 Airkompakt p1926
Metody testowe	ČSN EN 14511-3:2023, ČSN EN 14825:2023, ČSN EN 12102-1:2023 Raporty z testów:
Podstawa certyfikatu	39-17622/T z 2024-04-09 39-17622/T z 2024-04-09 Dokumentacja techniczna KOŁTON SPÓŁKA KOMANDYTOWA NISKA TEMPERATURA (Referencyjna temperatura wody 35°C)
Zastosowana temp.	ŚREDNIA TEMPERATURA (Referencyjna temperatura wody 55°C)

Specyfikacja warunków:

Sterowanie prędkością sprężarki	Stałe	Przepływ objętościowy wody grzewczej (wewnętrzny wymiennik ciepła)	Zmienny
Temperatura wody na wylocie (wewnętrzny wymiennik ciepła)	Zmienna	Objętość przepływu cieczy źródłowej (zewnętrzny wymiennik ciepła)	-
Funkcja	Odwracalna		

O-B-00606-24, strona 1 (2)

[okrągła pieczęć]

[Hologram]

Instytut Testów Inżynieryjnych, Przedsiębiorstwo Publiczne,
Hudcova 424/56b, 621 00 Brno, Republika Czeska

www.szutest.cz



Wyniki:

Nazwy modeli		Airkompakt p0916 (Testowany)	Airkompakt p1118 (Nietestowany)	Airkompakt P1522 (Testowany)	Airkompakt p1926 (Nietestowany)	
Warunki temperaturowe						
A7/W35	Skorygowana wydajność grzewcza	[kW]	9,062	11,200	16,117	19,650
	Efektywny pobór mocy	[kW]	1,950	2,599	3,473	4,226
	Współczynnik efektywności	[-]	4,647	4,310	4,640	4,650
	Ustawienia sterowania	[-]	-	-	-	-
A7/W55	Skorygowana wydajność grzewcza	[kW]	8,428	11,200	15,332	17,400
	Efektywny pobór mocy	[kW]	2,678	3,478	4,775	5,918
	Współczynnik efektywności	[-]	3,148	3,220	3,221	2,940
	Ustawienia sterowania	[-]	-	-	-	-
A2/W35	Skorygowana wydajność grzewcza	[kW]	6,996 (Nietestowane)	9,400	13,500 (Nietestowane)	14,400
	Efektywny pobór mocy	[kW]	1,911 (Nietestowane)	2,473	3,562 (Nietestowane)	3,891
	Współczynnik efektywności	[-]	3,660 (Nietestowane)	3,800	3,790 (Nietestowane)	3,700
	Ustawienia sterowania	[-]	-	-	-	-

Poziom mocy akustycznej w warunkach A7/W55*:

L_{WA}	[dB(A)]	$62,9 \pm 1,5$	$66,0 \pm 1,5$	$63,1 \pm 1,5$	$69,0 \pm 1,5$
----------	---------	----------------	----------------	----------------	----------------

Klasa dokładności

Inżynieria (2)

(*) Komentarz do skróconego oznaczenia, np. A7W55:

„A” powietrze, „7” temperatura na wlocie (temperatura termometru suchego) w °C, „W” woda, „55” temperatura na wylocie w °C.

(Testowany) Ta próbka testowa została przetestowana w Laboratorium Badawczym.

(Nietestowany) Dane techniczne zostały zadeklarowane przez Producenta zgodnie ze specyfikacją typoszeregu i nie były sprawdzane przez Laboratorium Badawcze.

Instytut Testów Inżynieryjnych, Przedsiębiorstwo Publiczne potwierdza niniejszym Certyfikatem Testów, że badanie danego produktu zostało przeprowadzone z wynikami podanymi powyżej. Instytut Testów Inżynieryjnych, Przedsiębiorstwo Publiczne, jest akredytowanym Laboratorium Badawczym 1045.1.

Certyfikat testów unieważnia i zastępuje O-B-01502-22 rev.1 z 30 września 2022 r.

Brno, 10.04.2024 r.

[nieczytelny podpis]

Ing. Mario Jankola

Kierownik Stacji Badań Urządzeń Ciepłych i Przyjaznych Środowisku

- KONIEC CERTYFIKATU TESTÓW -

[okrągła pieczęć]

O-B-00606-24, strona 2 (2)

Instytut Testów Inżynieryjnych, Przedsiębiorstwo Publiczne,

Hudcova 424/56b, 621 00 Brno, Republika Czeska

www.szutest.cz

Nr rep. 763/24

Stwierdzam zgodność powyższego przekładu z okazanym dokumentem

Tytułem wynagrodzenia pobrano -

Augustów, dnia: 13.04.2024 r.

Tłumacz przysięgły języka angielskiego – mgr Piotr Szlauzys (nr TP/4453/05)



Tłumaczenie przysięgłe z jęz. angielskiego na jęz. polski

Instytut Testów Inżynieryjnych, Przedsiębiorstwo Publiczne, Brno, Republika Czeska

CERTYFIKAT TESTÓW

Numer: O-B-00629-24

Klient KOŁTON SPÓŁKA KOMANDYTOWA
ul. Sosnowa 2
34-480 Jabłonka
POLSKA

Produkt Zewnętrzna pompa ciepła typu powietrze/woda – monoblok

Oznaczenie typu/
znak towarowy **Airkompakt p0916**
Airkompakt p1118
Airkompakt p1522
Airkompakt p1926

Metody testowe ČSN EN 14511-3:2023, ČSN EN 14825:2023;

Podstawa certyfikatu Raporty z testów:
39-17622/T z 2024-04-09
39-17622/H z 2024-04-09
Dokumentacja techniczna KOŁTON SPÓŁKA KOMANDYTOWA

Zastosowana temp. **NISKA TEMPERATURA**
(Referencyjna temperatura wody 35°C)

Referencyjny sezon grzewczy „A” = umiarkowany / „W” = ciepły / „C” = chłodny
(Referencyjny warunek projektowy dla ogrzewania $T_{designh} = -10\text{ °C}/+2\text{ °C}/-22\text{ °C}$)

Specyfikacja warunków:

Sterowanie prędkością sprężarki	Stałe	Przepływ objętościowy wody grzewczej (wewnętrzny wymiennik ciepła)	Zmienny
Temperatura wody na wylocie (wewnętrzny wymiennik ciepła)	Zmienna	Objętość przepływu cieczy źródłowej (zewnętrzny wymiennik ciepła)	-
Funkcja	Odwracalna		

[okrągła pieczęć]

O-B-00629-24, strona 1 (2)

[Hologram]

Instytut Testów Inżynieryjnych, Przedsiębiorstwo Publiczne,

Hudcova 424/56b, 621 00 Brno, Republika Czeska

www.szutest.cz



Wyniki:

Nazwy modeli		Zastosowanie niskotemperaturowe (Referencyjna temperatura wody 35°C)				
		Airkompakt p0916 (Testowany)	Airkompakt p1118 (Nietestowany)	Airkompakt p1522 (Testowany)	Airkompakt p1926 (Nietestowany)	
Znamionowa moc cieplna	$P_{designh}$ [kW]	A	6,20	8,59	12,45	14,58
		W	7,00	9,40	13,50 (Nietestowany)	14,40
		C	5,65	7,97	9,68 (Nietestowany)	12,38
Temperatura biwalentna	$T_{bivalent}$ [°C]	A	-7	-7	-7	-7
		W	2	2	2	2
		C	-15	-15	-15	-15
Sezonowy współczynnik efektywności	SCOP [-]	A	4,00	4,05	4,12	4,08
		W	5,00 (Nietestowany)	5,16	4,96 (Nietestowany)	5,13
		C	3,54 (Nietestowany)	3,61	3,55 (Nietestowany)	3,53
Sezonowa efektywność energetyczna ogrzewania pomieszczeń	n_s [%]	A	157,2	159,1	161,6	160,2
		W	196,9 (Nietestowany)	203,3	195,3 (Nietestowany)	202,3
		C	138,7 (Nietestowany)	141,2	139,1 (Nietestowany)	138,3

(Testowany) Ta próbka testowa została przetestowana w Laboratorium Badawczym.

(Nietestowany) Dane techniczne zostały zadeklarowane przez Producenta zgodnie ze specyfikacją typoszeregu i nie były sprawdzane przez Laboratorium Badawcze.

Instytut Testów Inżynieryjnych, Przedsiębiorstwo Publiczne, potwierdza niniejszym Certyfikatem Testów, że badanie danego produktu zostało przeprowadzone z wynikami podanymi powyżej. Instytut Testów Inżynieryjnych, Przedsiębiorstwo Publiczne, jest akredytowanym Laboratorium Badawczym 1045.1.

Certyfikat testów unieważnia i zastępuje O-B-01500-22 rev.1 z 30 września 2022 r.
Brno, 11.04.2024 r.

[nieczytelny podpis] Ing. Mario Jankola

Kierownik Stacji Badań Urządzeń Ciepłych i Przyjaznych Środowisku

- KONIEC CERTYFIKATU TESTÓW -

[okrągła pieczęć]

O-B-00629-24, strona 2 (2)

Instytut Testów Inżynieryjnych, Przedsiębiorstwo Publiczne,
Hudcova 424/56b, 621 00.Brno, Republika Czeska

www.szutest.cz

Nr rep. 762/24

Stwierdzam zgodność powyższego przekładu z okazanym dokumentem

Tytułem wynagrodzenia pobrano -

Augustów, dnia: 13.04.2024 r.

Tłumacz przysięgły języka angielskiego – mgr Piotr Szlauzys (nr TP/4453/05)



Tłumaczenie przysięgłe z jęz. angielskiego na jęz. polski

Instytut Testów Inżynieryjnych, Przedsiębiorstwo Publiczne, Brno, Republika Czeska

CERTYFIKAT TESTÓW

Numer: O-B-00630-24

Klient KOŁTON SPÓŁKA KOMANDYTOWA
ul. Sosnowa 2
34-480 Jabłonka
POLSKA

Produkt Zewnętrzna pompa ciepła typu powietrze/woda – monoblok

Oznaczenie typu/
znak towarowy **Airkompakt p0916**
Airkompakt p1118
Airkompakt p1522
Airkompakt p1926

Metody testowe ČSN EN 14511-3:2023, ČSN EN 14825:2023

Podstawa certyfikatu Raporty z testów:
39-17622/T z 2024-04-09
39-17622/H z 2024-04-09

Zastosowana temp. Dokumentacja techniczna KOŁTON SPÓŁKA KOMANDYTOWA
ŚREDNIA TEMPERATURA
(Referencyjna temperatura wody 55°C)

Referencyjny sezon grzewczy „A” = **umiarkowany** / „W” = **ciepły** / „C” = **chłodny**
(Referencyjny warunek projektowy dla ogrzewania $T_{designh} = -10\text{ °C}/+2\text{ °C}/-22\text{ °C}$)

Specyfikacja warunków:

Sterowanie prędkością sprężarki	Stałe	Przepływ objętościowy wody grzewczej (wewnętrzny wymiennik ciepła)	Zmienny
Temperatura wody na wylocie (wewnętrzny wymiennik ciepła)	Zmienna	Objętość przepływu cieczy źródłowej (zewnętrzny wymiennik ciepła)	-
Funkcja	Odwracalna		

[okrągła pieczęć]

O-B-00630-24, strona 1 (2)

[Hologram]

Instytut Testów Inżynieryjnych, Przedsiębiorstwo Publiczne,

Hudcova 424/56b, 621 00 Brno, Republika Czeska

www.szutest.cz



Wyniki:

Nazwy modeli		Zastosowanie średnotemperaturowe (Referencyjna temperatura wody 55°C)				
		Airkompakt p0916 (Testowany)	Airkompakt p1118 (Nietestowany)	Airkompakt p1522 (Testowany)	Airkompakt p1926 (Nietestowany)	
Znamionowa moc cieplna	$P_{designh}$ [kW]	A	6,28	8,59	11,96	13,90
		W	6,52	8,90	11,60 (Nietestowany)	14,40
		C	5,29	7,72	9,68 (Nietestowany)	12,38
Temperatura biwalentna	$T_{bivalent}$ [°C]	A	-7	-7	-7	-7
		W	2	2	2	2
		C	-15	-15	-15	-15
Sezonowy współczynnik efektywności	SCOP [-]	A	3,25	3,39	3,28	3,35
		W	4,03 (Nietestowany)	4,07	4,13 (Nietestowany)	4,10
		C	2,82 (Nietestowany)	2,97	2,93 (Nietestowany)	2,94
Sezonowa efektywność energetyczna ogrzewania pomieszczeń	n_s [%]	A	127,0	132,8	128,4	131,2
		W	158,4 (Nietestowany)	159,8	162,4 (Nietestowany)	161,1
		C	109,8 (Nietestowany)	116,0	114,2 (Nietestowany)	114,5

(Testowany) Ta próbka testowa została przetestowana w Laboratorium Badawczym.

(Nietestowany) Dane techniczne zostały zadeklarowane przez Producenta zgodnie ze specyfikacją typoszeregu i nie były sprawdzane przez Laboratorium Badawcze.

Instytut Testów Inżynieryjnych, Przedsiębiorstwo Publiczne, potwierdza niniejszym Certyfikatem Testów, że badanie danego produktu zostało przeprowadzone z wynikami podanymi powyżej. Instytut Testów Inżynieryjnych, Przedsiębiorstwo Publiczne, jest akredytowanym Laboratorium Badawczym 1045.1.

Certyfikat testów unieważnia i zastępuje O-B-01501-22 rev.1 z 30 września 2022 r.
Brno, 11.04.2024 r.

[nieczytelny podpis]

Ing. Mario Jankola

Kierownik Stacji Badań Urządzeń Ciepłych i Przyjaznych Środowisku
- KONIEC CERTYFIKATU TESTÓW -

[okrągła pieczęć]

O-B-00630-24, strona 2 (2)

Instytut Testów Inżynieryjnych, Przedsiębiorstwo Publiczne,
Hudcova 424/56b, 621 00 Brno, Republika Czeska

www.szutest.cz

Nr rep. 761/24

Stwierdzam zgodność powyższego przekładu z okazanym dokumentem

Tytułem wynagrodzenia pobrano -

Augustów, dnia: 13.04.2024 r.

Tłumacz przysięgły języka angielskiego – mgr Piotr Szlauzys (nr TP/4453/05)



OŚWIADCZENIE

Producent **KOŁTON SPÓŁKA KOMANDYTOWA** oświadcza, iż pompy ciepła

1) AIRKOMPAKT P1522

Oznaczenie/typ/identyfikator modelu

2) AIRKOMPAKT P1926

Oznaczenie/typ/identyfikator modelu

3)

Oznaczenie/typ/identyfikator modelu

4)

Oznaczenie/typ/identyfikator modelu

5)

Oznaczenie/typ/identyfikator modelu

Należą do jednego podtypu w danym typoszeregu i spełniają łącznie następujące warunki:

- identyczna konstrukcja obiegu chłodniczego, ten sam czynnik chłodniczy/roboczy;
- ten sam producent, typ i liczba sprężarek;
- ten sam typ elementu rozprężnego;
- ten sam typ skraplacza;
- ten sam typ parownika;
- ten sam typ procesu odszraniania;
- ten sam sterownik i zasada sterowania wydajnością;
- ten sam producent, typ i liczba wentylatorów parownika (w przypadku powietrznych pomp ciepła) i zasada sterowania wydajnością (stała, zmienna lub stopniowana regulacja prędkości obrotowej);
- urządzenia z i bez zaworu czterodrogowego nie mogą być zaliczone do tego samego typoszeregu.

Jabłonka, dn. 10.04.2024 r.

Miejscowość, data

 **KOŁTON**

KOŁTON spółka komandytowa
ul. Sosnowa 2, 34-480 Jabłonka

NIP 735 274 90 54 REGON 120755317 KRS 0000987297


Podpis osoby upoważnionej

