

TEST REPORT

Report no.:
300-KLAB-24-044 rev. 2 - 1



**DANISH
TECHNOLOGICAL
INSTITUTE**

Teknologiparken
Kongsvang Allé 29
DK-8000 Aarhus C
+45 72 20 20 00
Info@teknologisk.dk
www.teknologisk.dk

Page 1 of 36
Init: KAMA/HSG
File no.: 251355
Enclosures: 1

Customer: Company: NINGBO AUX ELECTRIC CO., LTD
Address: NO.1166 MingGuang North Road
City: JiangShan Town, Yinzhou Disrtict, Ningbo, Zhejiang,China PR CHINA

Component: Brand: AUX
Type: Air to water heat pump (Split)
Model: Outdoor unit: ACHP-H08/4R3HA-O
Indoor unit: ACHP-H08/4R3HA-I
Series no.: Outdoor unit: 8E0384002404110001
Indoor unit: 8C1493002404210001
Prod. year: Outdoor unit:2024.04 Indoor unit:2024.04

Dates: Component tested: July 2024 – August 2024

Brand name: Brand: SEVRA
Type: Air to water heat pump (mono block)
Model: SEV-ACHP3-08-I / SEV-ACHP1-08-O

Remarks: This report replaces report 300-KLAB-24-044-1 issued 2024.09.11, as the customer name was changed. The unit was delivered by the customer. The installation and test settings were done according to the manufacturer's instructions. The report for the tested unit is named 300-KLAB-24-044 rev 1. issued 2024.08.23. Also see appendix 2.

Terms: This test was conducted under accreditation in accordance with international requirements (ISO/IEC 17025:2017) and in accordance with the General Terms and Conditions of Danish Technological Institute. The test results solely apply to the tested item. This test report may be quoted in extract only if Danish Technological Institute has granted its written consent.

The customer may not mention or refer to Danish Technological Institute or Danish Technological Institute's employees for advertising or marketing purposes unless Danish Technological Institute has granted its written consent in each case.

Division/Centre: Danish Technological Institute
Energy and Climate
Heat Pump Laboratory, Aarhus

Date: 2024.09.19

Signature:
Kamalathasan Arumugam
B.Sc. Engineer

Co-reader:
Henning S. Grindorf
B.TecMan & MarEng



DIGITALLY SIGNED DOCUMENT

20 September 2024

DANISH TECHNOLOGICAL INSTITUTE



 **DANAK**
Test Reg. nr. 300



Objective

The objective of this report is to document the following:

The Seasonal Coefficient of Performance (SCOP) at low and medium temperature application for average climate according to EN 14825:2022.

In order to calculate the SCOP, tests were carried out at the part load conditions stated in the tables on page 4 and 5.

COP test at standard rating conditions A7/W35 according to EN 14511:2022.

COP test at standard rating conditions A7/W55 according to EN 14511:2022.

Sound power measurements according to EN 12102-1:2022.



Contents:

Test conditions.....	4
SCOP test conditions for low temperature – EN 14825	4
SCOP test conditions for medium temperature – EN 14825.....	5
COP test conditions - low temperature – EN 14511	6
COP test conditions - medium temperature – EN 14511	6
Test conditions for sound power measurement - EN12102-1.....	6
Test results	7
Test results of SCOP test at low temperature - heating season average – EN 14825	7
Test results of SCOP test at medium temperature - heating season average – EN 14825.....	8
COP test results - low temperature – EN 14511.....	9
COP test results - medium temperature – EN 14511	9
Test results of sound power measurements - EN 12102-1	9
Photos	10
SCOP - detailed calculation	12
Detailed SCOP calculation of low temperature and average climate conditions – EN 14825	12
Detailed SCOP calculation of medium temperature and average climate conditions – EN 14825.....	14
Detailed test results.....	16
Detailed SCOP part load test results - low temperature application - average climate – EN 14825.....	16
Detailed SCOP part load test results - medium temperature application - average climate – EN 14825	21
Detailed COP test results - low temperature – EN 14511	26
Detailed COP test results - medium temperature – EN 14511.....	27
Detailed test results of sound power measurement – EN 12102-1.....	28
Appendix 1.....	30



Test conditions

SCOP test conditions for low temperature – EN 14825

Part load conditions for reference SCOP and reference SCOPon calculation of air to water units for low temperature application for the reference heating season;

“A” = average, “W” = warmer, and “C” = colder.

	Part load ratio in %				Outdoor heat exchanger		Indoor heat exchanger			
					Dry (wet) bulb temperature °C		Fixed outlet °C	Variable outlet ^d °C		
	Formula	Average	Warmer	Colder	Outdoor air	Exhaust air	All climates	Average	Warmer	Colder
A	$(-7 - 16) / (T_{\text{designh}} - 16)$	88,46	n.a.	60,53	-7(-8)	20(12)	a / 35	a / 34	n.a.	a / 30
B	$(+2 - 16) / (T_{\text{designh}} - 16)$	53,85	100,00	36,84	2(1)	20(12)	a / 35	a / 30	a / 35	a / 27
C	$(+7 - 16) / (T_{\text{designh}} - 16)$	34,62	64,29	23,68	7(6)	20(12)	a / 35	a / 27	a / 31	a / 25
D	$(+12 - 16) / (T_{\text{designh}} - 16)$	15,38	28,57	10,53	12(11)	20(12)	a / 35	a / 24	a / 26	a / 24
E	$(TOL^e - 16) / (T_{\text{designh}} - 16)$				TOL^e	20(12)	a / 35	a / b	a / b	a / b
F	$(T_{\text{biv}} - 16) / (T_{\text{designh}} - 16)$				T_{biv}	20(12)	a / 35	a / c	a / c	a / c
G	$(-15 - 16) / (T_{\text{designh}} - 16)$	n.a.	n.a.	81,58	-15	20(12)	a / 35	n.a.	n.a.	a / 32

Additional information

Climate	T_{designh} [°C]	T_{bivalent} [°C]	TOL [°C]	Outlet temperature	Flow rate
Average	-10	-7	-10	Variable	Variable



SCOP test conditions for medium temperature – EN 14825

Part load conditions for reference SCOP and reference SCOPon calculation of air to water units for medium temperature application for the reference heating season;

“A” = average, “W” = warmer, and “C” = colder.

	Part load ratio in %				Outdoor heat exchanger		Indoor heat exchanger			
					Dry (wet) bulb temperature °C		Fixed outlet °C	Variable outlet ^d °C		
	Formula	Average	Warmer	Colder	Outdoor air	Exhaust air	All climates	Average	Warmer	Colder
A	$(-7 - 16) / (T_{\text{designh}} - 16)$	88,46	n.a.	60,53	-7(-8)	20(12)	^a / 55	^a / 52	n.a.	^a / 44
B	$(+2 - 16) / (T_{\text{designh}} - 16)$	53,85	100	36,84	2(1)	20(12)	^a / 55	^a / 42	^a / 55	^a / 37
C	$(+7 - 16) / (T_{\text{designh}} - 16)$	34,62	64,29	23,68	7(6)	20(12)	^a / 55	^a / 36	^a / 46	^a / 32
D	$(+12 - 16) / (T_{\text{designh}} - 16)$	15,38	28,57	10,53	12(11)	20(12)	^a / 55	^a / 30	^a / 34	^a / 28
E	$(TOL^e - 16) / (T_{\text{designh}} - 16)$				TOL^e	20(12)	^a / 55	^a / ^b	^a / ^b	^a / ^b
F	$(T_{\text{biv}} - 16) / (T_{\text{designh}} - 16)$				T_{biv}	20(12)	^a / 55	^a / ^c	^a / ^c	^a / ^c
G	$(-15 - 16) / (T_{\text{designh}} - 16)$	n.a.	n.a.	81,58	-15	20(12)	^a / 55	n.a.	n.a.	^a / 49

Additional information

Climate	T_{designh} [°C]	T_{bivalent} [°C]	TOL [°C]	Outlet temperature	Flow rate
Average	-10	-7	-10	Variable	Variable



COP test conditions - low temperature – EN 14511

N#	Heat source		Heat sink	
	Inlet dry bulb temperature (°C)	Inlet wet bulb temperature (°C)	Inlet temperature (°C)	Outlet temperature (°C)
1 ^S	7	6	30	35

S: Standard rating condition

COP test conditions - medium temperature – EN 14511

N#	Heat source		Heat sink	
	Inlet dry bulb temperature (°C)	Inlet wet bulb temperature (°C)	Inlet temperature (°C)	Outlet temperature (°C)
1 ^S	7	6	47	55

S: Standard rating condition

Test conditions for sound power measurement - EN12102-1

N#	Test condition		Heat pump setting			
	Ambient air temperature (°C)	Out/Indoor - heat exchanger (°C)	Compressor speed (Hz)	Fan speed (rpm)	Heating capacity (kW)	Power input (kW)
1 ¹	20	7/55	-	-	2.55	1.14
2 ²	7	7/55	25	400	2.55	1.14

- 1) Indoor unit
2) Outdoor unit



Test results

Test results of SCOP test at low temperature - heating season average – EN 14825

Model (Outdoor)	ACHP-H08/4R3HA-O
Air-to-water heat pump mono bloc	N
Low-temperature heat pump	N
Equipped with supplementary heater	Y
Heat pump combination heater	N

Rated heat output¹⁾	P_{rated}	8.1 [kW]
Seasonal space heating energy efficiency	η_s	199.2 [%]
	SCOP	5.06 [-]

Measured capacity for heating for part load at outdoor temperature T_j	Average Climate	$T_j = -15\text{ °C}$	P_{dh}	- [kW]
	-	$T_j = -7\text{ °C}$	P_{dh}	6.64 [kW]
	Low temperature application	$T_j = 2\text{ °C}$	P_{dh}	4.18 [kW]
		$T_j = 7\text{ °C}$	P_{dh}	3.00 [kW]
		$T_j = 12\text{ °C}$	P_{dh}	2.47 [kW]
		$T_j = \text{bivalent temperature}$	P_{dh}	6.64 [kW]
		$T_j = \text{operation limit}$	P_{dh}	6.78 [kW]

Measured coefficient of performance at outdoor temperature T_j	Average Climate	$T_j = -15\text{ °C}$	COP _d	- [-]
	-	$T_j = -7\text{ °C}$	COP _d	3.26 [-]
	Low temperature application	$T_j = 2\text{ °C}$	COP _d	4.99 [-]
		$T_j = 7\text{ °C}$	COP _d	6.79 [-]
		$T_j = 12\text{ °C}$	COP _d	7.60 [-]
		$T_j = \text{bivalent temperature}$	COP _d	3.26 [-]
		$T_j = \text{operation limit}$	COP _d	2.90 [-]

Bivalent temperature	$T_{bivalent}$	-7 [°C]
Operation limit temperatures	TOL	-10 [°C]
	WTOL	- [°C]
Degradation coefficient	C_{dh}	0.90 [-]

Power consumption in modes other than active mode	Off mode	P_{OFF}	0.015 [kW]
	Thermostat-off mode	P_{TO}	0.060 [kW]
	Standby mode	P_{SB}	0.015 [kW]
	Crankcase heater mode	P_{CK}	0.011 [kW]
Supplementary heater¹⁾	Rated heat output	P_{SUP}	1.32 [kW]
	Type of energy input		Electrical

Other items	Capacity control		Variable
	Water flow control		Variable
	Water flow rate		-
	Annual energy consumption	Q_{HE}	3310 [kWh]

¹⁾For heat pump space heaters and heat pump combination heaters, the rated heat output, P_{rated} , is equal to the design load for heating, $P_{designh}$, and the rated heat output of a supplementary heater, P_{sup} , is equal to the supplementary capacity for heating, $sup(T_j)$.



Test results of SCOP test at medium temperature - heating season average – EN 14825

Model (Outdoor)		ACHP-H08/4R3HA-O	
Air-to-water heat pump mono bloc		N	
Low-temperature heat pump		N	
Equipped with supplementary heater		Y	
Heat pump combination heater		N	
Rated heat output¹⁾	P _{rated}	6.6 [kW]	
Seasonal space heating energy efficiency	η _s	142.3 [%]	
	SCOP	3.63 [-]	
Measured capacity for heating for part load at outdoor temperature T_j	Average Climate	T _j = -15 °C	P _{dh} - [kW]
	-	T _j = -7 °C	P _{dh} 6.20 [kW]
	Medium temperature application	T _j =2 °C	P _{dh} 3.83 [kW]
		T _j =7 °C	P _{dh} 2.52 [kW]
		T _j =12 °C	P _{dh} 2.23 [kW]
		T _j =bivalent temperature	P _{dh} 6.20 [kW]
		T _j =operation limit	P _{dh} 5.60 [kW]
Measured coefficient of performance at outdoor temperature T_j	Average Climate	T _j = -15 °C	COP _d - [-]
	-	T _j = -7 °C	COP _d 2.29 [-]
	Medium temperature application	T _j =2 °C	COP _d 3.61 [-]
		T _j =7 °C	COP _d 4.61 [-]
		T _j =12 °C	COP _d 6.30 [-]
		T _j =bivalent temperature	COP _d 2.29 [-]
		T _j =operation limit	COP _d 1.97 [-]
Bivalent temperature	T _{bivalent}	-7 [°C]	
Operation limit temperatures	TOL	-10 [°C]	
	WTOL	- [°C]	
Degradation coefficient	C _{dh}	0.90 [-]	
Power consumption in modes other than active mode	Off mode	P _{OFF}	0.015 [kW]
	Thermostat-off mode	P _{TO}	0.060 [kW]
	Standby mode	P _{SB}	0.015 [kW]
	Crankcase heater mode	P _{CK}	0.011 [kW]
Supplementary heater¹⁾	Rated heat output	P _{SUP}	1.00 [kW]
	Type of energy input	Electrical	
Other items	Capacity control	Variable	
	Water flow control	Variable	
	Water flow rate	-	
	Annual energy consumption	Q _{HE}	3753 [kWh]

¹⁾For heat pump space heaters and heat pump combination heaters, the rated heat output, P_{rated}, is equal to the design load for heating, P_{design,h}, and the rated heat output of a supplementary heater, P_{sup}, is equal to the supplementary capacity for heating, sup(T_j).



COP test results - low temperature – EN 14511

N#	Test conditions	Heating capacity [kW]	COP
1	A7/W35	8.367	4.994

COP test results - medium temperature – EN 14511

N#	Test conditions	Heating capacity [kW]	COP
1	A7/W55	8.354	3.075

Test results of sound power measurements - EN 12102-1

N#	Sound power level LW(A) [dB re 1pW]	Uncertainty (dB) (weighted value)
1 ¹	44.9	1.6
2 ²	53.8	1.6

- 1) Indoor unit
2) Outdoor unit

The A-weighted total sound power level is determined for the measured frequency range from 100 Hz to 10 kHz. For the calculation of uncertainty, see appendix 1.

The sound power measurements are carried out by Kamalathasan Arumugam (KAMA) and co-read by Patrick Glibert (PGL), Danish Technological Institute.



Photos

Rating plate outdoor unit




Outdoor unit





Rating plate indoor unit



Indoor unit





SCOP - detailed calculation

Detailed SCOP calculation of low temperature and average climate conditions – EN 14825

Calculation of reference SCOP

$$SCOP = \frac{P_{designh} \times H_{he}}{\frac{P_{designh} \times H_{he}}{SCOP_{on}} + H_{TO} \times P_{TO} + H_{SB} \times P_{SB} + H_{CK} \times P_{CK} + H_{OFF} \times P_{OFF}}$$

Where

P_{design} = Heating load of the building at design temperature, kW

H_{he} = Number of equivalent heating hours, 2066 h

H_{TO} , H_{SB} , H_{CK} , H_{OFF} = Number of hours for which the unit is considered to work in thermostat off mode, standby mode, crankcase heater mode and off mode, h, respectively

P_{TO} , P_{SB} , P_{CK} , P_{OFF} = Electricity consumption during thermostat off mode, standby mode, crankcase heater mode and off mode, kW, respectively

Data for SCOP

	Outdoor temperature [°C]	Part load ratio [%]	Part load [kW]	Declared capacity [kW]	Declared COP [-]	cdh [-]	CR [-]	COPbin [-]
A	-7	88	7.17	6.64	3.26	0.97	1.00	3.26
B	2	54	4.36	4.18	4.99	0.93	1.00	4.99
C	7	35	2.80	3.00	6.79	0.90	1.00	6.79
D	12	15	1.25	2.47	7.60	0.90	0.50	6.92
E	-10	100	8.10	6.78	2.90	0.97	1.00	2.90
F - BIV	-7	88	7.17	6.64	3.26	0.97	1.00	3.26

Energy consumption for thermostat off, standby, off mode, crankcase heater mode

	Hours [h]	Power input [kW]	Applied to SCOP calculation [kW]	Energy consumption [kWh]
Off mode	0	0.015385	0.01539	0
Thermostat off	178	0.060397	0.0604	10.750666
Standby	0	0.015385	0.01539	0
Crankcase heater	178	0.010899	0	0



Calculation Bin for SCOPon

	Bin [-]	Outdoor temperature [°C]	Hours [h]	Heat load [kW]	Heat load covered by heat pump [kW]	Electrical back up heater [kW]	Annual backup heater energy input [kWh]	COPbin [-]	Annual heating demand [kWh]	Annual energy input [kWh]	Net annual heating capacity [kWh]	Net annual power input [kWh]
E	21	-10	1	8.10	6.78	1.32	1.32	2.90	8.10	3.66	6.78	2.34
	22	-9	25	7.79	6.73	1.06	26.39	3.02	194.71	82.16	168.32	55.76
	23	-8	23	7.48	6.69	0.79	18.15	3.14	171.97	67.11	153.82	48.96
A / F - BIV	24	-7	24	7.17	6.64	0.00	0.00	3.26	171.97	52.67	171.97	52.67
	25	-6	27	6.85	6.37	0.00	0.00	3.46	185.05	53.54	185.05	53.54
	26	-5	68	6.54	6.09	0.00	0.00	3.65	444.88	121.94	444.88	121.94
	27	-4	91	6.23	5.82	0.00	0.00	3.84	567.00	147.66	567.00	147.66
	28	-3	89	5.92	5.55	0.00	0.00	4.03	526.81	130.67	526.81	130.67
	29	-2	165	5.61	5.27	0.00	0.00	4.22	925.27	219.08	925.27	219.08
	30	-1	173	5.30	5.00	0.00	0.00	4.42	916.23	207.52	916.23	207.52
	31	0	240	4.98	4.72	0.00	0.00	4.61	1196.31	259.68	1196.31	259.68
	32	1	280	4.67	4.45	0.00	0.00	4.80	1308.46	272.67	1308.46	272.67
B	33	2	320	4.36	4.18	0.00	0.00	4.99	1395.69	279.68	1395.69	279.68
	34	3	357	4.05	3.90	0.00	0.00	5.35	1445.85	270.21	1445.85	270.21
	35	4	356	3.74	3.63	0.00	0.00	5.71	1330.89	233.04	1330.89	233.04
	36	5	303	3.43	3.35	0.00	0.00	6.07	1038.36	171.02	1038.36	171.02
	37	6	330	3.12	3.08	0.00	0.00	6.43	1028.08	159.84	1028.08	159.84
C	38	7	326	2.80	2.80	0.00	0.00	6.79	914.05	134.57	914.05	134.57
	39	8	348	2.49	2.49	0.00	0.00	6.82	867.32	127.21	867.32	127.21
	40	9	335	2.18	2.18	0.00	0.00	6.84	730.56	106.74	730.56	106.74
	41	10	315	1.87	1.87	0.00	0.00	6.87	588.81	85.71	588.81	85.71
	42	11	215	1.56	1.56	0.00	0.00	6.90	334.90	48.57	334.90	48.57
D	43	12	169	1.25	1.25	0.00	0.00	6.92	210.60	30.43	210.60	30.43
	44	13	151	0.93	0.93	0.00	0.00	6.95	141.13	20.31	141.13	20.31
	45	14	105	0.62	0.62	0.00	0.00	6.97	65.42	9.38	65.42	9.38
	46	15	74	0.31	0.31	0.00	0.00	7.00	23.05	3.29	23.05	3.29
SUM									16731.48	3298.38	16685.62	3252.51
SCOPon										5.07	SCOPnet	5.13



Detailed SCOP calculation of medium temperature and average climate conditions – EN 14825

Calculation of reference SCOP

$$SCOP = \frac{P_{designh} \times H_{he}}{\frac{P_{designh} \times H_{he}}{SCOP_{on}} + H_{TO} \times P_{TO} + H_{SB} \times P_{SB} + H_{CK} \times P_{CK} + H_{OFF} \times P_{OFF}}$$

Where

P_{design} =

Heating load of the building at design temperature, kW

H_{he} =

Number of equivalent heating hours, 2066 h

H_{TO} , H_{SB} , H_{CK} , H_{OFF} =

Number of hours for which the unit is considered to work in thermostat off mode, standby mode, crankcase heater mode and off mode, h, respectively

P_{TO} , P_{SB} , P_{CK} , P_{OFF} =

Electricity consumption during thermostat off mode, standby mode, crankcase heater mode and off mode, kW, respectively

Data for SCOP

	Outdoor temperature [°C]	Part load ratio [%]	Part load [kW]	Declared capacity [kW]	Declared COP [-]	cdh [-]	CR [-]	COPbin [-]
A	-7	88	5.84	6.20	2.29	0.98	1.00	2.29
B	2	54	3.55	3.83	3.61	0.94	1.00	3.61
C	7	35	2.28	2.52	4.61	0.90	1.00	4.61
D	12	15	1.02	2.23	6.30	0.90	0.46	5.63
E	-10	100	6.60	5.60	1.97	0.98	1.00	1.97
F - BIV	-7	88	5.84	6.20	2.29	0.98	1.00	2.29

Energy consumption for thermostat off, standby, off mode, crankcase heater mode

	Hours [h]	Power input [kW]	Applied to SCOP calculation [kW]	Energy consumption [kWh]
Off mode	0	0.015385	0.01539	0
Thermostat off	178	0.060397	0.0604	10.750666
Standby	0	0.015385	0.01539	0
Crankcase heater	178	0.010899	0	0



Calculation Bin for SCOPon

	Bin [-]	Outdoor temperature [°C]	Hours [h]	Heat load [kW]	Heat load covered by heat pump [kW]	Electrical back up heater [kW]	Annual backup heater energy input [kWh]	COPbin [-]	Annual heating demand [kWh]	Annual energy input [kWh]	Net annual heating capacity [kWh]	Net annual power input [kWh]
E	21	-10	1	6.60	5.60	1.00	1.00	1.97	6.60	3.84	5.60	2.85
	22	-9	25	6.35	5.68	0.67	16.63	2.08	158.65	85.02	142.02	68.39
	23	-8	23	6.09	5.76	0.33	7.65	2.18	140.12	68.28	132.47	60.63
A / F - BIV	24	-7	24	5.84	5.84	0.00	0.00	2.29	140.12	61.11	140.12	61.11
	25	-6	27	5.58	5.58	0.00	0.00	2.44	150.78	61.81	150.78	61.81
	26	-5	68	5.33	5.33	0.00	0.00	2.59	362.49	140.18	362.49	140.18
	27	-4	91	5.08	5.08	0.00	0.00	2.73	462.00	169.08	462.00	169.08
	28	-3	89	4.82	4.82	0.00	0.00	2.88	429.25	149.10	429.25	149.10
	29	-2	165	4.57	4.57	0.00	0.00	3.03	753.92	249.20	753.92	249.20
	30	-1	173	4.32	4.32	0.00	0.00	3.17	746.56	235.37	746.56	235.37
	31	0	240	4.06	4.06	0.00	0.00	3.32	974.77	293.75	974.77	293.75
	32	1	280	3.81	3.81	0.00	0.00	3.46	1066.15	307.71	1066.15	307.71
B	33	2	320	3.55	3.55	0.00	0.00	3.61	1137.23	314.91	1137.23	314.91
	34	3	357	3.30	3.30	0.00	0.00	3.81	1178.10	309.16	1178.10	309.16
	35	4	356	3.05	3.05	0.00	0.00	4.01	1084.43	270.44	1084.43	270.44
	36	5	303	2.79	2.79	0.00	0.00	4.21	846.07	201.01	846.07	201.01
	37	6	330	2.54	2.54	0.00	0.00	4.41	837.69	190.02	837.69	190.02
C	38	7	326	2.28	2.28	0.00	0.00	4.61	744.78	161.64	744.78	161.64
	39	8	348	2.03	2.03	0.00	0.00	4.81	706.71	146.85	706.71	146.85
	40	9	335	1.78	1.78	0.00	0.00	5.02	595.27	118.65	595.27	118.65
	41	10	315	1.52	1.52	0.00	0.00	5.22	479.77	91.88	479.77	91.88
	42	11	215	1.27	1.27	0.00	0.00	5.43	272.88	50.29	272.88	50.29
D	43	12	169	1.02	1.02	0.00	0.00	5.63	171.60	30.47	171.60	30.47
	44	13	151	0.76	0.76	0.00	0.00	5.84	114.99	19.70	114.99	19.70
	45	14	105	0.51	0.51	0.00	0.00	6.04	53.31	8.82	53.31	8.82
	46	15	74	0.25	0.25	0.00	0.00	6.25	18.78	3.01	18.78	3.01
SUM									13633.06	3741.31	13607.78	3716.03
SCOPon										3.64	SCOPnet	3.66



Detailed test results

Detailed SCOP part load test results - low temperature application - average climate – EN 14825

Detailed result for 'EN14825:2022' Average Low (A) A -7 /W34		
Tested according to:	EN14511:2022 and EN14825:2022	
Climate zone:	Average	
Temperature application:	Low	
Condition name:	A	
Condition temperature:	°C	-7
Part load:	%	88%
Chosen Tbivalent	°C	-7
Tdesign	°C	-10
Pdesign	kW	8.10
Heating demand:	kW	7.17
CR:	-	1.0
Minimum flow reached:	-	No
Measurement type:	Steady State	
Integrated liquid pump:	Yes	
Integrated liquid pump able to generate a positive ext. static pressure difference:	No	
Included corrections (Final result)		
Heating capacity	kW	6.643
COP	-	3.265
Power consumption	kW	2.035
Measured		
Heating capacity	kW	6.634
COP	-	3.277
Power consumption	kW	2.024
During heating		
Air_inlet temperature dry bulb	°C	-6.98
Air temperature wet bulb	°C	-8.00
Water_inlet temperature	°C	29.01
water_outlet temperature	°C	34.02
Water_outlet temperature (Time averaged)	°C	34.02
Circulation pump		
Measured external static pressure difference, liquid pump	Pa	4211
Calculated Hydraulic power	W	1
Calculated global efficiency	η	0.13
Calculated Capacity correction	W	-9
Calculated Power correction	W	-10
Water Flow	m³/s	0.000319



Detailed result for 'EN14825:2022' Average Low (B) A 2 /W30		
Tested according to:	EN14511:2022 and EN14825:2022	
Climate zone:	Average	
Temperature application:	Low	
Condition name:	B	
Condition temperature:	°C	2
Part load:	%	54%
Chosen Tbivalent	°C	-7
Tdesign	°C	-10
Pdesign	kW	8.10
Heating demand:	kW	4.36
CR:	-	1.0
Minimum flow reached:	-	No
Measurement type:	Steady State	
Integrated liquid pump:	Yes	
Integrated liquid pump able to generate a positive ext. static pressure difference:	Yes	
Included corrections (Final result)		
Heating capacity	kW	4.177
COP	-	4.990
Power consumption	kW	0.837
Measured		
Heating capacity	kW	4.179
COP	-	4.977
Power consumption	kW	0.840
During heating		
Air_inlet temperature dry bulb	°C	2.04
Air temperature wet bulb	°C	1.00
Water_inlet temperature	°C	24.99
water_outlet temperature	°C	29.82
Water_outlet temperature (Time averaged)	°C	29.82
Circulation pump		
Measured external static pressure difference, liquid pump	Pa	1462
Calculated Hydraulic power	W	0
Calculated global efficiency	η	0.12
Calculated Capacity correction	W	2
Calculated Power correction	W	3
Water Flow	m³/s	0.000208



Detailed result for 'EN14825:2022' Average Low (C) A 7 /W27		
Tested according to:	EN14511:2022 and EN14825:2022	
Climate zone:	Average	
Temperature application:	Low	
Condition name:	C	
Condition temperature:	°C	7
Part load:	%	35%
Chosen Tbivalent	°C	-7
Tdesign	°C	-10
Pdesign	kW	8.10
Heating demand:	kW	2.80
CR:	-	1.0
Minimum flow reached:	-	Yes
Measurement type:	Steady State	
Integrated liquid pump:	Yes	
Integrated liquid pump able to generate a positive ext. static pressure difference:	Yes	
Included corrections (Final result)		
Heating capacity	kW	2.999
COP	-	6.792
Power consumption	kW	0.442
Measured		
Heating capacity	kW	3.002
COP	-	6.747
Power consumption	kW	0.445
During heating		
Air_inlet temperature dry bulb	°C	7.00
Air temperature wet bulb	°C	6.01
Water_inlet temperature	°C	22.98
water_outlet temperature	°C	26.98
Water_outlet temperature (Time averaged)	°C	26.98
Circulation pump		
Measured external static pressure difference, liquid pump	Pa	2240
Calculated Hydraulic power	W	0
Calculated global efficiency	η	0.12
Calculated Capacity correction	W	3
Calculated Power correction	W	3
Water Flow	m³/s	0.000180



Detailed result for 'EN14825:2022' Average Low (D) A 12 /W24		
Tested according to:	EN14511:2022 and EN14825:2022	
Climate zone:		Average
Temperature application:		Low
Condition name:		D
Condition temperature:	°C	12
Part load:	%	15%
Chosen Tbivalent	°C	-7
Tdesign	°C	-10
Pdesign	kW	8.10
Heating demand:	kW	1.25
CR:	-	0.5
Minimum flow reached:	-	Yes
Measurement type:		Steady State
Integrated liquid pump:		Yes
Integrated liquid pump able to generate a positive ext. static pressure difference:		Yes
Included corrections (Final result)		
Heating capacity	kW	2.473
COP	-	7.603
Power consumption	kW	0.325
Measured		
Heating capacity	kW	2.516
COP	-	6.548
Power consumption	kW	0.384
During heating		
Air_inlet temperature dry bulb	°C	12.02
Air temperature wet bulb	°C	10.98
Water_inlet temperature	°C	22.50
water_outlet temperature	°C	25.61
Water_outlet temperature (Time averaged)	°C	24.07
Circulation pump		
Measured external static pressure difference, liquid pump	Pa	85001
Calculated Hydraulic power	W	16
Calculated global efficiency	η	0.28
Calculated Capacity correction	W	42
Calculated Power correction	W	59
Water Flow	m ³ /s	0.000194



Detailed result for 'EN14825:2022' Average Low (E) A -10 /W35		
Tested according to:	EN14511:2022 and EN14825:2022	
Climate zone:		Average
Temperature application:		Low
Condition name:		E
Condition temperature:	°C	-10
Part load:	%	100%
Chosen Tbivalent	°C	-7
Tdesign	°C	-10
Pdesign	kW	8.10
Heating demand:	kW	8.10
CR:	-	1.0
Minimum flow reached:	-	No
Measurement type:		Steady State
Integrated liquid pump:		Yes
Integrated liquid pump able to generate a positive ext. static pressure difference:		No
Included corrections (Final result)		
Heating capacity	kW	6.778
COP	-	2.895
Power consumption	kW	2.341
Measured		
Heating capacity	kW	6.768
COP	-	2.905
Power consumption	kW	2.330
During heating		
Air_inlet temperature dry bulb	°C	-9.98
Air temperature wet bulb	°C	-10.99
Water_inlet temperature	°C	30.00
water_outlet temperature	°C	35.07
Water_outlet temperature (Time averaged)	°C	35.07
Circulation pump		
Measured external static pressure difference, liquid pump	Pa	4351
Calculated Hydraulic power	W	1
Calculated global efficiency	η	0.13
Calculated Capacity correction	W	-9
Calculated Power correction	W	-11
Water Flow	m ³ /s	0.000321



Detailed SCOP part load test results - medium temperature application - average climate – EN 14825

Detailed result for 'EN14825:2022' Average Medium (A) A -7 /W52		
Tested according to:	EN14511:2022 and EN14825:2022	
Climate zone:		Average
Temperature application:		Medium
Condition name:		A
Condition temperature:	°C	-7
Part load:	%	88%
Chosen Tbivalent	°C	-7
Tdesign	°C	-10
Pdesign	kW	6.60
Heating demand:	kW	5.84
CR:	-	1.0
Minimum flow reached:	-	Yes
Measurement type:		Steady State
Integrated liquid pump:		Yes
Integrated liquid pump able to generate a positive ext. static pressure difference:		Yes
Included corrections (Final result)		
Heating capacity	kW	6.199
COP	-	2.293
Power consumption	kW	2.704
Measured		
Heating capacity	kW	6.242
COP	-	2.259
Power consumption	kW	2.762
During heating		
Air_inlet temperature dry bulb	°C	-6.98
Air temperature wet bulb	°C	-7.99
Water_inlet temperature	°C	44.32
water_outlet temperature	°C	52.11
Water_outlet temperature (Time averaged)	°C	52.11
Circulation pump		
Measured external static pressure difference, liquid pump	Pa	84837
Calculated Hydraulic power	W	16
Calculated global efficiency	η	0.28
Calculated Capacity correction	W	42
Calculated Power correction	W	59
Water Flow	m ³ /s	0.000194



Detailed result for 'EN14825:2022' Average Medium (B) A 2 /W42		
Tested according to:	EN14511:2022 and EN14825:2022	
Climate zone:		Average
Temperature application:		Medium
Condition name:		B
Condition temperature:	°C	2
Part load:	%	54%
Chosen Tbivalent	°C	-7
Tdesign	°C	-10
Pdesign	kW	6.60
Heating demand:	kW	3.55
CR:	-	1.0
Minimum flow reached:	-	Yes
Measurement type:		Steady State
Integrated liquid pump:		Yes
Integrated liquid pump able to generate a positive ext. static pressure difference:		Yes
Included corrections (Final result)		
Heating capacity	kW	3.829
COP	-	3.611
Power consumption	kW	1.060
Measured		
Heating capacity	kW	3.832
COP	-	3.602
Power consumption	kW	1.064
During heating		
Air_inlet temperature dry bulb	°C	2.01
Air temperature wet bulb	°C	1.01
Water_inlet temperature	°C	36.61
water_outlet temperature	°C	41.74
Water_outlet temperature (Time averaged)	°C	41.74
Circulation pump		
Measured external static pressure difference, liquid pump	Pa	2379
Calculated Hydraulic power	W	0
Calculated global efficiency	η	0.12
Calculated Capacity correction	W	3
Calculated Power correction	W	4
Water Flow	m ³ /s	0.000180



Detailed result for 'EN14825:2022' Average Medium (C) A 7 /W36		
Tested according to:		N14825:2022
Climate zone:		Average
Temperature application:		Medium
Condition name:		C
Condition temperature:	°C	7
Part load:	%	35%
Chosen Tbivalent	°C	-7
Tdesign	°C	-10
Pdesign	kW	6.60
Heating demand:	kW	2.28
CR:	-	1.0
Minimum flow reached:	-	Yes
Measurement type:		Steady State
Integrated liquid pump:		Yes
Integrated liquid pump able to generate a positive ext. static pressure difference:		Yes
Included corrections (Final result)		
Heating capacity	kW	2.521
COP	-	4.608
Power consumption	kW	0.547
Measured		
Heating capacity	kW	2.561
COP	-	4.251
Power consumption	kW	0.603
During heating		
Air_inlet temperature dry bulb	°C	7.00
Air temperature wet bulb	°C	6.01
Water_inlet temperature	°C	32.71
water_outlet temperature	°C	35.89
Water_outlet temperature (Time averaged)	°C	35.89
Circulation pump		
Measured external static pressure difference, liquid pump	Pa	76840
Calculated Hydraulic power	W	15
Calculated global efficiency	η	0.27
Calculated Capacity correction	W	40
Calculated Power correction	W	55
Water Flow	m ³ /s	0.000194



Detailed result for 'EN14825:2022' Average Medium (D) A 12 /W30		
Tested according to:		N14825:2022
Climate zone:		Average
Temperature application:		Medium
Condition name:		D
Condition temperature:	°C	12
Part load:	%	15%
Chosen Tbivalent	°C	-7
Tdesign	°C	-10
Pdesign	kW	6.60
Heating demand:	kW	1.02
CR:	-	0.5
Minimum flow reached:	-	Yes
Measurement type:		Steady State
Integrated liquid pump:		Yes
Integrated liquid pump able to generate a positive ext. static pressure difference:		Yes
Included corrections (Final result)		
Heating capacity	kW	2.229
COP	-	6.304
Power consumption	kW	0.354
Measured		
Heating capacity	kW	2.271
COP	-	5.506
Power consumption	kW	0.412
During heating		
Air_inlet temperature dry bulb	°C	11.99
Air temperature wet bulb	°C	10.99
Water_inlet temperature	°C	28.70
water_outlet temperature	°C	31.52
Water_outlet temperature (Time averaged)	°C	29.98
Circulation pump		
Measured external static pressure difference, liquid pump	Pa	85126
Calculated Hydraulic power	W	17
Calculated global efficiency	η	0.28
Calculated Capacity correction	W	42
Calculated Power correction	W	59
Water Flow	m ³ /s	0.000194



Detailed result for 'EN14825:2022' Average Medium (E) A -10 /W55		
Tested according to:		N14825:2022
Climate zone:		Average
Temperature application:		Medium
Condition name:		E
Condition temperature:	°C	-10
Part load:	%	100%
Chosen Tbivalent	°C	-7
Tdesign	°C	-10
Pdesign	kW	6.60
Heating demand:	kW	6.60
CR:	-	1.0
Minimum flow reached:	-	Yes
Measurement type:		Steady State
Integrated liquid pump:		Yes
Integrated liquid pump able to generate a positive ext. static pressure difference:		Yes
Included corrections (Final result)		
Heating capacity	kW	5.602
COP	-	1.969
Power consumption	kW	2.846
Measured		
Heating capacity	kW	5.644
COP	-	1.943
Power consumption	kW	2.905
During heating		
Air_inlet temperature dry bulb	°C	-10.03
Air temperature wet bulb	°C	-11.00
Water_inlet temperature	°C	48.01
water_outlet temperature	°C	55.07
Water_outlet temperature (Time averaged)	°C	55.07
Circulation pump		
Measured external static pressure difference, liquid pump	Pa	84644
Calculated Hydraulic power	W	16
Calculated global efficiency	η	0.28
Calculated Capacity correction	W	42
Calculated Power correction	W	59
Water Flow	m ³ /s	0.000194



Detailed COP test results - low temperature – EN 14511

Detailed result for 'EN14511:2022' A7/W35		
Tested according to:		EN14511:2022
Minimum flow reached:		No
Measurement type:		Steady State
Integrated liquid pump:		Yes
Integrated liquid pump able to generate a positive ext. static pressure difference:		No
Included corrections (Final result)		
Heating capacity	kW	8.367
COP	-	4.994
Power consumption	kW	1.676
Measured		
Heating capacity	kW	8.347
COP	-	5.053
Power consumption	kW	1.652
During heating		
Air_inlet temperature dry bulb	°C	6.99
Air temperature wet bulb	°C	6.03
Water_inlet temperature	°C	30.00
water_outlet temperature	°C	35.04
Circulation pump		
Measured external static pressure difference, liquid pump	Pa	9397
Calculated Hydraulic power	W	4
Calculated global efficiency	η	0.16
Calculated Capacity correction	W	-20
Calculated Power correction	W	-23
Water Flow	m ³ /s	0.000399



Detailed COP test results - medium temperature – EN 14511

Detailed result for 'EN14511:2022' A7/W55		
Tested according to:		EN14511:2022
Minimum flow reached:		No
Measurement type:		Steady State
Integrated liquid pump:		Yes
Integrated liquid pump able to generate a positive ext. static pressure difference:		No
Included corrections (Final result)		
Heating capacity	kW	8.354
COP	-	3.075
Power consumption	kW	2.717
Measured		
Heating capacity	kW	8.353
COP	-	3.076
Power consumption	kW	2.715
During heating		
Air_inlet temperature dry bulb	°C	6.99
Air temperature wet bulb	°C	6.03
Water_inlet temperature	°C	46.99
water_outlet temperature	°C	55.12
Circulation pump		
Measured external static pressure difference, liquid pump	Pa	810
Calculated Hydraulic power	W	0
Calculated global efficiency	η	0.11
Calculated Capacity correction	W	-2
Calculated Power correction	W	-2
Water Flow	m ³ /s	0.000249

Detailed test results of sound power measurement – EN 12102-1


Test#1_Indoor unit

		Sound power levels according to ISO 3743-1:2010	
Engineering method for small, movable sources in reverberant fields - Comparison method for hard-walled test rooms			
Client:	KLIMA-THERM		Date of test: 20-08-2024
Object:	Type: Split air to water heat pump, Model: IDU: ACHP-H08 5R3HA-I & ODU: ACHP-H08/4R3HA-O		
Mounting conditions:	The indoor unit is mounted at a height of 1.7 meter above floor level using a metal support frame and a wooden board (90 x 110 cm). The IDU is mounted on the wooden board using vibration isolators. The metal frame is damped by filling the pipes with dry sand placed it all on placed on four pices of concrete tiles (50x50x2.5 cm), which are placed in a water drop tray on two pieces of heavy concrete tiles (90x90x10cm) laying on a vibration damping mat on the floor. The noise radiated by the indoor unit has been measured in Test room 1 and the outdoor unit is installed in the neighboring Test room 2.		
Operating conditions:	IDU: Ambient temperature = 20°C, ODU: A7W55, Compressor speed: 25[Hz], Fan speed: 400 [rpm], Heating capacity: 2.55 [kW], Power input: 1.140[kW], Water flow rate: 700 [l/h] and dp _{water} : 839 [mbar]		
Static pressure:	1013 hPa	<u>Reference box:</u>	
Air temperature:	20.0 °C	L1: 0.4 m	
Relative air humidity:	73.0 %	L2: 0.3 m	
Test room volume:	102.8 m³	Room: Room 1	L3: 0.8 m
Area, S, of test room:	138.9 m²		Volume: 0.1 m³

Frequency <i>f</i> [Hz]	L _w 1/3 octave [dB]	1/1 oct [dB]
100	45.6	
125	43.7	50.5 ¹
160	47.3	
200	37.4	
250	37.0	46.9
315	45.8	
400	39.1	
500	40.1	43.1
630	32.7	
800	32.0	
1000	36.2	38.2
1250	29.1	
1600	25.1	
2000	27.4	30.6
2500	24.2	
3150	23.1	
4000	22.6	27.6 ²
5000	22.9	
6300	21.1	
8000	21.9	26.6 ²
10000	22.5	

¹ Diff. to backgr. noise < 6dB

² Correction




Sound power level L_w(A):	44.9 dB [re 1pW]	Uncertainty σ_{tot}: 1.6 dB
--	-------------------------	--

Name of test institute:	DTI	Date: 20-08-2024
No. of test report:	300-KLAB-24-044	

In conformity with ISO 3743-1, except for some frequencies where the sound level is close to the background noise, see table. Difference less than 0.52 dB. The result thus represent the upper bound.



Test#2_Outdoor unit

 		Sound power levels according to ISO 3743-1:2010		 TEKNOLOGISK INSTITUT																																																																			
Engineering method for small, movable sources in reverberant fields - Comparison method for hard-walled test rooms																																																																							
Client:		KLIMA-THERM		Date of test: 20-08-2024																																																																			
Object:		Type: Split air to water heat pump, Model: IDU: ACHP-H08 5R3HA-I & ODU: ACHP-H08/4R3HA-O																																																																					
Mounting conditions:		The outdoor unit is mounted on the supporting metal support frame using two pieces of vibration isolators and placed on four pieces of concrete tiles (45x45x5 cm). All of these are placed in a water drop tray on two pieces of heavy concrete tiles (90x90x10cm) laying on a vibration damping mat on the floor. The noise radiated by the outdoor unit has been measured in Test room 2.																																																																					
Operating conditions:		A7W55, Compressor speed: 25[Hz], Fan speed: 400 [rpm], Heating capacity: 2.55 [kW], Power_input: 1.140[kW], Water flow rate: 700 [l/h] and dP_water: 839 [mbar]																																																																					
Static pressure:		1013 hPa		<u>Reference box:</u>																																																																			
Air temperature:		7.0 °C		L1: 1.0 m																																																																			
Relative air humidity:		84.0 %		L2: 0.4 m																																																																			
Test room volume:		102.8 m³		Room: Room 2																																																																			
Area, S, of test room:		138.9 m²		L3: 0.8 m																																																																			
				Volume: 0.3 m³																																																																			
<table border="1"><thead><tr><th>Frequency f [Hz]</th><th>L_w 1/3 octave [dB]</th><th>1/1 oct [dB]</th></tr></thead><tbody><tr><td>100</td><td>59.8</td><td></td></tr><tr><td>125</td><td>49.1</td><td>61.3</td></tr><tr><td>160</td><td>54.9</td><td></td></tr><tr><td>200</td><td>45.1</td><td></td></tr><tr><td>250</td><td>49.8</td><td>52.4</td></tr><tr><td>315</td><td>46.7</td><td></td></tr><tr><td>400</td><td>46.4</td><td></td></tr><tr><td>500</td><td>45.3</td><td>49.8</td></tr><tr><td>630</td><td>42.7</td><td></td></tr><tr><td>800</td><td>44.0</td><td></td></tr><tr><td>1000</td><td>46.6</td><td>50.2</td></tr><tr><td>1250</td><td>45.4</td><td></td></tr><tr><td>1600</td><td>39.6</td><td></td></tr><tr><td>2000</td><td>36.6</td><td>42.2</td></tr><tr><td>2500</td><td>34.9</td><td></td></tr><tr><td>3150</td><td>35.3</td><td></td></tr><tr><td>4000</td><td>33.3</td><td>39.1</td></tr><tr><td>5000</td><td>34.3</td><td></td></tr><tr><td>6300</td><td>31.4</td><td></td></tr><tr><td>8000</td><td>32.9</td><td>39.9</td></tr><tr><td>10000</td><td>38.1</td><td></td></tr></tbody></table>		Frequency f [Hz]	L _w 1/3 octave [dB]	1/1 oct [dB]	100	59.8		125	49.1	61.3	160	54.9		200	45.1		250	49.8	52.4	315	46.7		400	46.4		500	45.3	49.8	630	42.7		800	44.0		1000	46.6	50.2	1250	45.4		1600	39.6		2000	36.6	42.2	2500	34.9		3150	35.3		4000	33.3	39.1	5000	34.3		6300	31.4		8000	32.9	39.9	10000	38.1					
Frequency f [Hz]	L _w 1/3 octave [dB]	1/1 oct [dB]																																																																					
100	59.8																																																																						
125	49.1	61.3																																																																					
160	54.9																																																																						
200	45.1																																																																						
250	49.8	52.4																																																																					
315	46.7																																																																						
400	46.4																																																																						
500	45.3	49.8																																																																					
630	42.7																																																																						
800	44.0																																																																						
1000	46.6	50.2																																																																					
1250	45.4																																																																						
1600	39.6																																																																						
2000	36.6	42.2																																																																					
2500	34.9																																																																						
3150	35.3																																																																						
4000	33.3	39.1																																																																					
5000	34.3																																																																						
6300	31.4																																																																						
8000	32.9	39.9																																																																					
10000	38.1																																																																						
<table border="1"><tr><td>Sound power level L_w(A):</td><td>53.8 dB [re 1pW]</td><td>Uncertainty σ_{tot}:</td><td>1.6 dB</td></tr></table>						Sound power level L _w (A):	53.8 dB [re 1pW]	Uncertainty σ_{tot} :	1.6 dB																																																														
Sound power level L _w (A):	53.8 dB [re 1pW]	Uncertainty σ_{tot} :	1.6 dB																																																																				
Name of test institute:		DTI		Date: 20-08-2024																																																																			
No. of test report:		300-KLAB-24-044																																																																					
Measurements are in full conformity with ISO 3743-1																																																																							



Appendix 1

Operating conditions and environment

The operating conditions of the unit under test fulfill the requirements for Class A.

The acoustic test chamber is a hard wall reverberant room (103 m³) and equipped with relevant sound diffusing reflector panels. The acoustical test chamber fulfils the requirements of ISO3743-1 accuracy grade 2 (engineering grade).

The measurements of the average sound pressure levels in 1/3 octave frequency bands are carried out using three microphones in the test chamber. During the measurements, the microphones are traversed up and down for one meter in the arc of a quarter circle.

The picture below shows the installation of the unit during test, position of microphones, sound diffusing reflector panels, and the reference sound source.

Test#1_indoor unit





Test#2_outdoor unit





Measurement instruments

Id nr.	Manufacturer	Description	Calibration company
100864	GRAS	Gras 40AE_26CA, 1/2" free field microphone, Room 1	Norsonic A/S, Norway
100865	GRAS	Gras 40AE_26CA, 1/2" free field microphone, Room 1	Norsonic A/S, Norway
100866	GRAS	Gras 40AE_26CA, 1/2" free field microphone, Room 1	Norsonic A/S, Norway
100867	GRAS	Gras 40AE_26CA, 1/2" free field microphone, Room 2	Norsonic A/S, Norway
100868	GRAS	Gras 40AE_26CA, 1/2" free field microphone, Room 2	Norsonic A/S, Norway
100869	GRAS	Gras 40AE_26CA, 1/2" free field microphone, Room 2	Norsonic A/S, Norway
100870	GRAS	Gras 40AE_26CA, 1/2" free field microphone, Roof monitor	Norsonic A/S, Norway
100873	Brüel & Kjær	Acoustical calibrator, Brüel & Kjær 4231	Element Metech, Denmark
100859	Norsonic	Reference sound source, Norsonic Nor278 Room 1	RISE, Sweden
100872	Norsonic	Reference sound source, Norsonic Nor278 Room 2	RISE, Sweden
100620	Norsonic	Multi-channel measurement system Nor850	Norsonic A/S, Norway

All microphones are equipped with windshields.



Test Procedure

The measurements of the emitted sound power level from the heat pump are carried out according to the following standard:

- DS/EN 14511:2022
- EN 12102-1:2022
- ISO/EN 3743-1:2010

The basic acoustic measurement standard DS/EN 3743-1 is a comparison method using a calibrated reference sound source. Two series of sound pressure measurements are made under exactly the same acoustic conditions, e.g., the same microphone positions, temperature and air humidity. The calibrated sound power levels are known for the reference sound source at each frequency band, and they are used in the estimation of the acoustical correction factor for the calculation of the sound power emitted from the unit under test. The background noise levels are measured and used for relevant corrections.

The final total A-weighted sound power level is based on measurements and calculations in 1/3-octave levels, which then are summed into 1/1-octave levels. The A-weighted total sound power level is determined for the measured frequency range from 100 Hz to 10 kHz.

The actual microphone positions and correction values are saved in data files linked to the complete project documentation according to the DANAK-accreditation.

The complete measurement system is documented and regularly calibrated according to DANAK.

The detailed description of the measurement method is given in Danish in the quality database system "QA Web" at Danish Technological Institute, which is accessible by DANAK.

Measurement uncertainty

The uncertainty of sound power level in decibel is determined in accordance with ISO 3743-1, equation 22 $\sigma_{tot} = \sqrt{\sigma_{RO}^2 + \sigma_{omc}^2}$ where:

- σ_{RO} is the standard deviation of the reproducibility of the method
- σ_{omc} is the standard deviation describing the uncertainty associated with the instability of the operating and mounting conditions for the particular noise source during test.

σ_{RO} expresses the uncertainty in test results delivered by the different accredited test laboratories due to different instrumentation and implementation of measurement procedure as well different radiation characteristics of the noise source during test.

σ_{omc} expresses the uncertainty associated with the instability of the operating and mounting conditions for the particular noise source during test. The mounting and installation conditions in two DTI acoustical test chambers are well defined in the test procedure. Possible instability of the operating conditions is monitored and assessed prior to each noise test.



The test uncertainty σ_{omc} is calculated according to ISO3743-1 Annex C formula C.1 and is typically below 1.0dB. However, the uncertainty is rounded up to the nearest 0.5 or 1.0dB increment in the report. As pr. Table C.1 (accuracy grade 2), the uncertainty σ_{RO} is set to 1.5.

The expanded uncertainty U is calculated according to ISO 3743-1 equation 23:
 $U = k \sigma_{\text{tot}}$ where $k = 2$ for 95% confidence.

EXAMPLE: $\sigma_{\text{tot}}: \sqrt{1.5^2 + 0.5^2} = 1.6 \text{ dB}$ and $U(95\%) = 3.2 \text{ dB}$

Note: The expanded uncertainty does not include the standard deviation of production which is used in ISO4871 for the purpose of making noise declaration for batches of machines.



Appendix 2 Authorization letter

CE DECLARATION OF CONFORMITY

We, NINGBO AUX ELECTRIC.,CO, LTD BUILDING B4 4 NO:1166 NORTH MINGGUANG ROAD,JIANGSHAN,YINZHOU NINGBO,CHINA

Declare under our sole responsibility that the devices:

Brand name: **SEVRA**

Type of units: Heat Pumps

Model: please see the list below

We, NINGBO AUX ELECTRIC CO., LTD (BUILDING B4 4 NO:1166 NORTH MINGGUANG ROAD , JIANGSHAN, YINZHOU NINGBO, CHINA) hereby confirm that all below Heat Pumps are the same except model no., nameplate specification and address. We declare that these units are produced by us under SEVRA BRAND NAME and shipped to Wienkra sp. z o.o. (located in Ul. Kotlarska 34, 31-539 Kraków, Poland) and we declare that this declaration is in conformity with the requirements set out in the Council Directive on the Approximation of the Laws of the Member States relating to Electro Magnetic Compatibility (2014/30/EU), Low Voltage (2014/35/EU) for evaluation of compliance with this directives, following standards were applied

EMC (2014/30/EU)

EN55014-1:2017+A11:2020

EN55014-2:2015

EN IEC 61000-3-2:2019

EN 61000-3-3:2013+A1:2019

LVD (2014/35/EU)

EN60335-2-40:2003+A11:2004+A12:2005+A1:2006+A2:2009+A13:2012

EN60035-1:2012+A11:2014+A13:2017+A1:2019+A14:2009+A2:2009

EN62233:2008





Model List:

SEVRA Model

AUX Model

SEV-ACHP3-08-I / SEV-ACHP1-08-O

ACHP-H08/4R3HA-I / ACHP-H08/4R3HA-O

This Declaration of Conformity is issued under the sole responsibility of the Manufacturer.

Authorized representative:

NINGBO AUX ELECTRIC.,CO,LTD


NAME : Ada Qiu

Title: CAC Regional Sales Manager of Central & Southeast Europe

Date : Aug 30th, 2024

SIGNATURE:

Ada Qiu



Mgr Edyta Winiarska-Stachowicz
Tłumacz przysięgły języka angielskiego
Ul. Kazimierza Wielkiego 4/4, Kraków
tel. 609-570-720
Uwierzytelnione tłumaczenie z języka angielskiego



Raport z przeprowadzonej próby

Nr raportu:
300-KLAB-24-044 rew. 2 - 1



**DANISH
TECHNOLOGICAL
INSTITUTE**

Teknologiparken
Kongsvang Alle 29
DK-8000 Aarhus C
+45 72 20 20 00
Info@teknologisk.dk
www.teknologisk.dk

Strona 1 z 36
Znak: KAMA/HSG
Nr pliku: 251355
Załączniki: 1

Klient: Firma: NINGBO AUX ELECTRIC CO., LTD
Adres: NO.1166 MingGuang North Road
Miejscowość: JiangShan Town, Yinzhou Disrtict, Ningbo, Zhejiang, ChRL

Charakt. prod.: Nazwa: AUX
Typ: Pompa ciepła typu powietrze-woda (dzielona)
Model: Jedn. zewn.: ACHP-H08/4R3HA-O
Jedn. wewn.: ACHP-H08/4R3HA-I
Nr fabr.: Jedn. zewn.: 8E0384002404110001
Jedn. wewn.: 8C1493002404210001
Rok prod.: Jedn. zewnętrzna: 2024.04 Jedn. wewnętrzna: 2024.04

Data: Prod. badany: lipiec 2024 r. - sierpień 2024 r.

Nazwa marki: Nazwa: SEVRA
Typ: Pompa ciepła typu powietrze-woda (monoblok)
Model: SEV-ACHP3-08-I / SEV-ACHP1-08-O

Uwagi: Niniejszy raport zastępuje raport 300-KLAB-24-044-1 wydany 2024.09.11, ponieważ zmieniono nazwę klienta. Urządzenie dostarczył klient. Instalacja i ustawienia testowe zostały wykonane zgodnie z zaleceniami producenta. Raport dotyczący testowanej jednostki nosi nazwę 300-KLAB-24-044 rev 1.; data wydania 2024.08.23. Zob. również załącznik 2.

Warunki przeprowadzenia próby: Niniejsza próba została przeprowadzona w ramach akredytacji zgodnie z międzynarodowymi wymogami (ISO/IEC 17025:2017) oraz zgodnie z Ogólnymi Warunkami Duńskiego Instytutu Technologicznego. Wyniki próby odnoszą się wyłącznie do testowanego produktu. Niniejszy raport z przeprowadzonej próby można przytaczać we fragmentach wyłącznie za pisemną zgodą Duńskiego Instytutu Technologicznego.

Klient nie może powoływać się na Duński Instytut Technologiczny lub jego pracowników w celach reklamowych lub marketingowych, chyba że Duński Instytut Technologiczny wyrazi na to każdorazowo pisemną zgodę.

Oddział/Centrum: Danish Technological Institute
Energy and Climate
Heat Pump Laboratory, Aarhus

Data: 2024.09.19

Podpis:
Kamalathasan Arumugam
B.Sc. Engineer

Współpraca:
Henning S. Grindorf
B.TecMan & MarEng



DOKUMENT PODPISANY CYFROWO

20 września 2024

DANISH TECHNOLOGICAL INSTITUTE



Test Reg. nr. 300





Cel przeprowadzenia próby

Celem niniejszego raportu jest udokumentowanie następujących kwestii:

Sezonowy współczynnik wydajności (SCOP) przy zastosowaniu w niskiej i średniej temperaturze dla klimatu umiarkowanego zgodnie z normą EN 14825:2022.

W celu obliczenia SCOP przeprowadzono próby w warunkach obciążenia częściowego podanych w tabelach na stronie 4 i 5.

Standardowe warunki znamionowe próby COP A7/W35 według normy EN 14511:2022.

Standardowe warunki znamionowe próby COP A7/W55 według normy EN 14511:2022.

Pomiary mocy akustycznej według normy EN 12102-1:2022.





Warunki prowadzenia próby

Warunki próby SCOP dla niskich temperatur - EN 14825

Warunki częściowego obciążenia dla referencyjnego SCOP i referencyjnego SCOPon do obliczania jednostek powietrze-woda dla zastosowań niskotemperaturowych dla referencyjnego sezonu grzewczego;

„A” = umiarkowanie, „W” = cieplej, „C” = chłodniej.

	Współczynnik obciążenia częściowego w %				Zewnętrzny wymiennik ciepła		Wewnętrzny wymiennik ciepła			
					Temperatura termometru suchego (mokrego) °C		Wylot stały °C	Wylot zmienny ^d °C		
	Wzór	War. umiarkow.	Cieplej	Chłodniej	Powietrze zewnętrzne	Powietrze wylotowe	Wsz. war. klimatyczne	War. umiarkow.	Cieplej	Chłodniej
A	$(-7-16)/(T_{designh}-16)$	88,46	n.d.	60,53	-7(-8)	20(12)	a / 35	a / 34	n.d.	a / 30
B	$(+2-16)/(T_{designh}-16)$	53,85	100,00	36,84	2(1)	20(12)	a / 35	a / 30	a / 35	a / 27
C	$(+7-16)/(T_{designh}-16)$	34,62	64,29	23,68	7(6)	20(12)	a / 35	a / 27	a / 31	a / 25
D	$(+12-16)/(T_{designh}-16)$	15,38	28,57	10,53	12(11)	20(12)	a / 35	a / 24	a / 26	a / 24
E	$(TOL^e - 16) / (T_{designh} - 16)$				TOL^e	20(12)	a / 35	a / b	a / b	a / b
F	$(T_{biv} - 16) / (T_{designh} - 16)$				T_{biv}	20(12)	a / 35	a / c	a / c	a / c
G	$(-15-16)/(T_{designh}-16)$	n.d.	n.d.	81,58	-15	20(12)	a / 35	n.d.	n.d.	a / 32

Informacje dodatkowe

Uwarunk. klimatyczne	$T_{designh}$ [°C]	$T_{bivalent}$ [°C]	TOL [°C]	Temperatura zewnętrzna	Natężenie przepływu
War. umiarkow.	-10	-7	-10	Zmienna	Zmienna





Warunki próby SCOP dla średnich temperatur - EN 14825

Warunki częściowego obciążenia dla referencyjnego SCOP i referencyjnego SCOPon do obliczania jednostek powietrze-woda dla zastosowań średnotemperaturowych dla referencyjnego sezonu grzewczego;

	Współczynnik obciążenia częściowego w %				Zewnętrzny wymiennik ciepła		Wewnętrzny wymiennik ciepła			
					Temperatura termometru suchego (mokrego) °C		Wylot stały °C	Wylot zmienny °C		
	Wzór	War. umiarkow	Cieplej	Chłodniej	Powietrze zewnętrzne	Powietrze wylotowe	Wsz. war. klimatyczne	War. umiarkow	Cieplej	Chłodniej
A	$\frac{(-7 - 16)}{(T_{designh} - 16)}$	88,46	n.d.	60,53	-7(-8)	20(12)	a / 55	a / 52	n.d.	a / 44
B	$\frac{(+2 - 16)}{(T_{designh} - 16)}$	53,85	100	36,84	2(1)	20(12)	a / 55	a / 42	a / 55	a / 37
C	$\frac{(+7 - 16)}{(T_{designh} - 16)}$	34,62	64,29	23,68	7(6)	20(12)	a / 55	a / 36	a / 46	a / 32
D	$\frac{(+12 - 16)}{(T_{designh} - 16)}$	15,38	28,57	10,53	12(11)	20(12)	a / 55	a / 30	a / 34	a / 28
E	$(TOL^e - 16) / (T_{designh} - 16)$				TOL^e	20(12)	a / 55	a / b	a / b	a / b
F	$(T_{biv} - 16) / (T_{designh} - 16)$				T_{biv}	20(12)	a / 55	a / c	a / c	a / c
G	$\frac{(-15 - 16)}{(T_{designh} - 16)}$	n.d.	n.d.	81,58	-15	20(12)	a / 55	n.d.	n.d.	a / 49

Informacje dodatkowe

Uwarunk. klimatyczne	$T_{designh}$ [°C]	$T_{bivalent}$ [°C]	TOL [°C]	Temperatura zewnętrzna	Natężenie przepływu
War. umiarkow.	-10	-7	-10	Zmienna	Zmienna





Warunki próby COP dla niskich temperatur - EN 14511

N#	Źródło ciepła		Ujście ciepła	
	Temperatura termometru suchego na wlocie (°C)	Temperatura termometru mokrego na wlocie (°C)	Temperatura wlotowa (°C)	Temperatura wylotowa (°C)
1 ^S	7	6	30	35

S: Standardowy warunek znamionowy

Warunki próby COP dla umiarkowanych temperatur - EN 14511

N#	Źródło ciepła		Ujście ciepła	
	Temperatura termometru suchego na wlocie (°C)	Temperatura termometru mokrego na wlocie (°C)	Temperatura wlotowa (°C)	Temperatura wylotowa (°C)
1 ^S	7	6	47	55

S: Standardowy warunek znamionowy

Warunki prowadzenia prób dla pomiaru mocy akustycznej - EN12102-1

N#	Warunki prowadzenia próby		Ustawienia pompy ciepła			
	Temperatura otaczającego powietrza (°C)	Zewnętrzny/wewnętrzny wymiennik ciepła (°C)	Prędkość obrotowa sprężarki (Hz)	Prędkość obrotowa wentylatora (obr./min.)	Wydajność grzewcza (kW)	Moc wejściowa (kW)
1 ¹	20	7/55	-	-	2,55	1,14
2 ²	7	7/55	25	400	2,55	1,14

1) Jedn. wewnętrzna

2) Jedn. zewnętrzna





Wyniki przeprowadzonej próby Wyniki przeprowadzonej próby SCOP w niskiej temperaturze - średnia sezonu grzewczego - EN 14825

Model (zewnątrzny)	ACHP-H08/4R3HA-O
Monoblokowa pompa ciepła powietrze-woda	N
Niskotemperaturowa pompa ciepła	N
Wyposażona w dodatkowy podgrzewacz	Y
Podgrzewacz kombinowany z pompą ciepła	N

Znamionowa moc cieplna ¹⁵	P_{rated}	8,1 [kW]
Sezonowa efektywność energetyczna ogrzewania pomieszczeń	η_s SCOP	199,2 [%] 5,06 [-]

Zmierzona wydajność ogrzewania dla częściowego obciążenia przy temperaturze zewnętrznej T_j	Umiark. war. klimatyczne	$T_j = -15^{\circ}\text{C}$	P_{dh}	- [kW]
		$T_j = -7^{\circ}\text{C}$	P_{dh}	6,64 [kW]
		$T_j = 2^{\circ}\text{C}$	P_{dh}	4,18 [kW]
	Aplikacja niskotemperaturowa	$T_j = 7^{\circ}\text{C}$	P_{dh}	3,00 [kW]
		$T_j = 12^{\circ}\text{C}$	P_{dh}	2,47 [kW]
		$T_j = \text{temperatura dwuwartościowa}$	P_{dh}	6,64 [kW]
		$T_j = \text{limit operacyjny}$	P_{dh}	6,78 [kW]

Zmierzony współczynnik wydajności przy temperaturze zewnętrznej T_j	Umiark. war. klimatyczne	$T_j = -15^{\circ}\text{C}$	COPd	- [-]
		$T_j = -7^{\circ}\text{C}$	COPd	3,26 H
		$T_j = 2^{\circ}\text{C}$	COPd	4,99 [-]
	Aplikacja niskotemperaturowa	$T_j = 7^{\circ}\text{C}$	COPd	6,79 [-]
		$T_j = 12^{\circ}\text{C}$	COPd	7,60 [-]
		$T_j = \text{temperatura dwuwartościowa}$	COPd	3,26 H
		$T_j = \text{limit operacyjny}$	COPd	2,90 [-]

Temperatura dwuwartościowa	Tbivalent	-7 [°C]
Limit operacyjny	TOL	-10 [°C]
temperatury	WTOL	- [°C]
Współczynnik utraty energii	Cdh	0,90 [*]

Pobór mocy w trybach innych niż tryb aktywny	Tryb wył.	POFF	0,015 [kW]
	Tryb wył. termostatu	PTO	0,060 [kW]
	Tryb oczekiwania	PSB	0,015 [kW]
	Tryb grzania skrzyni korbowej	PCK	0,011 [kW]
Podgrzewacz dodatkowy ¹⁾	Znamionowa moc cieplna	PSUP	1,32 [kW]
	Rodzaj dostarczanej energii		Elektryczna

Pozostałe elementy	Sterowanie przepustowością		Zmienna
	Sterowanie przepływem wody		Zmienna
	Natężenie przepływu wody		-
	Roczne zapotrzebowanie na energię	Q_{HE}	3310 [kWh]

¹⁾ W przypadku ogrzewaczy pomieszczeń z pompą ciepła i wielofunkcyjnych podgrzewaczy z pompą ciepła znamionowa moc cieplna P_{rated} , jest równa projektowemu obciążeniu grzewczemu, $P_{designh}$, a znamionowa moc cieplna dodatkowego ogrzewacza, P_{sup} , jest równa dodatkowej wydajności grzewczej, $sup(T_j)$.





Wyniki próby SCOP w średnich temperaturach - średnia sezonu grzewczego - EN 14825

Model (zewnątrzny)	ACHP-H08/4R3HA-O		
Monoblokowa pompa ciepła powietrze-woda	N		
Niskotemperaturowa pompa ciepła	N		
Wyposażona w dodatkowy podgrzewacz	Y		
Podgrzewacz kombinowany z pompą ciepła	N		
Znamionowa moc cieplna ¹¹	P _{rated}	6,6 [kW]	
Sezonowa efektywność energetyczna pomieszczeń	n _s	142,3 [%]	
	SCOP	3,63 [-]	

Zmierzona wydajność ogrzewania dla częściowego obciążenia przy temperaturze zewnętrznej T _j	Umiark. war. klimatyczne	T _j = -15°C	P _{dh}	- [kW]
		T _j = 7°C	P _{dh}	6,20 [kW]
		T _j = 2°C	P _{dh}	3,83 [kW]
	Aplikacja średniotemperaturowa	T _j = 7°C	P _{dh}	2,52 [kW]
		T _j = 12°C	P _{dh}	2,23 [kW]
		T _j = temperatura dwuwartościowa	P _{dh}	6,20 [kW]
		T _j = limit operacyjny	P _{dh}	5,60 [kW]

Zmierzony współczynnik wydajności przy temperaturze zewnętrznej T _j	Umiark. war. klimatyczne	T _j = -15°C	COP _d	- [-]
		T _j = -7°C	COP _d	2,29 [-]
		T _j = 2°C	COP _d	3,61 [-]
	Aplikacja średniotemperaturowa	T _j = 7°C	COP _d	4,61 [-]
		T _j = 12°C	COP _d	6,30 [-]
		T _j = temperatura dwuwartościowa	COP _d	2,29 [-]
		T _j = limit operacyjny	COP _d	1,97 [-]

Temperatura dwuwartościowa	T _{bivalent}	-7 [°C]
Limit operacyjny temperatury	TOL	-10 [°C]
Współczynnik utraty energii	C _{dh}	0,90 [-]

Pobór mocy w trybach innych niż tryb aktywny	Tryb wył.	P _{OFF}	0,015 [kW]
	Tryb wył. termostatu	P _{TO}	0,060 [kW]
	Tryb oczekiwania	P _{SB}	0,015 [kW]
	Tryb grzania skrzyni korbowej	P _{CK}	0,011 [kW]
Podgrzewacz dodatkowy ¹⁾	Znamionowa moc cieplna	P _{SUP}	1,00 [kW]
	Rodzaj dostarczanej energii		Elektryczna

Pozostałe elementy	Sterowanie przepustowością		Zmienna
	Sterowanie przepływem wody		Zmienna
	Natężenie przepływu wody		-
	Roczne zapotrzebowanie na energię	Q _{ME}	3753 [kWh]

¹¹⁾ W przypadku ogrzewaczy pomieszczeń z pompą ciepła i wielofunkcyjnych podgrzewaczy z pompą ciepła znamionowa moc cieplna P_{rated}, jest równa projektowemu obciążeniu grzewczemu, P_{designh}, a znamionowa moc cieplna dodatkowego ogrzewacza, P_{sup}, jest równa dodatkowej wydajności grzewczej, sup(T_j).



Wyniki próby COP - niska temperatura - EN 14511

N#	Warunki prowadzenia próby	Wydajność grzewcza [kW]	COP
1	A7/W35	8,367	4,994

Wyniki próby COP - średnia temperatura - EN 14511

N#	Warunki prowadzenia próby	Wydajność grzewcza [kW]	COP
1	A7/W55	8,354	3,075

Wyniki próby pomiaru mocy akustycznej – EN 12102-1


N#	Poziom mocy akustycznej LW(A) [dB re 1pW]	Niepewność (dB) (wartość ważona)
1 ¹	44,9	1,6
2 ²	53,8	1,6

1) Jedn. wewnętrzna

2) Jedn. zewnętrzna

Całkowity poziom mocy akustycznej skorygowany charakterystyką A jest określany dla mierzonego zakresu częstotliwości od 100 Hz do 10 kHz. W celu obliczenia niepewności należy zapoznać się z załącznikiem 1.

Pomiary mocy akustycznej zostały przeprowadzone przez Kamalathasana Arumugama (KAMA) i nadzorowane przez Patricka Gliberta (PGL) z Duńskiego Instytutu Technologicznego.





Załącznik 2 List uwierzytelniający

DEKLARACJA ZGODNOŚCI CE

Firma NINGBO AUX ELECTRIC, CO, LTD BUILDING B4 4 NO:1166 NORTH MINGGUANG ROAD,
JIANGSHAN, YINZHOU NINGBO, CHINY

oświadcza na swoją wyłączną odpowiedzialność, że urządzenia:

Nazwa marki: **SEVRA**

Typ: Pompy ciepła

Model: zapoznać się z poniższym wykazem

Firma NINGBO AUX ELECTRIC CO., LTD (BUILDING B4 4 NO:1166 NORTH MINGGUANG ROAD ,
JIANGSHAN, YINZHOU NINGBO, CHINY) niniejszym potwierdza, że wszystkie poniższe pompy
ciepła są takie same, z wyjątkiem modelu o numerze, wyszczególnionym w treści tabliczki
znamionowej i adresie. Oświadczamy, że niniejsze urządzenia zostały wyprodukowane przez naszą
firmę pod marką SEVRA i wysłane do przedsiębiorstwa Wienkra sp. z o.o. (z siedzibą przy ul.
Kotlarskiej 34; 31-539 Kraków, Polska) i oświadczamy, że niniejsza deklaracja jest zgodna z
wymaganiami określonymi w Dyrektywie Rady w sprawie zbliżenia ustawodawstw państw
członkowskich odnoszących się do kompatybilności elektromagnetycznej (2014/30/UE),
niskonapięciowej (2014/35/UE) w celu oceny zgodności z tymi dyrektywami zastosowano następujące
normy:

EMC (2014/30/EU)

EN55014-1:2017+A11:2020

EN55014-2:2015

EN IEC 61000-3-2:2019

EN 61000-3-3:2013+A1:2019

LVD(2014/35/EU)

EN60335-2-40:2003+A11:2004+A12:2005+A1:2006+A2:2009+A13:2012

EN60035-1:2012+A11:2014+A13:2017+A1:2019+A14:2009+A2:2009

EN62233:2008



DANAK

Test Reg. nr. 300





Wykaz modeli:

Model SEVRA

Model AUX

SEV-ACHP3-08-I / SEV-ACHP1-08-O

ACHP-H08/4R3HA-I / ACHP-H08/4R3HA-O

Niniejsza Deklaracja zgodności została wydana na wyłączną odpowiedzialność Producenta.

Upoważniony przedstawiciel:

NINGBO AUX ELECTRIC.,CO, LTD

NAZWISKO: Ada Qiu

Stanowisko: CAC Regional Sales Manager of Central & Southeast Europe

Data: 30 sierpnia 2024

PODPIS:

Ada Qiu





Poświadczam zgodność powyższego tłumaczenia z okazanym mi dokumentem w języku angielskim.

Kraków, dnia 4 października 2024 r.

Rep. nr 10/634/24

Edyta Winiarska-Stachowicz
Tłumacz przysięgły języka angielskiego



OŚWIADCZENIE

Producent SEVRA

oświadcza, iż pompy ciepła

1) SEV-ACHP3-08-I + SEV-ACHP1-08-O

2) SEV-ACHP3-10-I + SEV-ACHP1-10-O

3)

Oznaczenie/typ/identyfikator modelu

4)

Oznaczenie/typ/identyfikator modelu

5)

Oznaczenie/typ/identyfikator modelu

Należą do jednego podtypu w danym typoszeregu i spełniają łącznie następujące warunki:

- identyczna konstrukcja obiegu chłodniczego, ten sam czynnik chłodniczy/roboczy;
- ten sam producent, typ i liczba sprężarek;
- ten sam typ elementu rozprężnego;
- ten sam typ skraplacza;
- ten sam typ parownika;
- ten sam typ procesu odszraniania;
- ten sam sterownik i zasada sterowania wydajnością;
- ten sam producent, typ i liczba wentylatorów parownika (w przypadku powietrznych pomp ciepła) i zasada sterowania wydajnością (stała, zmienna lub stopniowana regulacja prędkości obrotowej);
- urządzenia z i bez zaworu czterodrogowego nie mogą być zaliczone do tego samego typoszeregu.

Kraków, 15.10.2024

Miejscowość, data



Podpis osoby upoważnionej