

Dorota Szmajda-Kuberczyk
 tłumacz przysięgły języka angielskiego
 Rybie, ul. Kasztanowa 33, 05-090 Raszyn
 tel. 501 123 253

POŚWIADCZONE TŁUMACZENIE Z JĘZYKA ANGIELSKIEGO

[Dokument źródłowy, przedstawiony w formie elektronicznej, składa się z 34 numerowanych arkuszy. Na życzenie Klienta przetłumaczono strony jak niżej.
 Tekst w nawiasach kwadratowych pochodzi od tłumacza.] -----

[arkusz 8]: -----

[nagłówek]: logo · **DUŃSKI INSTYTUT TECHNOLOGICZNY** [ang. Danish Technological Institute] · strona 8 z 34 · 300-KLAB024-004-1 -----
 [stopka (na każdym arkuszu)]: logo ilac-MRA · logo DANAK · Test Reg. nr. 300 -----


Wyniki badań SCOP w niskiej temperaturze – dla średniej sezonu grzewczego – EN 14825 -----

Model (jednostka zewnętrzna)	PASRW060-BP-PS-D	
Pompa ciepła powietrze-woda monoblok	T	
Niskotemperaturowa pompa ciepła	N	
Wyposażona w dodatkowy ogrzewacz	N	
Wielofunkcyjny ogrzewacz z pompą ciepła	N	

Znamionowa moc cieplna¹⁾	P_{RATED}	12,55 [kW]
Sezonowa efektywność ogrzewania	η _s	197,5 [%]
pomieszczeń	SCOP	5,01 [-]

Zmierzona wydajność grzewcza przy częściowym obciążeniu w temperaturze zewnętrznej T_j	Klimat umiarkowany - Zastosowanie w niskiej temperaturze	T _j = 15°C	Pdh	- [kW]
		T _j = -7°C		11,31 [kW]
		T _j = 2°C	Pdh	7,27 [kW]
		T _j = 7°C	Pdh	5,27 [kW]
		T _j = 12°C	Pdh	6,19 [kW]
		T _j = temperatura dwuwartościowa	Pdh	11,31 [kW]
		T _j = granica działania	Pdh	12,73 [kW]

Zmierzony współczynnik wydajności temperaturze zewnętrznej T_j	Klimat umiarkowany - Zastosowanie w niskiej temperaturze	T _j = 15°C	COPd	- [-]
		T _j = 7°C	COPd	3,10 [-]
		T _j = 2°C	COPd	4,87 [-]
		T _j = 7°C	COPd	6,60 [-]
		T _j = 12°C	COPd	9,26 [-]
		T _j = temperatura dwuwartościowa	COPd	3,10 [-]
		T _j = granica działania	COPd	2,38 [-]



Temperatura dwuwartościowa	Tbivalent	-7 [°C]
Graniczna temperatura robocza	TOL WTOL	-10 [°C] - [°C]
Współczynnik strat	Cdh	0,96[-]

Pobór mocy w trybach innych niż aktywny	Tryb wyłączenia	P _{OFF}	0,012 [kW]
	Tryb wyłączonego termostatu	P _{TO}	0,028 [kW]
	Tryb gotowości	P _{SB}	0,012 [kW]
	Tryb włączonej grzałki karteru	P _{CK}	0,012 [kW]
Ogrzewacz dodatkowy¹⁾	Znamionowa moc cieplna	P _{SUP}	0,00 [kW]
	Rodzaj energii zasilania		elektryczna

Inne pozycje	Regulacja wydajności	zmienna
	Regulacja przepływu wody	stała
	Natężenie przepływu wody	2688 [l/h]
	Rocznego zużycia energii	Q _{HE} 5172 [kWh]

W przypadku ogrzewaczy pomieszczeń z pompą ciepła i wielofunkcyjnych ogrzewaczy z pompą ciepła znamionowa moc cieplna (Prated) jest równa obciążeniu obliczeniowemu dla trybu ogrzewania (Pdesignh), a znamionowa moc grzewcza ogrzewacza dodatkowego (Psup), jest równa dodatkowej wydajności grzewczej (sup(Tj)).

[arkusz 9]: -----

[nagłówek]: logo · DUŃSKI INSTYTUT TECHNOLOGICZNY [ang. Danish Technological Institute] · strona 9 z 34 · 300-KLAB024-004-1 -----


Wyniki badań SCOP w średniej temperaturze – dla średniej sezonu grzewczego (A) – EN 14825 -----

Model (jednostka zewnętrzna)	PASRW060-BP-PS-D		
Pompa ciepła powietrze-woda monoblok		T	
Niskotemperaturowa pompa ciepła		N	
Wyposażona w dodatkową grzałkę		N	
Kombinowana grzałka z pompą ciepła		N	

Znamionowa moc cieplna¹⁾	P _{RATED}	12,34 [kW]
Sezonowa efektywność energetyczna ogrzewania pomieszczeń	η _S	142,6 [%]
	SCOP	3,64 [-]

Zmierzona wydajność grzewcza przy częściowym obciążeniu przy temperaturze zewnętrznej T_j	Klimat umiarkowany -	T _j = 15°C	Pdh	- [kW]
		T _j = -7°C		11,47 [kW]
		T _j = 2°C	Pdh	6,57 [kW]
		T _j = 7°C	Pdh	6,16 [kW]
		T _j = 12°C	Pdh	7,33 [kW]
		T _j = temperatura dwuwartościowa	Pdh	11,47 [kW]
		T _j = granica działania	Pdh	12,39 [kW]

Zmierzony współczynnik wydajności przy	Klimat umiarkowany -	T _j = 15°C	COPd	- [-]
		T _j = -7°C	COPd	2,32 [-]
		T _j = 2°C	COPd	3,46 [-]



temperaturze zewnętrznej T_j	Zastosowanie w średniej temperaturze	$T_j = 7^\circ\text{C}$	COPd	4,82 [-]
		$T_j = 12^\circ\text{C}$	COPd	6,73 [-]
		T_j = temperatura dwuwartościowa	COPd	2,32 [-]
		T_j = granica działania	COPd	2,04 [-]

Temperatura dwuwartościowa	Tbivalent	-7 [°C]
Graniczna temperatura robocza	TOL	-10 [°C]
Współczynnik strat	WTOL	- [°C]
	Cdh	0,97[-]

Pobór mocy w trybach innych niż aktywny	Tryb wyłączenia	P _{OFF}	0,012 [kW]
	Tryb wyłączonego termostatu	P _{TO}	0,028 [kW]
	Tryb gotowości	P _{SB}	0,012 [kW]
	Tryb włączonej grzalki karteru	P _{CK}	0,012 [kW]
Ogrzewacz dodatkowy¹⁾	Znamionowa moc cieplna	P _{SUP}	0,00 [kW]
	Rodzaj energii zasilania		elektryczna

Inne pozycje	Regulacja wydajności	zmienna
	Regulacja przepływu wody	stała
	Natężenie przepływu wody	1700 [l/h]
	Rocznego zużycia energii	Q _{HE} 7006 [kWh]

W przypadku ogrzewaczy pomieszczeń z pompą ciepła i wielofunkcyjnych ogrzewaczy z pompą ciepła znamionowa moc cieplna (Prated) jest równa obciążeniu obliczeniowemu dla trybu ogrzewania (Pdesignh), a znamionowa moc grzewcza ogrzewacza dodatkowego (Psup), jest równa dodatkowej wydajności grzewczej (sup(Tj)).

[arkusz 11]: -----

[nagłówek]: logo · DUŃSKI INSTYTUT TECHNOLOGICZNY [ang. Danish Technological Institute] · strona 11 z 34 · 300-KLAB024-004-1 -----

Wyniki testu dla całkowitej awarii zasilania – EN 14511-4 -----

Nr	Poświadczenie testu	
1	zaliczony	

Wyniki pomiaru mocy akustycznej – EN 12102-1 -----

Nr	Warunki badania	Poziom mocy akustycznej LW(A) [dB re 1pW]	Niepewność σ_{tot} [dB]
1 ^E	A7/W55	57,6	1,6

E) Oznaczenie ErP -----

Poziom mocy akustycznej odniesionej do A jest oznaczony dla mierzonego zakresu częstotliwości od 100 Hz do 10 kHz. W celu obliczenia niepewności zob. Załącznik 1. -----

Pomiary mocy akustycznej wykonuje Kamalathasan Arumugam (KAMA) we współpracy z Patrickiem Gilbertem (PGL), Duński Instytut Technologiczny. ---

[arkusz 34]: -----

[nagłówek]: logo · DUŃSKI INSTYTUT TECHNOLOGICZNY [ang. Danish

Załącznik 2 – Nazwa marki -----

Upoważnienie -----

[ang. Authorization Letter] -----

Niniejsza Deklaracja zgodności zostaje wydana na wyjątkową odpowiedzialność: -----

Nazwa producenta: Guangdong PHNIX ECO-Energy Solution LTD -----

Adres producenta: No. 3 Tianyuan Road, Dagang Town, Nansha District
Guangzhou Guangdong, 511470 Chiny -----

Oświadczamy, iż poniższy produkty, pompy ciepła, który wyprodukowaliśmy dla firmy COOPER AND HUNTER OVERSEAS LP, są identyczne jak nasze poniższe modele: -----

Model Cooper&Hunter	CH-HP15UIMPZM
Model PHNIX	PASRW060S-BP-PS-D

Nazwa [firma] Cooper&Hunter: COOPER AND HUNTER OVERSEAS LP -----

Nazwa marki Cooper&Hunter: Cooper&Hunter -----

Adres Cooper&Hunter: SUITE 201, 45B WEST WILMOT STREET,
RICHMOND HILL, ON L4B2P3 KANADA -----

Uwaga: Niniejsza deklaracja traci ważność w przypadku wprowadzenia zmian technologicznych lub funkcjonalnych bez zgody producenta. -----

Data: 24 maja 2024 r. -----

Podmiot upoważniony: Guangdong PHNIX ECO-Energy Solution LTD -----

[-], nieczytelny podpis -----

[Odcisk pieczęci o treści]: W imieniu Guangdong PHNIX ECO-Energy Solution LTD · *[-], nieczytelny podpis* · Podpis osoby upoważnionej -----

[koniec tłumaczenia]

Ja, Dorota Szmajda-Kuberczyk, tłumacz przysięgły języka angielskiego wpisana na listę tłumaczy przysięgłych Ministra Sprawiedliwości pod numerem TP/2161/05, stwierdzam zgodność powyższego tłumaczenia z dokumentem w języku angielskim (dokument elektroniczny pdf, którego wydruk, opatrzony pieczęcią i podpisem tłumacza, załączono do niniejszego).

Rybie, 26.07.2024 r.

Nr Repertorium: 508/24



Dorota Szmajda-Kuberczyk *S. S. B.* *B.*



Test results of SCOP test at low temperature - heating season average - EN 14825

Model (Outdoor)	PASRW060S-BP-PS-D
Air-to-water heat pump mono bloc	Y
Low-temperature heat pump	N
Equipped with supplementary heater	N
Heat pump combination heater	N

Rated heat output¹⁾	P _{rated}	12.55 [kW]
Seasonal space heating energy efficiency	η _s	197.5 [%]

Measured capacity for heating for part load at outdoor temperature T_j	Average Climate - Low temperature application	T _j =-15 °C	P _{dh}	- [kW]
		T _j =-7 °C	P _{dh}	11.31 [kW]
		T _j =2 °C	P _{dh}	7.27 [kW]
		T _j =7 °C	P _{dh}	5.27 [kW]
		T _j =12 °C	P _{dh}	6.19 [kW]
		T _j =bivalent temperature	P _{dh}	11.31 [kW]
		T _j =operation limit	P _{dh}	12.73 [kW]

Measured coefficient of performance at outdoor temperature T_j	Average Climate - Low temperature application	T _j =-15 °C	COP _d	- [-]
		T _j =-7 °C	COP _d	3.10 [-]
		T _j =2 °C	COP _d	4.87 [-]
		T _j =7 °C	COP _d	6.60 [-]
		T _j =12 °C	COP _d	9.26 [-]
		T _j =bivalent temperature	COP _d	3.10 [-]
		T _j =operation limit	COP _d	2.38 [-]

Bivalent temperature	T _{bivalent}	-7 [°C]
Operation limit temperatures	TOL	-10 [°C]
WTOL		- [°C]
Degradation coefficient	C _{dh}	0.96 [-]

Power consumption in modes other than active mode	Off mode	P _{off}	0.012 [kW]
	Thermostat-off mode	P _{TO}	0.028 [kW]
	Standby mode	P _{SB}	0.012 [kW]
	Crankcase heater mode	P _{CK}	0.012 [kW]
Supplementary heater¹⁾	Rated heat output	P _{SUP}	0.00 [kW]
	Type of energy input		Electrical

Other items	Capacity control		Variable
	Water flow control		Fixed
	Water flow rate		2688 [l/h]
	Annual energy consumption	Q _{HE}	5172 [kWh]

¹⁾For heat pump space heaters and heat pump combination heaters, the rated heat output, P_{rated}, is equal to the design load for heating, P_{designh}, and the rated heat output of a supplementary heater, P_{sup}, is equal to the supplementary capacity for heating, sup(T_j).



Test results of SCOP test at medium temperature - heating season average – EN 14825

Model (Outdoor)	PASRW060S-BP-PS-D		
Air-to-water heat pump mono bloc		Y	
Low-temperature heat pump		N	
Equipped with supplementary heater		N	
Heat pump combination heater		N	

Rated heat output¹⁾	P _{rated}	12.34 [kW]
Seasonal space heating energy efficiency	η _s SCOP	142.6 [%] 3.64 [-]

Measured capacity for heating for part load at outdoor temperature T_j	Average Climate	T _j =-15 °C	Pdh	- [kW]
	-	T _j =-7 °C	Pdh	11.47 [kW]
	Medium	T _j =2 °C	Pdh	6.57 [kW]
	temperature	T _j =7 °C	Pdh	6.16 [kW]
	application	T _j =12 °C	Pdh	7.33 [kW]
		T _j =bivalent temperature	Pdh	11.47 [kW]
		T _j =operation limit	Pdh	12.39 [kW]

Measured coefficient of performance at outdoor temperature T_j	Average Climate	T _j =-15 °C	COPd	- [-]
	-	T _j =-7 °C	COPd	2.32 [-]
	Medium	T _j =2 °C	COPd	3.46 [-]
	temperature	T _j =7 °C	COPd	4.82 [-]
	application	T _j =12 °C	COPd	6.73 [-]
		T _j =bivalent temperature	COPd	2.32 [-]
		T _j =operation limit	COPd	2.04 [-]

Bivalent temperature	Tbivalent	-7 [°C]
Operation limit	TOL	-10 [°C]
temperatures	WTOL	- [°C]
Degradation coefficient	Cdh	0.97 [-]

Power consumption in modes other than active mode	Off mode	P _{OFF}	0.012 [kW]
	Thermostat-off mode	P _{TO}	0.028 [kW]
	Standby mode	P _{SB}	0.012 [kW]
	Crankcase heater mode	P _{CK}	0.012 [kW]
Supplementary heater¹⁾	Rated heat output	P _{SUP}	0.00 [kW]
	Type of energy input		Electrical

Other items	Capacity control	Variable
	Water flow control	Fixed
	Water flow rate	1700 [l/h]
	Annual energy consumption	Q _{HE} 7006 [kWh]

¹⁾For heat pump space heaters and heat pump combination heaters, the rated heat output, P_{rated}, is equal to the design load for heating, P_{designh}, and the rated heat output of a supplementary heater, P_{sup}, is equal to the supplementary capacity for heating, sup(T_j).



Test results for complete power supply failure – EN 14511-4

N [#]	Test validation
1	Passed

Test results of sound power measurements – EN 12102-1

N [#]	Test conditions	Sound power level LW(A) [dB re 1pW]	Uncertainty σ_{tot} [dB]
1 ^E	A7/W55	57.6	1.6

E) ErP labelling

The A-weighted total sound power level is determined for the measured frequency range from 100 Hz to 10 kHz. For the calculation of uncertainty, see appendix 1.

The sound power measurements are carried out by Kamalathasan Arumugam (KAMA) and co-read by Patrick Glibert (PGL), Danish Technological Institute.



Appendix 2 Brand name

Authorization Letter

This declaration of conformity is issued under the sole responsibility of

Manufacturer's Name: Guangdong PHNIX ECO-Energy Solution LTD

Manufacturer's Address: No. 3 Tianyuan Road, Dagang Town, Nansha District
Guangzhou Guangdong, 511470 China

We declare that the following Heat pump product we produced for COOPER
AND HUNTER OVERSEAS LP are identical to our following models

Cooper&Hunter model	CH-HP22UIMPZM
PHNIX model	PASRW060S-BP-PS-D

Cooper&Hunter company name: COOPER AND HUNTER OVERSEAS LP

Cooper&Hunter brand /-mark: Cooper&Hunter

Cooper&Hunter address: SUITE 201, 45B WEST WILMOT STREET,
RICHMOND HILL, ON L4B2P3 CANADA

Note: This declaration becomes invalid if technical or operational modifications
are introduced without the manufacturer's consent.

Date: 24 May 2024

Authorised party: Guangdong PHNIX ECO-Energy Solution LTD

For and on behalf of
GUANGDONG PHNIX ECO-ENERGY SOLUTION LTD.
广东芬尼克赛节能设备有限公司

Evan Chan

Authorized Signature(s)



DANAK

Test Reg. nr. 300

TEST REPORT

Report no.:
300-KLAB-24-014-1



DANISH
TECHNOLOGICAL
INSTITUTE

Teknologiparken
Kongsvang Allé 29
DK-8000 Aarhus C
+45 72 20 20 00
Info@teknologisk.dk
www.teknologisk.dk

Page 1 of 34
Init: RTHI/PRES/AAS
File no.: 265639
Enclosures: 2

Customer: Company: GUANGDONG PHNIX ECO-ENERGY SOLUTION LTD.
Address: No. 3 Tianyuan Road, Dagang Town, Nansha District,
City: Guangzhou, Guangdong, 511470, China
Tel.: +86 020-39067523

Component: Brand: Phinx
Type: Air to water heat pump
Model: PASRW060S-BP-PS-D
Series no.: 13130251
Prod. Year: FEB 2023
Outdoor unit: N/A

Dates: Component tested: March-May 2024

Brand name: Brand: Cooper&Hunter
Type: Air to water heat pump
Model: CH-HP22UIMPZM

Procedure: See objective (page 2) for list of standards.

Remarks: The unit was delivered by the customer. The installation and test settings were done according to the manufacturer's instructions. The report for the tested unit is named 300-KLAB-24-014 issued 2024.06.19 - Also see appendix 2.

Terms: This test was conducted under accreditation in accordance with international requirements (ISO/IEC 17025:2017) and in accordance with the General Terms and Conditions of Danish Technological Institute. The test results solely apply to the tested item. This test report may be quoted in extract only if Danish Technological Institute has granted its written consent.

The customer may not mention or refer to Danish Technological Institute or Danish Technological Institute's employees for advertising or marketing purposes unless Danish Technological Institute has granted its written consent in each case.

Division/Centre: Danish Technological Institute
Energy and Climate
Heat Pump Laboratory, Aarhus

Date: 2024.07.09

Signature:
Preben Eskerod
B.TecMan & MarEng

Co-reader:
Rasmus Thisgaard
B.TecMan & MarEng



DANAK
Test Reg. nr. 300



Objective

The objective of this report is to document the following:

The Seasonal Coefficient of Performance (SCOP) at low and medium temperature application for average climate according to EN 14825:2022.

In order to calculate the SCOP, tests were carried out at the part load conditions stated in the tables on page 4 and 5.

COP test standard rating conditions A7/W35 and A7/W55 according to EN 14511:2022.

Operating requirements according to EN 14511-4:2022

- 4.2.1 Starting and operating tests
- 4.5 Shutting off the heat transfer medium flows
- 4.6 Complete power supply failure

Sound power measurements according to EN 12102-1:2022.



Contents:

SCOP test conditions for low temperature – EN 14825	4
SCOP test conditions for medium temperature – EN 14825	5
COP test conditions - low temperature – EN 14511	6
COP test conditions - medium temperature – EN 14511.....	6
Test conditions for operating requirements – EN 14511-4	6
Test conditions for shutting off the heat transfer medium – EN 14511-4	7
Test conditions for complete power supply failure – EN 14511-4.....	7
Test conditions for sound power measurements – EN 12102-1	7
Test results of SCOP test at low temperature - heating season average – EN 14825.....	8
Test results of SCOP test at medium temperature - heating season average – EN 14825	9
COP test results - low temperature – EN 14511	10
COP test results - medium temperature – EN 14511.....	10
Test results for starting and operating test - EN 14511-4.....	10
Test results for shutting off the heat transfer medium – EN 14511-4	10
Test results for complete power supply failure – EN 14511-4.....	11
Test results of sound power measurements – EN 12102-1	11
Photos	12
SCOP - detailed calculation	13
Detailed SCOP calculation of low temperature and average climate conditions – EN 14825	13
Detailed SCOP calculation of medium temperature and average climate conditions – EN 14825	15
Detailed test results	17
Detailed SCOP part load test results - medium temperature application - average climate – EN 14825	22
Detailed COP test results - low temperature – EN 14511.....	27
Detailed COP test results - medium temperature – EN 14511	28
Detailed test results of sound power measurement – Test N#1.....	29
Appendix 1 Acoustic test chamber.....	30
Appendix 2 Brand name.....	34



Test conditions

SCOP test conditions for low temperature – EN 14825

Part load conditions for reference SCOP and reference SCOPon calculation of air to water units for low temperature application for the reference heating season;

"A" = average, "W" = warmer, and "C" = colder.

	Part load ratio in %				Outdoor heat exchanger		Indoor heat exchanger			
					Dry (wet) bulb temperature °C		Fixed outlet °C	Variable outlet ^d °C		
	Formula	Average	Warmer	Colder	Outdoor air	Exhaust air	All climates	Average	Warmer	Colder
A	$(-7 - 16) / (T_{designh} - 16)$	88,46	n.a.	60,53	-7(-8)	20(12)	^a / 35	^a / 34	n.a.	^a / 30
B	$(+2 - 16) / (T_{designh} - 16)$	53,85	100,00	36,84	2(1)	20(12)	^a / 35	^a / 30	^a / 35	^a / 27
C	$(+7 - 16) / (T_{designh} - 16)$	34,62	64,29	23,68	7(6)	20(12)	^a / 35	^a / 27	^a / 31	^a / 25
D	$(+12 - 16) / (T_{designh} - 16)$	15,38	28,57	10,53	12(11)	20(12)	^a / 35	^a / 24	^a / 26	^a / 24
E	$(TOL^e - 16) / (T_{designh} - 16)$				TOL ^e	20(12)	^a / 35	^a / b	^a / b	^a / b
F	$(T_{biv} - 16) / (T_{designh} - 16)$				T _{biv}	20(12)	^a / 35	^a / c	^a / c	^a / c
G	$(-15 - 16) / (T_{designh} - 16)$	n.a.	n.a.	81,58	-15	20(12)	^a / 35	n.a.	n.a.	^a / 32

Additional information

Climate	T _{designh} [°C]	T _{bivalent} [°C]	TOL [°C]	Outlet temperature	Flow rate
Average	-10	-7	-10	Variable	Fixed





SCOP test conditions for medium temperature – EN 14825

Part load conditions for reference SCOP and reference SCOPon calculation of air to water units for medium temperature application for the reference heating season;
"A" = average, "W" = warmer, and "C" = colder.

	Part load ratio in %				Outdoor heat exchanger		Indoor heat exchanger			
					Dry (wet) bulb temperature °C		Fixed outlet °C	Variable outlet ^d °C		
	Formula	Average	Warmer	Colder	Outdoor air	Exhaust air	All climates	Average	Warmer	Colder
A	$(-7 - 16) / (T_{designh} - 16)$	88,46	n.a.	60,53	-7(-8)	20(12)	^a / 55	^a / 52	n.a.	^a / 44
B	$(+2 - 16) / (T_{designh} - 16)$	53,85	100	36,84	2(1)	20(12)	^a / 55	^a / 42	^a / 55	^a / 37
C	$(+7 - 16) / (T_{designh} - 16)$	34,62	64,29	23,68	7(6)	20(12)	^a / 55	^a / 36	^a / 46	^a / 32
D	$(+12 - 16) / (T_{designh} - 16)$	15,38	28,57	10,53	12(11)	20(12)	^a / 55	^a / 30	^a / 34	^a / 28
E	$(TOL^e - 16) / (T_{designh} - 16)$				TOL^e	20(12)	^a / 55	^a / b	^a / b	^a / b
F	$(T_{biv} - 16) / (T_{designh} - 16)$				T_{biv}	20(12)	^a / 55	^a / c	^a / c	^a / c
G	$(-15 - 16) / (T_{designh} - 16)$	n.a.	n.a.	81,58	-15	20(12)	^a / 55	n.a.	n.a.	^a / 49

Additional information

Climate	$T_{designh}$ [°C]	$T_{bivalent}$ [°C]	TOL [°C]	Outlet temperature	Flow rate
Average	-10	-7	-10	Variable	Fixed





COP test conditions - low temperature – EN 14511

N [#]	Heat source		Heat sink		Heat pump settings
	Inlet dry bulb temperature (°C)	Inlet wet bulb temperature (°C)	Inlet temperature (°C)	Outlet temperature (°C)	
1 ^S	7	6	30	35	

S: Standard rating condition

COP test conditions - medium temperature – EN 14511

N [#]	Heat source		Heat sink		Heat pump settings
	Inlet dry bulb temperature (°C)	Inlet wet bulb temperature (°C)	Inlet temperature (°C)	Outlet temperature (°C)	
1 ^S	7	6	47	55	

S: Standard rating condition

Test conditions for operating requirements – EN 14511-4

N [#]	Heat source		Heat sink	Water flow rate at indoor heat exchanger	Test
	Inlet dry bulb temperature (°C)	Inlet wet bulb temperature (°C)	Inlet temperature (°C)		
1	-25	-	9	1500 L/h	Starting
2	-25	-	60	1500 L/h	Operating





Test conditions for shutting off the heat transfer medium – EN 14511-4

N [#]	Heat source		Heat sink		Heat exchanger
	Inlet dry bulb temperature (°C)	Inlet wet bulb temperature (°C)	Inlet temperature (°C)	Outlet temperature (°C)	
1	7	6	35	55	Indoor
2	7	6	35	55	Outdoor

Test conditions for complete power supply failure – EN 14511-4

N [#]	Heat source		Heat sink		
	Inlet dry bulb temperature (°C)	Inlet wet bulb temperature (°C)	Inlet temperature (°C)	Outlet temperature (°C)	
1	7	6	30	35	

Test conditions for sound power measurements – EN 12102-1

N [#]	Test condition		Heat pump setting			
	Outdoor heat exchanger (dry bulb/ wet bulb) (°C)	Indoor heat exchanger (inlet/ outlet) (°C)	Compressor speed (Hz)	Fan speed outdoor (rpm)	Heating capacity (kW)	Power input (kW)
1 ^E	7/6	47/55	30	485	6.31	2.41

E) ErP labelling





Test results of SCOP test at low temperature - heating season average - EN 14825

Model (Outdoor)	PASRW060S-BP-PS-D		
Air-to-water heat pump mono bloc		P _{rated}	Y
Low-temperature heat pump		η _s	N
Equipped with supplementary heater		SCOP	N
Heat pump combination heater			N

Rated heat output¹⁾	P _{rated}	12.55 [kW]
Seasonal space heating energy efficiency	η _s	197.5 [%]

Measured capacity for heating for part load at outdoor temperature T_j	Average Climate - Low temperature application	T _j =-15 °C	P _{dh}	- [kW]
		T _j =-7 °C	P _{dh}	11.31 [kW]
		T _j =2 °C	P _{dh}	7.27 [kW]
		T _j =7 °C	P _{dh}	5.27 [kW]
		T _j =12 °C	P _{dh}	6.19 [kW]
		T _j =bivalent temperature	P _{dh}	11.31 [kW]
		T _j =operation limit	P _{dh}	12.73 [kW]

Measured coefficient of performance at outdoor temperature T_j	Average Climate - Low temperature application	T _j =-15 °C	COP _d	- [-]
		T _j =-7 °C	COP _d	3.10 [-]
		T _j =2 °C	COP _d	4.87 [-]
		T _j =7 °C	COP _d	6.60 [-]
		T _j =12 °C	COP _d	9.26 [-]
		T _j =bivalent temperature	COP _d	3.10 [-]
		T _j =operation limit	COP _d	2.38 [-]

Bivalent temperature	Tbivalent	-7 [°C]
Operation limit temperatures	TOL	-10 [°C]
Degradation coefficient	WTOL	- [°C]
	Cdh	0.96 [-]

Power consumption in modes other than active mode	Off mode	P _{OFF}	0.012 [kW]
	Thermostat-off mode	P _{TO}	0.028 [kW]
	Standby mode	P _{SB}	0.012 [kW]
	Crankcase heater mode	P _{CK}	0.012 [kW]
Supplementary heater¹⁾	Rated heat output	P _{SUP}	0.00 [kW]
	Type of energy input		Electrical

Other items	Capacity control	Variable
	Water flow control	Fixed
	Water flow rate	2688 [l/h]
	Annual energy consumption	Q _{HE} 5172 [kWh]

¹⁾For heat pump space heaters and heat pump combination heaters, the rated heat output, P_{rated}, is equal to the design load for heating, P_{designh}, and the rated heat output of a supplementary heater, P_{sup}, is equal to the supplementary capacity for heating, sup(T_j).





Test results of SCOP test at medium temperature - heating season average – EN 14825

Model (Outdoor)	PASRW060S-BP-PS-D
Air-to-water heat pump mono bloc	Y
Low-temperature heat pump	N
Equipped with supplementary heater	N
Heat pump combination heater	N

Rated heat output ¹⁾	P_{rated}	12.34 [kW]
Seasonal space heating energy efficiency	η_s	142.6 [%]

Measured capacity for heating for part load at outdoor temperature T_j	Average Climate - Medium temperature application	$T_j=-15\text{ }^{\circ}\text{C}$	P_{dh}	- [kW]
		$T_j=-7\text{ }^{\circ}\text{C}$	P_{dh}	11.47 [kW]
		$T_j=2\text{ }^{\circ}\text{C}$	P_{dh}	6.57 [kW]
		$T_j=7\text{ }^{\circ}\text{C}$	P_{dh}	6.16 [kW]
		$T_j=12\text{ }^{\circ}\text{C}$	P_{dh}	7.33 [kW]
		$T_j=\text{bivalent temperature}$	P_{dh}	11.47 [kW]
		$T_j=\text{operation limit}$	P_{dh}	12.39 [kW]

Measured coefficient of performance at outdoor temperature T_j	Average Climate - Medium temperature application	$T_j=-15\text{ }^{\circ}\text{C}$	COP_d	- [-]
		$T_j=-7\text{ }^{\circ}\text{C}$	COP_d	2.32 [-]
		$T_j=2\text{ }^{\circ}\text{C}$	COP_d	3.46 [-]
		$T_j=7\text{ }^{\circ}\text{C}$	COP_d	4.82 [-]
		$T_j=12\text{ }^{\circ}\text{C}$	COP_d	6.73 [-]
		$T_j=\text{bivalent temperature}$	COP_d	2.32 [-]
		$T_j=\text{operation limit}$	COP_d	2.04 [-]

Bivalent temperature	Tbivalent	-7 [$^{\circ}\text{C}$]
Operation limit	TOL	-10 [$^{\circ}\text{C}$]
temperatures	WTOL	- [$^{\circ}\text{C}$]
Degradation coefficient	Cdh	0.97 [-]

Power consumption in modes other than active mode	Off mode	P_{OFF}	0.012 [kW]
	Thermostat-off mode	P_{TO}	0.028 [kW]
	Standby mode	P_{SB}	0.012 [kW]
	Crankcase heater mode	P_{CK}	0.012 [kW]
Supplementary heater ¹⁾	Rated heat output	P_{SUP}	0.00 [kW]
	Type of energy input		Electrical

Other items	Capacity control	Variable
	Water flow control	Fixed
	Water flow rate	1700 [l/h]
	Annual energy consumption	Q_{HE}

¹⁾For heat pump space heaters and heat pump combination heaters, the rated heat output, P_{rated} , is equal to the design load for heating, $P_{designh}$, and the rated heat output of a supplementary heater, P_{sup} , is equal to the supplementary capacity for heating, $sup(T_j)$.





COP test results - low temperature – EN 14511

N [#]	Test conditions	Heating capacity [kW]	COP
1	A7/W35	15.424	4.448

COP test results - medium temperature – EN 14511

N [#]	Test conditions	Heating capacity [kW]	COP
1	A7/W55	15.086	2.866

Test results for starting and operating test - EN 14511-4

N [#]	Test conditions air/water inlet [°C]	Test validation
Starting	A-25/W9	Passed
Operating	A-25/W60	Passed

Test results for shutting off the heat transfer medium – EN 14511-4

N [#]	Heat exchanger	Test validation
1	Indoor	Passed
2	Outdoor	Passed





Test results for complete power supply failure – EN 14511-4

N [#]	Test validation
1	Passed

Test results of sound power measurements – EN 12102-1

N [#]	Test conditions	Sound power level LW(A) [dB re 1pW]	Uncertainty σ_{tot} [dB]
1 ^E	A7/W55	57.6	1.6

E) ErP labelling

The A-weighted total sound power level is determined for the measured frequency range from 100 Hz to 10 kHz. For the calculation of uncertainty, see appendix 1.

The sound power measurements are carried out by Kamalathasan Arumugam (KAMA) and co-read by Patrick Glibert (PGL), Danish Technological Institute.



DANAK

Test Reg. nr. 300



Photos

Rating plate



Outdoor unit





SCOP - detailed calculation

Detailed SCOP calculation of low temperature and average climate conditions – EN 14825

Calculation of reference SCOP

$$SCOP = \frac{P_{designh} \times H_{he}}{P_{designh} \times H_{he} + H_{TO} \times P_{TO} + H_{SB} \times P_{SB} + H_{CK} \times P_{CK} + H_{OFF} \times P_{OFF}}$$

Where

P_{design} =

Heating load of the building at design temperature, kW

H_{he} =

Number of equivalent heating hours, 2066 h

H_{TO}, H_{SB}, H_{CK}, H_{OFF} =

Number of hours for which the unit is considered to work in thermostat off mode, standby mode, crankcase heater mode and off mode, h, respectively

P_{TO}, P_{SB}, P_{CK}, P_{OFF} =

Electricity consumption during thermostat off mode, standby mode, crankcase heater mode and off mode, kW, respectively

Data for SCOP

	Outdoor temperature [°C]	Part load ratio [%]	Part load [kW]	Declared capacity [kW]	Declared COP [-]	cdh [-]	CR [-]	COPbin [-]
A	-7	88	11.10	11.31	3.10	0.99	1.00	3.10
B	2	54	6.76	7.27	4.87	0.98	1.00	4.87
C	7	35	4.34	5.27	6.60	0.97	0.82	6.55
D	12	15	1.93	6.19	9.26	0.96	0.31	8.48
E	-10	100	12.55	12.73	2.38	0.99	1.00	2.38
F - BIV	-7	88	11.10	11.31	3.10	0.99	1.00	3.10

Energy consumption for thermostat off, standby, off mode, crankcase heater mode

	Hours [h]	Power input [kW]	Applied to SCOP calculation [kW]	Energy consumption [kWh]
Off mode	0	0.01216	0.01216	0
Thermostat off	178	0.02772	0.02772	4.93416
Standby	0	0.01216	0.01216	0
Crankcase heater	178	0.01209	0	0





Calculation Bin for SCOPon

	Bin [-]	Outdoor temperature [°C]	Hours [h]	Heat load [kW]	Heat load covered by heat pump [kW]	Electrical back up heater [kW]	Annual backup heater energy input [kWh]	COPbin [-]	Annual heating demand [kWh]	Annual energy input [kWh]	Net annual heating capacity [kWh]	Net annual power input [kWh]
E	21	-10	1	12.55	12.55	0.00	0.00	2.38	12.55	5.26	12.55	5.26
	22	-9	25	12.07	12.07	0.00	0.00	2.62	301.68	115.06	301.68	115.06
	23	-8	23	11.58	11.58	0.00	0.00	2.86	266.45	93.16	266.45	93.16
A / F - BIV	24	-7	24	11.10	11.10	0.00	0.00	3.10	266.45	86.01	266.45	86.01
	25	-6	27	10.62	10.62	0.00	0.00	3.29	286.72	87.03	286.72	87.03
	26	-5	68	10.14	10.14	0.00	0.00	3.49	689.28	197.46	689.28	197.46
	27	-4	91	9.65	9.65	0.00	0.00	3.69	878.50	238.26	878.50	238.26
	28	-3	89	9.17	9.17	0.00	0.00	3.88	816.23	210.17	816.23	210.17
	29	-2	165	8.69	8.69	0.00	0.00	4.08	1433.60	351.37	1433.60	351.37
	30	-1	173	8.21	8.21	0.00	0.00	4.28	1419.60	331.96	1419.60	331.96
	31	0	240	7.72	7.72	0.00	0.00	4.47	1853.54	414.40	1853.54	414.40
	32	1	280	7.24	7.24	0.00	0.00	4.67	2027.31	434.18	2027.31	434.18
	B	33	2	320	6.76	6.76	0.00	0.00	4.87	2162.46	444.43	2162.46
B	34	3	357	6.28	6.28	0.00	0.00	5.20	2240.18	430.58	2240.18	430.58
	35	4	356	5.79	5.79	0.00	0.00	5.54	2062.06	372.23	2062.06	372.23
	36	5	303	5.31	5.31	0.00	0.00	5.88	1608.81	273.76	1608.81	273.76
	37	6	330	4.83	4.83	0.00	0.00	6.21	1592.88	256.35	1592.88	256.35
C	38	7	326	4.34	4.34	0.00	0.00	6.55	1416.22	216.19	1416.22	216.19
	39	8	348	3.86	3.86	0.00	0.00	6.94	1343.82	193.73	1343.82	193.73
	40	9	335	3.38	3.38	0.00	0.00	7.32	1131.91	154.58	1131.91	154.58
	41	10	315	2.90	2.90	0.00	0.00	7.71	912.29	118.35	912.29	118.35
D	42	11	215	2.41	2.41	0.00	0.00	8.09	518.89	64.11	518.89	64.11
	43	12	169	1.93	1.93	0.00	0.00	8.48	326.30	38.48	326.30	38.48
	44	13	151	1.45	1.45	0.00	0.00	8.87	218.66	24.66	218.66	24.66
	45	14	105	0.97	0.97	0.00	0.00	9.25	101.37	10.96	101.37	10.96
	46	15	74	0.48	0.48	0.00	0.00	9.64	35.72	3.71	35.72	3.71

SUM 25923.47 5166.44 25923.47 5166.44

SCOPon 5.02 SCOPnet 5.02



Detailed SCOP calculation of medium temperature and average climate conditions – EN 14825

Calculation of reference SCOP

$$SCOP = \frac{P_{designh} \times H_{he}}{P_{designh} \times H_{he} + H_{TO} \times P_{TO} + H_{SB} \times P_{SB} + H_{CK} \times P_{CK} + H_{OFF} \times P_{OFF}}$$

Where

P_{design} =

Heating load of the building at design temperature, kW

H_{he} =

Number of equivalent heating hours, 2066 h

$H_{TO}, H_{SB}, H_{CK}, H_{OFF}$ =

Number of hours for which the unit is considered to work in thermostat off mode, standby mode, crankcase heater mode and off mode, h, respectively

$P_{TO}, P_{SB}, P_{CK}, P_{OFF}$ =

Electricity consumption during thermostat off mode, standby mode, crankcase heater mode and off mode, kW, respectively

Data for SCOP

	Outdoor temperature [°C]	Part load ratio [%]	Part load [kW]	Declared capacity [kW]	Declared COP [-]	cdh [-]	CR [-]	COPbin [-]
A	-7	88	10.92	11.47	2.32	0.99	1.00	2.32
B	2	54	6.64	6.57	3.46	0.99	1.00	3.46
C	7	35	4.27	6.16	4.82	0.98	0.69	4.78
D	12	15	1.90	7.33	6.73	0.97	0.26	6.27
E	-10	100	12.34	12.39	2.04	1.00	1.00	2.04
F - BIV	-7	88	10.92	11.47	2.32	0.99	1.00	2.32

Energy consumption for thermostat off, standby, off mode, crankcase heater mode

	Hours [h]	Power input [kW]	Applied to SCOP calculation [kW]	Energy consumption [kWh]
Off mode	0	0.01216	0.01216	0
Thermostat off	178	0.02772	0.02772	4.93416
Standby	0	0.01216	0.01216	0
Crankcase heater	178	0.01209	0	0





Calculation Bin for SCOPon

	Bin [-]	Outdoor temperature [°C]	Hours [h]	Heat load [kW]	Heat load covered by heat pump [kW]	Electrical back up heater [kW]	Annual backup heater energy input [kWh]	COPbin [-]	Annual heating demand [kWh]	Annual energy input [kWh]	Net annual heating capacity [kWh]	Net annual power input [kWh]
E	21	-10	1	12.34	12.34	0.00	0.00	2.04	12.34	6.05	12.34	6.05
	22	-9	25	11.87	11.87	0.00	0.00	2.13	296.63	139.08	296.63	139.08
	23	-8	23	11.39	11.39	0.00	0.00	2.23	261.99	117.69	261.99	117.69
A / F - BIV	24	-7	24	10.92	10.92	0.00	0.00	2.32	261.99	112.96	261.99	112.96
	25	-6	27	10.44	10.43	0.00	0.00	2.45	281.92	115.28	281.92	115.28
	26	-5	68	9.97	9.95	0.00	0.00	2.57	677.75	263.53	677.75	263.53
	27	-4	91	9.49	9.47	0.00	0.00	2.70	863.80	320.15	863.80	320.15
	28	-3	89	9.02	8.99	0.00	0.00	2.82	802.57	284.16	802.57	284.16
	29	-2	165	8.54	8.50	0.00	0.00	2.95	1409.61	477.73	1409.61	477.73
	30	-1	173	8.07	8.02	0.00	0.00	3.08	1395.84	453.65	1395.84	453.65
	31	0	240	7.59	7.54	0.00	0.00	3.20	1822.52	568.97	1822.52	568.97
	32	1	280	7.12	7.05	0.00	0.00	3.33	1993.38	598.71	1993.38	598.71
B	33	2	320	6.64	6.57	0.00	0.00	3.46	2126.28	615.29	2126.28	615.29
	34	3	357	6.17	6.11	0.00	0.00	3.72	2202.69	592.17	2202.69	592.17
	35	4	356	5.70	5.65	0.00	0.00	3.98	2027.56	508.98	2027.56	508.98
	36	5	303	5.22	5.19	0.00	0.00	4.25	1581.89	372.43	1581.89	372.43
	37	6	330	4.75	4.73	0.00	0.00	4.51	1566.23	347.17	1566.23	347.17
C	38	7	326	4.27	4.27	0.00	0.00	4.78	1392.52	291.60	1392.52	291.60
	39	8	348	3.80	3.80	0.00	0.00	5.07	1321.33	260.37	1321.33	260.37
	40	9	335	3.32	3.32	0.00	0.00	5.37	1112.97	207.09	1112.97	207.09
	41	10	315	2.85	2.85	0.00	0.00	5.67	897.02	158.10	897.02	158.10
	42	11	215	2.37	2.37	0.00	0.00	5.97	510.21	85.42	510.21	85.42
D	43	12	169	1.90	1.90	0.00	0.00	6.27	320.84	51.15	320.84	51.15
	44	13	151	1.42	1.42	0.00	0.00	6.57	215.00	32.72	215.00	32.72
	45	14	105	0.95	0.95	0.00	0.00	6.87	99.67	14.51	99.67	14.51
	46	15	74	0.47	0.47	0.00	0.00	7.17	35.12	4.90	35.12	4.90

SUM	25489.69	6999.84	25489.69	6999.84
SCOPon	3.64	SCOPnet	3.64	



Detailed test results

Detailed SCOP part load test results - low temperature application

- average climate – EN 14825

Detailed result for 'EN14825:2022' Average Low (A and F) A -7/W34			
Tested according to:		EN14511:2022 and EN14825:2022	
Climate zone:		Average	
Temperature application:		Low	
Condition name:		A and F	
Condition temperature:	°C	-7	
Part load:	%	88%	
Chosen Tbivalent	°C	-7	
Tdesign	°C	-10	
Pdesign	kW	12.55	
Heating demand:	kW	11.10	
CR:	-	1.0	
Minimum flow reached:	-	Yes	
Measurement type:		Steady State	
Integrated liquid pump:		Yes	
Integrated liquid pump able to generate a positive ext. static pressure difference:		Yes	
Included corrections (Final result)			
Heating capacity	kW	11.307	
COP	-	3.098	
Power consumption	kW	3.650	
Measured			
Heating capacity	kW	11.407	
COP	-	2.992	
Power consumption	kW	3.812	
During heating			
Air_inlet temperature dry bulb	°C	-6.97	
Air temperature wet bulb	°C	-8.18	
Water_inlet temperature	°C	30.49	
water_outlet temperature	°C	34.17	
Water_outlet temperature (Time averaged)	°C	34.17	
Circulation pump			
Measured external static pressure difference, liquid pump	Pa	84131	
Calculated Hydraulic power	W	63	
Calculated global efficiency	n	0.39	
Calculated Capacity correction	W	99	
Calculated Power correction	W	162	
Water Flow	m³/s	0.000747	





Detailed result for 'EN14825:2022' Average Low (B) A 2 /W30

Tested according to:	EN14511:2022 and EN14825:2022	
Climate zone:	Average	
Temperature application:	Low	
Condition name:	B	
Condition temperature:	°C 2	
Part load:	% 54%	
Chosen Tbivalent	°C -7	
Tdesign	°C -10	
Pdesign	kW 12.55	
Heating demand:	kW 6.76	
CR:	- 1.0	
Minimum flow reached:	- No	
Measurement type:	Steady State	
Integrated circulation pump:	Yes	
Included corrections (Final result)		
Heating capacity	kW 7.273	
COP	- 4.866	
Power consumption	kW 1.495	
Measured		
Heating capacity	kW 7.371	
COP	- 4.456	
Power consumption	kW 1.654	
During heating		
Air temperature dry bulb	°C 2.12	
Air temperature wet bulb	°C 0.93	
Inlet temperature	°C 27.79	
Outlet temperature	°C 30.16	
Outlet temperature (Time averaged)	°C 30.16	
Circulation pump		
Measured: Static differential pressure, liquid pump	Pa 82473	
Calculated Hydraulic power	W 62	
Calculated global efficiency	η 0.39	
Calculated Capacity correction	W 98	
Calculated Power correction	W 160	
Water Flow	m³/s 0.000747	





Detailed result for 'EN14825:2022' Average Low (C) A 7 /W27			
Tested according to:	EN14511:2022 and EN14825:2022	Average	
Climate zone:		Low	
Temperature application:		C	
Condition name:			
Condition temperature:	°C	7	
Part load:	%	35%	
Chosen Tbivalent	°C	-7	
Tdesign	°C	-10	
Pdesign	kW	12.55	
Heating demand:	kW	4.34	
CR:	-	0.8	
Minimum flow reached:	-	No	
Measurement type:		Steady State	
Integrated circulation pump:		Yes	
Included corrections (Final result)			
Heating capacity	kW	5.269	
COP	-	6.599	
Power consumption	kW	0.798	
Measured			
Heating capacity	kW	5.367	
COP	-	5.603	
Power consumption	kW	0.958	
During heating			
Air temperature dry bulb	°C	6.99	
Air temperature wet bulb	°C	6.01	
Inlet temperature	°C	25.60	
Outlet temperature	°C	27.33	
Outlet temperature (Time averaged)	°C	27.03	
Circulation pump			
Measured: Static differential pressure, liquid pump	Pa	82451	
Calculated Hydraulic power	W	62	
Calculated global efficiency	η	0.39	
Calculated Capacity correction	W	98	
Calculated Power correction	W	160	
Water Flow	m³/s	0.000747	





Detailed result for 'EN14825:2022' Average Low (D) A 12 /W24			
Tested according to:	EN14511:2022 and EN14825:2022		Average
Climate zone:			Low
Temperature application:			D
Condition name:			
Condition temperature:	°C	12	
Part load:	%	15%	
Chosen Tbivalent	°C	-7	
Tdesign	°C	-10	
Pdesign	kW	12.55	
Heating demand:	kW	1.93	
CR:	-	0.3	
Minimum flow reached:	-	No	
Measurement type:			Steady State
Integrated circulation pump:			Yes
Included corrections (Final result)			
Heating capacity	kW	6.194	
COP	-	9.255	
Power consumption	kW	0.669	
Measured			
Heating capacity	kW	6.291	
COP	-	7.599	
Power consumption	kW	0.828	
During heating			
Air temperature dry bulb	°C	12.00	
Air temperature wet bulb	°C	11.01	
Inlet temperature	°C	23.37	
Outlet temperature	°C	25.39	
Outlet temperature (Time averaged)	°C	24.00	
Circulation pump			
Measured: Static differential pressure, liquid pump	Pa	81950	
Calculated Hydraulic power	W	61	
Calculated global efficiency	η	0.39	
Calculated Capacity correction	W	98	
Calculated Power correction	W	159	
Water Flow	m³/s	0.000747	





Detailed result for 'EN14825:2022' Average Low (E) A -10 /W35

Tested according to:	EN14511:2022 and EN14825:2022		
Climate zone:	Average		
Temperature application:	Low		
Condition name:	E		
Condition temperature:	°C	-10	
Part load:	%	100%	
Chosen Tbivalent	°C	-7	
Tdesign	°C	-10	
Pdesign	kW	12.55	
Heating demand:	kW	12.55	
CR:	-	1.0	
Minimum flow reached:	-	Yes	
Measurement type:	Transient		
Integrated liquid pump:	Yes		
Integrated liquid pump able to generate a positive ext. static pressure difference:	Yes		
Included corrections (Final result)			
Heating capacity	kW	12.728	
COP	-	2.384	
Power consumption	kW	5.339	
Measured			
Heating capacity	kW	12.828	
COP	-	2.331	
Power consumption	kW	5.503	
During heating			
Air_inlet temperature dry bulb	°C	-10.09	
Air temperature wet bulb	°C	-11.03	
Water_inlet temperature	°C	30.57	
water_outlet temperature	°C	35.12	
Water_outlet temperature (Time averaged)	°C	35.12	
Circulation pump			
Measured external static pressure difference, liquid pump	Pa	84578	
Calculated Hydraulic power	W	63	
Calculated global efficiency	η	0.39	
Calculated Capacity correction	W	100	
Calculated Power correction	W	163	
Water Flow	m³/s	0.000747	





Detailed SCOP part load test results - medium temperature application - average climate – EN 14825

Detailed result for 'EN14825:2022' Average Medium (A and F) A -7/W52					
Tested according to:	EN14511:2022 and EN14825:2022				
Climate zone:	Average				
Temperature application:	Medium				
Condition name:	A and F				
Condition temperature:	°C	-7			
Part load:	%	88%			
Chosen Tbivalent	°C	-7			
Tdesign	°C	-10			
Pdesign	kW	12.34			
Heating demand:	kW	10.92			
CR:	-	1.0			
Minimum flow reached:	-	No			
Measurement type:	Steady State				
Integrated circulation pump:	Yes				
Included corrections (Final result)					
Heating capacity	kW	11.466			
COP	-	2.319			
Power consumption	kW	4.944			
Measured					
Heating capacity	kW	11.555			
COP	-	2.272			
Power consumption	kW	5.086			
During heating					
Air temperature dry bulb	°C	-6.91			
Air temperature wet bulb	°C	-8.15			
Inlet temperature	°C	46.11			
Outlet temperature	°C	52.04			
Outlet temperature (Time averaged)	°C	52.04			
Circulation pump					
Measured: Static differential pressure, liquid pump	Pa	114296			
Calculated Hydraulic power	W	54			
Calculated global efficiency	η	0.38			
Calculated Capacity correction	W	89			
Calculated Power correction	W	143			
Water Flow	m³/s	0.000472			



Detailed result for 'EN14825:2022' Average Medium (B) A 2 /W42

Tested according to:	EN14511:2022 and EN14825:2022	
Climate zone:	Average	
Temperature application:	Medium	
Condition name:	B	
Condition temperature:	°C	2
Part load:	%	54%
Chosen Tbivalent	°C	-7
Tdesign	°C	-10
Pdesign	kW	12.34
Heating demand:	kW	6.64
CR:	-	1.0
Minimum flow reached:	-	No
Measurement type:	Steady State	
Integrated circulation pump:	Yes	
Included corrections (Final result)		
Heating capacity	kW	6.572
COP	-	3.456
Power consumption	kW	1.902
Measured		
Heating capacity	kW	6.660
COP	-	3.258
Power consumption	kW	2.044
During heating		
Air temperature dry bulb	°C	2.13
Air temperature wet bulb	°C	0.94
Inlet temperature	°C	38.60
Outlet temperature	°C	42.01
Outlet temperature (Time averaged)	°C	42.01
Circulation pump		
Measured: Static differential pressure, liquid pump	Pa	114476
Calculated Hydraulic power	W	54
Calculated global efficiency	η	0.38
Calculated Capacity correction	W	89
Calculated Power correction	W	143
Water Flow	m³/s	0.000472





Detailed result for 'EN14825:2022' Average Medium (C) A 7 /W36

Tested according to:	EN14511:2022 and EN14825:2022	Average		
Climate zone:		Medium		
Temperature application:		C		
Condition name:		Condition temperature:	°C	7
Part load:	%	35%		
Chosen Tbivalent	°C	-7		
Tdesign	°C	-10		
Pdesign	kW	12.34		
Heating demand:	kW	4.27		
CR:	-	0.7		
Minimum flow reached:	-	No		
Measurement type:		Steady State		
Integrated circulation pump:		Yes		
Included corrections (Final result)				
Heating capacity	kW	6.158		
COP	-	4.821		
Power consumption	kW	1.277		
Measured				
Heating capacity	kW	6.246		
COP	-	4.399		
Power consumption	kW	1.420		
During heating				
Air temperature dry bulb	°C	7.00		
Air temperature wet bulb	°C	6.00		
Inlet temperature	°C	33.79		
Outlet temperature	°C	36.98		
Outlet temperature (Time averaged)	°C	36.00		
Circulation pump				
Measured: Static differential pressure, liquid pump	Pa	114472		
Calculated Hydraulic power	W	54		
Calculated global efficiency	η	0.38		
Calculated Capacity correction	W	89		
Calculated Power correction	W	143		
Water Flow	m³/s	0.000472		





Detailed result for 'EN14825:2022' Average Medium (D) A 12 /W30

Tested according to:	EN14511:2022 and EN14825:2022	
Climate zone:	Average	
Temperature application:	Medium	
Condition name:	D	
Condition temperature:	°C	12
Part load:	%	15%
Chosen Tbivalent	°C	-7
Tdesign	°C	-10
Pdesign	kW	12.34
Heating demand:	kW	1.90
CR:	-	0.3
Minimum flow reached:	-	No
Measurement type:	Steady State	
Integrated circulation pump:	Yes	
Included corrections (Final result)		
Heating capacity	kW	7.334
COP	-	6.729
Power consumption	kW	1.090
Measured		
Heating capacity	kW	7.422
COP	-	6.021
Power consumption	kW	1.233
During heating		
Air temperature dry bulb	°C	12.01
Air temperature wet bulb	°C	10.99
Inlet temperature	°C	28.96
Outlet temperature	°C	32.74
Outlet temperature (Time averaged)	°C	29.94
Circulation pump		
Measured: Static differential pressure, liquid pump	Pa	114519
Calculated Hydraulic power	W	54
Calculated global efficiency	η	0.38
Calculated Capacity correction	W	89
Calculated Power correction	W	143
Water Flow	m³/s	0.000472





Detailed result for 'EN14825:2022' Average Medium (E) A -10/W55

Tested according to:	EN14511:2022 and EN14825:2022	Average
Climate zone:		Medium
Temperature application:		E
Condition name:		
Condition temperature:	°C	-10
Part load:	%	100%
Chosen Tbivalent	°C	-7
Tdesign	°C	-10
Pdesign	kW	12.34
Heating demand:	kW	12.34
CR:	-	1.0
Minimum flow reached:	-	No
Measurement type:		Steady State
Integrated circulation pump:		Yes
Included corrections (Final result)		
Heating capacity	kW	12.391
COP	-	2.040
Power consumption	kW	6.075
Measured		
Heating capacity	kW	12.479
COP	-	2.007
Power consumption	kW	6.218
During heating		
Air temperature dry bulb	°C	-10.00
Air temperature wet bulb	°C	-11.02
Inlet temperature	°C	48.62
Outlet temperature	°C	55.03
Outlet temperature (Time averaged)	°C	55.03
Circulation pump		
Measured: Static differential pressure, liquid pump	Pa	114239
Calculated Hydraulic power	W	54
Calculated global efficiency	η	0.38
Calculated Capacity correction	W	89
Calculated Power correction	W	143
Water Flow	m³/s	0.000472





Detailed COP test results - low temperature – EN 14511

Detailed result for 'EN14511:2022' A7/W35		
Tested according to:		EN14511:2022
Minimum flow reached:		No
Measurement type:		Steady State
Integrated circulation pump:		Yes
Included corrections (Final result)		
Heating capacity	kW	15.424
COP	-	4.448
Power consumption	kW	3.468
Measured		
Heating capacity	kW	15.523
COP	-	4.277
Power consumption	kW	3.630
During heating		
Air temperature dry bulb	°C	6.91
Air temperature wet bulb	°C	6.03
Inlet temperature	°C	30.01
Outlet temperature	°C	35.01
Circulation pump		
Measured: Static differential pressure, liquid pump	Pa	83915
Calculated Hydraulic power	W	63
Calculated global efficiency	η	0.39
Calculated Capacity correction	W	99
Calculated Power correction	W	162
Water Flow	m³/s	0.000747





Detailed COP test results - medium temperature – EN 14511

Detailed result for 'EN14511:2022' A7/W55			
Tested according to:		EN14511:2022	
Minimum flow reached:		No	
Measurement type:		Steady State	
Integrated circulation pump:		Yes	
Included corrections (Final result)			
Heating capacity	kW	15.086	
COP	-	2.866	
Power consumption	kW	5.264	
Measured			
Heating capacity	kW	15.175	
COP	-	2.807	
Power consumption	kW	5.406	
During heating			
Air temperature dry bulb	°C	7.00	
Air temperature wet bulb	°C	6.03	
Inlet temperature	°C	46.99	
Outlet temperature	°C	54.79	
Circulation pump			
Measured: Static differential pressure, liquid pump	Pa	114336	
Calculated Hydraulic power	W	54	
Calculated global efficiency	η	0.38	
Calculated Capacity correction	W	89	
Calculated Power correction	W	143	
Water Flow	m³/s	0.000472	





Detailed test results of sound power measurement – Test N#1



DANAK
TEST Reg. nr. 300

Sound power levels according to
ISO 3743-1:2010

**TEKNOLOGISK
INSTITUT**


Engineering method for small, movable sources in reverberant fields - Comparison method for hard-walled test rooms

Client: GUANGDONG PHNIX ECO-ENERGY SOLUTION LTD. Date of test: 26-04-2024
 Object: Type: Mono air to water heat pump, Model: PASRW060S-BP-PS-D
 Mounting conditions: The outdoor unit is mounted on the supporting metal support frame using four pieces of spring mounts vibration isolators and placed on four pieces of concrete tiles (20x20x2.5 cm). All of these are placed in a water drop dry on two pieces of heavy concrete tiles (90x90x10cm) laying on a vibration damping mat on the floor. The noise radiated by the outdoor unit has been measured in Test room 2.

Operating conditions: A7/W55, Compressor speed: 30[Hz], Fan speed: 485[rpm], Heating capacity: 6.31 [kW], Power_input: 2.41 [kW], Water flow rate: 1700 [l/h] and dP_water: 1139 [mbar]

Static pressure:	1014 hPa	Reference box:
Air temperature:	7.0 °C	L1: 1.2 m
Relative air humidity:	84.0 %	L2: 0.5 m
Test room volume:	102.8 m ³	L3: 1.3 m
Area, S, of test room:	138.9 m ²	Volume: 0.8 m ³

Frequency f [Hz]	L _w 1/3 octave [dB]	L _w 1/1 oct [dB]
100	64.4	
125	59.1	65.9
160	54.5	
200	54.6	
250	54.2	58.9
315	53.4	
400	51.7	
500	51.1	55.8
630	50.0	
800	49.0	
1000	47.2	52.3
1250	46.0	
1600	44.2	
2000	39.4	45.9
2500	36.3	
3150	33.1	
4000	31.0	35.9
5000	27.6	
6300	28.2	
8000	25.8	31.2
10000	24.4	



² Correction

Sound power level L_w(A): 57.6 dB [re 1pW] Uncertainty σ_{tot} : 1.6 dB

Name of test institute: DTI Date: 26-04-2024

No. of test report: 300-KLAB-24-014

Measurements are in full conformity with ISO 3743-1



DANAK
Test Reg. nr. 300



Appendix 1 Acoustic test chamber Unit specification

Type of unit: Mono air to water heat pump

Manufacturer: Phnix

Size of the heat pump: 0.5 x 1.2 x 1.3m (W x L x H)

Year of production: February 2023

Operating conditions and environment

The operating conditions of the unit under test fulfill the requirements for Class A.

The acoustic test chamber is a hard wall reverberant room (103 m³) and equipped with relevant sound diffusing reflector panels. The acoustical test chamber fulfills the requirements of ISO3743-1 accuracy grade 2 (engineering grade).

The measurements of the average sound pressure levels in 1/3 octave frequency bands are carried out using three microphones in the test chamber. During the measurements, the microphones are traversed up and down for one meter in the arc of a quarter circle.

The picture below shows the installation of the unit during test, position of microphones, sound diffusing reflector panels, and the reference sound source.



Measurement instruments



Id nr.	Manufacturer	Description	Calibration company
100864	GRAS	Gras 40AE_26CA, ½" free field microphone, Room 1	Norsonic A/S, Norway
100865	GRAS	Gras 40AE_26CA, ½" free field microphone, Room 1	Norsonic A/S, Norway
100866	GRAS	Gras 40AE_26CA, ½" free field microphone, Room 1	Norsonic A/S, Norway
100867*	GRAS	Gras 40AE_26CA, ½" free field microphone, Room 2	Norsonic A/S, Norway
100868*	GRAS	Gras 40AE_26CA, ½" free field microphone, Room 2	Norsonic A/S, Norway
100869*	GRAS	Gras 40AE_26CA, ½" free field microphone, Room 2	Norsonic A/S, Norway
100870	GRAS	Gras 40AE_26CA, ½" free field microphone, Roof monitor	Norsonic A/S, Norway
100873*	Brüel & Kjær	Acoustical calibrator, Brüel & Kjær 4231	Element Metech, Denmark
100859	Norsonic	Reference sound source, Norsonic Nor278 Room 1	RISE, Sweden
100872*	Norsonic	Reference sound source, Norsonic Nor278 Room 2	RISE, Sweden
100620*	Norsonic	Multi-channel measurement system Nor850	Norsonic A/S, Norway

*Instruments are used for the actual measurements for the calculation of the test results.

The other instruments are used for control measurements.

All microphones are equipped with windshields.



Test Procedure

The measurements of the emitted sound power level from the heat pump are carried out according to the following standard:

- DS/EN 14511:2022
- EN 12102-1:2022
- ISO/EN 3743-1:2010

The basic acoustic measurement standard DS/EN 3743-1 is a comparison method using a calibrated reference sound source. Two series of sound pressure measurements are made under exactly the same acoustic conditions, e.g., the same microphone positions, temperature and air humidity. The calibrated sound power levels are known for the reference sound source at each frequency band, and they are used in the estimation of the acoustical correction factor for the calculation of the sound power emitted from the unit under test. The background noise levels are measured and used for relevant corrections.

The final total A-weighted sound power level is based on measurements and calculations in 1/3-octave levels, which then are summed into 1/1-octave levels. The A-weighted total sound power level is determined for the measured frequency range from 100 Hz to 10 kHz.

The actual microphone positions and correction values are saved in data files linked to the complete project documentation according to the DANAK-accreditation.

The complete measurement system is documented and regularly calibrated according to DANAK.

The detailed description of the measurement method is given in Danish in the quality database system "QA Web" at Danish Technological Institute, which is accessible by DANAK.

Measurement uncertainty

The uncertainty of sound power level in decibel is determined in accordance with ISO 3743-1, equation 22 $\sigma_{tot} = \sqrt{\sigma_{RO}^2 + \sigma_{omc}^2}$ where:

- σ_{RO} is the standard deviation of the reproducibility of the method
- σ_{omc} is the standard deviation describing the uncertainty associated with the instability of the operating and mounting conditions for the particular noise source during test.

σ_{RO} expresses the uncertainty in test results delivered by the different accredited test laboratories due to different instrumentation and implementation of measurement procedure as well different radiation characteristics of the noise source during test.

σ_{omc} expresses the uncertainty associated with the instability of the operating and mounting conditions for the particular noise source during test. The mounting and installation conditions in two DTI acoustical test chambers are well defined in the test procedure. The possible instability of the operating conditions is monitored and assessed prior to each noise test.



The test uncertainty σ_{omc} is calculated according to ISO3743-1 Annex C formula C.1 and is typically below 1.0dB. However, the uncertainty is rounded up to the nearest 0.5 or 1.0dB increment in the report. As pr. Table C.1 (accuracy grade 2), the uncertainty σ_{RO} is set to 1.5.

The expanded uncertainty U is calculated according to ISO 3743-1 equation 23:
 $U = k \sigma_{\text{tot}}$ where $k = 2$ for 95% confidence.

EXAMPLE: $\sigma_{\text{tot}}: \sqrt{1.5^2 + 0.5^2} = 1.6 \text{ dB}$ and $U(95\%) = 3.2 \text{ dB}$

Note: The expanded uncertainty does not include the standard deviation of production which is used in ISO4871 for the purpose of making noise declaration for batches of machines.



DANISH
TECHNOLOGICAL
INSTITUTE

Page 34 of 34
300-KLAB-24-014-1

Appendix 2 Brand name

Authorization Letter

This declaration of conformity is issued under the sole responsibility of

Manufacturer's Name: Guangdong PHNIX ECO-Energy Solution LTD

Manufacturer's Address: No. 3 Tianyuan Road, Dagang Town, Nansha District
Guangzhou Guangdong, 511470 China

We declare that the following Heat pump product we produced for COOPER AND HUNTER OVERSEAS LP are identical to our following models

Cooper&Hunter model	CH-HP22UIMPZM
PHNIX model	PASRW060S-BP-PS-D

Cooper&Hunter company name: COOPER AND HUNTER OVERSEAS LP

Cooper&Hunter brand /-mark: Cooper&Hunter

Cooper&Hunter address: SUITE 201, 45B WEST WILMOT STREET,
RICHMOND HILL, ON L4B2P3 CANADA

Note: This declaration becomes invalid if technical or operational modifications
are introduced without the manufacturer's consent.

Date: 24 May 2024

Authorised party: Guangdong PHNIX ECO-Energy Solution LTD

For and on behalf of
GUANGDONG PHNIX ECO-ENERGY SOLUTION LTD.
广东芬尼克斯节能设备有限公司

Evan Chan
Authorized Signature(s)



DANAK

Test Reg. nr. 300