

TEST REPORT

Report no.:
300-KLAB-20-003



**DANISH
TECHNOLOGICAL
INSTITUTE**

Teknologiparken
Kongsvang Allé 29
DK-8000 Aarhus C
+45 72 20 20 00
Info@teknologisk.dk
www.teknologisk.dk

Page 1 of 12
Init: KAMA/BBJN
File no.: 906730
Enclosures: 1

Customer: Company: Panasonic DE GmbH
Address: Hagenauer Strasse 43
City: 65203 Wiesbaden
Tel.: +49 1724 141441

Component: Brand: Panasonic
Type: Air to water heat pump
Model: Outdoor: WH-UD03JE5 Indoor: WH-ADC0309J3E5
Series no.: Outdoor: 5621201008 Indoor: 5704001319
Production year: Outdoor:2019.04 Indoor: 2019.05

Dates: Component tested: February 2020

Procedure: See objective (page 2) for list of standards

Remarks: The unit was delivered by the customer. The installation and test settings were done according to the manufacturer's instructions.

Terms: The test has been performed according to the conditions laid down by DANAK (The Danish Accreditation), cf. www.danak.dk, and the general terms and conditions of Danish Technological Institute. The results from DTI's work in this report, i.e. analyses, assessments and instructions may only be used or reported in their entirety. The customer may not mention or refer to DTI or DTI's employees for advertising or marketing purposes unless DTI has granted its written consent in each case.

Division/Centre: Danish Technological Institute
Energy and Climate
Heat Pump Laboratory, Aarhus

Date: 2020.03.17

Signature:
Kamalathan Arumugam
B.Sc. Engineer

Co-reader:
Birger Bech Jessen
Senior specialist



 **DANAK**
Test Reg. nr. 300



Objective

The objective of this report is to document the acoustical performance of the outdoor unit with different heat pump settings and setups.

The tests were carried out in the following order (test 1-6):

Sound power measurement without any modification of the outdoor unit.

1. With free mode at A7/W55
2. With free mode and quiet mode 3 at A7/W55

Sound power measurement with a noise reduction box mounted around the outdoor unit.

3. With free mode at A7/W55
4. With free mode and quiet mode 3 at A7/W55

Sound power measurement with a soundproof kit mounted in the outdoor unit (in order to mount the soundproof kit, both the noise reduction box and the enclosure materials of the compressor from the factory must be removed).

5. With free mode at A7/W55
6. With free mode and quiet mode 3 at A7/W55

The sound power level of the outdoor unit according to EN 12102:2017 for average climate at the highest temperature application. The measurement of the sound power level is performed using the Class A method. ISO 3743-1 is the basic method of carrying out sound power measurements. The method is briefly described in appendix 1. For a more detailed description, please view the accreditation papers DANAK-300 (in Danish only).





Test order and conditions of sound power test according to EN12102

N°	Test condition		Heat pump setting			
	Outdoor heat exchanger (dry/wet bulb) (°C)	Indoor heat exchanger (inlet/outlet) (°C)	Compressor speed (Hz)	Fan speed Outdoor (rpm)	Heating capacity (kW)	Power input (kW)
1	7/6	48.7/55	45 - 46	730 - 7400	3.20	1.1
2	7/6	51.6/55	28 - 29	290 - 310	1.65	0.72
3	7/6	48.8/55	45 - 46	730 - 7400	3.10	1.1
4	7/6	51.6/55	28 - 29	290 - 310	1.62	0.71
5	7/6	48.7/55	45 - 46	730 - 7400	3.15	1.1
6	7/6	51.6/55	28 - 29	290 - 310	1.65	0.71

All measurements were done with a water flow rate of 450 (l/h), which is the minimum flow rate of the unit.

Test results of sound power test according to EN12102

N°	Sound power level LW(A) [dB re 1pW]	Uncertainty (dB) (weighted value)
1	55.8	0.5
2	49.1	1.0
3	48.4	0.5
4	43.2	1.5
5	54.8	0.5
6	49.8	1.0

The uncertainty value is a weighted value using the level and frequency dependant influence for each 1/1-octave level on the final A-weighted sound power level.

The A-weighted total sound power level is determined for the measured frequency range from 100 Hz to 10 kHz.





Outdoor unit



Outdoor unit rating plate

Panasonic
AIR-TO-WATER HEATPUMP

OUTDOOR UNIT
Model No. **WH-UD03JE5**

RATED VOLTAGE 230 V~
FREQUENCY 50 Hz
MAXIMUM INPUT 2.59kW/12.0A
REFRIGERANT R32 900g

	HEATING (A7W35)	HEATING (A2W35)
CAPACITY	3.20kW	3.20kW
CURRENT	2.9A	4.2A
POWER INPUT	0.60kW	0.88kW
COP	5.33	3.64

	COOLING (A35W7)
CAPACITY	3.20kW
CURRENT	4.3A
POWER INPUT	0.91kW
EER	3.52

(E N 1 4 5 1 1)

PS H.P. 4. 15MPa (41.5bar)
L.P. 2. 00MPa (20.0bar)

SERIAL NO.
5621201008
PRODUCTION DATE 2019.04

Panasonic Appliances
Air-Conditioning Malaysia
Sdn. Bhd.
Shah Alam, Malaysia

Authorized representative in EU
Panasonic Testing Centre
Panasonic Marketing Europe GmbH
Winsberggring 15, 22525 Hamburg,
Germany

IPX4
Made in Malaysia **CE 0035**

R32

THIS PRODUCT CONTAINS FLUORINATED GREENHOUSE GASES

WARNING

RISK OF EXPLOSION DURING SERVICE
After pump down operation, fully close 2, 3 way valve.
Before remove refrigerant pipes, compressor must be stopped.

ACXF02-40630





Indoor unit



Indoor unit rating plate

Panasonic

AIR-TO-WATER HYDROMODULE + TANK
Model No. WH-ADC0309J3E5
OUTDOOR UNIT WH-UD03JE5
WH-UD05JE5
WH-UD07JE5
WH-UD09JE5

POWER SUPPLY 1 (HEAT PUMP)
RATED VOLTAGE 230V~
RATED FREQUENCY 50Hz
POWER SUPPLY 2 (BACKUP HEATER)
RATED VOLTAGE 230V~
RATED FREQUENCY 50Hz
MAXIMUM POWER 3.00kW
MAXIMUM CURRENT 13.00A
MAX. WORKING PRESSURE MPa (Bar)
- SPACE HEAT/COOL 0.3 (3.0)
- TANK CIRCUIT 0.8 (8.0)
TANK UNIT CAPACITY (NETT) 185L

Panasonic AVC Networks Czech, s.r.o.
U Panasoniku 1, 320 84 Plzeň, Czech Republic
Assembled in the Czech Republic
Authorized representative in EU
Panasonic Testing Centre
Panasonic Marketing Europe GmbH
Winsberggring 15, 22525 Hamburg, Germany
SERIAL NO. **5704001319**

CE


IP21 ACXF09-04700

PRODUCTION DATE 2019.05





Detailed test results of sound power measurement N° 1

 		Sound power levels according to ISO 3743-1:2010		 TEKNOLOGISK INSTITUT																																																																			
Engineering method for small, movable sources in reverberant fields - Comparison method for hard-walled test rooms																																																																							
Client:		Panasonic Europe GmbH		Date of test: 05-02-2020																																																																			
Object:		Type: Split Air to water heat pump Model: WH-UD03JE5 (OD) + WH-ADC0309J3E5 (ID)																																																																					
Mounting conditions:		The outdoor unit is standing free on four 5.5 cm thick heavy concrete tiles placed on a vibration damping mat, which is placed on a water drop tray. The water drop tray is located on a 2.5 cm thick wooden board laying on the floor. The outdoor unit is mounted on the supporting metal support frame using 4 vibration isolators. The sound power measurement on outdoor unit only without any modification.																																																																					
Operating conditions:		A7/W48.7-55, Compressor speed: 45 - 46[Hz], Heating capacity: 3.2 [kW], Power_input: 1.1 [kW], Water flow rate: 450 [l/h], Fan_speed : 730 - 740 [rpm], dp_water : 111 [mbar]																																																																					
Static pressure:		1028 kPa		<u>Reference box:</u>																																																																			
Air temperature:		7.0 °C		L1: 0.8 m																																																																			
Relative air humidity:		85.0 %		L2: 0.3 m																																																																			
Test room volume:		102.8 m³		Room: Room 1																																																																			
Area, S, of test room:		138.9 m²		L3: 0.6 m																																																																			
				Volume: 0.1 m³																																																																			
<table border="1"> <thead> <tr> <th>Frequency f [Hz]</th> <th>L_w 1/3 octave [dB]</th> <th>1/1 oct [dB]</th> </tr> </thead> <tbody> <tr><td>100</td><td>56.5</td><td></td></tr> <tr><td>125</td><td>54.8</td><td>60.1</td></tr> <tr><td>160</td><td>54.4</td><td></td></tr> <tr><td>200</td><td>53.4</td><td></td></tr> <tr><td>250</td><td>53.7</td><td>57.9</td></tr> <tr><td>315</td><td>52.2</td><td></td></tr> <tr><td>400</td><td>50.4</td><td></td></tr> <tr><td>500</td><td>47.3</td><td>53.7</td></tr> <tr><td>630</td><td>48.4</td><td></td></tr> <tr><td>800</td><td>47.9</td><td></td></tr> <tr><td>1000</td><td>44.3</td><td>50.6</td></tr> <tr><td>1250</td><td>44.2</td><td></td></tr> <tr><td>1600</td><td>42.1</td><td></td></tr> <tr><td>2000</td><td>38.6</td><td>44.4</td></tr> <tr><td>2500</td><td>36.0</td><td></td></tr> <tr><td>3150</td><td>34.6</td><td></td></tr> <tr><td>4000</td><td>34.6</td><td>39.7</td></tr> <tr><td>5000</td><td>35.4</td><td></td></tr> <tr><td>6300</td><td>32.6</td><td></td></tr> <tr><td>8000</td><td>30.9</td><td>35.3</td></tr> <tr><td>10000</td><td>25.2</td><td></td></tr> </tbody> </table>		Frequency f [Hz]	L _w 1/3 octave [dB]	1/1 oct [dB]	100	56.5		125	54.8	60.1	160	54.4		200	53.4		250	53.7	57.9	315	52.2		400	50.4		500	47.3	53.7	630	48.4		800	47.9		1000	44.3	50.6	1250	44.2		1600	42.1		2000	38.6	44.4	2500	36.0		3150	34.6		4000	34.6	39.7	5000	35.4		6300	32.6		8000	30.9	35.3	10000	25.2					
Frequency f [Hz]	L _w 1/3 octave [dB]	1/1 oct [dB]																																																																					
100	56.5																																																																						
125	54.8	60.1																																																																					
160	54.4																																																																						
200	53.4																																																																						
250	53.7	57.9																																																																					
315	52.2																																																																						
400	50.4																																																																						
500	47.3	53.7																																																																					
630	48.4																																																																						
800	47.9																																																																						
1000	44.3	50.6																																																																					
1250	44.2																																																																						
1600	42.1																																																																						
2000	38.6	44.4																																																																					
2500	36.0																																																																						
3150	34.6																																																																						
4000	34.6	39.7																																																																					
5000	35.4																																																																						
6300	32.6																																																																						
8000	30.9	35.3																																																																					
10000	25.2																																																																						
¹ Too high																																																																							
Sound power level L_w(A): 55.8 dB [re 1pW]																																																																							
Name of test institute:		DTI																																																																					
No. of test report:		300-KLAB-20-003																																																																					
Date:		05-02-2020																																																																					





Detailed test results of sound power measurement N° 2

 		Sound power levels according to ISO 3743-1:2010		 TEKNOLOGISK INSTITUT																																																																			
Engineering method for small, movable sources in reverberant fields - Comparison method for hard-walled test rooms																																																																							
Client:	Panasonic Europe GmbH			Date of test: 05-02-2020																																																																			
Object:	Type: Split Air to water heat pump Model: WH-UD03JE5 (OD) + WH-ADC0309J3E5 (ID)																																																																						
Mounting conditions:	The outdoor unit is standing free on four 5.5 cm thick heavy concrete tiles placed on a vibration damping mat, which is placed on a water drop tray. The water drop tray is located on a 2.5 cm thick wooden board laying on the floor. The outdoor unit is mounted on the supporting metal support frame using 4 vibration isolators. The sound power measurement on outdoor unit only without any modification.																																																																						
Operating conditions:	A7/W51.6-55, Quiet mode 3, Compressor speed: 28 - 29[Hz], Heating capacity: 1.65 [kW], Power_input: 0.72 [kW], Water flow rate: 450 [l/h], Fan_speed : 290 - 310 [rpm], dp_water : 111																																																																						
Static pressure:	1028 kPa	Room: Room 1		Reference box:																																																																			
Air temperature:	7.0 °C			L1:	0.8 m																																																																		
Relative air humidity:	85.0 %			L2:	0.3 m																																																																		
Test room volume:	102.8 m³			L3:	0.6 m																																																																		
Area, S, of test room:	138.9 m²			Volume:	0.1 m³																																																																		
<table border="1"> <thead> <tr> <th>Frequency f [Hz]</th> <th>L_w 1/3 octave [dB]</th> <th>1/1 oct [dB]</th> </tr> </thead> <tbody> <tr><td>100</td><td>44.7</td><td></td></tr> <tr><td>125</td><td>51.2</td><td>54.3</td></tr> <tr><td>160</td><td>50.4</td><td></td></tr> <tr><td>200</td><td>47.3</td><td></td></tr> <tr><td>250</td><td>50.1</td><td>52.9</td></tr> <tr><td>315</td><td>45.7</td><td></td></tr> <tr><td>400</td><td>40.6</td><td></td></tr> <tr><td>500</td><td>42.4</td><td>45.4</td></tr> <tr><td>630</td><td>37.6</td><td></td></tr> <tr><td>800</td><td>36.8</td><td></td></tr> <tr><td>1000</td><td>36.2</td><td>42.2</td></tr> <tr><td>1250</td><td>38.9</td><td></td></tr> <tr><td>1600</td><td>33.7</td><td></td></tr> <tr><td>2000</td><td>28.2</td><td>35.5</td></tr> <tr><td>2500</td><td>27.3</td><td></td></tr> <tr><td>3150</td><td>27.0</td><td></td></tr> <tr><td>4000</td><td>27.3</td><td>32.0</td></tr> <tr><td>5000</td><td>27.4</td><td></td></tr> <tr><td>6300</td><td>32.7</td><td></td></tr> <tr><td>8000</td><td>31.9</td><td>35.6</td></tr> <tr><td>10000</td><td>23.3</td><td></td></tr> </tbody> </table>		Frequency f [Hz]	L _w 1/3 octave [dB]	1/1 oct [dB]	100	44.7		125	51.2	54.3	160	50.4		200	47.3		250	50.1	52.9	315	45.7		400	40.6		500	42.4	45.4	630	37.6		800	36.8		1000	36.2	42.2	1250	38.9		1600	33.7		2000	28.2	35.5	2500	27.3		3150	27.0		4000	27.3	32.0	5000	27.4		6300	32.7		8000	31.9	35.6	10000	23.3					
Frequency f [Hz]	L _w 1/3 octave [dB]	1/1 oct [dB]																																																																					
100	44.7																																																																						
125	51.2	54.3																																																																					
160	50.4																																																																						
200	47.3																																																																						
250	50.1	52.9																																																																					
315	45.7																																																																						
400	40.6																																																																						
500	42.4	45.4																																																																					
630	37.6																																																																						
800	36.8																																																																						
1000	36.2	42.2																																																																					
1250	38.9																																																																						
1600	33.7																																																																						
2000	28.2	35.5																																																																					
2500	27.3																																																																						
3150	27.0																																																																						
4000	27.3	32.0																																																																					
5000	27.4																																																																						
6300	32.7																																																																						
8000	31.9	35.6																																																																					
10000	23.3																																																																						
¹ Too high		Sound power level L_w(A): 49.1 dB [re 1pW]																																																																					
Name of test institute:	DTI																																																																						
No. of test report:	300-KLAB-20-003																																																																						
Date:	05-02-2020																																																																						





Detailed test results of sound power measurement N° 3

		Sound power levels according to ISO 3743-1:2010	
Engineering method for small, movable sources in reverberant fields - Comparison method for hard-walled test rooms			
Client:	Panasonic Europe GmbH	Date of test:	10-03-2020
Object:	Type: Split Air to water heat pump Model: WH-UD03JE5 (OD) + WH-ADC0309J3E5 (ID)		
Mounting conditions:	The out door unit is standing free on two pieces of heavy concrete tiles (90x90x10cm) placed on the floor. The sound power measurement on outdoor unit only without any modification. Test with a noise reduction box mounted around the outdoor unit		
Operating conditions:	A7/W48.9-55, Compressor speed: 45 - 46[Hz], Heating capacity: 3.1 [kW], Power_input: 1.1 [kW], Water flow rate: 450 [l/h], Fan_speed : 730 - 740 [rpm], dp_water : 168 [mbar]		
Static pressure:	1000 kPa	<u>Reference box:</u>	
Air temperature:	7.0 °C	L1:	0.8 m
Relative air humidity:	85.0 %	L2:	0.3 m
Test room volume:	102.8 m³	Room:	Room 1
Area, S, of test room:	138.9 m²	L3:	0.6 m
		Volume:	0.1 m³

Frequency f [Hz]	L _w 1/3 octave [dB]	1/1 oct [dB]
100	60.2	
125	46.0	60.6
160	47.0	
200	48.6	
250	47.8	52.1
315	44.7	
400	43.6	
500	40.3	46.2
630	39.1	
800	37.4	
1000	31.4	38.9
1250	29.1	
1600	26.0	
2000	21.7	28.0
2500	19.0	
3150	18.2	
4000	18.6	23.5
5000	19.3	
6300	17.8 ¹	
8000	17.6 ¹	22.2
10000	16.8 ¹	

Sound power level L_w(A): 48.4 dB [re 1pW]

Name of test institute:	DTI
No. of test report:	300-KLAB-20-003
Date:	10-03-2020






Detailed test results of sound power measurement N° 4

	Sound power levels according to ISO 3743-1:2010	 TEKNOLOGISK INSTITUT	
Engineering method for small, movable sources in reverberant fields - Comparison method for hard-walled test rooms			
Client:	Panasonic Europe GmbH	Date of test:	10-02-2020
Object:	Type: Split Air to water heat pump Model: WH-UD03JE5 (OD) + WH-ADC0309J3E5 (ID)		
Mounting conditions:	The outdoor unit is standing free on four 5.5 cm thick heavy concrete tiles placed on a vibration damping mat, which is placed on a water drop tray. The water drop tray is located on a 2.5 cm thick wooden board laying on the floor. The sound power measurement on outdoor unit only. Test with a noise reduction box mounted around the out unit.		
Operating conditions:	A7/W51.6-55, Quiet mode 3, Compressor speed: 28 - 29[Hz], Heating capacity: 1.62 [kW], Power_input: 0.71 [kW], Water flow rate: 450 [l/h], Fan_speed : 290 - 310 [rpm], dp_water : 115		
Static pressure:	973 kPa	<u>Reference box:</u>	
Air temperature:	7.0 °C	L1:	0.8 m
Relative air humidity:	85.0 %	L2:	0.3 m
Test room volume:	102.8 m³	Room:	Room 1
Area, S, of test room:	138.9 m²	L3:	0.6 m
		Volume:	0.1 m³

Frequency f [Hz]	L _w 1/3 octave [dB]	1/1 oct [dB]
100	42.1 ¹	
125	43.5	52.5
160	51.5	
200	46.5	
250	43.0	49.0
315	41.9	
400	34.8	
500	32.2	37.5
630	30.0	
800	24.4	
1000	24.3	28.7
1250	22.9	
1600	17.4	
2000	11.0 ¹	18.9
2500	9.7 ¹	
3150	9.6 ¹	
4000	11.5 ¹	16.5
5000	13.4 ¹	
6300	17.8 ¹	
8000	18.2 ¹	22.4
10000	16.7 ¹	

¹ Too high



Sound power level L_w(A): 43.2 dB [re 1pW]

Name of test institute:	DTI
No. of test report:	300-KLAB-20-003
Date:	10-02-2020





Detailed test results of sound power measurement N ° 5

 		Sound power levels according to ISO 3743-1:2010		 TEKNOLOGISK INSTITUT																																																																			
Engineering method for small, movable sources in reverberant fields - Comparison method for hard-walled test rooms																																																																							
Client:	Panasonic Europe GmbH			Date of test: 12-02-2020																																																																			
Object:	Type: Split Air to water heat pump Model: WH-UD03JE5 (OD) + WH-ADC0309J3E5 (ID)																																																																						
Mounting conditions:	The out door unit is standing free on four 5.5 cm thick heavy concrete tiles placed on a vibration damping mat, which is placed on a water drop tray. The water drop tray is located on a 2.5 cm thick wooden board laying on the floor. The outdoor unit is mounted on the supporting metal support frame using 4 vibration isolators. The sound power measurement on outdoor unit only. Test with a sound proof kit.																																																																						
Operating conditions:	A7/W48.7-55, Compressor speed: 45 - 46[Hz], Heating capacity: 3.15 [kW], Power_input: 1.1 [kW], Water flow rate: 450 [l/h], Fan_speed : 730 - 740 [rpm], dp_water : 111 [mbar]																																																																						
Static pressure:	1028 kPa	Room: Room 1		Reference box:																																																																			
Air temperature:	7.0 °C			L1:	0.8 m																																																																		
Relative air humidity:	85.0 %			L2:	0.3 m																																																																		
Test room volume:	102.8 m³			L3:	0.6 m																																																																		
Area, S, of test room:	138.9 m²			Volume:	0.1 m³																																																																		
<table border="1"> <thead> <tr> <th>Frequency f [Hz]</th> <th>L_w 1/3 octave [dB]</th> <th>1/1 oct [dB]</th> </tr> </thead> <tbody> <tr><td>100</td><td>55.7</td><td></td></tr> <tr><td>125</td><td>50.5</td><td>58.0</td></tr> <tr><td>160</td><td>51.5</td><td></td></tr> <tr><td>200</td><td>54.4</td><td></td></tr> <tr><td>250</td><td>54.8</td><td>58.3</td></tr> <tr><td>315</td><td>50.2</td><td></td></tr> <tr><td>400</td><td>47.4</td><td></td></tr> <tr><td>500</td><td>45.8</td><td>51.8</td></tr> <tr><td>630</td><td>47.7</td><td></td></tr> <tr><td>800</td><td>46.6</td><td></td></tr> <tr><td>1000</td><td>43.8</td><td>49.5</td></tr> <tr><td>1250</td><td>42.8</td><td></td></tr> <tr><td>1600</td><td>39.9</td><td></td></tr> <tr><td>2000</td><td>37.1</td><td>42.6</td></tr> <tr><td>2500</td><td>35.0</td><td></td></tr> <tr><td>3150</td><td>33.9</td><td></td></tr> <tr><td>4000</td><td>34.6</td><td>39.4</td></tr> <tr><td>5000</td><td>35.3</td><td></td></tr> <tr><td>6300</td><td>31.8</td><td></td></tr> <tr><td>8000</td><td>29.9</td><td>34.4</td></tr> <tr><td>10000</td><td>24.7</td><td></td></tr> </tbody> </table>		Frequency f [Hz]	L _w 1/3 octave [dB]	1/1 oct [dB]	100	55.7		125	50.5	58.0	160	51.5		200	54.4		250	54.8	58.3	315	50.2		400	47.4		500	45.8	51.8	630	47.7		800	46.6		1000	43.8	49.5	1250	42.8		1600	39.9		2000	37.1	42.6	2500	35.0		3150	33.9		4000	34.6	39.4	5000	35.3		6300	31.8		8000	29.9	34.4	10000	24.7					
Frequency f [Hz]	L _w 1/3 octave [dB]	1/1 oct [dB]																																																																					
100	55.7																																																																						
125	50.5	58.0																																																																					
160	51.5																																																																						
200	54.4																																																																						
250	54.8	58.3																																																																					
315	50.2																																																																						
400	47.4																																																																						
500	45.8	51.8																																																																					
630	47.7																																																																						
800	46.6																																																																						
1000	43.8	49.5																																																																					
1250	42.8																																																																						
1600	39.9																																																																						
2000	37.1	42.6																																																																					
2500	35.0																																																																						
3150	33.9																																																																						
4000	34.6	39.4																																																																					
5000	35.3																																																																						
6300	31.8																																																																						
8000	29.9	34.4																																																																					
10000	24.7																																																																						
¹ Too high		Sound power level L_w(A): 54.8 dB [re 1pW]																																																																					
Name of test institute:	DTI																																																																						
No. of test report:	300-KLAB-20-003																																																																						
Date:	12-02-2020																																																																						






Detailed test results of sound power measurement N ° 6

		Sound power levels according to ISO 3743-1:2010			
Engineering method for small, movable sources in reverberant fields - Comparison method for hard-walled test rooms					
Client:	Panasonic Europe GmbH			Date of test:	12-02-2020
Object:	Type: Split Air to water heat pump Model: WH-UD03JE5 (OD) + WH-ADC0309J3E5 (ID)				
Mounting conditions:	The outdoor unit is standing free on four 5.5 cm thick heavy concrete tiles placed on a vibration damping mat, which is placed on a water drop tray. The water drop tray is located on a 2.5 cm thick wooden board laying on the floor. The outdoor unit is mounted on the supporting metal support frame using 4 vibration isolators. The sound power measurement on outdoor unit only. Test with a sound proof kit.				
Operating conditions:	A7/W51.6-55, Quiet mode 3, Compressor speed: 28 - 29[Hz], Heating capacity: 1.64 [kW], Power_input: 0.71 [kW], Water flow rate: 450 [l/h], Fan_speed : 290 - 310 [rpm], dp_water : 111				
Static pressure:	1028 kPa	Room:		Reference box:	
Air temperature:	7.0 °C	Room 1		L1:	0.8 m
Relative air humidity:	85.0 %			L2:	0.3 m
Test room volume:	102.8 m³			L3:	0.6 m
Area, S, of test room:	138.9 m²			Volume:	0.1 m³

Frequency f [Hz]	L _w 1/3 octave [dB]	1/1 oct [dB]
100	43.8	
125	49.8	55.2
160	53.3	
200	49.2	
250	52.2	54.7
315	46.5	
400	39.4	
500	40.3	43.9
630	37.1	
800	34.8	
1000	37.9	42.1
1250	38.5	
1600	35.0	
2000	30.5	37.6
2500	31.6	
3150	32.6	
4000	29.8	35.1
5000	26.8	
6300	29.3	
8000	28.0	32.0
10000	19.6 ¹	

¹ Too high



Sound power level L_w(A):	49.8 dB [re 1pW]
--	-------------------------

Name of test institute:	DTI
No. of test report:	300-KLAB-20-003
Date:	12-02-2020





Appendix 1: Test Procedure

The measurements of the emitted sound power level from the heat pump are carried out according to the following:

- DS/EN 14511:2013
- EN 12102:2017
- DS/EN 3743/1

The basic acoustic measurement standard DS/EN 3743-1 is a comparison method using a calibrated reference sound source. Two series of sound pressure measurements are made under exactly the same acoustic conditions, e.g. the same microphone positions, temperature and air humidity. The calibrated sound power levels are known for the reference sound source at each frequency band, and they are used in the estimation of the acoustical correction factor for the calculation of the sound power emitted from the tested heat pump. The background noise levels are measured and used for relevant corrections.

The final total A-weighted sound power level is based on measurements and calculations in 1/3-octave levels, which then are summed into 1/1-octave levels. The uncertainty is estimated on the weighted standard deviations in 1/1-octave levels.

The actual microphone positions and correction values are saved in data files linked to the complete project documentation according to the DANAK-accreditation.

The complete measurement system is documented and regularly calibrated according to DANAK.

The detailed description of the measurement method is given in Danish in the quality database system "QA Web" at Danish Technological Institute, which is accessible by DANAK.

