

TEST REPORT

Report no.:
300-KLAB-24-002



DANISH
TECHNOLOGICAL
INSTITUTE

Teknologiparken
Kongsvang Allé 29
DK-8000 Aarhus C
+45 72 20 20 00
Info@teknologisk.dk
www.teknologisk.dk

Page 1 of 39
Init: RTHI/KAMA
File no.: 226011
Enclosures: 1

Customer: Company: GD MIDEA HEATING & VENTILATING EQUIPMENT CO., LTD.
Address: Penglai Industry Road, Beijiao
City: Shunde, Foshan, Guangdong, 528311, China
Tel.: +86 13902810522

Component: Brand: Midea
Type: Air to water heat pump (mono block)
Model: MHC-V10WD2N7
Series no.: 541140007773A18010002Z
Prod. Year: Outdoor unit: N/A

Dates: Component tested: January – February 2024

Procedure: See objective (page 2) for list of standards.

Remarks: The unit was delivered by the customer. The installation and test settings were done according to the manufacturer's instructions. Between each test condition, Midea has been changing various parameters like compressor speed, expansion valve, fan speed, pump speed, defrost time, heating time.

Terms: This test was conducted under accreditation in accordance with international requirements (ISO/IEC 17025:2017) and in accordance with the General Terms and Conditions of Danish Technological Institute. The test results solely apply to the tested item. This test report may be quoted in extract only if Danish Technological Institute has granted its written consent.

The customer may not mention or refer to Danish Technological Institute or Danish Technological Institute's employees for advertising or marketing purposes unless Danish Technological Institute has granted its written consent in each case.

Division/Centre: Danish Technological Institute
Energy and Climate
Heat Pump Laboratory, Aarhus

Date: 2024.03.19

Signature:
Rasmus Thisgaard
B.TecMan & MarEng

Co-reader:
Kamathasan Arumugam
B.Sc. Engineer

DIGITALLY SIGNED DOCUMENT

19 March 2024

DANISH TECHNOLOGICAL INSTITUTE



Test Reg. nr. 300



Heat pumps of identical design

According to GD MIDEA HEATING & VENTILATING EQUIPMENT CO. LTD. The heat pumps listed in the table below are considered identical with the tested unit. They have identical:

- a. heating capacity
- b. refrigerant cycle (incl. refrigerant mass)
- c. heat source and sink medium
- d. main components / operating principle and control strategy
- e. same outdoor casing

Midea	MHC-V10WD2N7
Midea	MHC-V10WD2N7-E30
Midea	MHC-V10WD2N7-ER60
Midea	MHC-V10WD2N7-ER90



Objective

The objective of this report is to document the following:

The Seasonal Coefficient of Performance (SCOP) at low and medium temperature application for average climate according to EN 14825:2022.

In order to calculate the SCOP, tests were carried out at the part load conditions stated in the tables on page 5 and 6.

SCOP part load test in condition SCOP_C at low temperature application for warmer climate according to EN 14825:2022.

SCOP part load test conditions SCOP_A and SCOP_{F/G} at low temperature application for colder climate according to EN 14825:2022.

COP test standard rating conditions A7/W35 and A7/W55 according to EN 14511:2022.

Operating requirements according to EN 14511-4:2022

- 4.2.1 Starting and operating tests
- 4.5 Shutting off the heat transfer medium flows
- 4.6 Complete power supply failure

Sound power measurements according to EN 12102-1:2022.



Contents:

Test conditions	5
SCOP test conditions for low temperature – EN 14825	5
SCOP test conditions for medium temperature – EN 14825	6
COP test conditions - low temperature – EN 14511	7
COP test conditions - medium temperature – EN 14511	7
Test conditions for operating requirements – EN 14511-4	7
Test conditions for shutting off the heat transfer medium – EN 14511-4	8
Test conditions for complete power supply failure – EN 14511-4	8
Test conditions for sound power measurements – EN 12102-1	8
Test results.....	9
Test results of SCOP test at low temperature - heating season average – EN 14825.....	9
Test results of SCOP test at medium temperature - heating season average – EN 14825	10
Test results for warmer climate, low temperature according to EN14825.....	11
Test results for colder climate, low temperature according to EN14825	11
COP test results - low temperature – EN 14511	11
COP test results - medium temperature – EN 14511.....	11
Test results for starting and operating test - EN 14511-4.....	12
Test results for shutting off the heat transfer medium – EN 14511-4.....	12
Test results for complete power supply failure – EN 14511-4.....	12
Test results of sound power measurements – EN 12102-1	13
Photos	14
SCOP - detailed calculation.....	16
Detailed SCOP calculation of low temperature and average climate conditions – EN 14825.....	16
Detailed SCOP calculation of medium temperature and average climate conditions – EN 14825	18
Detailed test results	20
Detailed SCOP part load test results - low temperature application - average climate – EN 14825....	20
Detailed SCOP part load test results - medium temperature application - average climate – EN 14825	25
Detailed SCOP part load test results - low temperature application - warmer climate – EN 1482	30
Detailed SCOP part load test results - low temperature application - colder climate – EN 14825.....	31
Detailed COP test results - low temperature – EN 14511.....	33
Detailed COP test results - medium temperature – EN 14511	34
Detailed test results of sound power measurement – Test N#1	35
Appendix 1	36



Test conditions

SCOP test conditions for low temperature – EN 14825

Part load conditions for reference SCOP and reference SCOPon calculation of air to water units for low temperature application for the reference heating season;

"A" = average, "W" = warmer, and "C" = colder.

	Part load ratio in %				Outdoor heat exchanger		Indoor heat exchanger			
					Dry (wet) bulb temperature °C		Fixed outlet °C	Variable outlet ^d °C		
	Formula	Average	Warmer	Colder	Outdoor air	Exhaust air	All climates	Average	Warmer	Colder
A	$(-7 - 16) / (T_{designh} - 16)$	88,46	n.a.	60,53	-7(-8)	20(12)	^a / 35	^a / 34	n.a.	^a / 30
B	$(+2 - 16) / (T_{designh} - 16)$	53,85	100,00	36,84	2(1)	20(12)	^a / 35	^a / 30	^a / 35	^a / 27
C	$(+7 - 16) / (T_{designh} - 16)$	34,62	64,29	23,68	7(6)	20(12)	^a / 35	^a / 27	^a / 31	^a / 25
D	$(+12 - 16) / (T_{designh} - 16)$	15,38	28,57	10,53	12(11)	20(12)	^a / 35	^a / 24	^a / 26	^a / 24
E	$(TOL^e - 16) / (T_{designh} - 16)$				TOL^e	20(12)	^a / 35	^a / b	^a / b	^a / b
F	$(T_{biv} - 16) / (T_{designh} - 16)$				T_{biv}	20(12)	^a / 35	^a / c	^a / c	^a / c
G	$(-15 - 16) / (T_{designh} - 16)$	n.a.	n.a.	81,58	-15	20(12)	^a / 35	n.a.	n.a.	^a / 32

Additional information

Climate	$T_{designh}$ [°C]	$T_{bivalent}$ [°C]	TOL [°C]	Outlet temperature	Flow rate
Average	-10	-7	-10	Variable	Variable
Warmer	2	7	2	Variable	Variable
Colder	-22	-15	-22	Variable	Variable



SCOP test conditions for medium temperature – EN 14825

Part load conditions for reference SCOP and reference SCOPon calculation of air to water units for medium temperature application for the reference heating season;
"A" = average, "W" = warmer, and "C" = colder.

	Part load ratio in %				Outdoor heat exchanger		Indoor heat exchanger			
					Dry (wet) bulb temperature °C		Fixed outlet °C	Variable outlet ^d °C		
	Formula	Average	Warmer	Colder	Outdoor air	Exhaust air	All climates	Average	Warmer	Colder
A	$(-7 - 16) / (T_{\text{designh}} - 16)$	88,46	n.a.	60,53	-7(-8)	20(12)	^a / 55	^a / 52	n.a.	^a / 44
B	$(+2 - 16) / (T_{\text{designh}} - 16)$	53,85	100	36,84	2(1)	20(12)	^a / 55	^a / 42	^a / 55	^a / 37
C	$(+7 - 16) / (T_{\text{designh}} - 16)$	34,62	64,29	23,68	7(6)	20(12)	^a / 55	^a / 36	^a / 46	^a / 32
D	$(+12 - 16) / (T_{\text{designh}} - 16)$	15,38	28,57	10,53	12(11)	20(12)	^a / 55	^a / 30	^a / 34	^a / 28
E	$(TOL^e - 16) / (T_{\text{designh}} - 16)$				TOL^e	20(12)	^a / 55	^a / b	^a / b	^a / b
F	$(T_{\text{biv}} - 16) / (T_{\text{designh}} - 16)$				T_{biv}	20(12)	^a / 55	^a / c	^a / c	^a / c
G	$(-15 - 16) / (T_{\text{designh}} - 16)$	n.a.	n.a.	81,58	-15	20(12)	^a / 55	n.a.	n.a.	^a / 49

Additional information

Climate	T_{designh} [°C]	T_{bivalent} [°C]	TOL [°C]	Outlet temperature	Flow rate
Average	-10	-7	-10	Variable	Variable



COP test conditions - low temperature – EN 14511

N [#]	Heat source		Heat sink		Heat pump settings
	Inlet dry bulb temperature (°C)	Inlet wet bulb temperature (°C)	Inlet temperature (°C)	Outlet temperature (°C)	
1 ^S	7	6	30	35	

S: Standard rating condition

COP test conditions - medium temperature – EN 14511

N [#]	Heat source		Heat sink		Heat pump settings
	Inlet dry bulb temperature (°C)	Inlet wet bulb temperature (°C)	Inlet temperature (°C)	Outlet temperature (°C)	
1 ^S	7	6	47	55	

S: Standard rating condition

Test conditions for operating requirements – EN 14511-4

N [#]	Heat source		Heat sink	Water flow rate at indoor heat exchanger	Test
	Inlet dry bulb temperature (°C)	Inlet wet bulb temperature (°C)	Inlet temperature (°C)		
1	-25	-	12	400 L/h	Starting
2	-25	-	48	400 L/h	Operating



Test conditions for shutting off the heat transfer medium – EN 14511-4

N [#]	Heat source		Heat sink		Heat exchanger
	Inlet dry bulb temperature (°C)	Inlet wet bulb temperature (°C)	Inlet temperature (°C)	Outlet temperature (°C)	
1	7	6	30	35	Indoor
2	7	6	30	35	Outdoor

Test conditions for complete power supply failure – EN 14511-4

N [#]	Heat source		Heat sink		
	Inlet dry bulb temperature (°C)	Inlet wet bulb temperature (°C)	Inlet temperature (°C)	Outlet temperature (°C)	
1	7	6	30	35	

Test conditions for sound power measurements – EN 12102-1

N [#]	Test condition		Heat pump setting			
	Outdoor heat exchanger (dry bulb/wet bulb) (°C)	Indoor heat exchanger (inlet/outlet) (°C)	Compressor speed (Hz)	Fan speed outdoor (rpm)	Heating capacity (kW)	Power input (kW)
1 ^E	7/6	47/55	33	400	3.73	1.27

E) ErP labelling



Test results

Test results of SCOP test at low temperature - heating season average - EN 14825

Model (Outdoor)	MHC-V10WD2N7			
Air-to-water heat pump mono bloc	Y			
Low-temperature heat pump	N			
Equipped with supplementary heater	N			
Heat pump combination heater	N			
Reversible	Y			
Rated heat output¹⁾	P_{rated}	9.2 [kW]		
Seasonal space heating energy efficiency	η_s	200.4 [%]		
	SCOP	5.09 [-]		
Measured capacity for heating for part load at outdoor temperature T_j	Average Climate - Low temperature application	$T_j=-15\text{ }^\circ\text{C}$ $T_j=-7\text{ }^\circ\text{C}$ $T_j=2\text{ }^\circ\text{C}$ $T_j=7\text{ }^\circ\text{C}$ $T_j=12\text{ }^\circ\text{C}$ $T_j=\text{bivalent temperature}$ $T_j=\text{operation limit}$	P_{dh} P_{dh} P_{dh} P_{dh} P_{dh} P_{dh} P_{dh}	- [kW] 8.09 [kW] 5.07 [kW] 3.77 [kW] 4.46 [kW] 8.09 [kW] 8.52 [kW]
Measured coefficient of performance at outdoor temperature T_j	Average Climate - Low temperature application	$T_j=-15\text{ }^\circ\text{C}$ $T_j=-7\text{ }^\circ\text{C}$ $T_j=2\text{ }^\circ\text{C}$ $T_j=7\text{ }^\circ\text{C}$ $T_j=12\text{ }^\circ\text{C}$ $T_j=\text{bivalent temperature}$ $T_j=\text{operation limit}$	COP_d COP_d COP_d COP_d COP_d COP_d COP_d	- [-] 2.78 [-] 5.07 [-] 6.94 [-] 9.18 [-] 2.78 [-] 2.48 [-]
Bivalent temperature	Tbivalent			-7 [°C]
Operation limit temperatures	TOL			-10 [°C]
Degradation coefficient	WTOL			- [°C]
Power consumption in modes other than active mode	Off mode Thermostat-off mode Standby mode Crankcase heater mode	P_{OFF} P_{TO} P_{SB} P_{CK}	0.008 [kW] 0.009 [kW] 0.008 [kW] 0.008 [kW]	
Supplementary heater¹⁾	Rated heat output Type of energy input	P_{sup}	0.68 [kW] Electrical	
Other items	Capacity control Water flow control Water flow rate Annual energy consumption		Q_{HE}	Variable Variable - 3737 [kWh]

¹⁾For heat pump space heaters and heat pump combination heaters, the rated heat output, P_{rated} , is equal to the design load for heating, $P_{designh}$, and the rated heat output of a supplementary heater, P_{sup} , is equal to the supplementary capacity for heating, $sup(T_j)$.

²⁾For SCOP calculation the value $P_{CK} - P_{SB}$ is used. See section "SCOP - detailed calculation"



Test results of SCOP test at medium temperature - heating season average – EN 14825

Model (Outdoor)	MHC-V10WD2N7			
Air-to-water heat pump mono bloc	Y			
Low-temperature heat pump	N			
Equipped with supplementary heater	N			
Heat pump combination heater	N			
Reversible	Y			
Rated heat output¹⁾	P_{rated}	7.8 [kW]		
Seasonal space heating energy efficiency	η_s	156.9 [%]		
	SCOP	4.00 [-]		
Measured capacity for heating for part load at outdoor temperature T_j	Average Climate	$T_j=-15^{\circ}C$	P_{dh}	- [kW]
	-	$T_j=-7^{\circ}C$	P_{dh}	7.07 [kW]
	Medium temperature application	$T_j=2^{\circ}C$	P_{dh}	4.22 [kW]
		$T_j=7^{\circ}C$	P_{dh}	3.69 [kW]
		$T_j=12^{\circ}C$	P_{dh}	4.23 [kW]
		$T_j=bivalent\ temperature$	P_{dh}	7.07 [kW]
		$T_j=operation\ limit$	P_{dh}	7.86 [kW]
Measured coefficient of performance at outdoor temperature T_j	Average Climate	$T_j=-15^{\circ}C$	COP_d	- [-]
	-	$T_j=-7^{\circ}C$	COP_d	2.38 [-]
	Medium temperature application	$T_j=2^{\circ}C$	COP_d	3.92 [-]
		$T_j=7^{\circ}C$	COP_d	5.31 [-]
		$T_j=12^{\circ}C$	COP_d	6.65 [-]
		$T_j=bivalent\ temperature$	COP_d	2.38 [-]
		$T_j=operation\ limit$	COP_d	2.02 [-]
Bivalent temperature	Tbivalent	-7 [°C]		
Operation limit	TOL	-10 [°C]		
temperatures	WTOL	- [°C]		
Degradation coefficient	Cdh	0.99 [-]		
Power consumption in modes other than active mode	Off mode	P_{OFF}	0.008 [kW]	
	Thermostat-off mode	P_{TO}	0.009 [kW]	
	Standby mode	P_{SB}	0.008 [kW]	
	Crankcase heater mode	P_{CK}	0.008 [kW]	
Supplementary heater¹⁾	Rated heat output	P_{SUP}	0.00 [kW]	
	Type of energy input		Electrical	
Other items	Capacity control	Variable		
	Water flow control	Variable		
	Water flow rate	-		
	Annual energy consumption	Q_{HE}	4032 [kWh]	

¹⁾For heat pump space heaters and heat pump combination heaters, the rated heat output, P_{rated} , is equal to the design load for heating, $P_{designh}$, and the rated heat output of a supplementary heater, P_{sup} , is equal to the supplementary capacity for heating, $sup(T_j)$.

²⁾For SCOP calculation the value PCK - PSB is used. See section "SCOP - detailed calculation"



Test results for warmer climate, low temperature according to EN14825

N°	Test condition	Heating capacity [kW]	COP
1	Tbivalent C	5.482	6.214

Test results for colder climate, low temperature according to EN14825

N°	Test condition	Heating capacity [kW]	COP
1	A	4.958	3.741
2	F&G	6.516	2.692

COP test results - low temperature – EN 14511

N*	Test conditions	Heating capacity [kW]	COP
1	A7/W35	9.861	4.604

COP test results - medium temperature – EN 14511

N*	Test conditions	Heating capacity [kW]	COP
1	A7/W55	9.416	3.054



Test results for starting and operating test - EN 14511-4

N#	Test conditions air/water inlet [°C]	Test validation
Starting	A-25/W12	Passed
Operating	A-25/W48	Passed

Test results for shutting off the heat transfer medium – EN 14511-4

N#	Heat exchanger	Test validation
1	Indoor	Passed
2	Outdoor	Passed

Test results for complete power supply failure – EN 14511-4

N#	Test validation
1	Passed



Test results of sound power measurements – EN 12102-1

N [#]	Test conditions	Sound power level LW(A) [dB re 1pW]	Uncertainty Δ_{tot} [dB]
1 ^E	A7/W55	51.1	1.6

E) ErP labelling

The A-weighted total sound power level is determined for the measured frequency range from 100 Hz to 10 kHz. For the calculation of uncertainty, see appendix 1.

The sound power measurements are carried out by Kamalathasan Arumugam (KAMA) and co-read by Patrick Glibert (PGL), Danish Technological Institute.



Photos

Rating plate





DANISH
TECHNOLOGICAL
INSTITUTE

Page 15 of 39
300-KLAB-24-002

Outdoor unit



DANAK
Test Reg. nr. 300



SCOP - detailed calculation

Detailed SCOP calculation of low temperature and average climate conditions – EN 14825

Calculation of reference SCOP

$$SCOP = \frac{P_{designh} \times H_{he}}{P_{designh} \times H_{he} + H_{TO} \times P_{TO} + H_{SB} \times P_{SB} + H_{CK} \times P_{CK} + H_{OFF} \times P_{OFF}}$$

Where

P_{design} =

Heating load of the building at design temperature, kW

H_{he} =

Number of equivalent heating hours, 2066 h

$H_{TO}, H_{SB}, H_{CK}, H_{OFF}$ =

Number of hours for which the unit is considered to work in thermostat off mode, standby mode, crankcase heater mode and off mode, h, respectively

$P_{TO}, P_{SB}, P_{CK}, P_{OFF}$ =

Electricity consumption during thermostat off mode, standby mode, crankcase heater mode and off mode, kW, respectively

Data for SCOP

	Outdoor temperature [°C]	Part load ratio [%]	Part load [kW]	Declared capacity [kW]	Declared COP [-]	cdh [-]	CR [-]	COPbin [-]
A	-7	88	8.14	8.09	2.78	1.00	1.00	2.78
B	2	54	4.95	5.07	5.07	0.99	1.00	5.07
C	7	35	3.18	3.77	6.94	0.98	0.84	6.92
D	12	15	1.42	4.46	9.18	0.98	0.32	8.84
E	-10	100	9.20	8.52	2.48	1.00	1.00	2.48
F - BIV	-7	88	8.14	8.09	2.78	1.00	1.00	2.78

Energy consumption for thermostat off, standby, off mode, crankcase heater mode

	Hours [h]	Power input [kW]	Applied to SCOP calculation [kW]	Energy consumption [kWh]
Off mode	0	0.0082	0.0082	0
Thermostat off	178	0.0086	0.0086	1.5308
Standby	0	0.0082	0.0082	0
Crankcase heater	178	0.0082	0	0



Calculation Bin for SCOP_{on}

Bin [-]	Outdoor temperature [°C]	Hours [h]	Heat load [kW]	Heat load covered by heat pump [kW]	Electrical back up heater energy input [kW]	Backup heater energy input [kWh]	COP _{bin} [-]	Annual heating demand [kWh]	Annual energy input [kWh]	Net annual heating capacity [kWh]	Net annual power input [kWh]
E	21	-10	1	9.20	8.52	0.68	0.68	2.48	9.20	4.11	8.52
	22	-9	25	8.85	8.38	0.47	11.69	2.58	221.15	92.86	209.46
	23	-8	23	8.49	8.23	0.26	5.97	2.68	195.32	76.66	189.35
A / F - BIV	24	-7	24	8.14	8.09	0.00	0.00	2.78	195.32	70.33	195.32
	25	-6	27	7.78	7.74	0.00	0.00	3.03	210.18	69.33	210.18
	26	-5	68	7.43	7.39	0.00	0.00	3.29	505.29	153.77	505.29
	27	-4	91	7.08	7.04	0.00	0.00	3.54	644.00	181.90	644.00
	28	-3	89	6.72	6.69	0.00	0.00	3.79	598.35	157.67	598.35
	29	-2	165	6.37	6.35	0.00	0.00	4.05	1050.92	259.52	1050.92
	30	-1	173	6.02	6.00	0.00	0.00	4.30	1040.66	241.79	1040.66
	31	0	240	5.66	5.65	0.00	0.00	4.56	1358.77	298.08	1358.77
	32	1	280	5.31	5.30	0.00	0.00	4.81	1486.15	308.79	1486.15
B	33	2	320	4.95	4.95	0.00	0.00	5.07	1585.23	312.83	1585.23
	34	3	357	4.60	4.60	0.00	0.00	5.44	1642.20	302.04	1642.20
	35	4	356	4.25	4.25	0.00	0.00	5.81	1511.63	260.32	1511.63
	36	5	303	3.89	3.89	0.00	0.00	6.18	1179.37	190.95	1179.37
	37	6	330	3.54	3.54	0.00	0.00	6.55	1167.69	178.38	1167.69
C	38	7	326	3.18	3.18	0.00	0.00	6.92	1038.18	150.12	1038.18
	39	8	348	2.83	2.83	0.00	0.00	7.30	985.11	134.94	985.11
	40	9	335	2.48	2.48	0.00	0.00	7.69	829.77	107.97	829.77
	41	10	315	2.12	2.12	0.00	0.00	8.07	668.77	82.87	668.77
	42	11	215	1.77	1.77	0.00	0.00	8.45	380.38	44.99	380.38
D	43	12	169	1.42	1.42	0.00	0.00	8.84	239.20	27.06	239.20
	44	13	151	1.06	1.06	0.00	0.00	9.22	160.29	17.38	160.29
	45	14	105	0.71	0.71	0.00	0.00	9.61	74.31	7.73	74.31
	46	15	74	0.35	0.35	0.00	0.00	9.99	26.18	2.62	26.18

SUM	19003.66	3734.99	18985.32	3716.65
SCOP_{on}	5.09	SCOP_{net}	5.11	



Detailed SCOP calculation of medium temperature and average climate conditions – EN 14825

Calculation of reference SCOP

$$SCOP = \frac{P_{designh} \times H_{he}}{P_{designh} \times H_{he} + H_{TO} \times P_{TO} + H_{SB} \times P_{SB} + H_{CK} \times P_{CK} + H_{OFF} \times P_{OFF}}$$

Where

P_{design} =

Heating load of the building at design temperature, kW

H_{he} =

Number of equivalent heating hours, 2066 h

$H_{TO}, H_{SB}, H_{CK}, H_{OFF}$ =

Number of hours for which the unit is considered to work in thermostat off mode, standby mode, crankcase heater mode and off mode, h, respectively

$P_{TO}, P_{SB}, P_{CK}, P_{OFF}$ =

Electricity consumption during thermostat off mode, standby mode, crankcase heater mode and off mode, kW, respectively

Data for SCOP

	Outdoor temperature [°C]	Part load ratio [%]	Part load [kW]	Declared capacity [kW]	Declared COP [-]	cdh [-]	CR [-]	COPbin [-]
A	-7	88	6.90	7.07	2.38	1.00	1.00	2.38
B	2	54	4.20	4.22	3.92	0.99	1.00	3.92
C	7	35	2.70	3.69	5.31	0.99	0.73	5.29
D	12	15	1.20	4.23	6.65	0.99	0.28	6.43
E	-10	100	7.80	7.86	2.02	1.00	1.00	2.02
F - BIV	-7	88	6.90	7.07	2.38	1.00	1.00	2.38

Energy consumption for thermostat off, standby, off mode, crankcase heater mode

Hours [h]	Power input [kW]	Applied to SCOP calculation [kW]	Energy consumption [kWh]
Off mode	0	0.0082	0.0082
Thermostat off	178	0.0086	0.0086
Standby	0	0.0082	0.0082
Crankcase heater	178	0.0082	0.0082



Calculation Bin for SCOP_{on}

Bin [-]	Outdoor temperature [°C]	Hours [h]	Heat load [kW]	Heat load covered by heat pump [kW]	Electrical back up heater [kW]	Backup heater energy input [kWh]	COP _{bin} [-]	Annual heating demand [kWh]	Annual energy input [kWh]	Annual heating capacity [kWh]	Net annual heating capacity [kWh]	Net annual power input [kWh]
E	21	-10	1	7.80	7.50	0.00	0.00	2.14	187.50	87.52	187.50	87.52
	22	-9	25	7.50	7.20	0.00	0.00	2.26	165.60	73.29	165.60	73.29
	23	-8	23	7.20	7.20	0.00	0.00	2.38	165.60	69.67	165.60	69.67
A / F - BIV	24	-7	24	6.90	6.90	0.00	0.00	2.55	178.20	69.92	178.20	69.92
	25	-6	27	6.60	6.60	0.00	0.00	2.72	428.40	157.49	428.40	157.49
	26	-5	68	6.30	6.30	0.00	0.00	2.89	546.00	188.81	546.00	188.81
	27	-4	91	6.00	6.00	0.00	0.00	3.06	507.30	165.60	507.30	165.60
	28	-3	89	5.70	5.70	0.00	0.00	3.24	891.00	275.42	891.00	275.42
	29	-2	165	5.40	5.40	0.00	0.00	3.41	882.30	258.99	882.30	258.99
	30	-1	173	5.10	5.10	0.00	0.00	3.58	1152.00	321.94	1152.00	321.94
	31	0	240	4.80	4.80	0.00	0.00	3.75	1260.00	336.00	1260.00	336.00
	32	1	280	4.50	4.50	0.00	0.00	3.92	1344.00	342.72	1344.00	342.72
B	33	2	320	4.20	4.20	0.00	0.00	4.19	1392.30	331.92	1392.30	331.92
	34	3	357	3.90	3.90	0.00	0.00	4.47	1281.60	286.86	1281.60	286.86
	35	4	356	3.60	3.60	0.00	0.00	4.74	999.90	210.91	999.90	210.91
	36	5	303	3.30	3.30	0.00	0.00	5.01	990.00	197.45	990.00	197.45
C	37	6	330	3.00	3.00	0.00	0.00	5.29	880.20	166.48	880.20	166.48
	38	7	326	2.70	2.70	0.00	0.00	5.51	835.20	151.44	835.20	151.44
	39	8	348	2.40	2.40	0.00	0.00	5.74	703.50	122.50	703.50	122.50
	40	9	335	2.10	2.10	0.00	0.00	5.97	567.00	94.96	567.00	94.96
	41	10	315	1.80	1.80	0.00	0.00	6.20	322.50	52.03	322.50	52.03
D	42	11	215	1.50	1.50	0.00	0.00	6.43	202.80	31.56	202.80	31.56
	43	12	169	1.20	1.20	0.00	0.00	6.65	135.90	20.42	135.90	20.42
	44	13	151	0.90	0.90	0.00	0.00	6.88	63.00	9.15	63.00	9.15
	45	14	105	0.60	0.60	0.00	0.00	7.11	22.20	3.12	22.20	3.12
	46	15	74	0.30	0.30	0.00	0.00					
SUM			16111.80		4030.02				16111.80	4030.02	16111.80	4030.02
SCOP _{on}												4.00



Detailed test results

Detailed SCOP part load test results - low temperature application - average climate – EN 14825

Detailed result for 'EN14825:2022' Average Low (A and F) A -7/W34			
Tested according to:	EN14511:2022 and	EN14825:2022	
Climate zone:	Average		
Temperature application:	Low		
Condition name:	A and F		
Condition temperature:	°C	-7	
Part load:	%	88%	
Chosen Tbivalent	°C	-7	
Tdesign	°C	-10	
Pdesign	kW	9.20	
Heating demand:	kW	8.14	
CR:	-	1.0	
Minimum flow reached:	-	No	
Measurement type:	Transient		
Integrated circulation pump:	Yes		
Included corrections (Final result)			
Heating capacity	kW	8.087	
COP	-	2.777	
Power consumption	kW	2.912	
Measured			
Heating capacity	kW	8.099	
COP	-	2.767	
Power consumption	kW	2.927	
During heating			
Air temperature dry bulb	°C	-7.05	
Air temperature wet bulb	°C	-8.18	
Inlet temperature	°C	29.02	
Outlet temperature	°C	34.03	
Outlet temperature (Time averaged)	°C	34.03	
Circulation pump			
Measured: Static differential pressure, liquid pump	Pa	4917	
Calculated Hydraulic power	W	2	
Calculated global efficiency	η	0.14	
Calculated Capacity correction	W	13	
Calculated Power correction	W	15	
Water Flow	m³/s	0.000414	



Detailed result for 'EN14825:2022' Average Low (B) A 2 /W30		
Tested according to:	EN14511:2022 and EN14825:2022	
Climate zone:	Average	
Temperature application:	Low	
Condition name:	B	
Condition temperature:	°C	2
Part load:	%	54%
Chosen Tbivalent	°C	-7
Tdesign	°C	-10
Pdesign	kW	9.20
Heating demand:	kW	4.95
CR:	-	1.0
Minimum flow reached:	-	No
Measurement type:	Steady State	
Integrated circulation pump:	Yes	
Included corrections (Final result)		
Heating capacity	kW	5.066
COP	-	5.067
Power consumption	kW	1.000
Measured		
Heating capacity	kW	5.072
COP	-	5.037
Power consumption	kW	1.007
During heating		
Air temperature dry bulb	°C	2.00
Air temperature wet bulb	°C	0.93
Inlet temperature	°C	25.03
Outlet temperature	°C	30.04
Outlet temperature (Time averaged)	°C	30.04
Circulation pump		
Measured: Static differential pressure, liquid pump	Pa	3651
Calculated Hydraulic power	W	1
Calculated global efficiency	η	0.12
Calculated Capacity correction	W	6
Calculated Power correction	W	7
Water Flow	m³/s	0.000243



Detailed result for 'EN14825:2022' Average Low (C) A 7 /W27

Tested according to:	EN14511:2022 and EN14825:2022	Average
Climate zone:		Low
Temperature application:		C
Condition name:		Condition temperature:
Condition temperature:	°C	7
Part load:	%	35%
Chosen Tbivalent	°C	-7
Tdesign	°C	-10
Pdesign	kW	9.20
Heating demand:	kW	3.18
CR:	-	0.8
Minimum flow reached:	-	No
Measurement type:		Steady State
Integrated circulation pump:		Yes
Included corrections (Final result)		
Heating capacity	kW	3.770
COP	-	6.936
Power consumption	kW	0.544
Measured		
Heating capacity	kW	3.778
COP	-	6.834
Power consumption	kW	0.553
During heating		
Air temperature dry bulb	°C	7.01
Air temperature wet bulb	°C	6.00
Inlet temperature	°C	22.87
Outlet temperature	°C	27.74
Outlet temperature (Time averaged)	°C	26.99
Circulation pump		
Measured: Static differential pressure, liquid pump	Pa	6346
Calculated Hydraulic power	W	1
Calculated global efficiency	η	0.13
Calculated Capacity correction	W	8
Calculated Power correction	W	9
Water Flow	m³/s	0.000186



Detailed result for 'EN14825:2022' Average Low (D) A 12 /W24

Tested according to:	EN14511:2022 and EN14825:2022	Average
Climate zone:		Low
Temperature application:		D
Condition name:		
Condition temperature:	°C	12
Part load:	%	15%
Chosen Tbivalent	°C	-7
Tdesign	°C	-10
Pdesign	kW	9.20
Heating demand:	kW	1.42
CR:	-	0.3
Minimum flow reached:	-	No
Measurement type:		Steady State
Integrated circulation pump:		Yes
Included corrections (Final result)		
Heating capacity	kW	4.461
COP	-	9.176
Power consumption	kW	0.486
Measured		
Heating capacity	kW	4.464
COP	-	9.122
Power consumption	kW	0.489
During heating		
Air temperature dry bulb	°C	11.99
Air temperature wet bulb	°C	11.00
Inlet temperature	°C	22.38
Outlet temperature	°C	27.38
Outlet temperature (Time averaged)	°C	23.97
Circulation pump		
Measured: Static differential pressure, liquid pump	Pa	1743
Calculated Hydraulic power	W	0
Calculated global efficiency	η	0.12
Calculated Capacity correction	W	3
Calculated Power correction	W	3
Water Flow	m³/s	0.000214



Detailed result for 'EN14825:2022' Average Low (E) A -10 /W35			
Tested according to:	EN14511:2022 and EN14825:2022		
Climate zone:		Average	
Temperature application:		Low	
Condition name:		E	
Condition temperature:	°C	-10	
Part load:	%	100%	
Chosen Tbivalent	°C	-7	
Tdesign	°C	-10	
Pdesign	kW	9.20	
Heating demand:	kW	9.20	
CR:	-	1.0	
Minimum flow reached:	-	No	
Measurement type:		Transient	
Integrated circulation pump:		Yes	
Included corrections (Final result)			
Heating capacity	kW	8.524	
COP	-	2.482	
Power consumption	kW	3.434	
Measured			
Heating capacity	kW	8.558	
COP	-	2.461	
Power consumption	kW	3.477	
During heating			
Air temperature dry bulb	°C	-10.18	
Air temperature wet bulb	°C	-11.21	
Inlet temperature	°C	30.03	
Outlet temperature	°C	35.05	
Outlet temperature (Time averaged)	°C	35.05	
Circulation pump			
Measured: Static differential pressure, liquid pump	Pa	23072	
Calculated Hydraulic power	W	10	
Calculated global efficiency	n	0.23	
Calculated Capacity correction	W	33	
Calculated Power correction	W	43	
Water Flow	m³/s	0.000431	



Detailed SCOP part load test results - medium temperature application - average climate – EN 14825

Detailed result for 'EN14825:2022' Average Medium (A and F) A -7 /W52			
Tested according to:	EN14511:2022 and	EN14825:2022	
Climate zone:		Average	
Temperature application:		Medium	
Condition name:		A and F	
Condition temperature:	°C	-7	
Part load:	%	88%	
Chosen Tbivalent	°C	-7	
Tdesign	°C	-10	
Pdesign	kW	7.80	
Heating demand:	kW	6.90	
CR:	-	1.0	
Minimum flow reached:	-	No	
Measurement type:		Steady State	
Integrated circulation pump:		Yes	
Included corrections (Final result)			
Heating capacity	kW	7.067	
COP	-	2.377	
Power consumption	kW	2.973	
Measured			
Heating capacity	kW	7.071	
COP	-	2.375	
Power consumption	kW	2.977	
During heating			
Air temperature dry bulb	°C	-6.90	
Air temperature wet bulb	°C	-8.08	
Inlet temperature	°C	44.00	
Outlet temperature	°C	52.01	
Outlet temperature (Time averaged)	°C	52.01	
Circulation pump			
Measured: Static differential pressure, liquid pump	Pa	2231	
Calculated Hydraulic power	W	0	
Calculated global efficiency	η	0.12	
Calculated Capacity correction	W	4	
Calculated Power correction	W	4	
Water Flow	m³/s	0.000214	



Detailed result for 'EN14825:2022' Average Medium (B) A 2 /W42

Tested according to:	EN14511:2022 and EN14825:2022	
Climate zone:	Average	
Temperature application:	Medium	
Condition name:	B	
Condition temperature:	°C	2
Part load:	%	54%
Chosen Tbivalent	°C	-7
Tdesign	°C	-10
Pdesign	kW	7.80
Heating demand:	kW	4.20
CR:	-	1.0
Minimum flow reached:	-	No
Measurement type:	Steady State	
Integrated circulation pump:	Yes	
Included corrections (Final result)		
Heating capacity	kW	4.219
COP	-	3.922
Power consumption	kW	1.076
Measured		
Heating capacity	kW	4.223
COP	-	3.910
Power consumption	kW	1.080
During heating		
Air temperature dry bulb	°C	2.21
Air temperature wet bulb	°C	0.99
Inlet temperature	°C	33.98
Outlet temperature	°C	41.96
Outlet temperature (Time averaged)	°C	41.96
Circulation pump		
Measured: Static differential pressure, liquid pump	Pa	3654
Calculated Hydraulic power	W	0
Calculated global efficiency	η	0.12
Calculated Capacity correction	W	3
Calculated Power correction	W	4
Water Flow	m³/s	0.000128



Detailed result for 'EN14825:2022' Average Medium (C) A 7 /W36

Tested according to:	EN14511:2022 and EN14825:2022	
Climate zone:	Average	
Temperature application:	Medium	
Condition name:	C	
Condition temperature:	°C	7
Part load:	%	35%
Chosen Tbivalent	°C	-7
Tdesign	°C	-10
Pdesign	kW	7.80
Heating demand:	kW	2.70
CR:	-	0.7
Minimum flow reached:	-	No
Measurement type:	Steady State	
Integrated circulation pump:	Yes	
Included corrections (Final result)		
Heating capacity	kW	3.689
COP	-	5.311
Power consumption	kW	0.695
Measured		
Heating capacity	kW	3.695
COP	-	5.274
Power consumption	kW	0.701
During heating		
Air temperature dry bulb	°C	6.97
Air temperature wet bulb	°C	6.00
Inlet temperature	°C	30.29
Outlet temperature	°C	38.11
Outlet temperature (Time averaged)	°C	36.02
Circulation pump		
Measured: Static differential pressure, liquid pump	Pa	6378
Calculated Hydraulic power	W	1
Calculated global efficiency	η	0.12
Calculated Capacity correction	W	5
Calculated Power correction	W	6
Water Flow	m³/s	0.000114



Detailed result for 'EN14825:2022' Average Medium (D) A 12 /W30

Tested according to:	EN14511:2022 and EN14825:2022	
Climate zone:	Average Medium	
Temperature application:	Medium	
Condition name:	D	
Condition temperature:	°C	12
Part load:	%	15%
Chosen Tbivalent	°C	-7
Tdesign	°C	-10
Pdesign	kW	7.80
Heating demand:	kW	1.20
CR:	-	0.3
Minimum flow reached:	-	No
Measurement type:	Steady State	
Integrated circulation pump:	Yes	
Included corrections (Final result)		
Heating capacity	kW	4.230
COP	-	6.646
Power consumption	kW	0.636
Measured		
Heating capacity	kW	4.237
COP	-	6.577
Power consumption	kW	0.644
During heating		
Air temperature dry bulb	°C	11.98
Air temperature wet bulb	°C	10.99
Inlet temperature	°C	27.70
Outlet temperature	°C	35.69
Outlet temperature (Time averaged)	°C	29.97
Circulation pump		
Measured: Static differential pressure, liquid pump	Pa	7476
Calculated Hydraulic power	W	1
Calculated global efficiency	η	0.12
Calculated Capacity correction	W	7
Calculated Power correction	W	8
Water Flow	m³/s	0.000128



Detailed result for 'EN14825:2022' Average Medium (E) A -10 /W55

Tested according to:	EN14511:2022 and EN14825:2022	
Climate zone:	Average	
Temperature application:	Medium	
Condition name:	E	
Condition temperature:	°C	-10
Part load:	%	100%
Chosen Tbivalent	°C	-7
Tdesign	°C	-10
Pdesign	kW	7.80
Heating demand:	kW	7.80
CR:	-	1.0
Minimum flow reached:	-	No
Measurement type:	Steady State	
Integrated circulation pump:	Yes	
Included corrections (Final result)		
Heating capacity	kW	7.858
COP	-	2.025
Power consumption	kW	3.880
Measured		
Heating capacity	kW	7.863
COP	-	2.023
Power consumption	kW	3.887
During heating		
Air temperature dry bulb	°C	-9.94
Air temperature wet bulb	°C	-11.10
Inlet temperature	°C	47.02
Outlet temperature	°C	55.01
Outlet temperature (Time averaged)	°C	55.01
Circulation pump		
Measured: Static differential pressure, liquid pump	Pa	3421
Calculated Hydraulic power	W	1
Calculated global efficiency	η	0.12
Calculated Capacity correction	W	6
Calculated Power correction	W	7
Water Flow	m³/s	0.000239



Detailed SCOP part load test results - low temperature application - warmer climate – EN 1482

Detailed result for 'EN14825:2022' Warmer Low (C) A 7/W31			
Tested according to:	EN14511:2022 and EN14825:2022		
Climate zone:		Warmer	
Temperature application:		Low	
Condition name:		C	
Condition temperature:	°C	7	
Part load:	%	64%	
Chosen Tbivalent	°C	2	
Tdesign	°C	2	
Pdesign	kW	8.60	
Heating demand:	kW	5.53	
CR:	-	1.0	
Minimum flow reached:	-	No	
Measurement type:		Steady State	
Integrated circulation pump:		Yes	
Included corrections (Final result)			
Heating capacity	kW	5.482	
COP	-	6.214	
Power consumption	kW	0.882	
Measured			
Heating capacity	kW	5.488	
COP	-	6.174	
Power consumption	kW	0.889	
During heating			
Air temperature dry bulb	°C	7.01	
Air temperature wet bulb	°C	6.01	
Inlet temperature	°C	26.00	
Outlet temperature	°C	30.90	
Outlet temperature (Time averaged)	°C	30.90	
Circulation pump			
Measured: Static differential pressure, liquid pump	Pa	3036	
Calculated Hydraulic power	W	1	
Calculated global efficiency	n	0.12	
Calculated Capacity correction	w	6	
Calculated Power correction	w	7	
Water Flow	m³/s	0.000269	



Detailed SCOP part load test results - low temperature application - colder climate – EN 14825

Detailed result for 'EN14825:2022' Colder Low (A) A -7/W30			
Tested according to:	EN14511:2022 and	EN14825:2022	
Climate zone:		Colder	
Temperature application:		Low	
Condition name:		A	
Condition temperature:	°C	-7	
Part load:	%	61%	
Chosen Tbivalent	°C	-7	
Tdesign	°C	-22	
Pdesign	kW	7.90	
Heating demand:	kW	4.78	
CR:	-	1.0	
Minimum flow reached:	-	No	
Measurement type:		Steady State	
Integrated circulation pump:		Yes	
Included corrections (Final result)			
Heating capacity	kW	4.958	
COP	-	3.741	
Power consumption	kW	1.325	
Measured			
Heating capacity	kW	4.966	
COP	-	3.721	
Power consumption	kW	1.335	
During heating			
Air temperature dry bulb	°C	-7.01	
Air temperature wet bulb	°C	-8.00	
Inlet temperature	°C	25.01	
Outlet temperature	°C	30.07	
Outlet temperature (Time averaged)	°C	30.07	
Circulation pump			
Measured: Static differential pressure, liquid pump	Pa	5208	
Calculated Hydraulic power	W	1	
Calculated global efficiency	η	0.13	
Calculated Capacity correction	W	8	
Calculated Power correction	W	10	
Water Flow	m³/s	0.000236	



Detailed result for 'EN14825:2022' Colder Low (F and G) A -15 /W32

Tested according to:	EN14511:2022 and EN14825:2022	
Climate zone:		Colder
Temperature application:		Low
Condition name:		F and G
Condition temperature:	°C	-15
Part load:	%	82%
Chosen Tbivalent	°C	-15
Tdesign	°C	-22
Pdesign	kW	7.90
Heating demand:	kW	6.44
CR:	-	1.0
Minimum flow reached:	-	No
Measurement type:		Steady State
Integrated circulation pump:		Yes
Included corrections (Final result)		
Heating capacity	kW	6.516
COP	-	2.692
Power consumption	kW	2.421
Measured		
Heating capacity	kW	6.536
COP	-	2.673
Power consumption	kW	2.446
During heating		
Air temperature dry bulb	°C	-15.00
Inlet temperature	°C	26.98
Outlet temperature	°C	32.00
Outlet temperature (Time averaged)	°C	32.00
Circulation pump		
Measured: Static differential pressure, liquid pump	Pa	13023
Calculated Hydraulic power	W	4
Calculated global efficiency	η	0.16
Calculated Capacity correction	W	21
Calculated Power correction	W	25
Water Flow	m ³ /s	0.000313



Detailed COP test results - low temperature – EN 14511

Detailed result for 'EN14511:2022' A7/W35			
Tested according to:		EN14511:2022	
Minimum flow reached:		No	
Measurement type:		Steady State	
Integrated circulation pump:		Yes	
Included corrections (Final result)			
Heating capacity	kW	9.861	
COP	-	4.604	
Power consumption	kW	2.142	
Measured			
Heating capacity	kW	9.882	
COP	-	4.560	
Power consumption	kW	2.167	
During heating			
Air temperature dry bulb	°C	7.00	
Air temperature wet bulb	°C	6.02	
Inlet temperature	°C	30.00	
Outlet temperature	°C	35.00	
Circulation pump			
Measured: Static differential pressure, liquid pump	Pa	8627	
Calculated Hydraulic power	W	4	
Calculated global efficiency	η	0.16	
Calculated Capacity correction	W	21	
Calculated Power correction	W	25	
Water Flow	m³/s	0.000476	



Detailed COP test results - medium temperature – EN 14511

Detailed result for 'EN14511:2022' A7/W55		
Tested according to:		EN14511:2022
Minimum flow reached:		No
Measurement type:		Steady State
Integrated circulation pump:		Yes
Included corrections (Final result)		
Heating capacity	kW	9.416
COP	-	3.054
Power consumption	kW	3.083
Measured		
Heating capacity	kW	9.429
COP	-	3.043
Power consumption	kW	3.098
During heating		
Air temperature dry bulb	°C	7.02
Air temperature wet bulb	°C	5.90
Inlet temperature	°C	46.99
Outlet temperature	°C	55.07
Circulation pump		
Measured: Static differential pressure, liquid pump	Pa	7536
Calculated Hydraulic power	W	2
Calculated global efficiency	η	0.14
Calculated Capacity correction	W	13
Calculated Power correction	W	15
Water Flow	m³/s	0.000283



Detailed test results of sound power measurement – Test N#1

Mec-MRA		DANAK TEST Reg. nr. 300		Sound power levels according to ISO 3743-1:2010		TEKNOLOGISK INSTITUT																																																																																											
Engineering method for small, movable sources in reverberant fields - Comparison method for hard-walled test rooms																																																																																																	
Client:	Midea	Date of test:	07-02-2024																																																																																														
Object:	Type: Air to water heat pump Model: MHC-V10WD2N7																																																																																																
Mounting conditions:	The outdoor unit is mounted on the supporting metal support frame using six vibration insulators and placed on four pieces of concrete tiles (20x20x2.5 cm). All of these are placed in a water drop dry on two pieces of heavy concrete tiles (90x90x10cm) laying on a vibration damping mat on the floor. The noise radiated by the outdoor unit has been measured in Test room 2.																																																																																																
Operating conditions:	A7/W35, Compressor speed: 33[Hz], Fan speed: 400[rpm], Pump speed: 30 [%], EXV1(P): 90, Heating capacity: 3.73 [kW], Power_input: 1.27 [kW], Water flow rate: 410 [l/h]																																																																																																
Static pressure:	99.8 kPa	Reference box:																																																																																															
Air temperature:	7.0 °C	L1:	1.4 m																																																																																														
Relative air humidity:	84.0 %	L2:	0.4 m																																																																																														
Test room volume:	102.8 m ³	Room:	Room 2	L3:	0.9 m																																																																																												
Area, S, of test room:	138.9 m ²			Volume:	0.5 m ³																																																																																												
<table border="1"> <thead> <tr> <th>Frequency f [Hz]</th> <th>L_w 1/3 octave [dB]</th> <th>L_w 1/1 oct [dB]</th> </tr> </thead> <tbody> <tr><td>100</td><td>52.4</td><td></td></tr> <tr><td>125</td><td>50.1</td><td>55.1</td></tr> <tr><td>160</td><td>46.6</td><td></td></tr> <tr><td>200</td><td>46.7</td><td></td></tr> <tr><td>250</td><td>47.8</td><td>52.4</td></tr> <tr><td>315</td><td>48.2</td><td></td></tr> <tr><td>400</td><td>46.3</td><td></td></tr> <tr><td>500</td><td>44.3</td><td>49.8</td></tr> <tr><td>630</td><td>44.1</td><td></td></tr> <tr><td>800</td><td>41.6</td><td></td></tr> <tr><td>1000</td><td>40.5</td><td>45.6</td></tr> <tr><td>1250</td><td>40.1</td><td></td></tr> <tr><td>1600</td><td>35.4</td><td></td></tr> <tr><td>2000</td><td>34.8</td><td>39.0</td></tr> <tr><td>2500</td><td>31.6</td><td></td></tr> <tr><td>3150</td><td>30.7</td><td></td></tr> <tr><td>4000</td><td>29.8</td><td>35.9</td></tr> <tr><td>5000</td><td>32.4</td><td></td></tr> <tr><td>6300</td><td>30.6</td><td></td></tr> <tr><td>8000</td><td>28.9</td><td></td></tr> <tr><td>10000</td><td>29.8</td><td>34.6</td></tr> </tbody> </table>		Frequency f [Hz]	L _w 1/3 octave [dB]	L _w 1/1 oct [dB]	100	52.4		125	50.1	55.1	160	46.6		200	46.7		250	47.8	52.4	315	48.2		400	46.3		500	44.3	49.8	630	44.1		800	41.6		1000	40.5	45.6	1250	40.1		1600	35.4		2000	34.8	39.0	2500	31.6		3150	30.7		4000	29.8	35.9	5000	32.4		6300	30.6		8000	28.9		10000	29.8	34.6	<p>The chart displays sound power levels in dB across various frequency bands. The Y-axis ranges from 20 to 80 dB. The X-axis shows frequency points at 125, 250, 500, 1000, 2000, 4000, and 8000 Hz. Blue bars represent the sound power level Lw(A), and red bars represent LwW(A). The levels generally decrease as frequency increases, with a notable peak around 125-250 Hz.</p> <table border="1"> <caption>Data extracted from the sound power level chart</caption> <thead> <tr> <th>Frequency, f, Hz</th> <th>L_w (dB)</th> <th>L_{wW} (dB)</th> </tr> </thead> <tbody> <tr><td>125</td><td>55.1</td><td>38.0</td></tr> <tr><td>250</td><td>52.4</td><td>45.0</td></tr> <tr><td>500</td><td>49.8</td><td>46.0</td></tr> <tr><td>1000</td><td>45.6</td><td>45.5</td></tr> <tr><td>2000</td><td>39.0</td><td>40.0</td></tr> <tr><td>4000</td><td>35.9</td><td>36.5</td></tr> <tr><td>8000</td><td>34.6</td><td>34.0</td></tr> </tbody> </table>						Frequency, f, Hz	L _w (dB)	L _{wW} (dB)	125	55.1	38.0	250	52.4	45.0	500	49.8	46.0	1000	45.6	45.5	2000	39.0	40.0	4000	35.9	36.5	8000	34.6	34.0
Frequency f [Hz]	L _w 1/3 octave [dB]	L _w 1/1 oct [dB]																																																																																															
100	52.4																																																																																																
125	50.1	55.1																																																																																															
160	46.6																																																																																																
200	46.7																																																																																																
250	47.8	52.4																																																																																															
315	48.2																																																																																																
400	46.3																																																																																																
500	44.3	49.8																																																																																															
630	44.1																																																																																																
800	41.6																																																																																																
1000	40.5	45.6																																																																																															
1250	40.1																																																																																																
1600	35.4																																																																																																
2000	34.8	39.0																																																																																															
2500	31.6																																																																																																
3150	30.7																																																																																																
4000	29.8	35.9																																																																																															
5000	32.4																																																																																																
6300	30.6																																																																																																
8000	28.9																																																																																																
10000	29.8	34.6																																																																																															
Frequency, f, Hz	L _w (dB)	L _{wW} (dB)																																																																																															
125	55.1	38.0																																																																																															
250	52.4	45.0																																																																																															
500	49.8	46.0																																																																																															
1000	45.6	45.5																																																																																															
2000	39.0	40.0																																																																																															
4000	35.9	36.5																																																																																															
8000	34.6	34.0																																																																																															
Sound power level L_w(A): 51.1 dB [re 1pW], Uncertainty σ_{tot}: 1.6 dB																																																																																																	
Name of test institute:	DTI	Date:	07-02-2024																																																																																														
No. of test report:	300-KLAB-24-002																																																																																																
Measurements are in full conformity with ISO 3743-1																																																																																																	



Appendix 1

Unit specification

Type of unit: Mono air to water heat pump

Manufacturer: Midea

Size of the heat pump: 0.4 x 0.9 x 1.3m (W x L x H)

Year of production: n/a.

Operating conditions and environment

The operating conditions of the unit under test fulfill the requirements for Class A.

The acoustic test chamber is a hard wall reverberant room (103 m³) and equipped with relevant sound diffusing reflector panels. The acoustical test chamber fulfills the requirements of ISO3743-1 accuracy grade 2 (engineering grade).

The measurements of the average sound pressure levels in 1/3 octave frequency bands are carried out using three microphones in the test chamber. During the measurements, the microphones are traversed up and down for one meter in the arc of a quarter circle.

The picture below shows the installation of the unit during test, position of microphones, sound diffusing reflector panels, and the reference sound source.





Measurement instruments

Id nr.	Manufacturer	Description	Calibration company
100864	GRAS	Gras 40AE_26CA, ½" free field microphone, Room 1	Norsonic A/S, Norway
100865	GRAS	Gras 40AE_26CA, ½" free field microphone, Room 1	Norsonic A/S, Norway
100866	GRAS	Gras 40AE_26CA, ½" free field microphone, Room 1	Norsonic A/S, Norway
100867*	GRAS	Gras 40AE_26CA, ½" free field microphone, Room 2	Norsonic A/S, Norway
100868*	GRAS	Gras 40AE_26CA, ½" free field microphone, Room 2	Norsonic A/S, Norway
100869*	GRAS	Gras 40AE_26CA, ½" free field microphone, Room 2	Norsonic A/S, Norway
100870	GRAS	Gras 40AE_26CA, ½" free field microphone, Roof monitor	Norsonic A/S, Norway
100873*	Brüel & Kjær	Acoustical calibrator, Brüel & Kjær 4231	Element Metech, Denmark
100859	Norsonic	Reference sound source, Norsonic Nor278 Room 1	RISE, Sweden
100872*	Norsonic	Reference sound source, Norsonic Nor278 Room 2	RISE, Sweden
100620*	Norsonic	Multi-channel measurement system Nor850	Norsonic A/S, Norway

*Instruments are used for the actual measurements for the calculation of the test results.

The other instruments are used for control measurements.

All microphones are equipped with windshields.



Test Procedure

The measurements of the emitted sound power level from the heat pump are carried out according to the following standard:

- DS/EN 14511:2022
- EN 12102-1:2022
- ISO/EN 3743-1:2010

The basic acoustic measurement standard DS/EN 3743-1 is a comparison method using a calibrated reference sound source. Two series of sound pressure measurements are made under exactly the same acoustic conditions, e.g., the same microphone positions, temperature and air humidity. The calibrated sound power levels are known for the reference sound source at each frequency band, and they are used in the estimation of the acoustical correction factor for the calculation of the sound power emitted from the unit under test. The background noise levels are measured and used for relevant corrections.

The final total A-weighted sound power level is based on measurements and calculations in 1/3-octave levels, which then are summed into 1/1-octave levels. The A-weighted total sound power level is determined for the measured frequency range from 100 Hz to 10 kHz.

The actual microphone positions and correction values are saved in data files linked to the complete project documentation according to the DANAK-accreditation.

The complete measurement system is documented and regularly calibrated according to DANAK.

The detailed description of the measurement method is given in Danish in the quality database system "QA Web" at Danish Technological Institute, which is accessible by DANAK.

Measurement uncertainty

The uncertainty of sound power level in decibel is determined in accordance with ISO 3743-1, equation 22 $\sigma_{tot} = \sqrt{\sigma_{RO}^2 + \sigma_{omc}^2}$ where:

- σ_{RO} is the standard deviation of the reproducibility of the method
- σ_{omc} is the standard deviation describing the uncertainty associated with the instability of the operating and mounting conditions for the particular noise source during test.

σ_{RO} expresses the uncertainty in test results delivered by the different accredited test laboratories due to different instrumentation and implementation of measurement procedure as well different radiation characteristics of the noise source during test.

σ_{omc} expresses the uncertainty associated with the instability of the operating and mounting conditions for the particular noise source during test. The mounting and installation conditions in two DTI acoustical test chambers are well defined in the test procedure. Possible instability of the operating conditions is monitored and assessed prior to each noise test.



The test uncertainty σ_{omc} is calculated according to ISO3743-1 Annex C formula C.1 and is typically below 1.0dB. However, the uncertainty is rounded up to the nearest 0.5 or 1.0dB increment in the report. As pr. Table C.1 (accuracy grade 2), the uncertainty σ_{Ro} is set to 1.5.

The expanded uncertainty U is calculated according to ISO 3743-1 equation 23:

$U = k \sigma_{tot}$ where $k = 2$ for 95% confidence.

EXAMPLE: $\sigma_{tot}: \sqrt{1.5^2 + 0.5^2} = 1.6 \text{ dB}$ and $U(95\%) = 3.2 \text{ dB}$

Note: The expanded uncertainty does not include the standard deviation of production which is used in ISO4871 for the purpose of making noise declaration for batches of machines.

RAPORT Z BADANIA

Raport nr:
300-KLAB-24-002

[logo]
DUŃSKI INSTYTUT TECHNOLOGICZNY

Teknologiparken
Kongsvang Allé 29
DK-8000 Aarhus C
+45 72 20 20 00
Info@teknologisk.dk
www.teknologisk.dk

Strona 1 z 39
Ref.: RTHI/KAMA
Nr pliku: 226011
Załącznik: 1

Klient: Spółka: GD MIDEA HEATING & VENTILATING EQUIPMENT CO., LTD.
Adres: Penglai Industry Road, Beijiao
Miasto: Shunde, Foshan, Guangdong, 528311, Chiny
Tel: +86 13902810522

Komponent: Marka: Midea
Typ: Pompa ciepła powietrze-woda (monoblok)
Model: MHC-V10WD2N7
Nr serii: 541140007773A18010002Z
Rok prod: Jednostka zewnętrzna: NIE DOTYCZY

Daty: Badany komponent: Styczeń - Luty 2024

Procedura: Aby zapoznać się z listą norm, patrz cel (strona 2)

Uwagi: Urządzenie zostało dostarczone przez klienta. Montaż i ustawienia badawcze zostały wykonane zgodnie z instrukcjami producenta. Pomiędzy każdym badaniem Midea zmieniono różne parametry obejmujące prędkość sprężarki, zawór rozprężny, prędkość wentylatora, prędkość pompy, czas odszraniania, czas nagrzewania.

Warunki: Niniejsze badanie został przeprowadzone w ramach akredytacji zgodnie z międzynarodowymi wymogami (ISO/IEC 17025:2017) oraz zgodnie z Ogólnymi Warunkami Duńskiego Instytutu Technologicznego. Wyniki badania odnoszą się wyłącznie do badanego przedmiotu. Niniejszy raport z badania może być publikowany we fragmentach wyłącznie za pisemną zgodą Duńskiego Instytutu Technologicznego.

Klient nie może powoływać się na Duński Instytut Technologiczny lub pracowników Duńskiego Instytutu Technologicznego w celach reklamowych lub marketingowych, chyba że Duński Instytut Technologiczny udzielił pisemnej zgody w każdym przypadku.

Dział/Centrum: Duński Instytut Technologiczny
Energia i klimat
Laboratorium pomp ciepła, Aarhus

Data: 2024.03.19

Podpisał:
Rasmus Thisgaard
B.TecMan & MarEng

Sprawdził:
Kamathasan Arumugam
Inżynier

[logotypy]

Nr badania 300



[logo]

DUŃSKI INSTYTUT TECHNOLOGICZNY

Strona 2 z 39

300-KLAB-24-002

Pompy ciepła o identycznej konstrukcji

Według GD MIDEA HEATING & VENTILATING EQUIPMENT CO. LTD. Pompy ciepła wymienione w poniższej tabeli są uważane za identyczne z badaną jednostką. Mają one identyczne parametry:

- a. wydajność grzewcza
- b. cykl czynnika chłodniczego (w tym masa czynnika chłodniczego)
- c. źródło ciepła i medium pochłaniające
- d. główne komponenty / zasada eksploatacji i strategia sterowania
- e. ta sama obudowa zewnętrzna

Midea	MHC-V10WD2N7
Midea	MHC-V10WD2N7-E30
Midea	MHC-V10WD2N7-ER60
Midea	MHC-V10WD2N7-ER90

[logotypy]

Nr badania 300

KD



[logo]

DUŃSKI INSTYTUT TECHNOLOGICZNY

Strona 3 z 39

300-KLAB-24-002

Cel

Celem niniejszego raportu jest udokumentowanie następujących kwestii:

Sezonowy współczynnik wydajności (SCOP) przy zastosowaniu w niskiej i średniej temperaturze dla klimatu umiarkowanego zgodnie z normą EN 14825:2022.

W celu obliczenia SCOP przeprowadzono badania w warunkach obciążenia częściowego podanych w tabelach na stronie 5 i 6.

Badanie obciążenia częściowego SCOP w warunkach SCOP_c przy zastosowaniu w niskiej temperaturze dla cieplejszego klimatu zgodnie z EN 14825:2022.

Warunki badania obciążenia częściowego: SCOP_A i SCOP_{F/G} przy zastosowaniu w niskiej temperaturze dla chłodniejszego klimatu zgodnie z EN 14825:2022.

Standardowe warunki znamionowe badania COP A7/W35 i A7/W55 zgodnie z normą EN 14511:2022.

Wymagania eksploatacyjne zgodnie z normą EN 14511-4:2022

- 4.2.1 Badania rozruchowe i eksploatacyjne
- 4.5 Odcięcie przepływu nośnika ciepła
- 4.6 Całkowita awaria zasilania

Pomiary mocy akustycznej zgodnie z normą EN 12102-1:2022.

[logotypy]

Nr badania 300



Warunki badawcze

Warunki badawcze SCOP dla niskich temperatur - EN 14825

Warunki częściowego obciążenia dla referencyjnego SCOP i referencyjnego SCOPon przy obliczaniu jednostek powietrze-woda dla zastosowań niskotemperaturowych dla referencyjnego sezonu grzewczego; „A” = umiar. klimat, „W” = cieplejszy klimat, „C” = zimniejszy klimat.

	Współczynnik obciążenia częściowego w %				Zewnętrzny wymiennik ciepła		Wewnętrzny wymiennik ciepła			
					Temperatura termometru suchego (mokrego) °C	Stał wylot °C	Zmienny wylot d °C			
	Wzór	Umiar.	Cieplejszy	Chłodniejszy	Powietrze zewnętrz.	Wylot powietrza	Wszystkie klimaty	Umiar.	Cieplejszy	Chłodniejszy
A (-7 - 16) / (Tdesignh - 16)	88,46	nie dotyczy	60,53	-7(-8)	20(12)	a/35	a/34	nie dotyczy	a/30	
B (+2 - 16) / (Tdesignh - 16)	53,85	100,00	36,84	2(1)	20(12)	a/35	a/30	a/35	a/27	
C (+7 - 16) / (Tdesignh - 16)	34,62	64,29	23,68	7(6)	20(12)	a/35	a/27	a/31	a/25	
D (+12 - 16) / (Tdesignh - 16)	15,38	28,57	10,53	12(11)	20(12)	a/35	a/24	a/26	a/24	
E (TOLe - 16) / (Tdesignh - 16)				TOLe	20(12)	a/35	a/b	a/b	a/b	
F (Tbiv - 16) / (Tdesignh - 16)				Tbiv	20(12)	a/35	a/c	a/c	a/c	
G (-15 - 16) / (Tdesignh - 16)	nie dotyczy	nie dotyczy	81,58	-15	20(12)	a/35	nie dotyczy	nie dotyczy	a/32	

Dodatkowe informacje

Klimat	Tdesignh [°C]	Tbivalent [°C]	TOL [°C]	Temperatura na wylotie	Natężenie przepływu
Klimat umiar.	-10	-7	-10	Zmienna	Zmienne
Klimat cieplejszy	2	7	2	Zmienna	Zmienne
Klimat zimniejszy	-22	-15	-22	Zmienna	Zmienne

[logotypy]

Nr badania 300



Warunki badawcze SCOP dla średnich temperatur - EN 14825

Warunki częściowego obciążenia dla referencyjnego SCOP i referencyjnego SCOPon przy obliczaniu jednostek powietrze-woda dla zastosowań średniotemperaturowych dla referencyjnego sezonu grzewczego; „A” = umiar. klimat, „W” = cieplejszy klimat, „C” = zimniejszy klimat.

	Współczynnik obciążenia częściowego w %				Zewnętrzny wymiennik ciepła		Wewnętrzny wymiennik ciepła			
					Temperatura termometru suchego (mokrego) °C	Stał y wylot °C	Zmienny wylot °C			
	Wzór	Umiar.	Cieplejszy	Chłodniejszy	Powietrze zewnętrz.	Wylot powietrza	Wszystkie klimaty	Umiar.	Cieplejszy	Chłodniejszy
A (-7 - 16) / (Tdesignh - 16)	88,46	nie dotyczy	60,53	-7(-8)	20(12)	a/55	a/52	nie dotyczy	a/44	
B (+2 - 16) / (Tdesignh - 16)	53,85	100,00	36,84	2(1)	20(12)	a/55	a/42	a/55	a/37	
C (+7 - 16) / (Tdesignh - 16)	34,62	64,29	23,68	7(6)	20(12)	a/55	a/36	a/46	a/32	
D (+12 - 16) / (Tdesignh - 16)	15,38	28,57	10,53	12(11)	20(12)	a/55	a/30	a/34	a/28	
E <i>(TOLe - 16) / (Tdesignh - 16)</i>				<i>TOLe</i>	20(12)	a/55	a/b	a/b	a/b	
F <i>(Tbiv - 16) / (Tdesignh - 16)</i>				<i>Tbiv</i>	20(12)	a/55	a/c	a/c	a/c	
G (-15 - 16) / (Tdesignh - 16)	nie dotyczy	nie dotyczy	81,58	-15	20(12)	a/55	nie dotyczy	nie dotyczy	a/49	

Dodatkowe informacje

Klimat	Tdesignh [°C]	Tbivalent [°C]	TOL [°C]	Temperatura na wylocie	Nateżenie przepływu
Klimat umiar.	-10	-7	-10	Zmienna	Zmienne

[logotypy]

Nr badania 300



[logo]

DUŃSKI INSTYTUT TECHNOLOGICZNY

Strona 7 z 39

300-KLAB-24-002

Warunki badania COP - niska temperatura - EN 14511

Nr	Źródło ciepła		Radiator		Ustawienia pompy ciepła
	Temperatura termometru suchego na wlocie (°C)	Temperatura termometru mokrego na wlocie (°C)	Temperatura na wlocie (°C)	Temperatura na wylocie (°C)	
1 ^s	7	6	30	35	

S: Standardowy warunek oceny

Warunki badania COP - średnia temperatura - EN 14511

Nr	Źródło ciepła		Radiator		Ustawienia pompy ciepła
	Temperatura termometru suchego na wlocie (°C)	Temperatura termometru mokrego na wlocie (°C)	Temperatura na wlocie (°C)	Temperatura na wylocie (°C)	
1 ^s	7	6	47	55	

S: Standardowy warunek oceny

Warunki badawcze dla wymagań eksploatacyjnych - EN 14511-4

Nr	Źródło ciepła		Radiator	Natężenie przepływu wody wewnętrzny wymienniku ciepła	Badanie
	Temperatura termometru suchego na wlocie (°C)	Temperatura termometru mokrego na wlocie (°C)	Temperatura na wlocie (°C)		
1	-25	-	12	800 L/h	Rozruchowe
2	-25	-	38	710 L/h	Eksplotacyjne



[logo]

DUŃSKI INSTYTUT TECHNOLOGICZNY

Strona 8 z 39

300-KLAB-24-002

Warunki badawcze odcięcia nośnika ciepła - EN 14511-4

Nr	Źródło ciepła		Radiator		Wymiennik ciepła
	Temperatura termometru suchego na wlocie (°C)	Temperatura termometru mokrego na wlocie (°C)	Temperatura na wlocie (°C)	Temperatura na wylocie (°C)	
1	7	6	47	55	Wewnętrzny
2	7	6	47	55	Zewnętrzny

Warunki badania dla całkowitej awarii zasilania - EN 14511-4

Nr	Źródło ciepła		Radiator	
	Temperatura termometru suchego na wlocie (°C)	Temperatura termometru mokrego na wlocie (°C)	Temperatura na wlocie (°C)	Temperatura na wylocie (°C)
1	7	6	47	55

Warunki badawcze dla pomiarów mocy akustycznej - EN 12102-1

Nr	Warunki badania		Ustawienie pompy ciepła			
	Zewnętrzny wymiennik ciepła (termometr suchy / mokry) (°C)	Wewnętrzny wymiennik ciepła (wlot / wylot) (°C)	Prędkość sprężarki (Hz)	Prędkość wentylatora na zewnątrz (obr./min)	Moc grzewcza (kW)	Moc wejściowa (kW)
1E	7/6	47/55	33	400	3,73	1,27

E) Oznaczenie ErP

[logotypy]

Nr badania 300

The stamp contains the following text in a circular arrangement:

- Top: "REGULATR A KOS"
- Bottom: "PRZYSIĘGA JĘZYKA ANGIELSKIEGO"
- Left: "NR TP/313 07"
- Right: "ILUMACJA"


Wyniki badania**Wyniki badania SCOP w niskiej temperaturze - średnia sezonu grzewczego- EN 14825**

Model (zewnętrzny)	MHC-V10WD2N7		
Monoblokowa pompa ciepła powietrze-woda	T		
Niskotemperaturowa pompa ciepła	N		
Wyposażony w dodatkową grzałkę	N		
Kombinowany podgrzewacz z pompą ciepła	N		
Odwrotny	T		

Znamionowa moc cieplna ¹⁾	Pznam.		9,2 [kW]
Sezonowa efektywność energetyczna ogrzewania pomieszczeń	ns		200,4 [%]
	SCOP		5,09 [-]
Zmierzona wydajność ogrzewania dla częściowego obciążenia przy temperaturze zewnętrznej Tj	Klimat umiarkowany Zastosowanie w niskich temperaturach	Tj=-15 °C	Pdh - [kW]
		Tj=-7 °C	Pdh 8,09 [kW]
		Tj=2 °C	Pdh 5,07 [kW]
		Tj=7 °C	Pdh 3,77 [kW]
		Tj=12 °C	Pdh 4,46 [kW]
		Tj= temperatura dwuwartościowa	Pdh 8,09 [kW]
		Tj= limit operacyjny	Pdh 8,52 [kW]
Zmierzony współczynnik wydajności w temperaturze zewnętrznej Tj	Klimat umiarkowany Zastosowanie w niskich temperaturach	Tj=-15 °C	COPd -[-]
		Tj=-7 °C	COPd 2,78 [-]
		Tj=2 °C	COPd 5,07 [-]
		Tj=7 °C	COPd 6,94 [-]
		Tj=12 °C	COPd 9,18 [-]
		Tj= temperatura dwuwartościowa	COPd 2,78 [-]
		Tj= limit operacyjny	COPd 2,48 [-]
Temperatura dwuwartościowa	Tbivalent		-7 [°C]
Limit eksploatacji	TOL		-10 [°C]
temperatury	WTOL		-[°C]]
Współczynnik degradacji	Cdh		0,98 [-]
	Tryb Off	Poff	0,008 [kW]
Zużycie energii w trybach innych niż tryb aktywny	Termostat - Tryb off	PTO	0,009 [kW]
	Tryb gotowości	PSB	0,008 [kW]
	Tryb grzałki skrzyni korbowej ²⁾	PCK	0,008 [kW]
Grzałka dodatkowa 1)	Znamionowa moc cieplna Rodzaj pobieranej energii	Psup	0,68[kW] Elektryczna
Inne przedmioty	Kontrola wydajności		Zmienna
	Kontrola przepływu wody		Zmienna
	Natężenie przepływu wody		-
	Rocznego zużycie energii	QHE	3737 [kWh]

1) W przypadku ogrzewaczy pomieszczeń z pompą ciepła i wielofunkcyjnych ogrzewaczy z pompą ciepła znamionowa moc cieplna, Pznam., jest równa projektowemu obciążeniu grzewczemu, Pdesignh, a wskaźnik* mocy cieplnej dodatkowego ogrzewacza, Psup, jest równy dodatkowej wydajności grzewczej, sup(Tj).

2) Do obliczenia SCOP używana jest wartość PCK - PSB. Patrz sekcja "SCOP - szczegółowe obliczenia"



[logotypy]
Nr badania 300

Voj

Wyniki badania SCOP w średniej temperaturze - średnia sezonu grzewczego - EN 14825

Model (Zewnętrzny)	MHC-V10WD2N7
Monoblokowa pompa ciepła powietrze-woda	T
Niskotemperaturowa pompa ciepła	N
Wyposażony w dodatkową grzałkę	N
Kombinowany podgrzewacz z pompą ciepła	N
Odwrotny	T

Znamionowa moc cieplna ¹⁾	Pznam.		7,8 [kW]
Sezonowa efektywność energetyczna ogrzewania pomieszczeń	ns		156,9 [%]
	SCOP		4,00 [-]
Zmierzona wydajność ogrzewania dla częściowego obciążenia przy temperaturze zewnętrznej Tj	Klimat umiarkowany Zastosowanie w niskich temperaturach	Tj=-15 °C	Pdh - [kW]
		Tj=-7 °C	Pdh 7,07 [kW]
		Tj=2 °C	Pdh 4,22 [kW]
		Tj=7 °C	Pdh 3,69 [kW]
		Tj=12 °C	Pdh 4,23 [kW]
		Tj= temperatura dwuwartościowa	Pdh 7,07 [kW]
		Tj= limit operacyjny	Pdh 7,86 [kW]
Zmierzony współczynnik wydajności w temperaturze zewnętrznej Tj	Klimat umiarkowany Zastosowanie w niskich temperaturach	Tj=-15 °C	COPd - [-]
		Tj=-7 °C	COPd 2,38 [-]
		Tj=2 °C	COPd 3,92 [-]
		Tj=7 °C	COPd 5,31 [-]
		Tj=12 °C	COPd 6,65 [-]
		Tj= temperatura dwuwartościowa	COPd 2,38 [-]
		Tj= limit operacyjny	COPd 2,02 [-]
Temperatura dwuwartościowa	Tbivalent		-7 [°C]
Limit eksplotacji temperatury	TOL		-10 [°C]
Współczynnik degradacji	WTOL		- [°C]
	Cdh		0,99 [-]
	Tryb Off	P _{OFF}	0,008 [kW]
Zużycie energii w trybach innych niż tryb aktywny	Termostat - Tryb off	P _{TO}	0,009 [kW]
	Tryb gotowości	PSB	0,008 [kW]
	Tryb grzałki skrzyni korbowej	PCK	0,008 [kW]
Grzałka dodatkowa 1)	Znamionowa moc cieplna Rodzaj pobieranej energii	P _{sup}	0,00 [kW] Elektryczna
Inne przedmioty	Kontrola wydajności		Zmienna
	Kontrola przepływu wody		Zmienna
	Natężenie przepływu wody		-
	Rocznego zużycia energii	Q _{HE}	4032[kWh]


1) W przypadku ogrzewaczy pomieszczeń z pompą ciepła i wielofunkcyjnych ogrzewaczy z pompą ciepła znamionowa moc cieplna, Pznam., jest równa projektowemu obciążeniu grzewczemu, Pdesignh, a wskaźnik* mocy cieplnej dodatkowego ogrzewacza, P_{sup}, jest równy dodatkowej wydajności grzewczej, sup(Tj).

2) Do obliczenia SCOP używana jest wartość PCK - PSB. Patrz sekcja "SCOP - szczegółowe obliczenia"

[logotypy]

Nr badania 300

NR TP/313.07



[logo]

DUŃSKI INSTYTUT TECHNOLOGICZNY

Strona 11 z 39

300-KLAB-24-002

Wyniki badań dla cieplejszego klimatu, niska temperatura zgodnie z EN14825

Nr	Warunki badania	Moc grzewcza [kW]	COP
1	Tbivalent C	5,482	6,214

Wyniki badań dla chłodniejszego klimatu, niska temperatura zgodnie z EN14825

Nr	Warunki badania	Moc grzewcza [kW]	COP
1	A	4,958	3,741
2	Tbivalent F i G	6,516	2,692

Wyniki badania COP - niska temperatura - EN 14511

Nr	Warunki badania	Moc grzewcza [kW]	COP
1	A7/W35	9,861	4,604

Wyniki badania COP - średnia temperatura - EN 14511

Nr	Warunki badania	Moc grzewcza [kW]	COP
1	A7/W55	9,416	3,054

[logotypy]

Nr badania 300

Kos



[logo]

DUŃSKI INSTYTUT TECHNOLOGICZNY

Strona 12 z 39

300-KLAB-24-002

Wyniki badania rozruchu i eksploatacji - EN 14511-4

Nr	Warunki badawcze wlot powietrza/wody [°C]	Ocena badania
Rozruch	A-25/W12	Zaliczono
Eksplatacja	A-25/W48	Zaliczono

Wyniki badania odcięcia nośnika ciepła - EN 14511-4

Nr	Wymiennik ciepła	Ocena badania
1	Wewnętrzny	Zaliczono
2	Zewnętrzny	Zaliczono

Wyniki badania dla całkowitej awarii zasilania - EN 14511-4

Nr	Ocena badania
1	Zaliczono

[logotypy]

Nr badania 300

Kos



Wyniki pomiarów mocy akustycznej - EN 12102-1

Nr	Warunki badania	Poziom mocy akustycznej LW(A) [dB re 1pW]	Niepewność σ_{tot} [dB]
1F	A7/W55	51,5	1,6

E) Oznaczenie ErP

Całkowity poziom mocy akustycznej skorygowany charakterystyką A jest określany dla mierzonego zakresu częstotliwości od 100 Hz do 10 kHz. W celu obliczenia niepewności proszę zapoznać się z Załącznikiem 1.

Pomiary mocy akustycznej są przeprowadzane przez Kamalathasana Arumugama (KAMA) i sprawdzane przez Patricka Gliberta (PGL) z Duńskiego Instytutu Technologicznego.

[logotypy]
Nr badania 300

Ja, Małgorzata Kostrowska tłumacz przysięgły języka angielskiego (wpisana na listę tłumaczy przysięgłych Ministra Sprawiedliwości pod Nr TP/313/07), zaświadczam zgodność powyższego tłumaczenia z przedłożonym dokumentem sporządzonym w języku angielskim.
Nr rep.: 1232/2024

Data: 09.04.2024

Kos



OŚWIADCZENIE

Producent **GD Midea Heating & Ventilating Equipment Co. Ltd (Penglai industry road, Beijiao, Shunde, Foshan, Guangdong, P.R China)** oświadcza, iż pompy ciepła

1) MHC-V4W/D2N7-E30

Oznaczenie/typ/identyfikator modelu

2) MHC-V6W/D2N7-E30

Oznaczenie/typ/identyfikator modelu

3) MHC-V8W/D2N7-E30

Oznaczenie/typ/identyfikator modelu

4) MHC-V10W/D2N7-E30

Oznaczenie/typ/identyfikator modelu

5) MHC-V12W/D2RN7-E30

Oznaczenie/typ/identyfikator modelu

Należą do jednego podtypu w danym typoszeregu i spełniają łącznie następujące warunki:

- identyczna konstrukcja obiegu chłodniczego, ten sam czynnik chłodniczy/roboczy;
- ten sam producent, typ i liczba sprężarek;
- ten sam typ elementu rozprężnego;
- ten sam typ skraplacza;
- ten sam typ parownika;
- ten sam typ procesu odszraniania;
- ten sam sterownik i zasada sterowania wydajnością;
- ten sam producent, typ i liczba wentylatorów parownika (w przypadku powietrznych pomp ciepła) i zasada sterowania wydajnością (stała, zmienna lub stopniowana regulacja prędkości obrotowej);
- urządzenia z i bez zaworu czterodrogowego nie mogą być zaliczone do tego samego typoszeregu.

23.04.2024
Miejscowość, data


NABILATON Sp. z o.o.
Podgórska 5, 05-280 Kobyłka
Tel. 22 911 30 28
NIP 524-27-12-474, KRS 0000359324