DIN CERTCO
Gesellschaft für Konformitätsbewertung mbH

CERTIFICATE

Certificate holder	**Bosch Thermotechnik GmbH** **Sophienstr. 30-32** **35576 Wetzlar** **GERMANY**
Production facility	Aveiro, Tranas
Product	Air/Water Heat pumps
Type, Model	Buderus Logatherm WLW196i-6 AR and IR Buderus Logatherm WLW196i.2-4 AR
Testing basis	DIN EN 14511-1; DIN EN 14511-2; DIN EN 14511-3; DIN EN 14511-4:2019-07 DIN EN 14825:2019-07 DIN EN 12102-1:2018-02 DIN EN 16147:2017-08 European KEYMARK Scheme for Heat Pumps Rev. 8 (2020-09)
Mark of conformity	
Registration No.	011-1W0128
Valid until	2027-07-31
Right of use	This certificate entitles the holder to use the mark of conformity shown above in conjunction with the specified registration number. See annex for further information.

2021-05-17

S. Sy

Dipl.-Wi.-Ing. (FH) Sören Scholz
Head of Certification Body

DAkkS
Deutsche
Akkreditierungsstelle
D-ZE-11125-01-00

DIN

DIN CERTCO
Gesellschaft für Konformitätsbewertung mbH

ANNEX

Certificate	011-1W0128 dated 2021-05-17
Technical Data	See Heat Pump KEYMARK database for detailed information
Testing laboratory/ Inspection body	RISE Research Institutes of Sweden AB PO Box 857 501 15 Boras SWEDEN
Test report(s)	3P06665-04 rev 2 dated 2014-10-13

	Buderus Logatherm WLW196i-6 AR and IR, Buderus Logatherm WLW196i.2-4 AR	Reg. No.	011-1W0128
Certificate Holder			
	Bosch Thermotechnik GmbH (Buderus)		
	Sophienstraße 30-32		35576
	Wetzlar		Germany
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH		
Subtype title	Buderus Logatherm WLW196i-6 AR and IR, Buderus Logatherm WLW196i.2-4 AR		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R410A		
Mass of Refrigerant	1.75 kg		
Certification Date	18.07.2017		
Testing basis	HP KEYMARK certification scheme rules rev. 8		

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Model: Buderus Logatherm WLW196i-6 ARE

Configure model	
Model name	Buderus Logatherm WLW196i-6 ARE
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	2.29 kW	2.40 kW
El input	0.43 kW	0.88 kW
COP	5.27	2.75

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Warmer Climate

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	29 dB(A)	29 dB(A)
Sound power level outdoor	47 dB(A)	47 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	261 %	175 %
Prated	6.27 kW	5.60 kW
SCOP	6.59	4.45
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	6.27 kW	5.60 kW
COP Tj = +2°C	3.05	2.19
Pdh Tj = +7°C	4.09 kW	3.77 kW
COP Tj = +7°C	5.70	3.86
Pdh Tj = 12°C	1.79 kW	2.54 kW
COP Tj = 12°C	8.77	5.94
Pdh Tj = Tbiv	6.27 kW	5.60 kW
COP Tj = Tbiv	3.05	2.19
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.27 kW	5.60 kW

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.05	2.19
WTOL	60 °C	60 °C
Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	4 W	4 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	1270 kWh	1683 kWh

Colder Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	29 dB(A)	29 dB(A)
Sound power level outdoor	47 dB(A)	47 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	178 %	130 %
Prated	5.11 kW	4.82 kW
SCOP	4.53	3.32

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Tbiv	-17 °C	-17 °C
TOL	-20 °C	-19 °C
Pdh Tj = -7°C	3.20 kW	3.01 kW
COP Tj = -7°C	3.61	2.72
Pdh Tj = +2°C	1.80 kW	1.91 kW
COP Tj = +2°C	5.73	4.24
Pdh Tj = +7°C	1.19 kW	2.15 kW
COP Tj = +7°C	7.41	5.03
Pdh Tj = 12°C	1.31 kW	2.61 kW
COP Tj = 12°C	8.16	6.52
Pdh Tj = Tbiv	4.45 kW	4.20 kW
COP Tj = Tbiv	2.43	1.75
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.07 kW	3.39 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.25	1.65
WTOL	60 °C	60 °C
Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	4 W	4 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	5.11 kW	4.82 kW

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Annual energy consumption Qhe	2781 kWh	3575 kWh
Pdh Tj = -15°C (if TOL<-20°C)	4.15	1.97
COP Tj = -15°C (if TOL<-20°C)	2.68	1.97

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	29 dB(A)	29 dB(A)
Sound power level outdoor	47 dB(A)	47 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	202 %	143 %
Prated	5.43 kW	4.56 kW
SCOP	5.13	3.65
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	4.91 kW	4.26 kW
COP Tj = -7°C	3.08	2.24
Pdh Tj = +2°C	2.92 kW	2.57 kW
COP Tj = +2°C	5.00	3.66

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Pdh Tj = +7°C	1.84 kW	2.11 kW
COP Tj = +7°C	6.99	4.68
Pdh Tj = 12°C	1.33 kW	2.56 kW
COP Tj = 12°C	8.38	6.14
Pdh Tj = Tbiv	5.43 kW	4.56 kW
COP Tj = Tbiv	2.64	1.89
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.43 kW	4.56 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.64	1.89
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	1.00
WTOL	60 °C	60 °C
Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	4 W	4 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	2190 kWh	2580 kWh

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Model: Buderus Logatherm WLW196i-6 ARB

Configure model	
Model name	Buderus Logatherm WLW196i-6 ARB
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	2.29 kW	2.40 kW
El input	0.43 kW	0.88 kW
COP	5.27	2.75

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Warmer Climate

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	29 dB(A)	29 dB(A)
Sound power level outdoor	47 dB(A)	47 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	261 %	175 %
Prated	6.27 kW	5.60 kW
SCOP	6.59	4.45
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	6.27 kW	5.60 kW
COP Tj = +2°C	3.05	2.19
Pdh Tj = +7°C	4.09 kW	3.77 kW
COP Tj = +7°C	5.70	3.86
Pdh Tj = 12°C	1.79 kW	2.54 kW
COP Tj = 12°C	8.77	5.94
Pdh Tj = Tbiv	6.27 kW	5.60 kW
COP Tj = Tbiv	3.05	2.19
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.27 kW	5.60 kW

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.05	2.19
WTOL	60 °C	60 °C
Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	4 W	4 W
Supplementary Heater: Type of energy input	n/a	n/a
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	1270 kWh	1683 kWh

Colder Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	29 dB(A)	29 dB(A)
Sound power level outdoor	47 dB(A)	47 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	178 %	130 %
Prated	5.11 kW	4.82 kW
SCOP	4.53	3.32

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Tbiv	-17 °C	-17 °C
TOL	-20 °C	-19 °C
Pdh Tj = -7°C	3.20 kW	3.01 kW
COP Tj = -7°C	3.61	2.72
Pdh Tj = +2°C	1.80 kW	1.91 kW
COP Tj = +2°C	5.73	4.24
Pdh Tj = +7°C	1.19 kW	2.15 kW
COP Tj = +7°C	7.41	5.03
Pdh Tj = 12°C	1.31 kW	2.61 kW
COP Tj = 12°C	8.16	6.52
Pdh Tj = Tbiv	4.45 kW	4.20 kW
COP Tj = Tbiv	2.43	1.75
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.07 kW	3.39 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.25	1.65
WTOL	60 °C	60 °C
Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	4 W	4 W
Supplementary Heater: Type of energy input	n/a	n/a
Supplementary Heater: PSUP	0.00 kW	0.00 kW

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Annual energy consumption Qhe	2781 kWh	3575 kWh
Pdh Tj = -15°C (if TOL<-20°C)	4.15	1.97
COP Tj = -15°C (if TOL<-20°C)	2.68	1.97

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	29 dB(A)	29 dB(A)
Sound power level outdoor	47 dB(A)	47 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	202 %	143 %
Prated	5.43 kW	4.56 kW
SCOP	5.13	3.65
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	4.91 kW	4.26 kW
COP Tj = -7°C	3.08	2.24
Pdh Tj = +2°C	2.92 kW	2.57 kW
COP Tj = +2°C	5.00	3.66

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Pdh Tj = +7°C	1.84 kW	2.11 kW
COP Tj = +7°C	6.99	4.68
Pdh Tj = 12°C	1.33 kW	2.56 kW
COP Tj = 12°C	8.38	6.14
Pdh Tj = Tbiv	5.43 kW	4.56 kW
COP Tj = Tbiv	2.64	1.89
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.43 kW	4.56 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.64	1.89
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	1.00
WTOL	60 °C	60 °C
Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	4 W	4 W
Supplementary Heater: Type of energy input	n/a	n/a
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	2190 kWh	2580 kWh

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Model: Buderus Logatherm WLW196i-6 ART190

Configure model	
Model name	Buderus Logatherm WLW196i-6 ART190
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	2.29 kW	2.40 kW
El input	0.43 kW	0.88 kW
COP	5.27	2.75

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Warmer Climate

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	25 dB(A)	25 dB(A)
Sound power level outdoor	47 dB(A)	47 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	261 %	175 %
Prated	6.27 kW	5.60 kW
SCOP	6.59	4.45
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	6.27 kW	5.60 kW
COP Tj = +2°C	3.05	2.19
Pdh Tj = +7°C	4.09 kW	3.77 kW
COP Tj = +7°C	5.70	3.86
Pdh Tj = 12°C	1.79 kW	2.54 kW
COP Tj = 12°C	8.77	5.94
Pdh Tj = Tbiv	6.27 kW	5.60 kW
COP Tj = Tbiv	3.05	2.19
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.27 kW	5.60 kW

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.05	2.19
WTOL	60 °C	60 °C
Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	4 W	4 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	1270 kWh	1683 kWh

Colder Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	25 dB(A)	25 dB(A)
Sound power level outdoor	47 dB(A)	47 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	178 %	130 %
Prated	5.11 kW	4.82 kW
SCOP	4.53	3.32

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Tbiv	-17 °C	-17 °C
TOL	-20 °C	-19 °C
Pdh Tj = -7°C	3.20 kW	3.01 kW
COP Tj = -7°C	3.61	2.72
Pdh Tj = +2°C	1.80 kW	1.91 kW
COP Tj = +2°C	5.73	4.24
Pdh Tj = +7°C	1.19 kW	2.15 kW
COP Tj = +7°C	7.41	5.03
Pdh Tj = 12°C	1.31 kW	2.61 kW
COP Tj = 12°C	8.16	6.52
Pdh Tj = Tbiv	4.45 kW	4.20 kW
COP Tj = Tbiv	2.43	1.75
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.07 kW	3.39 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.25	1.65
WTOL	60 °C	60 °C
Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	4 W	4 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	5.11 kW	4.82 kW

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Annual energy consumption Qhe	2781 kWh	3575 kWh
Pdh Tj = -15°C (if TOL<-20°C)	4.15	1.97
COP Tj = -15°C (if TOL<-20°C)	2.68	1.97

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	25 dB(A)	25 dB(A)
Sound power level outdoor	47 dB(A)	47 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	202 %	143 %
Prated	5.43 kW	4.56 kW
SCOP	5.13	3.65
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	4.91 kW	4.26 kW
COP Tj = -7°C	3.08	2.24
Pdh Tj = +2°C	2.92 kW	2.57 kW
COP Tj = +2°C	5.00	3.66

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Pdh Tj = +7°C	1.84 kW	2.11 kW
COP Tj = +7°C	6.99	4.68
Pdh Tj = 12°C	1.33 kW	2.56 kW
COP Tj = 12°C	8.38	6.14
Pdh Tj = Tbiv	5.43 kW	4.56 kW
COP Tj = Tbiv	2.64	1.89
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.43 kW	4.56 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.64	1.89
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	1.00
WTOL	60 °C	60 °C
Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	4 W	4 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	2190 kWh	2580 kWh

Domestic Hot Water (DHW)

Warmer Climate

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

EN 16147	
Declared load profile	L
Efficiency ηDHW	119 %
COP	2.79
Heating up time	02:31 h:min
Standby power input	45.0 W
Reference hot water temperature	54.2 °C
Mixed water at 40°C	271 l

Colder Climate

EN 16147	
Declared load profile	L
Efficiency ηDHW	97 %
COP	2.26
Heating up time	04:04 h:min
Standby power input	64.0 W
Reference hot water temperature	53.1 °C
Mixed water at 40°C	271 l

Average Climate

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

EN 16147

Declared load profile	L
Efficiency ηDHW	106 %
COP	2.48
Heating up time	03:14 h:min
Standby power input	51.0 W
Reference hot water temperature	54.3 °C
Mixed water at 40°C	273 l

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Model: Buderus Logatherm WLW196i-6 ARTS185

Configure model	
Model name	Buderus Logatherm WLW196i-6 ARTS185
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	2.29 kW	2.40 kW
El input	0.43 kW	0.88 kW
COP	5.27	2.75

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Warmer Climate

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	25 dB(A)	25 dB(A)
Sound power level outdoor	47 dB(A)	47 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	261 %	175 %
Prated	6.27 kW	5.60 kW
SCOP	6.59	4.45
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	6.27 kW	5.60 kW
COP Tj = +2°C	3.05	2.19
Pdh Tj = +7°C	4.09 kW	3.77 kW
COP Tj = +7°C	5.70	3.86
Pdh Tj = 12°C	1.79 kW	2.54 kW
COP Tj = 12°C	8.77	5.94
Pdh Tj = Tbiv	6.27 kW	5.60 kW
COP Tj = Tbiv	3.05	2.19
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.27 kW	5.60 kW

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.05	2.19
WTOL	60 °C	60 °C
Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	4 W	4 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	1270 kWh	1683 kWh

Colder Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	25 dB(A)	25 dB(A)
Sound power level outdoor	47 dB(A)	47 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	178 %	130 %
Prated	5.11 kW	4.82 kW
SCOP	4.53	3.32

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Tbiv	-17 °C	-17 °C
TOL	-20 °C	-19 °C
Pdh Tj = -7°C	3.20 kW	3.01 kW
COP Tj = -7°C	3.61	2.72
Pdh Tj = +2°C	1.80 kW	1.91 kW
COP Tj = +2°C	5.73	4.24
Pdh Tj = +7°C	1.19 kW	2.15 kW
COP Tj = +7°C	7.41	5.03
Pdh Tj = 12°C	1.31 kW	2.61 kW
COP Tj = 12°C	8.16	6.52
Pdh Tj = Tbiv	4.45 kW	4.20 kW
COP Tj = Tbiv	2.43	1.75
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.07 kW	3.39 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.25	1.65
WTOL	60 °C	60 °C
Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	4 W	4 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	5.11 kW	4.82 kW

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Annual energy consumption Qhe	2781 kWh	3575 kWh
Pdh Tj = -15°C (if TOL<-20°C)	4.15	1.97
COP Tj = -15°C (if TOL<-20°C)	2.68	1.97

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	25 dB(A)	25 dB(A)
Sound power level outdoor	47 dB(A)	47 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	202 %	143 %
Prated	5.43 kW	4.56 kW
SCOP	5.13	3.65
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	4.91 kW	4.26 kW
COP Tj = -7°C	3.08	2.24
Pdh Tj = +2°C	2.92 kW	2.57 kW
COP Tj = +2°C	5.00	3.66

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Pdh Tj = +7°C	1.84 kW	2.11 kW
COP Tj = +7°C	6.99	4.68
Pdh Tj = 12°C	1.33 kW	2.56 kW
COP Tj = 12°C	8.38	6.14
Pdh Tj = Tbiv	5.43 kW	4.56 kW
COP Tj = Tbiv	2.64	1.89
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.43 kW	4.56 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.64	1.89
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	1.00
WTOL	60 °C	60 °C
Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	4 W	4 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	2190 kWh	2580 kWh

Domestic Hot Water (DHW)

Warmer Climate

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

EN 16147	
Declared load profile	L
Efficiency ηDHW	109 %
COP	2.58
Heating up time	02:34 h:min
Standby power input	47.0 W
Reference hot water temperature	52.8 °C
Mixed water at 40°C	257 l

Colder Climate

EN 16147	
Declared load profile	L
Efficiency ηDHW	95 %
COP	2.21
Heating up time	04:09 h:min
Standby power input	73.0 W
Reference hot water temperature	51.2 °C
Mixed water at 40°C	259 l

Average Climate

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

EN 16147	
Declared load profile	L
Efficiency ηDHW	103 %
COP	2.43
Heating up time	03:18 h:min
Standby power input	53.0 W
Reference hot water temperature	53.2 °C
Mixed water at 40°C	263 l

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Model: Buderus Logatherm WLW196i-6 IRE

Configure model	
Model name	Buderus Logatherm WLW196i-6 IRE
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	2.29 kW	2.34 kW
El input	0.46 kW	0.87 kW
COP	4.96	2.67

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Warmer Climate

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	48 dB(A)	48 dB(A)
Sound power level outdoor	36 dB(A)	36 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	255 %	163 %
Prated	5.77 kW	5.08 kW
SCOP	6.45	4.16
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	5.77 kW	5.08 kW
COP Tj = +2°C	2.91	2.09
Pdh Tj = +7°C	3.39 kW	3.55 kW
COP Tj = +7°C	5.70	3.62
Pdh Tj = 12°C	1.79 kW	2.42 kW
COP Tj = 12°C	8.45	5.56
Pdh Tj = Tbiv	5.77 kW	5.08 kW
COP Tj = Tbiv	2.91	2.09
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.77 kW	5.08 kW

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.91	2.09
WTOL	60 °C	60 °C
Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	4 W	4 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	1195 kWh	1631 kWh

Colder Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	48 dB(A)	48 dB(A)
Sound power level outdoor	36 dB(A)	36 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	168 %	128 %
Prated	5.27 kW	4.82 kW
SCOP	4.27	3.28

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Tbiv	-16 °C	-15 °C
TOL	-20 °C	-18 °C
Pdh Tj = -7°C	3.20 kW	2.91 kW
COP Tj = -7°C	3.17	2.72
Pdh Tj = +2°C	1.80 kW	1.91 kW
COP Tj = +2°C	5.73	4.24
Pdh Tj = +7°C	1.14 kW	2.15 kW
COP Tj = +7°C	7.41	5.03
Pdh Tj = 12°C	1.31 kW	2.61 kW
COP Tj = 12°C	8.16	6.52
Pdh Tj = Tbiv	4.45 kW	3.89 kW
COP Tj = Tbiv	2.43	1.97
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	3.50 kW	3.09 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.07	1.64
WTOL	60 °C	60 °C
Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	4 W	4 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	5.27 kW	4.82 kW

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Annual energy consumption Qhe	3040 kWh	3621 kWh
Pdh Tj = -15°C (if TOL<-20°C)	4.15	1.97
COP Tj = -15°C (if TOL<-20°C)	2.44	1.97

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	48 dB(A)	48 dB(A)
Sound power level outdoor	36 dB(A)	36 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	184 %	140 %
Prated	5.18 kW	4.20 kW
SCOP	4.68	3.57
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	4.67 kW	3.86 kW
COP Tj = -7°C	2.95	2.24
Pdh Tj = +2°C	2.81 kW	2.38 kW
COP Tj = +2°C	4.26	3.66

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Pdh Tj = +7°C	1.84 kW	2.11 kW
COP Tj = +7°C	6.99	4.43
Pdh Tj = 12°C	1.33 kW	2.56 kW
COP Tj = 12°C	8.06	5.56
Pdh Tj = Tbiv	5.18 kW	4.20 kW
COP Tj = Tbiv	2.64	1.89
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.18 kW	4.20 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.64	1.89
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	60 °C	60 °C
Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	4 W	4 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	2289 kWh	2431 kWh

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Model: Buderus Logatherm WLW196i-6 IRB

Configure model	
Model name	Buderus Logatherm WLW196i-6 IRB
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	2.29 kW	2.34 kW
El input	0.46 kW	0.87 kW
COP	4.96	2.67

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Warmer Climate

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	48 dB(A)	48 dB(A)
Sound power level outdoor	36 dB(A)	36 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	255 %	163 %
Prated	5.77 kW	5.08 kW
SCOP	6.45	4.16
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	5.77 kW	5.08 kW
COP Tj = +2°C	2.91	2.09
Pdh Tj = +7°C	3.39 kW	3.55 kW
COP Tj = +7°C	5.70	3.62
Pdh Tj = 12°C	1.79 kW	2.42 kW
COP Tj = 12°C	8.45	5.56
Pdh Tj = Tbiv	5.77 kW	5.08 kW
COP Tj = Tbiv	2.91	2.09
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.77 kW	5.08 kW

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.91	2.09
WTOL	60 °C	60 °C
Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	4 W	4 W
Supplementary Heater: Type of energy input	n/a	n/a
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	1195 kWh	1631 kWh

Colder Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	48 dB(A)	48 dB(A)
Sound power level outdoor	36 dB(A)	36 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	168 %	128 %
Prated	5.27 kW	4.82 kW
SCOP	4.27	3.28

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Tbiv	-16 °C	-15 °C
TOL	-20 °C	-18 °C
Pdh Tj = -7°C	3.20 kW	2.91 kW
COP Tj = -7°C	3.17	2.72
Pdh Tj = +2°C	1.80 kW	1.91 kW
COP Tj = +2°C	5.73	4.24
Pdh Tj = +7°C	1.14 kW	2.15 kW
COP Tj = +7°C	7.41	5.03
Pdh Tj = 12°C	1.31 kW	2.61 kW
COP Tj = 12°C	8.16	6.52
Pdh Tj = Tbiv	4.45 kW	3.89 kW
COP Tj = Tbiv	2.43	1.97
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	3.50 kW	3.09 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.07	1.64
WTOL	60 °C	60 °C
Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	4 W	4 W
Supplementary Heater: Type of energy input	n/a	n/a
Supplementary Heater: PSUP	0.00 kW	0.00 kW

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Annual energy consumption Qhe	3040 kWh	3621 kWh
Pdh Tj = -15°C (if TOL<-20°C)	4.15	1.97
COP Tj = -15°C (if TOL<-20°C)	2.44	1.97

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	48 dB(A)	48 dB(A)
Sound power level outdoor	36 dB(A)	36 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	184 %	140 %
Prated	5.18 kW	4.20 kW
SCOP	4.68	3.57
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	4.67 kW	3.86 kW
COP Tj = -7°C	2.95	2.24
Pdh Tj = +2°C	2.81 kW	2.38 kW
COP Tj = +2°C	4.26	3.66

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Pdh Tj = +7°C	1.84 kW	2.11 kW
COP Tj = +7°C	6.99	4.43
Pdh Tj = 12°C	1.33 kW	2.56 kW
COP Tj = 12°C	8.06	5.56
Pdh Tj = Tbiv	5.18 kW	4.20 kW
COP Tj = Tbiv	2.64	1.89
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.18 kW	4.20 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.64	1.89
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	60 °C	60 °C
Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	4 W	4 W
Supplementary Heater: Type of energy input	n/a	n/a
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	2289 kWh	2431 kWh

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Model: Buderus Logatherm WLW196i-6 IRT190

Configure model	
Model name	Buderus Logatherm WLW196i-6 IRT190
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	2.29 kW	2.34 kW
El input	0.46 kW	0.87 kW
COP	4.96	2.67

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Warmer Climate

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	48 dB(A)	48 dB(A)
Sound power level outdoor	36 dB(A)	36 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	255 %	163 %
Prated	5.77 kW	5.08 kW
SCOP	6.45	4.16
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	5.77 kW	5.08 kW
COP Tj = +2°C	2.91	2.09
Pdh Tj = +7°C	3.39 kW	3.55 kW
COP Tj = +7°C	5.70	3.62
Pdh Tj = 12°C	1.79 kW	2.42 kW
COP Tj = 12°C	8.45	5.56
Pdh Tj = Tbiv	5.77 kW	5.08 kW
COP Tj = Tbiv	2.91	2.09
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.77 kW	5.08 kW

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.91	2.09
WTOL	60 °C	60 °C
Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	4 W	4 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	1195 kWh	1631 kWh

Colder Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	48 dB(A)	48 dB(A)
Sound power level outdoor	36 dB(A)	36 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	168 %	128 %
Prated	5.27 kW	4.82 kW
SCOP	4.27	3.28

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Tbiv	-16 °C	-15 °C
TOL	-20 °C	-18 °C
Pdh Tj = -7°C	3.20 kW	2.91 kW
COP Tj = -7°C	3.17	2.72
Pdh Tj = +2°C	1.80 kW	1.91 kW
COP Tj = +2°C	5.73	4.24
Pdh Tj = +7°C	1.14 kW	2.15 kW
COP Tj = +7°C	7.41	5.03
Pdh Tj = 12°C	1.31 kW	2.61 kW
COP Tj = 12°C	8.16	6.52
Pdh Tj = Tbiv	4.45 kW	3.89 kW
COP Tj = Tbiv	2.43	1.97
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	3.50 kW	3.09 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.07	1.64
WTOL	60 °C	60 °C
Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	4 W	4 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	5.27 kW	4.82 kW

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Annual energy consumption Qhe	3040 kWh	3621 kWh
Pdh Tj = -15°C (if TOL<-20°C)	4.15	1.97
COP Tj = -15°C (if TOL<-20°C)	2.44	1.97

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	48 dB(A)	48 dB(A)
Sound power level outdoor	36 dB(A)	36 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	184 %	140 %
Prated	5.18 kW	4.20 kW
SCOP	4.68	3.57
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	4.67 kW	3.86 kW
COP Tj = -7°C	2.95	2.24
Pdh Tj = +2°C	2.81 kW	2.38 kW
COP Tj = +2°C	4.26	3.66

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Pdh Tj = +7°C	1.84 kW	2.11 kW
COP Tj = +7°C	6.99	4.43
Pdh Tj = 12°C	1.33 kW	2.56 kW
COP Tj = 12°C	8.06	5.56
Pdh Tj = Tbiv	5.18 kW	4.20 kW
COP Tj = Tbiv	2.64	1.89
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.18 kW	4.20 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.64	1.89
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	60 °C	60 °C
Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	4 W	4 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	2289 kWh	2431 kWh

Domestic Hot Water (DHW)

Warmer Climate

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

EN 16147	
Declared load profile	L
Efficiency ηDHW	119 %
COP	2.80
Heating up time	02:31 h:min
Standby power input	45.0 W
Reference hot water temperature	54.2 °C
Mixed water at 40°C	271 l

Colder Climate

EN 16147	
Declared load profile	L
Efficiency ηDHW	97 %
COP	2.26
Heating up time	04:04 h:min
Standby power input	64.0 W
Reference hot water temperature	53.1 °C
Mixed water at 40°C	271 l

Average Climate

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

EN 16147

Declared load profile	L
Efficiency ηDHW	106 %
COP	2.48
Heating up time	03:14 h:min
Standby power input	51.0 W
Reference hot water temperature	54.3 °C
Mixed water at 40°C	273 l

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Model: Buderus Logatherm WLW196i-6 IRTS185

Configure model	
Model name	Buderus Logatherm WLW196i-6 IRTS185
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	2.29 kW	2.34 kW
El input	0.46 kW	0.87 kW
COP	4.96	2.67

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Warmer Climate

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	48 dB(A)	48 dB(A)
Sound power level outdoor	36 dB(A)	36 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	255 %	163 %
Prated	5.77 kW	5.08 kW
SCOP	6.45	4.16
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	5.77 kW	5.08 kW
COP Tj = +2°C	2.91	2.09
Pdh Tj = +7°C	3.39 kW	3.55 kW
COP Tj = +7°C	5.70	3.62
Pdh Tj = 12°C	1.79 kW	2.42 kW
COP Tj = 12°C	8.45	5.56
Pdh Tj = Tbiv	5.77 kW	5.08 kW
COP Tj = Tbiv	2.91	2.09
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.77 kW	5.08 kW

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.91	2.09
WTOL	60 °C	60 °C
Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	4 W	4 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	1195 kWh	1631 kWh

Colder Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	48 dB(A)	48 dB(A)
Sound power level outdoor	36 dB(A)	36 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	168 %	128 %
Prated	5.27 kW	4.82 kW
SCOP	4.27	3.28

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Tbiv	-16 °C	-15 °C
TOL	-20 °C	-18 °C
Pdh Tj = -7°C	3.20 kW	2.91 kW
COP Tj = -7°C	3.17	2.72
Pdh Tj = +2°C	1.80 kW	1.91 kW
COP Tj = +2°C	5.73	4.24
Pdh Tj = +7°C	1.14 kW	2.15 kW
COP Tj = +7°C	7.41	5.03
Pdh Tj = 12°C	1.31 kW	2.61 kW
COP Tj = 12°C	8.16	6.52
Pdh Tj = Tbiv	4.45 kW	3.89 kW
COP Tj = Tbiv	2.43	1.97
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	3.50 kW	3.09 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.07	1.64
WTOL	60 °C	60 °C
Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	4 W	4 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	5.27 kW	4.82 kW

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Annual energy consumption Qhe	3040 kWh	3621 kWh
Pdh Tj = -15°C (if TOL<-20°C)	4.15	1.97
COP Tj = -15°C (if TOL<-20°C)	2.44	1.97

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	48 dB(A)	48 dB(A)
Sound power level outdoor	36 dB(A)	36 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	184 %	140 %
Prated	5.18 kW	4.20 kW
SCOP	4.68	3.57
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	4.67 kW	3.86 kW
COP Tj = -7°C	2.95	2.24
Pdh Tj = +2°C	2.81 kW	2.38 kW
COP Tj = +2°C	4.26	3.66

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Pdh Tj = +7°C	1.84 kW	2.11 kW
COP Tj = +7°C	6.99	4.43
Pdh Tj = 12°C	1.33 kW	2.56 kW
COP Tj = 12°C	8.06	5.56
Pdh Tj = Tbiv	5.18 kW	4.20 kW
COP Tj = Tbiv	2.64	1.89
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.18 kW	4.20 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.64	1.89
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	60 °C	60 °C
Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	4 W	4 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	2289 kWh	2431 kWh

Domestic Hot Water (DHW)

Warmer Climate

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

EN 16147	
Declared load profile	L
Efficiency ηDHW	109 %
COP	2.58
Heating up time	02:34 h:min
Standby power input	47.0 W
Reference hot water temperature	52.8 °C
Mixed water at 40°C	257 l

Colder Climate

EN 16147	
Declared load profile	L
Efficiency ηDHW	95 %
COP	2.21
Heating up time	04:09 h:min
Standby power input	73.0 W
Reference hot water temperature	51.8 °C
Mixed water at 40°C	259 l

Average Climate

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

EN 16147

Declared load profile	L
Efficiency ηDHW	103 %
COP	2.43
Heating up time	03:18 h:min
Standby power input	53.0 W
Reference hot water temperature	53.2 °C
Mixed water at 40°C	263 l

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Model: Buderus Logatherm WLW196i.2-4 ARB S+

Configure model	
Model name	Buderus Logatherm WLW196i.2-4 ARB S+
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	2.82 kW	1.78 kW
El input	0.56 kW	0.69 kW
COP	5.01	2.57

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Warmer Climate

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	29 dB(A)	29 dB(A)
Sound power level outdoor	50 dB(A)	50 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	240 %	163 %
Prated	5.50 kW	5.40 kW
SCOP	6.07	4.16
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	5.48 kW	5.40 kW
COP Tj = +2°C	3.03	2.10
Pdh Tj = +7°C	3.81 kW	3.56 kW
COP Tj = +7°C	5.16	3.57
Pdh Tj = 12°C	1.71 kW	2.44 kW
COP Tj = 12°C	8.06	5.53
Pdh Tj = Tbiv	5.48 kW	5.40 kW
COP Tj = Tbiv	3.03	2.10
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.48 kW	5.40 kW

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.03	2.10
WTOL	60 °C	60 °C
Poff	17 W	17 W
PTO	22 W	22 W
PSB	17 W	17 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	n/a	n/a
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	1211 kWh	1736 kWh

Colder Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	29 dB(A)	29 dB(A)
Sound power level outdoor	50 dB(A)	50 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	168 %	118 %
Prated	4.30 kW	4.00 kW
SCOP	4.27	3.03

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Tbiv	-17 °C	-17 °C
TOL	-20 °C	-18 °C
Pdh Tj = -7°C	2.50 kW	2.29 kW
COP Tj = -7°C	3.64	2.52
Cdh Tj = -7 °C		
Pdh Tj = +2°C	1.49 kW	1.80 kW
COP Tj = +2°C	5.22	3.82
Cdh Tj = +2 °C		
Pdh Tj = +7°C	1.14 kW	2.08 kW
COP Tj = +7°C	6.44	4.68
Cdh Tj = +7 °C		
Pdh Tj = 12°C	1.24 kW	2.48 kW
COP Tj = 12°C	7.03	6.02
Cdh Tj = +12 °C		
Pdh Tj = Tbiv	3.75 kW	3.53 kW
COP Tj = Tbiv	2.29	1.64
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	3.44 kW	3.39 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.11	1.56
WTOL	60 °C	60 °C
Poff	17 W	17 W
PTO	22 W	22 W

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

PSB	17 W	17 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	n/a	n/a
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	2482 kWh	3252 kWh
Pdh Tj = -15°C (if TOL<-20°C)		
COP Tj = -15°C (if TOL<-20°C)		
Cdh Tj = -15 °C		

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	29 dB(A)	29 dB(A)
Sound power level outdoor	50 dB(A)	50 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	196 %	133 %
Prated	4.76 kW	4.49 kW
SCOP	4.98	3.40
Tbiv	-10 °C	-10 °C

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

TOL	-10 °C	-10 °C
Pdh Tj = -7°C	4.27 kW	3.93 kW
COP Tj = -7°C	3.11	2.11
Pdh Tj = +2°C	2.51 kW	2.41 kW
COP Tj = +2°C	4.96	3.36
Pdh Tj = +7°C	1.51 kW	2.06 kW
COP Tj = +7°C	6.40	4.41
Pdh Tj = 12°C	1.27 kW	2.45 kW
COP Tj = 12°C	7.53	5.76
Pdh Tj = Tbiv	4.76 kW	4.49 kW
COP Tj = Tbiv	2.68	1.82
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.76 kW	4.49 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.68	1.82
WTOL	60 °C	60 °C
Poff	17 W	17 W
PTO	22 W	22 W
PSB	17 W	17 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	n/a	n/a
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	1975 kWh	2724 kWh

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Model: Buderus Logatherm WLW196i.2-4 ARE S+

Configure model	
Model name	Buderus Logatherm WLW196i.2-4 ARE S+
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	2.82 kW	1.78 kW
El input	0.56 kW	0.69 kW
COP	5.01	2.57

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Warmer Climate

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	29 dB(A)	29 dB(A)
Sound power level outdoor	50 dB(A)	50 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	240 %	163 %
Prated	5.50 kW	5.40 kW
SCOP	6.07	4.16
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	5.48 kW	5.40 kW
COP Tj = +2°C	3.03	2.10
Pdh Tj = +7°C	3.81 kW	3.56 kW
COP Tj = +7°C	5.16	3.57
Pdh Tj = 12°C	1.71 kW	2.44 kW
COP Tj = 12°C	8.06	5.53
Pdh Tj = Tbiv	5.48 kW	5.40 kW
COP Tj = Tbiv	3.03	2.10
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.48 kW	5.40 kW

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.03	2.10
WTOL	60 °C	60 °C
Poff	17 W	17 W
PTO	22 W	22 W
PSB	17 W	17 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	1211 kWh	1736 kWh

Colder Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	29 dB(A)	29 dB(A)
Sound power level outdoor	50 dB(A)	50 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	168 %	118 %
Prated	4.30 kW	4.00 kW
SCOP	4.27	3.03

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Tbiv	-17 °C	-17 °C
TOL	-20 °C	-18 °C
Pdh Tj = -7°C	2.50 kW	2.29 kW
COP Tj = -7°C	3.64	2.52
Cdh Tj = -7 °C		
Pdh Tj = +2°C	1.49 kW	1.80 kW
COP Tj = +2°C	5.22	3.82
Cdh Tj = +2 °C		
Pdh Tj = +7°C	1.14 kW	2.08 kW
COP Tj = +7°C	6.44	4.68
Cdh Tj = +7 °C		
Pdh Tj = 12°C	1.24 kW	2.48 kW
COP Tj = 12°C	7.03	6.02
Cdh Tj = +12 °C		
Pdh Tj = Tbiv	3.75 kW	3.53 kW
COP Tj = Tbiv	2.29	1.64
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	3.44 kW	3.39 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.11	1.56
WTOL	60 °C	60 °C
Poff	17 W	17 W
PTO	22 W	22 W

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

PSB	17 W	17 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	4.30 kW	4.00 kW
Annual energy consumption Qhe	2482 kWh	3252 kWh
Pdh Tj = -15°C (if TOL<-20°C)	3.75	3.53
COP Tj = -15°C (if TOL<-20°C)	2.29	1.64
Cdh Tj = -15 °C		

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	29 dB(A)	29 dB(A)
Sound power level outdoor	50 dB(A)	50 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	196 %	133 %
Prated	4.76 kW	4.49 kW
SCOP	4.98	3.40
Tbiv	-10 °C	-10 °C

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

TOL	-10 °C	-10 °C
Pdh Tj = -7°C	4.27 kW	3.93 kW
COP Tj = -7°C	3.11	2.11
Pdh Tj = +2°C	2.51 kW	2.41 kW
COP Tj = +2°C	4.96	3.36
Pdh Tj = +7°C	1.51 kW	2.06 kW
COP Tj = +7°C	6.40	4.41
Pdh Tj = 12°C	1.27 kW	2.45 kW
COP Tj = 12°C	7.53	5.76
Pdh Tj = Tbiv	4.76 kW	4.49 kW
COP Tj = Tbiv	2.68	1.82
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.76 kW	4.49 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.68	1.82
WTOL	60 °C	60 °C
Poff	17 W	17 W
PTO	22 W	22 W
PSB	17 W	17 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	1975 kWh	2724 kWh

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Model: Buderus Logatherm WLW196i.2-4 ART190 S+

Configure model	
Model name	Buderus Logatherm WLW196i.2-4 ART190 S+
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	2.82 kW	1.78 kW
El input	0.56 kW	0.69 kW
COP	5.01	2.57

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Warmer Climate

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	25 dB(A)	25 dB(A)
Sound power level outdoor	50 dB(A)	50 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	240 %	163 %
Prated	5.50 kW	5.40 kW
SCOP	6.07	4.16
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	5.48 kW	5.40 kW
COP Tj = +2°C	3.03	2.10
Pdh Tj = +7°C	3.81 kW	3.56 kW
COP Tj = +7°C	5.16	3.57
Pdh Tj = 12°C	1.71 kW	2.44 kW
COP Tj = 12°C	8.06	5.53
Pdh Tj = Tbiv	5.48 kW	5.40 kW
COP Tj = Tbiv	3.03	2.10
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.48 kW	5.40 kW

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.03	2.10
WTOL	60 °C	60 °C
Poff	17 W	17 W
PTO	22 W	22 W
PSB	17 W	17 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	1211 kWh	1736 kWh

Colder Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	25 dB(A)	25 dB(A)
Sound power level outdoor	50 dB(A)	50 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	168 %	118 %
Prated	4.30 kW	4.00 kW
SCOP	4.27	3.03

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Tbiv	-17 °C	-17 °C
TOL	-20 °C	-18 °C
Pdh Tj = -7°C	2.50 kW	2.29 kW
COP Tj = -7°C	3.64	2.52
Cdh Tj = -7 °C		
Pdh Tj = +2°C	1.49 kW	1.80 kW
COP Tj = +2°C	5.22	3.82
Cdh Tj = +2 °C		
Pdh Tj = +7°C	1.14 kW	2.08 kW
COP Tj = +7°C	6.44	4.68
Cdh Tj = +7 °C		
Pdh Tj = 12°C	1.24 kW	2.48 kW
COP Tj = 12°C	7.03	6.02
Cdh Tj = +12 °C		
Pdh Tj = Tbiv	3.75 kW	3.53 kW
COP Tj = Tbiv	2.29	1.64
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	3.44 kW	3.39 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.11	1.56
WTOL	60 °C	60 °C
Poff	17 W	17 W
PTO	22 W	22 W

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

PSB	17 W	17 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	4.30 kW	4.00 kW
Annual energy consumption Qhe	2482 kWh	3252 kWh
Pdh Tj = -15°C (if TOL<-20°C)	3.75	1.64
COP Tj = -15°C (if TOL<-20°C)	2.29	1.64
Cdh Tj = -15 °C		

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	25 dB(A)	25 dB(A)
Sound power level outdoor	50 dB(A)	50 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	196 %	133 %
Prated	4.76 kW	4.49 kW
SCOP	4.98	3.40
Tbiv	-10 °C	-10 °C

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

TOL	-10 °C	-10 °C
Pdh Tj = -7°C	4.27 kW	3.93 kW
COP Tj = -7°C	3.11	2.11
Pdh Tj = +2°C	2.51 kW	2.41 kW
COP Tj = +2°C	4.96	3.36
Pdh Tj = +7°C	1.51 kW	2.06 kW
COP Tj = +7°C	6.40	4.41
Pdh Tj = 12°C	1.27 kW	2.45 kW
COP Tj = 12°C	7.53	5.76
Pdh Tj = Tbiv	4.76 kW	4.49 kW
COP Tj = Tbiv	2.68	1.82
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.76 kW	4.49 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.68	1.82
WTOL	60 °C	60 °C
Poff	17 W	17 W
PTO	22 W	22 W
PSB	17 W	17 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	1975 kWh	2724 kWh

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Domestic Hot Water (DHW)

Warmer Climate

EN 16147	
Declared load profile	L
Efficiency ηDHW	119 %
COP	2.80
Heating up time	02:49 h:min
Standby power input	47.0 W
Reference hot water temperature	53.1 °C
Mixed water at 40°C	261 l

Colder Climate

EN 16147	
Declared load profile	L
Efficiency ηDHW	84 %
COP	1.96
Heating up time	04:11 h:min
Standby power input	66.0 W
Reference hot water temperature	53.0 °C
Mixed water at 40°C	279 l

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Average Climate

EN 16147	
Declared load profile	L
Efficiency ηDHW	100 %
COP	2.36
Heating up time	03:34 h:min
Standby power input	52.0 W
Reference hot water temperature	53.5 °C
Mixed water at 40°C	271 l

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Model: Buderus Logatherm WLW196i.2-4 ARTS185 S+

Configure model	
Model name	Buderus Logatherm WLW196i.2-4 ARTS185 S+
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	2.82 kW	1.78 kW
El input	0.56 kW	0.69 kW
COP	5.01	2.57

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Warmer Climate

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	25 dB(A)	25 dB(A)
Sound power level outdoor	50 dB(A)	50 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	240 %	163 %
Prated	5.50 kW	5.40 kW
SCOP	6.07	4.16
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	5.48 kW	5.40 kW
COP Tj = +2°C	3.03	2.10
Pdh Tj = +7°C	3.81 kW	3.56 kW
COP Tj = +7°C	5.16	3.57
Pdh Tj = 12°C	1.71 kW	2.44 kW
COP Tj = 12°C	8.06	5.53
Pdh Tj = Tbiv	5.48 kW	5.40 kW
COP Tj = Tbiv	3.03	2.10
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.48 kW	5.40 kW

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.03	2.10
WTOL	60 °C	60 °C
Poff	17 W	17 W
PTO	22 W	22 W
PSB	17 W	17 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	1211 kWh	1736 kWh

Colder Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	25 dB(A)	25 dB(A)
Sound power level outdoor	50 dB(A)	50 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	168 %	118 %
Prated	4.30 kW	4.00 kW
SCOP	4.27	3.03

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Tbiv	-17 °C	-17 °C
TOL	-20 °C	-18 °C
Pdh Tj = -7°C	2.50 kW	2.29 kW
COP Tj = -7°C	3.64	2.52
Cdh Tj = -7 °C		
Pdh Tj = +2°C	1.49 kW	1.80 kW
COP Tj = +2°C	5.22	3.82
Cdh Tj = +2 °C		
Pdh Tj = +7°C	1.14 kW	2.08 kW
COP Tj = +7°C	6.44	4.68
Cdh Tj = +7 °C		
Pdh Tj = 12°C	1.24 kW	2.48 kW
COP Tj = 12°C	7.03	6.02
Cdh Tj = +12 °C		
Pdh Tj = Tbiv	3.75 kW	3.53 kW
COP Tj = Tbiv	2.29	1.64
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	3.44 kW	3.39 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.11	1.56
WTOL	60 °C	60 °C
Poff	17 W	17 W
PTO	22 W	22 W

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

PSB	17 W	17 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	4.30 kW	4.00 kW
Annual energy consumption Qhe	2482 kWh	3252 kWh
Pdh Tj = -15°C (if TOL<-20°C)	3.75	1.64
COP Tj = -15°C (if TOL<-20°C)	2.29	1.64
Cdh Tj = -15 °C		

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	25 dB(A)	25 dB(A)
Sound power level outdoor	50 dB(A)	50 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	196 %	133 %
Prated	4.76 kW	4.49 kW
SCOP	4.98	3.40
Tbiv	-10 °C	-10 °C

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

TOL	-10 °C	-10 °C
Pdh Tj = -7°C	4.27 kW	3.93 kW
COP Tj = -7°C	3.11	2.11
Pdh Tj = +2°C	2.51 kW	2.41 kW
COP Tj = +2°C	4.96	3.36
Pdh Tj = +7°C	1.51 kW	2.06 kW
COP Tj = +7°C	6.40	4.41
Pdh Tj = 12°C	1.27 kW	2.45 kW
COP Tj = 12°C	7.53	5.76
Pdh Tj = Tbiv	4.76 kW	4.49 kW
COP Tj = Tbiv	2.68	1.82
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.76 kW	4.49 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.68	1.82
WTOL	60 °C	60 °C
Poff	17 W	17 W
PTO	22 W	22 W
PSB	17 W	17 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	1975 kWh	2724 kWh

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Domestic Hot Water (DHW)

Warmer Climate

EN 16147	
Declared load profile	L
Efficiency ηDHW	110 %
COP	2.58
Heating up time	02:45 h:min
Standby power input	49.0 W
Reference hot water temperature	51.7 °C
Mixed water at 40°C	247 l

Colder Climate

EN 16147	
Declared load profile	L
Efficiency ηDHW	80 %
COP	1.88
Heating up time	04:05 h:min
Standby power input	67.0 W
Reference hot water temperature	51.7 °C
Mixed water at 40°C	259 l

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Average Climate

EN 16147	
Declared load profile	L
Efficiency ηDHW	98 %
COP	2.31
Heating up time	03:12 h:min
Standby power input	54.0 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	261 l

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Model: Buderus Hybrid-Set WLW196i-6 A H

Configure model	
Model name	Buderus Hybrid-Set WLW196i-6 A H
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	9.03 kW	7.41 kW
El input	2.4 kW	2.82 kW
COP	3.76	2.62

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Warmer Climate

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	24 dB(A)	24 dB(A)
Sound power level outdoor	47 dB(A)	47 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	210 %	164 %
Prated	6.54 kW	6.10 kW
SCOP	5.31	4.16
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	6.54 kW	6.1 kW
COP Tj = +2°C	3.04	2.33
Cdh Tj = +2 °C	1.000	1.000
Pdh Tj = +7°C	4.02 kW	4.07 kW
COP Tj = +7°C	5.03	3.47
Cdh Tj = +7 °C	1.000	1.000
Pdh Tj = 12°C	1.77 kW	2.49 kW
COP Tj = 12°C	6.36	5.71
Cdh Tj = +12 °C	1.000	0.950

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Pdh Tj = Tbiv	6.54 kW	6.1 kW
COP Tj = Tbiv	3.04	2.33
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.54 kW	6.1 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.04	2.33
WTOL	62 °C	62 °C
Poff	7 W	7 W
PTO	6 W	6 W
PSB	17 W	17 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Gas	Gas
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	1645 kWh	1957 kWh

Colder Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	24 dB(A)	24 dB(A)
Sound power level outdoor	47 dB(A)	47 dB(A)

EN 14825		
	Low temperature	**Medium temperature**

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

η_s	152 %	122 %
Prated	5.35 kW	5.29 kW
SCOP	3.87	3.13
Tbiv	-17 °C	-15 °C
TOL	-20 °C	-19 °C
Pdh Tj = -7°C	3.19 kW	3.21 kW
COP Tj = -7°C	3.32	2.52
Cdh Tj = -7 °C	1.000	1.000
Pdh Tj = +2°C	1.18 kW	1.78 kW
COP Tj = +2°C	4.59	3.71
Cdh Tj = +2 °C	1.000	1.000
Pdh Tj = +7°C	1.18 kW	2.13 kW
COP Tj = +7°C	5.00	5.01
Cdh Tj = +7 °C	1.000	0.950
Pdh Tj = 12°C	1.36 kW	2.58 kW
COP Tj = 12°C	6.19	6.89
Cdh Tj = +12 °C	0.900	0.940
Pdh Tj = Tbiv	4.39 kW	4.32 kW
COP Tj = Tbiv	2.31	1.82
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.07 kW	1.77 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.16	1.54

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

WTOL	62 °C	62 °C
Poff	7 W	7 W
PTO	6 W	6 W
PSB	17 W	17 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Gas	Gas
Supplementary Heater: PSUP	1.28 kW	3.52 kW
Annual energy consumption Qhe	3405 kWh	4162 kWh
Pdh Tj = -15°C (if TOL<-20°C)		
COP Tj = -15°C (if TOL<-20°C)		
Cdh Tj = -15 °C		

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	24 dB(A)	24 dB(A)
Sound power level outdoor	47 dB(A)	47 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	169 %	133 %

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Prated	5.39 kW	6.25 kW
SCOP	4.31	3.4
Tbiv	-10 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	4.55 kW	5.53 kW
COP Tj = -7°C	2.96	2.02
Cdh Tj = -7 °C	1.000	1.000
Pdh Tj = +2°C	2.63 kW	3.53 kW
COP Tj = +2°C	4.34	3.31
Cdh Tj = +2 °C	1.000	1.000
Pdh Tj = +7°C	1.75 kW	2.13 kW
COP Tj = +7°C	5.24	4.55
Cdh Tj = +7 °C	1.000	1.000
Pdh Tj = 12°C	1.36 kW	2.54 kW
COP Tj = 12°C	6.25	6.41
Cdh Tj = +12 °C	0.900	0.940
Pdh Tj = Tbiv	5.39 kW	5.53 kW
COP Tj = Tbiv	2.56	2.02
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.39 kW	4.61 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.56	1.93
WTOL	62 °C	62 °C

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Poff	7 W	7 W
PTO	6 W	6 W
PSB	17 W	17 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Gas	Gas
Supplementary Heater: PSUP	0 kW	1.6 kW
Annual energy consumption Qhe	2586 kWh	3800 kWh

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Model: Buderus Logatherm WLW196i-6 IRTP120

Configure model	
Model name	Buderus Logatherm WLW196i-6 IRTP120
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	2.29 kW	2.34 kW
El input	0.49 kW	0.90 kW
COP	4.69	2.59

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Warmer Climate

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	48 dB(A)	48 dB(A)
Sound power level outdoor	36 dB(A)	36 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	237 %	156 %
Prated	5.77 kW	5.08 kW
SCOP	6.00	3.98
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	5.77 kW	5.08 kW
COP Tj = +2°C	2.83	2.06
Pdh Tj = +7°C	3.39 kW	3.55 kW
COP Tj = +7°C	5.39	3.53
Pdh Tj = 12°C	1.79 kW	2.42 kW
COP Tj = 12°C	7.60	5.29
Pdh Tj = Tbiv	5.77 kW	5.08 kW
COP Tj = Tbiv	2.83	2.06
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.77 kW	5.08 kW

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.83	2.06
WTOL	60 °C	60 °C
Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	1285 kWh	1704 kWh

Colder Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	48 dB(A)	48 dB(A)
Sound power level outdoor	36 dB(A)	36 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	158 %	122 %
Prated	5.27 kW	4.82 kW
SCOP	4.03	3.14

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Tbiv	-16 °C	-16 °C
TOL	-20 °C	-17 °C
Pdh Tj = -7°C	3.20 kW	2.91 kW
COP Tj = -7°C	3.07	2.66
Pdh Tj = +2°C	1.80 kW	1.91 kW
COP Tj = +2°C	5.33	4.05
Pdh Tj = +7°C	1.14 kW	2.15 kW
COP Tj = +7°C	6.53	4.79
Pdh Tj = 12°C	1.31 kW	2.61 kW
COP Tj = 12°C	7.20	6.16
Pdh Tj = Tbiv	4.45 kW	3.93 kW
COP Tj = Tbiv	2.38	1.73
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	3.50 kW	3.09 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.03	1.62
WTOL	60 °C	60 °C
Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	5.27 kW	4.82 kW

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Annual energy consumption Qhe	3222 kWh	3787 kWh
Pdh Tj = -15°C (if TOL<-20°C)	4.15	3.89
COP Tj = -15°C (if TOL<-20°C)	2.38	1.94

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	48 dB(A)	48 dB(A)
Sound power level outdoor	36 dB(A)	36 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	173 %	134 %
Prated	5.17 kW	4.20 kW
SCOP	4.41	3.44
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	4.67 kW	3.86 kW
COP Tj = -7°C	2.87	2.21
Pdh Tj = +2°C	2.81 kW	2.38 kW
COP Tj = +2°C	5.33	3.56

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Pdh Tj = +7°C	1.84 kW	2.11 kW
COP Tj = +7°C	6.40	4.26
Pdh Tj = 12°C	1.33 kW	2.56 kW
COP Tj = 12°C	7.13	5.35
Pdh Tj = Tbiv	5.18 kW	4.20 kW
COP Tj = Tbiv	2.58	1.88
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.18 kW	4.20 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.58	1.88
WTOL	60 °C	60 °C
Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	2421 kWh	2525 kWh

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Model: Buderus Logatherm WLW196i-6 ARTP120

Configure model	
Model name	Buderus Logatherm WLW196i-6 ARTP120
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	2.28 kW	2.40 kW
El input	0.46 kW	0.90 kW
COP	4.96	2.68

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Warmer Climate

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	49 dB(A)	49 dB(A)
Sound power level outdoor	47 dB(A)	47 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	241 %	167 %
Prated	6.27 kW	5.60 kW
SCOP	6.11	4.25
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	6.27 kW	5.60 kW
COP Tj = +2°C	2.95	2.16
Pdh Tj = +7°C	4.09 kW	3.77 kW
COP Tj = +7°C	5.41	3.76
Pdh Tj = 12°C	1.79 kW	2.54 kW
COP Tj = 12°C	7.85	5.64
Pdh Tj = Tbiv	6.27 kW	5.60 kW
COP Tj = Tbiv	2.95	2.16
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.27 kW	5.60 kW

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.95	2.16
WTOL	60 °C	60 °C
Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	4 W	4 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	1371 kWh	1762 kWh

Colder Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	49 dB(A)	49 dB(A)
Sound power level outdoor	47 dB(A)	47 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	167 %	125 %
Prated	5.11 kW	4.82 kW
SCOP	4.26	3.20

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Tbiv	-17 °C	-17 °C
TOL	-20 °C	-19 °C
Pdh Tj = -7°C	3.20 kW	3.01 kW
COP Tj = -7°C	3.49	2.66
Pdh Tj = +2°C	1.80 kW	1.91 kW
COP Tj = +2°C	5.32	4.05
Pdh Tj = +7°C	1.19 kW	2.15 kW
COP Tj = +7°C	6.54	4.78
Pdh Tj = 12°C	1.31 kW	2.61 kW
COP Tj = 12°C	7.19	6.16
Pdh Tj = Tbiv	4.45 kW	4.20 kW
COP Tj = Tbiv	2.38	1.73
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.07 kW	3.39 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.20	1.62
WTOL	60 °C	60 °C
Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	4 W	4 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	5.11 kW	4.82 kW

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Annual energy consumption Qhe	2956 kWh	3715 kWh
Pdh Tj = -15°C (if TOL<-20°C)	4.15	3.89
COP Tj = -15°C (if TOL<-20°C)	2.62	1.94

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	49 dB(A)	49 dB(A)
Sound power level outdoor	47 dB(A)	47 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	189 %	137 %
Prated	5.43 kW	4.56 kW
SCOP	4.81	3.50
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	4.90 kW	4.26 kW
COP Tj = -7°C	2.99	2.21
Pdh Tj = +2°C	2.92 kW	2.57 kW
COP Tj = +2°C	4.74	3.55

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Pdh Tj = +7°C	1.84 kW	2.11 kW
COP Tj = +7°C	6.41	4.47
Pdh Tj = 12°C	1.33 kW	2.56 kW
COP Tj = 12°C	7.37	5.82
Pdh Tj = Tbiv	5.43 kW	4.56 kW
COP Tj = Tbiv	2.58	1.87
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.43 kW	4.56 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.58	1.87
WTOL	60 °C	60 °C
Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	4 W	4 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	2335 kWh	2689 kWh

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Model: Buderus Logatherm WLW196i.2-4 ARTP120 S+

Configure model	
Model name	Buderus Logatherm WLW196i.2-4 ARTP120 S+
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	2.82 kW	1.78 kW
El input	0.59 kW	0.71 kW
COP	4.76	2.49

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Warmer Climate

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	49 dB(A)	49 dB(A)
Sound power level outdoor	50 dB(A)	50 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	223 %	158 %
Prated	5.50 kW	5.40 kW
SCOP	5.65	4.01
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	5.48 kW	5.40 kW
COP Tj = +2°C	2.93	2.07
Pdh Tj = +7°C	3.81 kW	3.56 kW
COP Tj = +7°C	4.91	3.48
Pdh Tj = 12°C	1.71 kW	2.44 kW
COP Tj = 12°C	7.26	5.26
Pdh Tj = Tbiv	5.48 kW	5.40 kW
COP Tj = Tbiv	2.93	2.07
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.48 kW	5.40 kW

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.93	2.07
WTOL	60 °C	60 °C
Poff	17 W	17 W
PTO	22 W	22 W
PSB	17 W	17 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	1301 kWh	1797 kWh

Colder Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	49 dB(A)	49 dB(A)
Sound power level outdoor	50 dB(A)	50 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	157 %	113 %
Prated	4.30 kW	4.00 kW
SCOP	4.00	2.90

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Tbiv	-17 °C	-17 °C
TOL	-20 °C	-18 °C
Pdh Tj = -7°C	2.50 kW	2.29 kW
COP Tj = -7°C	3.50	2.46
Pdh Tj = +2°C	1.49 kW	1.80 kW
COP Tj = +2°C	4.84	3.65
Pdh Tj = +7°C	1.14 kW	2.08 kW
COP Tj = +7°C	5.73	4.46
Pdh Tj = 12°C	1.24 kW	2.48 kW
COP Tj = 12°C	6.26	5.71
Pdh Tj = Tbiv	3.75 kW	3.53 kW
COP Tj = Tbiv	2.24	1.62
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	3.44 kW	3.39 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.07	1.54
WTOL	60 °C	60 °C
Poff	17 W	17 W
PTO	22 W	22 W
PSB	17 W	17 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	4.30 kW	4.00 kW

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Annual energy consumption Qhe	2650 kWh	3405 kWh
Pdh Tj = -15°C (if TOL<-20°C)	3.75	3.53
COP Tj = -15°C (if TOL<-20°C)	2.24	1.62

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	49 dB(A)	49 dB(A)
Sound power level outdoor	50 dB(A)	50 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	183 %	127 %
Prated	4.76 kW	4.49 kW
SCOP	4.66	3.26
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	4.27 kW	3.94 kW
COP Tj = -7°C	3.02	2.08
Pdh Tj = +2°C	2.51 kW	2.41 kW
COP Tj = +2°C	4.70	3.26

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Pdh Tj = +7°C	1.51 kW	2.06 kW
COP Tj = +7°C	5.85	4.21
Pdh Tj = 12°C	1.27 kW	2.45 kW
COP Tj = 12°C	6.67	5.47
Pdh Tj = Tbiv	4.76 kW	4.49 kW
COP Tj = Tbiv	2.62	1.80
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.76 kW	4.49 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.62	1.80
WTOL	60 °C	60 °C
Poff	17 W	17 W
PTO	22 W	22 W
PSB	17 W	17 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	2112 kWh	2843 kWh

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.