

TEST REPORT

Report no.:
300-KLAB-23-040-23



**DANISH
TECHNOLOGICAL
INSTITUTE**

Teknologiparken
Kongsvang Allé 29
DK-8000 Aarhus C
+45 72 20 20 00
Info@teknologisk.dk
www.teknologisk.dk

Page 1 of 42
Init: KAMA/RTHI/AAS
File no.: 225959
Enclosures: 2

Customer: Company: GD MIDEA HEATING & VENTILATING EQUIPMENT CO., LTD.
Address: Penglai Industry Road, Beijiao
City: Shunde, Foshan, Guangdong, 528311, China
Tel.: +86 13902810522

Component: Brand: Midea
Type: Air to water heat pump (mono block)
Model: MHC-V6W/D2N8-B
Series no.: 341H09752012A250100012
Prod. year: Outdoor unit: N/A
Dates: Teste period: January 2024

Brand name: Brand: SEVRA
Type: Air to water heat pump (mono block)
Model: SEV-HPMO1-06

Procedures See objective (page 3) for list of standards

Remarks: The unit was delivered by the customer. The installation and test settings were done according to the manufacturer's instructions. Between each test condition Midea has been changing various parameters like compressor speed, expansion valve, fan speed, pump speed, defrost time, heating time. The report for the tested unit is named 300-KLAB-23-040 issued 2024.03.12 Also see appendix 2.

Terms: This test was conducted under accreditation in accordance with international requirements (ISO/IEC 17025:2017) and in accordance with the General Terms and Conditions of Danish Technological Institute. The test results solely apply to the tested item. This test report may be quoted in extract only if Danish Technological Institute has granted its written consent.

The customer may not mention or refer to Danish Technological Institute or Danish Technological Institute's employees for advertising or marketing purposes unless Danish Technological Institute has granted its written consent in each case.

Division/Centre: Danish Technological Institute
Energy and Climate
Heat Pump Laboratory, Aarhus

Date: 2024.08.23

Signature:
Kamalathan Arumugam
B.Sc. Engineer

Co-reader:
Rasmus Thisgaard
B.TecMan & MarEng



 **DANAK**
Test Reg. nr. 300



Heat pumps of identical design

According to GD MIDEA HEATING & VENTILATING EQUIPMENT CO., LTD. The heat pumps listed in the table below are considered identical with the tested unit. They have identical:

- a. heating capacity
- b. refrigerant cycle (incl. refrigerant mass)
- c. heat source and sink medium
- d. main components / operating principle and control strategy
- e. same outdoor casing

Brand	Model
Midea	MHC-V6W/D2N8-B
Midea	MHC-V6W/D2N8-BE30
Midea	MHC-V6W/D2N8-BE30
Midea	MHC-V6W/D2N8-BE60
Midea	MHC-V6W/D2N8-BER90
Midea	MHC-V6W/D2N8-B1
Midea	MHC-V6W/D2N8-B1E30
Midea	MHC-V6W/D2N8-B1E60
Midea	MHC-V6W/D2N8-B1ER90
Midea	MHC-V6W/D2N8-B2
Midea	MHC-V6W/D2N8-B2E30
Midea	MHC-V6W/D2N8-B2E60
Midea	MHC-V6W/D2N8-B2ER90



Objective

The objective of this report is to document the following:

The Seasonal Coefficient of Performance (SCOP) at low and medium temperature application for average climate according to EN 14825:2022.

In order to calculate the SCOP, tests were carried out at the part load conditions stated in the tables on page 5 and 6.

SCOP part load test in conditions $SCOP_C$ and $SCOP_{B\&F}$ at low temperature application for warmer climate according to EN 14825:2022.

SCOP part load test conditions $SCOP_A$ and $SCOP_{G\&F}$ at low temperature application for colder climate according to EN 14825:2022.

COP test standard rating conditions (heating mode) at low and medium temperature according to EN 14511:2022.

Operating requirements according to EN 14511-4:2022

- 4.2.1 Starting and operating tests
- 4.5 Shutting of the heat transfer medium flows
- 4.6 Complete power supply failure

Sound power measurements according to EN 12102-1:2022



Contents:

Test conditions	5
SCOP test conditions for low temperature – EN 14825	5
SCOP test conditions for medium temperature – EN 14825	6
COP test conditions - low temperature – EN 14511	7
COP test conditions - medium temperature – EN 14511	7
Test conditions for operating requirements – EN 14511-4	7
Test conditions for shutting off the heat transfer medium – EN 14511-4	8
Test conditions for complete power supply failure – EN 14511-4	8
Test conditions for sound power measurements – EN 12102-1	8
Test results.....	9
Test results of SCOP test at low temperature - heating season average – EN 14825.....	9
Test results of SCOP test at medium temperature - heating season average – EN 14825	10
Test results for warmer climate, low temperature according to EN14825.....	11
Test results for colder climate, low temperature according to EN14825.....	11
COP test results - low temperature – EN 14511	11
COP test results - medium temperature – EN 14511.....	11
Test results of sound power measurements – EN 12102	12
Photos	13
SCOP - detailed calculation	14
Detailed SCOP calculation of low temperature and average climate conditions – EN 14825.....	14
Detailed SCOP calculation of medium temperature and average climate conditions – EN 14825	16
Detailed test results	18
Detailed SCOP part load test results - low temperature application - average climate – EN 14825.....	18
Detailed SCOP part load test results - medium temperature application - average climate – EN 14825	23
Detailed SCOP part load test results - low temperature application - warmer climate – EN 14825	28
Detailed SCOP part load test results - low temperature application - colder climate – EN 14825.....	30
Detailed COP test results - low temperature – EN 14511.....	32
Detailed COP test results - medium temperature – EN 14511	33
Detailed test results of sound power measurement – Test N#1	34
Detailed test results of sound power measurement – Test N#2	35
Detailed test results of sound power measurement – Test N#3	36
Detailed test results of sound power measurement – Test N# 4.....	37
Appendix 1 Sound power measurement.....	38
Appendix 2 Authorization letter.....	42



Test conditions

SCOP test conditions for low temperature – EN 14825

Part load conditions for reference SCOP and reference SCOPon calculation of air to water units for low temperature application for the reference heating season;

“A” = average, “W” = warmer, and “C” = colder.

	Part load ratio in %				Outdoor heat exchanger		Indoor heat exchanger			
					Dry (wet) bulb temperature °C		Fixed outlet °C	Variable outlet ^d °C		
	Formula	Average	Warmer	Colder	Outdoor air	Exhaust air	All climates	Average	Warmer	Colder
A	$(-7 - 16) / (T_{\text{designh}} - 16)$	88,46	n.a.	60,53	-7(-8)	20(12)	a / 35	a / 34	n.a.	a / 30
B	$(+2 - 16) / (T_{\text{designh}} - 16)$	53,85	100,00	36,84	2(1)	20(12)	a / 35	a / 30	a / 35	a / 27
C	$(+7 - 16) / (T_{\text{designh}} - 16)$	34,62	64,29	23,68	7(6)	20(12)	a / 35	a / 27	a / 31	a / 25
D	$(+12 - 16) / (T_{\text{designh}} - 16)$	15,38	28,57	10,53	12(11)	20(12)	a / 35	a / 24	a / 26	a / 24
E	$(TOL^e - 16) / (T_{\text{designh}} - 16)$				TOL^e	20(12)	a / 35	a / b	a / b	a / b
F	$(T_{\text{biv}} - 16) / (T_{\text{designh}} - 16)$				T_{biv}	20(12)	a / 35	a / c	a / c	a / c
G	$(-15 - 16) / (T_{\text{designh}} - 16)$	n.a.	n.a.	81,58	-15	20(12)	a / 35	n.a.	n.a.	a / 32

Additional information

Climate	T_{designh} [°C]	T_{bivalent} [°C]	TOL [°C]	Outlet temperature	Flow rate
Average	-10	-7	-10	Variable	Variable
Warmer	2	7	2	Variable	Variable
Colder	-22	-15	-22	Variable	Variable



SCOP test conditions for medium temperature – EN 14825

Part load conditions for reference SCOP and reference SCOPon calculation of air to water units for medium temperature application for the reference heating season;

“A” = average, “W” = warmer, and “C” = colder.

	Part load ratio in %				Outdoor heat exchanger		Indoor heat exchanger			
					Dry (wet) bulb temperature °C		Fixed outlet °C	Variable outlet ^d °C		
	Formula	Average	Warmer	Colder	Outdoor air	Exhaust air	All climates	Average	Warmer	Colder
A	$(-7 - 16) / (T_{designh} - 16)$	88,46	n.a.	60,53	-7(-8)	20(12)	^a / 55	^a / 52	n.a.	^a / 44
B	$(+2 - 16) / (T_{designh} - 16)$	53,85	100	36,84	2(1)	20(12)	^a / 55	^a / 42	^a / 55	^a / 37
C	$(+7 - 16) / (T_{designh} - 16)$	34,62	64,29	23,68	7(6)	20(12)	^a / 55	^a / 36	^a / 46	^a / 32
D	$(+12 - 16) / (T_{designh} - 16)$	15,38	28,57	10,53	12(11)	20(12)	^a / 55	^a / 30	^a / 34	^a / 28
E	$(TOL^e - 16) / (T_{designh} - 16)$				TOL^e	20(12)	^a / 55	^a / ^b	^a / ^b	^a / ^b
F	$(T_{biv} - 16) / (T_{designh} - 16)$				T_{biv}	20(12)	^a / 55	^a / ^c	^a / ^c	^a / ^c
G	$(-15 - 16) / (T_{designh} - 16)$	n.a.	n.a.	81,58	-15	20(12)	^a / 55	n.a.	n.a.	^a / 49

Additional information

Climate	$T_{designh}$ [°C]	$T_{bivalent}$ [°C]	TOL [°C]	Outlet temperature	Flow rate
Average	-10	-7	-10	Variable	Variable



COP test conditions - low temperature – EN 14511

N#	Heat source		Heat sink	
	Inlet dry bulb temperature (°C)	Inlet wet bulb temperature (°C)	Inlet temperature (°C)	Outlet temperature (°C)
1 ^S	7	6	30	35

S: Standard rating condition

COP test conditions - medium temperature – EN 14511

N#	Heat source		Heat sink	
	Inlet dry bulb temperature (°C)	Inlet wet bulb temperature (°C)	Inlet temperature (°C)	Outlet temperature (°C)
1 ^S	7	6	47	55

S: Standard rating condition

Test conditions for operating requirements – EN 14511-4

N#	Heat source		Heat sink	Water flow rate at indoor heat exchanger	Test
	Inlet dry bulb temperature (°C)	Inlet wet bulb temperature (°C)	Inlet temperature (°C)		
1	-25	-	14	415 L/h	Starting
2	-25	-	35	415 L/h	Operating



Test conditions for shutting off the heat transfer medium – EN 14511-4

N#	Heat source		Heat sink		Heat exchanger
	Inlet dry bulb temperature (°C)	Inlet wet bulb temperature (°C)	Inlet temperature (°C)	Outlet temperature (°C)	
1	7	6	47	55	Indoor
2	7	6	47	55	Outdoor

Test conditions for complete power supply failure – EN 14511-4

N#	Heat source		Heat sink	
	Inlet dry bulb temperature (°C)	Inlet wet bulb temperature (°C)	Inlet temperature (°C)	Outlet temperature (°C)
1	7	6	47	55

Test conditions for sound power measurements – EN 12102-1

N#	Test condition		Heat pump setting			
	Outdoor heat exchanger (dry bulb/wet bulb) (°C)	Indoor heat exchanger (inlet/outlet) (°C)	Compressor speed (Hz)	Fan speed outdoor (rpm)	Heating capacity (kW)	Power input (kW)
1 ^F	7/6	30/35	66	550	6.46	1.23
2 ^P	7/6	30/35	30	400	3.06	0.57
3 ^F	7/6	47/55	66	550	6.13	2.06
4 ^E	7/6	47/55	38	400	3.19	1.14

F) Full load, P) part load, E) ErP labelling



Test results

Test results of SCOP test at low temperature - heating season average - EN 14825

Model (Outdoor)	MHC-V6W/D2N8-B
Air-to-water heat pump mono bloc	Y
Low-temperature heat pump	N
Equipped with supplementary heater	Y
Heat pump combination heater	N
Reversible	Y

Rated heat output¹⁾	P_{rated}	6.8 [kW]
Seasonal space heating energy efficiency	η_s	192.8 [%]
	SCOP	4.89 [-]

Measured capacity for heating for part load at outdoor temperature T_j	Average Climate	$T_j = -15\text{ °C}$	P_{dh}	- [kW]
	-	$T_j = -7\text{ °C}$	P_{dh}	5.74 [kW]
	Low temperature application	$T_j = 2\text{ °C}$	P_{dh}	3.72 [kW]
		$T_j = 7\text{ °C}$	P_{dh}	3.21 [kW]
		$T_j = 12\text{ °C}$	P_{dh}	3.76 [kW]
		$T_j = \text{bivalent temperature}$	P_{dh}	5.74 [kW]
		$T_j = \text{operation limit}$	P_{dh}	5.39 [kW]

Measured coefficient of performance at outdoor temperature T_j	Average Climate	$T_j = -15\text{ °C}$	COPd	- [-]
	-	$T_j = -7\text{ °C}$	COPd	3.02 [-]
	Low temperature application	$T_j = 2\text{ °C}$	COPd	4.76 [-]
		$T_j = 7\text{ °C}$	COPd	6.79 [-]
		$T_j = 12\text{ °C}$	COPd	8.85 [-]
		$T_j = \text{bivalent temperature}$	COPd	3.02 [-]
		$T_j = \text{operation limit}$	COPd	2.68 [-]

Bivalent temperature	$T_{bivalent}$	-7 [°C]
Operation limit temperatures	TOL	-10 [°C]
	WTOL	- [°C]
Degradation coefficient	C_{dh}	0.95 [-]

Power consumption in modes other than active mode	Off mode	P_{OFF}	0.015 [kW]
	Thermostat-off mode	P_{TO}	0.020 [kW]
	Standby mode	P_{SB}	0.015 [kW]
	Crankcase heater mode ²⁾	P_{CK}	0.015 [kW]
Supplementary heater¹⁾	Rated heat output	P_{SUP}	1.41 [kW]
	Type of energy input		Electrical

Other items	Capacity control		Variable
	Water flow control		Variable
	Water flow rate		-
	Annual energy consumption	Q_{HE}	2870 [kWh]

¹⁾ For heat pump space heaters and heat pump combination heaters, the rated heat output, P_{rated} , is equal to the design load for heating, $P_{designh}$, and the rated heat output of a supplementary heater, P_{sup} , is equal to the supplementary capacity for heating, $sup(T_j)$.

²⁾ For SCOP calculation the value $P_{CK} - P_{SB}$ is used. See page 15



Test results of SCOP test at medium temperature - heating season average – EN 14825

Model (Outdoor)	MHC-V6W/D2N8-B
Air-to-water heat pump mono bloc	Y
Low-temperature heat pump	N
Equipped with supplementary heater	Y
Heat pump combination heater	N
Reversible	Y

Rated heat output¹⁾	P_{rated}	5.7 [kW]
Seasonal space heating energy efficiency	η_s	140.4 [%]
	SCOP	3.58 [-]

Measured capacity for heating for part load at outdoor temperature T_j	Average Climate	$T_j = -15\text{ °C}$	P_{dh}	- [kW]
	-	$T_j = -7\text{ °C}$	P_{dh}	5.18 [kW]
	Medium temperature application	$T_j = 2\text{ °C}$	P_{dh}	3.13 [kW]
		$T_j = 7\text{ °C}$	P_{dh}	2.94 [kW]
		$T_j = 12\text{ °C}$	P_{dh}	3.59 [kW]
		$T_j = \text{bivalent temperature}$	P_{dh}	5.18 [kW]
		$T_j = \text{operation limit}$	P_{dh}	4.49 [kW]

Measured coefficient of performance at outdoor temperature T_j	Average Climate	$T_j = -15\text{ °C}$	COPd	- [-]
	-	$T_j = -7\text{ °C}$	COPd	2.13 [-]
	Medium temperature application	$T_j = 2\text{ °C}$	COPd	3.58 [-]
		$T_j = 7\text{ °C}$	COPd	4.74 [-]
		$T_j = 12\text{ °C}$	COPd	6.39 [-]
		$T_j = \text{bivalent temperature}$	COPd	2.13 [-]
		$T_j = \text{operation limit}$	COPd	1.83 [-]

Bivalent temperature	$T_{bivalent}$	-7 [°C]
Operation limit temperatures	TOL	-10 [°C]
Degradation coefficient	C_{dh}	0.96 [-]

Power consumption in modes other than active mode	Off mode	P_{OFF}	0.015 [kW]
	Thermostat-off mode	P_{TO}	0.020 [kW]
	Standby mode	P_{SB}	0.015 [kW]
	Crankcase heater mode ²⁾	P_{CK}	0.015 [kW]
Supplementary heater¹⁾	Rated heat output	P_{SUP}	1.21 [kW]
	Type of energy input		Electrical

Other items	Capacity control		Variable
	Water flow control		Variable
	Water flow rate		-
	Annual energy consumption	Q_{HE}	3286 [kWh]

¹⁾For heat pump space heaters and heat pump combination heaters, the rated heat output, P_{rated} , is equal to the design load for heating, $P_{design,h}$, and the rated heat output of a supplementary heater, P_{sup} , is equal to the supplementary capacity for heating, $sup(T_j)$.

²⁾For SCOP calculation the value $P_{CK} - P_{SB}$ is used. See page 17



Test results for warmer climate, low temperature according to EN14825

N°	Test condition	Heating capacity [kW]	COP
1	B	5.895	3.817
2	Tbivalent C and F	3.994	6.027

Test results for colder climate, low temperature according to EN14825

N°	Test condition	Heating capacity [kW]	COP
1	A	3.392	3.736
2	Tbivalent F & G	4.526	2.365

COP test results - low temperature – EN 14511

N#	Test conditions	Heating capacity [kW]	COP
1	A7/W35	6.462	4.996

COP test results - medium temperature – EN 14511

N#	Test conditions	Heating capacity [kW]	COP
1	A7/W55	6.127	2.979



Test results of sound power measurements – EN 12102

N [#]	Test conditions	Sound power level LW(A) [dB re 1pW]	Uncertainty σ_{tot} [dB]
1 ^F	A7/W35	57.1	1.6
2 ^P	A7/W35	48.9	1.6
3 ^F	A7/W55	60.1	1.6
4 ^E	A7/55	50.7	1.6

F) Full load, P) part load, E) ErP labelling

The A-weighted total sound power level is determined for the measured frequency range from 100 Hz to 10 kHz. For the calculation of uncertainty, see appendix 1.

The sound power measurements are carried out by Kamalathan Arumugam (KAMA) and co-read by Patrick Glibert (PGL), Danish Technological Institute.



Photos

Rating plate (outdoor unit)

MONOBLOC HEAT PUMP	
MODEL	MHC-V6W/D2N8-B
COOLING CAPACITY/EER @ A35W18	6.50kW / 4.80
HEATING CAPACITY/COP @ A7W35	6.35kW / 4.95
POWER SOURCE	220-240V~ 50Hz
RATED INPUT	2700W
RATED WATER PRESSURE	0.1-0.3MPa
NET WEIGHT	86kg
REFRIGERANT	R32/1400g
GWP	675
EQUIVALENT CO ₂	0.95t
EXCESSIVE OPERATING PRESSURE	HIGH 4.3MPa LOW 2.6MPa
MAXIMUM ALLOWABLE PRESSURE	4.3MPa
OUTDOOR RESISTANCE CLASS	IP24
Hermetically sealed equipment contains fluorinated greenhouse gases	
GD Midea Heating & Ventilating Equipment Co., Ltd. <small>(Pengjia Industry Road, Beijing, Shunde, Foshan, Guangdong, P.R. China)</small>	



Outdoor unit





SCOP - detailed calculation

Detailed SCOP calculation of low temperature and average climate conditions – EN 14825

Calculation of reference SCOP

$$SCOP = \frac{P_{designh} \times H_{he}}{\frac{P_{designh} \times H_{he}}{SCOP_{on}} + H_{TO} \times P_{TO} + H_{SB} \times P_{SB} + H_{CK} \times P_{CK} + H_{OFF} \times P_{OFF}}$$

Where

P_{design} = Heating load of the building at design temperature, kW

H_{he} = Number of equivalent heating hours, 2066 h

H_{TO} , H_{SB} , H_{CK} , H_{OFF} = Number of hours for which the unit is considered to work in thermostat off mode, standby mode, crankcase heater mode and off mode, h, respectively

P_{TO} , P_{SB} , P_{CK} , P_{OFF} = Electricity consumption during thermostat off mode, standby mode, crankcase heater mode and off mode, kW, respectively

Data for SCOP

	Outdoor temperature [°C]	Part load ratio [%]	Part load [kW]	Declared capacity [kW]	Declared COP [-]	cdh [-]	CR [-]	COPbin [-]
A	-7	88	6.02	5.74	3.02	0.99	1.00	3.02
B	2	54	3.66	3.72	4.76	0.97	1.00	4.76
C	7	35	2.35	3.21	6.79	0.96	0.73	6.68
D	12	15	1.05	3.76	8.85	0.95	0.28	7.90
E	-10	100	6.80	5.39	2.68	0.99	1.00	2.68
F - BIV	-7	88	6.02	5.74	3.02	0.99	1.00	3.02

Energy consumption for thermostat off, standby, off mode, crankcase heater mode

	Hours [h]	Power input [kW]	Applied to SCOP calculation [kW]	Energy consumption [kWh]
Off mode	0	0.0149	0.0149	0
Thermostat off	178	0.0197	0.0197	3.5066
Standby	0	0.0149	0.0149	0
Crankcase heater	178	0.0149	0	0



Calculation Bin for SCOPon

Bin	Outdoor temperature [°C]	Hours [h]	Heat load [kW]	Heat load covered by heat pump [kW]	Electrical back up heater [kW]	Annual backup heater energy input [kWh]	COPbin	Annual heating demand [kWh]	Annual energy input [kWh]	Net annual heating capacity [kWh]	Net annual power input [kWh]	
E	21	-10	1	6.80	5.39	1.41	1.41	2.68	6.80	3.42	5.39	2.01
	22	-9	25	6.54	5.51	1.03	25.77	2.80	163.46	75.03	137.69	49.26
	23	-8	23	6.28	5.62	0.65	15.03	2.91	144.37	59.54	129.34	44.51
A / F - BIV	24	-7	24	6.02	5.74	0.00	0.00	3.02	144.37	47.85	144.37	47.85
	25	-6	27	5.75	5.51	0.00	0.00	3.21	155.35	48.39	155.35	48.39
	26	-5	68	5.49	5.28	0.00	0.00	3.40	373.48	109.73	373.48	109.73
	27	-4	91	5.23	5.05	0.00	0.00	3.60	476.00	132.33	476.00	132.33
	28	-3	89	4.97	4.82	0.00	0.00	3.79	442.26	116.68	442.26	116.68
	29	-2	165	4.71	4.58	0.00	0.00	3.98	776.77	194.99	776.77	194.99
	30	-1	173	4.45	4.35	0.00	0.00	4.18	769.18	184.15	769.18	184.15
	31	0	240	4.18	4.12	0.00	0.00	4.37	1004.31	229.80	1004.31	229.80
	32	1	280	3.92	3.89	0.00	0.00	4.56	1098.46	240.70	1098.46	240.70
	B	33	2	320	3.66	3.66	0.00	0.00	4.76	1171.69	246.31	1171.69
	34	3	357	3.40	3.40	0.00	0.00	5.14	1213.80	236.03	1213.80	236.03
	35	4	356	3.14	3.14	0.00	0.00	5.53	1117.29	202.12	1117.29	202.12
	36	5	303	2.88	2.88	0.00	0.00	5.91	871.71	147.41	871.71	147.41
	37	6	330	2.62	2.62	0.00	0.00	6.30	863.08	137.02	863.08	137.02
C	38	7	326	2.35	2.35	0.00	0.00	6.68	767.35	114.80	767.35	114.80
	39	8	348	2.09	2.09	0.00	0.00	6.93	728.12	105.11	728.12	105.11
	40	9	335	1.83	1.83	0.00	0.00	7.17	613.31	85.54	613.31	85.54
	41	10	315	1.57	1.57	0.00	0.00	7.41	494.31	66.68	494.31	66.68
	42	11	215	1.31	1.31	0.00	0.00	7.66	281.15	36.73	281.15	36.73
D	43	12	169	1.05	1.05	0.00	0.00	7.90	176.80	22.38	176.80	22.38
	44	13	151	0.78	0.78	0.00	0.00	8.14	118.48	14.55	118.48	14.55
	45	14	105	0.52	0.52	0.00	0.00	8.38	54.92	6.55	54.92	6.55
	46	15	74	0.26	0.26	0.00	0.00	8.63	19.35	2.24	19.35	2.24

SUM	14046.18	2866.09	14003.97	2823.88
SCOPon		4.90	SCOPnet	4.96



Detailed SCOP calculation of medium temperature and average climate conditions – EN 14825

Calculation of reference SCOP

$$SCOP = \frac{P_{designh} \times H_{he}}{\frac{P_{designh} \times H_{he}}{SCOP_{on}} + H_{TO} \times P_{TO} + H_{SB} \times P_{SB} + H_{CK} \times P_{CK} + H_{OFF} \times P_{OFF}}$$

Where

P_{design} = Heating load of the building at design temperature, kW

H_{he} = Number of equivalent heating hours, 2066 h

H_{TO} , H_{SB} , H_{CK} , H_{OFF} = Number of hours for which the unit is considered to work in thermostat off mode, standby mode, crankcase heater mode and off mode, h, respectively

P_{TO} , P_{SB} , P_{CK} , P_{OFF} = Electricity consumption during thermostat off mode, standby mode, crankcase heater mode and off mode, kW, respectively

Data for SCOP

	Outdoor temperature [°C]	Part load ratio [%]	Part load [kW]	Declared capacity [kW]	Declared COP [-]	cdh [-]	CR [-]	COPbin [-]
A	-7	88	5.04	5.18	2.13	0.99	1.00	2.13
B	2	54	3.07	3.13	3.58	0.98	1.00	3.58
C	7	35	1.97	2.94	4.74	0.97	0.67	4.67
D	12	15	0.88	3.59	6.39	0.96	0.24	5.77
E	-10	100	5.70	4.49	1.83	0.99	1.00	1.83
F - BIV	-7	88	5.04	5.18	2.13	0.99	1.00	2.13

Energy consumption for thermostat off, standby, off mode, crankcase heater mode

	Hours [h]	Power input [kW]	Applied to SCOP calculation [kW]	Energy consumption [kWh]
Off mode	0	0.0149	0.0149	0
Thermostat off	178	0.0197	0.0197	3.5066
Standby	0	0.0149	0.0149	0
Crankcase heater	178	0.0149	0	0



Calculation Bin for SCOPon

Bin	Outdoor temperature [°C]	Hours [h]	Heat load [kW]	Heat load covered by heat pump [kW]	Electrical back up heater [kW]	Annual backup heater energy input [kWh]	COPbin	Annual heating demand [kWh]	Annual energy input [kWh]	Net annual heating capacity [kWh]	Net annual power input [kWh]
E	21	-10	1	5.70	4.49	1.21	1.83	5.70	3.66	4.49	2.46
	22	-9	25	5.48	4.67	0.81	1.93	137.02	80.72	116.87	60.57
	23	-8	23	5.26	4.86	0.40	2.03	121.02	64.33	111.75	55.06
A / F - BIV	24	-7	24	5.04	5.04	0.00	2.13	121.02	56.81	121.02	56.81
	25	-6	27	4.82	4.82	0.00	2.29	130.22	56.84	130.22	56.84
	26	-5	68	4.60	4.60	0.00	2.45	313.06	127.69	313.06	127.69
	27	-4	91	4.38	4.38	0.00	2.61	399.00	152.72	399.00	152.72
	28	-3	89	4.17	4.17	0.00	2.77	370.72	133.66	370.72	133.66
	29	-2	165	3.95	3.95	0.00	2.93	651.12	221.89	651.12	221.89
	30	-1	173	3.73	3.73	0.00	3.10	644.76	208.30	644.76	208.30
	31	0	240	3.51	3.51	0.00	3.26	841.85	258.53	841.85	258.53
	32	1	280	3.29	3.29	0.00	3.42	920.77	269.46	920.77	269.46
	B	33	2	320	3.07	3.07	0.00	3.58	982.15	274.50	982.15
34		3	357	2.85	2.85	0.00	3.80	1017.45	268.03	1017.45	268.03
35		4	356	2.63	2.63	0.00	4.01	936.55	233.31	936.55	233.31
36		5	303	2.41	2.41	0.00	4.23	730.70	172.65	730.70	172.65
37		6	330	2.19	2.19	0.00	4.45	723.46	162.56	723.46	162.56
C	38	7	326	1.97	1.97	0.00	4.67	643.22	137.78	643.22	137.78
	39	8	348	1.75	1.75	0.00	4.89	610.34	124.87	610.34	124.87
	40	9	335	1.53	1.53	0.00	5.11	514.10	100.66	514.10	100.66
	41	10	315	1.32	1.32	0.00	5.33	414.35	77.79	414.35	77.79
	42	11	215	1.10	1.10	0.00	5.55	235.67	42.49	235.67	42.49
D	43	12	169	0.88	0.88	0.00	5.77	148.20	25.70	148.20	25.70
	44	13	151	0.66	0.66	0.00	5.98	99.31	16.59	99.31	16.59
	45	14	105	0.44	0.44	0.00	6.20	46.04	7.42	46.04	7.42
	46	15	74	0.22	0.22	0.00	6.42	16.22	2.53	16.22	2.53

SUM	11774.01	3281.51	11743.38	3250.88
SCOPon		3.59	SCOPnet	3.61



Detailed test results

Detailed SCOP part load test results - low temperature application - average climate – EN 14825

Detailed result for 'EN14825:2022' Average Low (A and F) A -7 /W34		
Tested according to:	EN14511:2022 and EN14825:2022	
Climate zone:		Average
Temperature application:		Low
Condition name:		A and F
Condition temperature:	°C	-7
Part load:	%	88%
Chosen Tbivalent	°C	-7
Tdesign	°C	-10
Pdesign	kW	6.80
Heating demand:	kW	6.02
CR:	-	1.0
Minimum flow reached:	-	No
Measurement type:		Transient
Integrated circulation pump:		Yes
Included corrections (Final result)		
Heating capacity	kW	5.739
COP	-	3.017
Power consumption	kW	1.902
Measured		
Heating capacity	kW	5.746
COP	-	3.007
Power consumption	kW	1.911
During heating		
Air temperature dry bulb	°C	-7.00
Air temperature wet bulb	°C	-8.12
Inlet temperature	°C	29.02
Outlet temperature	°C	33.99
Outlet temperature (Time averaged)	°C	33.99
Circulation pump		
Measured: Static differential pressure, liquid pump	Pa	3774
Calculated Hydraulic power	W	1
Calculated global efficiency	η	0.13
Calculated Capacity correction	W	8
Calculated Power correction	W	9
Water Flow	m ³ /s	0.000295



Detailed result for 'EN14825:2022' Average Low (B) A 2 /W30		
Tested according to:	EN14511:2022 and EN14825:2022	
Climate zone:	Average	
Temperature application:	Low	
Condition name:	B	
Condition temperature:	°C	2
Part load:	%	54%
Chosen Tbivalent	°C	-7
Tdesign	°C	-10
Pdesign	kW	6.80
Heating demand:	kW	3.66
CR:	-	1.0
Minimum flow reached:	-	No
Measurement type:	Transient	
Integrated circulation pump:	Yes	
Included corrections (Final result)		
Heating capacity	kW	3.716
COP	-	4.757
Power consumption	kW	0.781
Measured		
Heating capacity	kW	3.724
COP	-	4.709
Power consumption	kW	0.791
During heating		
Air temperature dry bulb	°C	2.09
Air temperature wet bulb	°C	0.95
Inlet temperature	°C	25.00
Outlet temperature	°C	29.86
Outlet temperature (Time averaged)	°C	29.86
Circulation pump		
Measured: Static differential pressure, liquid pump	Pa	6441
Calculated Hydraulic power	W	1
Calculated global efficiency	η	0.13
Calculated Capacity correction	W	8
Calculated Power correction	W	10
Water Flow	m ³ /s	0.000193



Detailed result for 'EN14825:2022' Average Low (C) A 7 /W27		
Tested according to:	EN14511:2022 and EN14825:2022	
Climate zone:	Average	
Temperature application:	Low	
Condition name:	C	
Condition temperature:	°C	7
Part load:	%	35%
Chosen Tbivalent	°C	-7
Tdesign	°C	-10
Pdesign	kW	6.80
Heating demand:	kW	2.35
CR:	-	0.7
Minimum flow reached:	-	No
Measurement type:	Steady State	
Integrated circulation pump:	Yes	
Included corrections (Final result)		
Heating capacity	kW	3.214
COP	-	6.786
Power consumption	kW	0.474
Measured		
Heating capacity	kW	3.222
COP	-	6.671
Power consumption	kW	0.483
During heating		
Air temperature dry bulb	°C	7.00
Air temperature wet bulb	°C	6.01
Inlet temperature	°C	23.23
Outlet temperature	°C	28.22
Outlet temperature (Time averaged)	°C	26.88
Circulation pump		
Measured: Static differential pressure, liquid pump	Pa	7725
Calculated Hydraulic power	W	1
Calculated global efficiency	η	0.13
Calculated Capacity correction	W	8
Calculated Power correction	W	9
Water Flow	m ³ /s	0.000155



Detailed result for 'EN14825:2022' Average Low (D) A 12 /W24		
Tested according to:	EN14511:2022 and EN14825:2022	
Climate zone:	Average	
Temperature application:	Low	
Condition name:	D	
Condition temperature:	°C	12
Part load:	%	15%
Chosen Tbivalent	°C	-7
Tdesign	°C	-10
Pdesign	kW	6.80
Heating demand:	kW	1.05
CR:	-	0.3
Minimum flow reached:	-	No
Measurement type:	Steady State	
Integrated circulation pump:	Yes	
Included corrections (Final result)		
Heating capacity	kW	3.760
COP	-	8.848
Power consumption	kW	0.425
Measured		
Heating capacity	kW	3.766
COP	-	8.724
Power consumption	kW	0.432
During heating		
Air temperature dry bulb	°C	12.00
Air temperature wet bulb	°C	10.92
Inlet temperature	°C	22.61
Outlet temperature	°C	27.47
Outlet temperature (Time averaged)	°C	23.96
Circulation pump		
Measured: Static differential pressure, liquid pump	Pa	4440
Calculated Hydraulic power	W	1
Calculated global efficiency	η	0.12
Calculated Capacity correction	W	6
Calculated Power correction	W	7
Water Flow	m ³ /s	0.000185



Detailed result for 'EN14825:2022' Average Low (E) A -10 /W35		
Tested according to:	EN14511:2022 and EN14825:2022	
Climate zone:	Average	
Temperature application:	Low	
Condition name:	E	
Condition temperature:	°C	-10
Part load:	%	100%
Chosen Tivalent	°C	-7
Tdesign	°C	-10
Pdesign	kW	6.80
Heating demand:	kW	6.80
CR:	-	1.0
Minimum flow reached:	-	No
Measurement type:	Steady State	
Integrated circulation pump:	Yes	
Included corrections (Final result)		
Heating capacity	kW	5.392
COP	-	2.684
Power consumption	kW	2.009
Measured		
Heating capacity	kW	5.404
COP	-	2.672
Power consumption	kW	2.023
During heating		
Air temperature dry bulb	°C	-10.00
Air temperature wet bulb	°C	-11.02
Inlet temperature	°C	29.99
Outlet temperature	°C	34.96
Outlet temperature (Time averaged)	°C	34.96
Circulation pump		
Measured: Static differential pressure, liquid pump	Pa	7052
Calculated Hydraulic power	W	2
Calculated global efficiency	η	0.14
Calculated Capacity correction	W	12
Calculated Power correction	W	14
Water Flow	m ³ /s	0.000261



Detailed SCOP part load test results - medium temperature application - average climate – EN 14825

Detailed result for 'EN14825:2022' Average Medium (A and F) A -7 /W52		
Tested according to:	EN14511:2022 and EN14825:2022	
Climate zone:	Average	
Temperature application:	Medium	
Condition name:	A and F	
Condition temperature:	°C	-7
Part load:	%	88%
Chosen Tivalent	°C	-7
Tdesign	°C	-10
Pdesign	kW	5.70
Heating demand:	kW	5.04
CR:	-	1.0
Minimum flow reached:	-	No
Measurement type:	Steady State	
Integrated circulation pump:	Yes	
Included corrections (Final result)		
Heating capacity	kW	5.180
COP	-	2.130
Power consumption	kW	2.433
Measured		
Heating capacity	kW	5.188
COP	-	2.125
Power consumption	kW	2.441
During heating		
Air temperature dry bulb	°C	-6.98
Air temperature wet bulb	°C	-8.01
Inlet temperature	°C	44.00
Outlet temperature	°C	52.01
Outlet temperature (Time averaged)	°C	52.01
Circulation pump		
Measured: Static differential pressure, liquid pump	Pa	7038
Calculated Hydraulic power	W	1
Calculated global efficiency	η	0.13
Calculated Capacity correction	W	8
Calculated Power correction	W	9
Water Flow	m ³ /s	0.000156



Detailed result for 'EN14825:2022' Average Medium (B) A 2 /W42		
Tested according to:	EN14511:2022 and EN14825:2022	
Climate zone:	Average	
Temperature application:	Medium	
Condition name:	B	
Condition temperature:	°C	2
Part load:	%	54%
Chosen Tbivalent	°C	-7
Tdesign	°C	-10
Pdesign	kW	5.70
Heating demand:	kW	3.07
CR:	-	1.0
Minimum flow reached:	-	No
Measurement type:	Steady State	
Integrated circulation pump:	Yes	
Included corrections (Final result)		
Heating capacity	kW	3.134
COP	-	3.578
Power consumption	kW	0.876
Measured		
Heating capacity	kW	3.138
COP	-	3.564
Power consumption	kW	0.880
During heating		
Air temperature dry bulb	°C	2.10
Air temperature wet bulb	°C	1.01
Inlet temperature	°C	35.01
Outlet temperature	°C	41.85
Outlet temperature (Time averaged)	°C	41.85
Circulation pump		
Measured: Static differential pressure, liquid pump	Pa	4813
Calculated Hydraulic power	W	1
Calculated global efficiency	η	0.12
Calculated Capacity correction	W	4
Calculated Power correction	W	4
Water Flow	m ³ /s	0.000110



Detailed result for 'EN14825:2022' Average Medium (C) A 7 /W36		
Tested according to:	EN14511:2022 and EN14825:2022	
Climate zone:	Average	
Temperature application:	Medium	
Condition name:	C	
Condition temperature:	°C	7
Part load:	%	35%
Chosen Tbivalent	°C	-7
Tdesign	°C	-10
Pdesign	kW	5.70
Heating demand:	kW	1.97
CR:	-	0.7
Minimum flow reached:	-	Yes
Measurement type:	Steady State	
Integrated circulation pump:	Yes	
Included corrections (Final result)		
Heating capacity	kW	2.938
COP	-	4.741
Power consumption	kW	0.620
Measured		
Heating capacity	kW	2.945
COP	-	4.695
Power consumption	kW	0.627
During heating		
Air temperature dry bulb	°C	7.00
Air temperature wet bulb	°C	6.00
Inlet temperature	°C	31.81
Outlet temperature	°C	38.11
Outlet temperature (Time averaged)	°C	36.04
Circulation pump		
Measured: Static differential pressure, liquid pump	Pa	8300
Calculated Hydraulic power	W	1
Calculated global efficiency	η	0.12
Calculated Capacity correction	W	7
Calculated Power correction	W	8
Water Flow	m ³ /s	0.000112



Detailed result for 'EN14825:2022' Average Medium (D) A 12 /W30		
Tested according to:	EN14511:2022 and EN14825:2022	
Climate zone:	Average	
Temperature application:	Medium	
Condition name:	D	
Condition temperature:	°C	12
Part load:	%	15%
Chosen Tbivalent	°C	-7
Tdesign	°C	-10
Pdesign	kW	5.70
Heating demand:	kW	0.88
CR:	-	0.2
Minimum flow reached:	-	Yes
Measurement type:	Steady State	
Integrated circulation pump:	Yes	
Included corrections (Final result)		
Heating capacity	kW	3.589
COP	-	6.391
Power consumption	kW	0.562
Measured		
Heating capacity	kW	3.593
COP	-	6.343
Power consumption	kW	0.566
During heating		
Air temperature dry bulb	°C	12.00
Air temperature wet bulb	°C	10.90
Inlet temperature	°C	28.11
Outlet temperature	°C	35.79
Outlet temperature (Time averaged)	°C	29.98
Circulation pump		
Measured: Static differential pressure, liquid pump	Pa	5273
Calculated Hydraulic power	W	1
Calculated global efficiency	η	0.12
Calculated Capacity correction	W	4
Calculated Power correction	W	5
Water Flow	m ³ /s	0.000112



Detailed result for 'EN14825:2022' Average Medium (E) A -10 /W55		
Tested according to:	EN14511:2022 and EN14825:2022	
Climate zone:	Average	
Temperature application:	Medium	
Condition name:	E	
Condition temperature:	°C	-10
Part load:	%	100%
Chosen Tivalent	°C	-7
Tdesign	°C	-10
Pdesign	kW	5.70
Heating demand:	kW	5.70
CR:	-	1.0
Minimum flow reached:	-	No
Measurement type:	Steady State	
Integrated circulation pump:	Yes	
Included corrections (Final result)		
Heating capacity	kW	4.491
COP	-	1.829
Power consumption	kW	2.455
Measured		
Heating capacity	kW	4.496
COP	-	1.827
Power consumption	kW	2.461
During heating		
Air temperature dry bulb	°C	-10.03
Air temperature wet bulb	°C	-11.14
Inlet temperature	°C	46.99
Outlet temperature	°C	55.08
Outlet temperature (Time averaged)	°C	55.08
Circulation pump		
Measured: Static differential pressure, liquid pump	Pa	5299
Calculated Hydraulic power	W	1
Calculated global efficiency	η	0.12
Calculated Capacity correction	W	5
Calculated Power correction	W	6
Water Flow	m ³ /s	0.000135



Detailed SCOP part load test results - low temperature application - warmer climate – EN 14825

Detailed result for 'EN14825:2022' Warmer Low (B) A 2 /W35		
Tested according to:	EN14511:2022 and EN14825:2022	
Climate zone:	Warmer	
Temperature application:	Low	
Condition name:	B	
Condition temperature:	°C	2
Part load:	%	100%
Chosen Tbivalent	°C	7
Tdesign	°C	2
Pdesign	kW	6.10
Heating demand:	kW	6.10
CR:	-	1.0
Minimum flow reached:	-	No
Measurement type:	Transient	
Integrated circulation pump:	Yes	
Included corrections (Final result)		
Heating capacity	kW	5.895
COP	-	3.817
Power consumption	kW	1.544
Measured		
Heating capacity	kW	5.906
COP	-	3.794
Power consumption	kW	1.556
During heating		
Air temperature dry bulb	°C	2.12
Air temperature wet bulb	°C	0.97
Inlet temperature	°C	30.05
Outlet temperature	°C	35.21
Outlet temperature (Time averaged)	°C	35.21
Circulation pump		
Measured: Static differential pressure, liquid pump	Pa	5353
Calculated Hydraulic power	W	2
Calculated global efficiency	η	0.13
Calculated Capacity correction	W	10
Calculated Power correction	W	12
Water Flow	m ³ /s	0.000295



Detailed result for 'EN14825:2022' Warmer Low (C) A 7 /W31		
Tested according to:	EN14511:2022 and EN14825:2022	
Climate zone:		Warmer
Temperature application:		Low
Condition name:		C
Condition temperature:	°C	7
Part load:	%	64%
Chosen Tbivalent	°C	7
Tdesign	°C	2
Pdesign	kW	6.10
Heating demand:	kW	3.92
CR:	-	1.0
Minimum flow reached:	-	No
Measurement type:		Steady State
Integrated circulation pump:		Yes
Included corrections (Final result)		
Heating capacity	kW	3.994
COP	-	6.027
Power consumption	kW	0.663
Measured		
Heating capacity	kW	3.997
COP	-	5.998
Power consumption	kW	0.666
During heating		
Air temperature dry bulb	°C	7.00
Air temperature wet bulb	°C	6.00
Inlet temperature	°C	26.01
Outlet temperature	°C	31.07
Outlet temperature (Time averaged)	°C	31.07
Circulation pump		
Measured: Static differential pressure, liquid pump	Pa	2369
Calculated Hydraulic power	W	0
Calculated global efficiency	η	0.12
Calculated Capacity correction	W	3
Calculated Power correction	W	4
Water Flow	m ³ /s	0.000190



Detailed SCOP part load test results - low temperature application - colder climate – EN 14825

Detailed result for 'EN14825:2022' Colder Low (A) A -7 /W30		
Tested according to:	EN14511:2022 and EN14825:2022	
Climate zone:	Colder	
Temperature application:	Low	
Condition name:	A	
Condition temperature:	°C	-7
Part load:	%	61%
Chosen Tbivalent	°C	-15
Tdesign	°C	-22
Pdesign	kW	5.60
Heating demand:	kW	3.39
CR:	-	1.0
Minimum flow reached:	-	No
Measurement type:	Steady State	
Integrated circulation pump:	Yes	
Included corrections (Final result)		
Heating capacity	kW	3.392
COP	-	3.736
Power consumption	kW	0.908
Measured		
Heating capacity	kW	3.400
COP	-	3.708
Power consumption	kW	0.917
During heating		
Air temperature dry bulb	°C	-6.98
Air temperature wet bulb	°C	-8.00
Inlet temperature	°C	25.00
Outlet temperature	°C	29.92
Outlet temperature (Time averaged)	°C	29.92
Circulation pump		
Measured: Static differential pressure, liquid pump	Pa	6897
Calculated Hydraulic power	W	1
Calculated global efficiency	η	0.13
Calculated Capacity correction	W	8
Calculated Power correction	W	9
Water Flow	m ³ /s	0.000166



Detailed result for 'EN14825:2022' Colder Low (F and G) A -15 /W32		
Tested according to:	EN14511:2022 and EN14825:2022	
Climate zone:	Colder	
Temperature application:	Low	
Condition name:	F and G	
Condition temperature:	°C	-15
Part load:	%	82%
Chosen Tivalent	°C	-15
Tdesign	°C	-22
Pdesign	kW	5.60
Heating demand:	kW	4.57
CR:	-	1.0
Minimum flow reached:	-	No
Measurement type:	Steady State	
Integrated circulation pump:	Yes	
Included corrections (Final result)		
Heating capacity	kW	4.526
COP	-	2.365
Power consumption	kW	1.913
Measured		
Heating capacity	kW	4.536
COP	-	2.356
Power consumption	kW	1.925
During heating		
Air temperature dry bulb	°C	-15.01
Air temperature wet bulb	°C	-15.07
Inlet temperature	°C	26.99
Outlet temperature	°C	31.89
Outlet temperature (Time averaged)	°C	31.89
Circulation pump		
Measured: Static differential pressure, liquid pump	Pa	6897
Calculated Hydraulic power	W	2
Calculated global efficiency	η	0.13
Calculated Capacity correction	W	10
Calculated Power correction	W	12
Water Flow	m ³ /s	0.000222



Detailed COP test results - low temperature – EN 14511

Detailed result for 'EN14511:2022' A7/W35		
Tested according to:		EN14511:2022
Minimum flow reached:		No
Measurement type:		Steady State
Integrated circulation pump:		Yes
Included corrections (Final result)		
Heating capacity	kW	6.462
COP	-	4.996
Power consumption	kW	1.294
Measured		
Heating capacity	kW	6.471
COP	-	4.961
Power consumption	kW	1.304
During heating		
Air temperature dry bulb	°C	6.99
Air temperature wet bulb	°C	6.00
Inlet temperature	°C	30.04
Outlet temperature	°C	35.09
Circulation pump		
Measured: Static differential pressure, liquid pump	Pa	4628
Calculated Hydraulic power	W	1
Calculated global efficiency	η	0.13
Calculated Capacity correction	W	10
Calculated Power correction	W	11
Water Flow	m ³ /s	0.000308



Wyniki próby dla cieplejszego klimatu; niska temperatura zgodnie z EN14825

N°	Warunki prowadzenia próby	Wydajność grzewcza [kW]	COP
1	B	5,895	3,817
2	Tbivalent C oraz F	3,994	6,027

Wyniki próby dla chłodniejszego klimatu; niska temperatura zgodnie z EN14825

N°	Warunki prowadzenia próby	Wydajność grzewcza [kW]	COP
1	A	3,392	3,736
2	Tbivalent F oraz G	4,526	2,365

Wyniki próby COP - niska temperatura - EN 14511

N°	Warunki prowadzenia próby	Wydajność grzewcza [kW]	COP
1	A7/W35	6,462	4,996

Wyniki próby COP - średnia temperatura - EN 14511

N°	Warunki prowadzenia próby	Wydajność grzewcza [kW]	COP
1	A7/W55	6,127	2,979





Wyniki próby pomiaru mocy akustycznej - EN 12102

N [#]	Warunki prowadzenia próby	Poziom mocy akustycznej LW(A) [dB re 1pW]	Niepewność σ_{tot} [dB]
1 ^F	A7/W35	57,1	1,6
2 ^P	A7/W35	48,9	1,6
3 ^F	A7/W55	60,1	1,6
4 ^E	A7/55	50,7	1,6

F) pełne obciążenie, P) częściowe obciążenie, E) etykietowanie ErP

Całkowity poziom mocy akustycznej skorygowany charakterystyką A jest określany dla mierzonego zakresu częstotliwości od 100 Hz do 10 kHz. W celu obliczenia niepewności należy zapoznać się z załącznikiem 1.

Pomiary mocy akustycznej zostały przeprowadzone przez Kamalathasana Arumugama (KAMA) i nadzorowane przez Patricka Gliberta (PGL) z Duńskiego Instytutu Technologicznego.





Załącznik 2 List uwierzytelniający

List uwierzytelniający

Niniejsza deklaracja zgodności została wydana na wyłączną odpowiedzialność producenta: GD Midea HEATING&VENTILATING Equipment Co.,Ltd.

Adres producenta: Midea Industrial City, Shunde, Foshan, Guangdong, P.R. Chiny

Oświadczamy, że następujące produkty wyprodukowane przez nas na rzecz firmy WIENKRA sp. z o. o. są identyczne z naszymi następującymi modelami:

Model Midea	Model SEVRA
MHC-V4WD2N8-B	SEV-HPMOI-04
MHC-V6WD2N8-B	SEV-HPMOI-06

Nazwa firmy: **WIENKRA sp. z o. o.**

Nazwa handlowa: **SEVRA**

Adres: Biuro Handlowe Kraków, ul. Kotlarska 34A, 31-539 Kraków


Informacja: Niniejsza deklaracja traci ważność w przypadku wprowadzenia przeróbek technicznych lub użytkowych bez zgody producenta.

Rok produkcji: 2022, 2023

Data: 15/08/2024

Pieczętka: [Okrągła czerwona pieczętka o treści:]

GD MIDEA HEATING & VENTILATING EQUIPMENT CO., LTD.




Poświadczam zgodność powyższego tłumaczenia z okazanym mi dokumentem w języku angielskim.

Kraków, dnia 18 września 2024 r.

Rep. nr 09/609/24

Edyta Winiarska-Stachowicz
Tłumacz przysięgły języka angielskiego

Edyta Winiarska-Stachowicz








Detailed COP test results - medium temperature – EN 14511


Detailed result for 'EN14511:2018' A7/W55		
Tested according to:		EN14511:2018
Minimum flow reached:		No
Measurement type:		Steady State
Integrated circulation pump:		Yes
Included corrections (Final result)		
Heating capacity	kW	6.127
COP	-	2.979
Power consumption	kW	2.057
Measured		
Heating capacity	kW	6.133
COP	-	2.972
Power consumption	kW	2.063
During heating		
Air temperature dry bulb	°C	7.00
Air temperature wet bulb	°C	6.00
Inlet temperature	°C	47.00
Outlet temperature	°C	54.99
Circulation pump		
Measured: Static differential pressure, liquid pump	Pa	4303
Calculated Hydraulic power	W	1
Calculated global efficiency	η	0.12
Calculated Capacity correction	W	6
Calculated Power correction	W	7
Water Flow	m ³ /s	0.000186



Detailed test results of sound power measurement – Test N#1

		<h3>Sound power levels according to ISO 3743-1:2010</h3>	
Engineering method for small, movable sources in reverberant fields - Comparison method for hard-walled test rooms			
Client: Midea		Date of test: 20-01-2024	
Object: Type: Air to water heat pump Model: MHC-V6WD2N8-BE30			
Mounting conditions: The outdoor unit is mounted on the supporting metal support frame using six vibration insulators and placed on four pieces of concrete tiles (20x20x2.5 cm). All of these are placed in a water drop tray on two pieces of heavy concrete tiles (90x90x10cm) laying on a vibration damping mat on the floor. The noise radiated by the outdoor unit has been measured in Test room 2.			
Operating conditions: A7/W35, Compressor speed: 66[Hz], Fan speed: 550[rpm], Pump speed: 40 [%], EXV1(P): 264, Heating capacity: 6.46 [kW], Power input: 1.23 [kW], Water flow rate: 1109 [l/h]			
Static pressure: 101.7 kPa		Reference box:	
Air temperature: 7.0 °C		L1: 1.3 m	
Relative air humidity: 84.0 %		L2: 0.4 m	
Test room volume: 102.8 m³	Room: Room 2	L3: 0.7 m	
Area, S, of test room: 138.9 m²		Volume: 0.4 m³	

Frequency f [Hz]	L _w 1/3 octave [dB]	1/1 oct [dB]
100	57.6	
125	57.3	60.7
160	48.6	
200	54.0	
250	55.6	58.9
315	52.2	
400	56.1	
500	49.9	57.6
630	48.6	
800	46.7	
1000	45.0	50.0
1250	43.3	
1600	43.0	
2000	40.2	45.5
2500	36.9	
3150	34.7	
4000	32.6	38.1
5000	32.2	
6300	33.2	
8000	33.7	38.6
10000	34.5	






Sound power level L_w(A): 57.1 dB [re 1pW],	Uncertainty σ_{tot}: 1.6 dB
--	--

Name of test institute: DTI	Date: 20-01-2024
No. of test report: 300-KLAB-23-040	
Measurements are in full conformity with ISO 3743-1	



Detailed test results of sound power measurement – Test N#2

				Sound power levels according to ISO 3743-1:2010																																																																					
Engineering method for small, movable sources in reverberant fields - Comparison method for hard-walled test rooms																																																																									
Client: Midea		Date of test: 20-01-2024																																																																							
Object: Type: Air to water heat pump Model: MHC-V6WD2N8-BE30																																																																									
Mounting conditions: The outdoor unit is mounted on the supporting metal support frame using six vibration insulators and placed on four pieces of concrete tiles (20x20x2.5 cm). All of these are placed in a water drop tray on two pieces of heavy concrete tiles (90x90x10cm) laying on a vibration damping mat on the floor. The noise radiated by the outdoor unit has been measured in Test room 2.																																																																									
Operating conditions: A7/W35, Compressor speed: 30[Hz], Fan speed: 400[rpm], Pump speed: 34 [%], EXV1(P): 124, Heating capacity: 3.06 [kW], Power_input: 0.566 [kW], Water flow rate: 525 [l/h]																																																																									
Static pressure: 101.7 kPa		Reference box:																																																																							
Air temperature: 7.0 °C		L1: 1.3 m																																																																							
Relative air humidity: 84.0 %		L2: 0.4 m																																																																							
Test room volume: 102.8 m³		L3: 0.7 m																																																																							
Area, S, of test room: 138.9 m²		Volume: 0.4 m³																																																																							
		Room: Room 2																																																																							
<table border="1"> <thead> <tr> <th>Frequency f [Hz]</th> <th>L_w 1/3 octave [dB]</th> <th>1/1 oct [dB]</th> </tr> </thead> <tbody> <tr><td>100</td><td>49.7</td><td></td></tr> <tr><td>125</td><td>47.8</td><td>53.1</td></tr> <tr><td>160</td><td>47.0</td><td></td></tr> <tr><td>200</td><td>44.3</td><td></td></tr> <tr><td>250</td><td>44.9</td><td>49.2</td></tr> <tr><td>315</td><td>44.2</td><td></td></tr> <tr><td>400</td><td>43.1</td><td></td></tr> <tr><td>500</td><td>46.1</td><td>48.6</td></tr> <tr><td>630</td><td>40.5</td><td></td></tr> <tr><td>800</td><td>38.1</td><td></td></tr> <tr><td>1000</td><td>36.8</td><td>42.3</td></tr> <tr><td>1250</td><td>37.6</td><td></td></tr> <tr><td>1600</td><td>34.5</td><td></td></tr> <tr><td>2000</td><td>31.8</td><td>37.1</td></tr> <tr><td>2500</td><td>28.7</td><td></td></tr> <tr><td>3150</td><td>26.7</td><td></td></tr> <tr><td>4000</td><td>26.5</td><td>32.5</td></tr> <tr><td>5000</td><td>29.4</td><td></td></tr> <tr><td>6300</td><td>28.6</td><td></td></tr> <tr><td>8000</td><td>26.3</td><td>31.7</td></tr> <tr><td>10000</td><td>25.2</td><td></td></tr> </tbody> </table>		Frequency f [Hz]	L _w 1/3 octave [dB]	1/1 oct [dB]	100	49.7		125	47.8	53.1	160	47.0		200	44.3		250	44.9	49.2	315	44.2		400	43.1		500	46.1	48.6	630	40.5		800	38.1		1000	36.8	42.3	1250	37.6		1600	34.5		2000	31.8	37.1	2500	28.7		3150	26.7		4000	26.5	32.5	5000	29.4		6300	28.6		8000	26.3	31.7	10000	25.2							
Frequency f [Hz]	L _w 1/3 octave [dB]	1/1 oct [dB]																																																																							
100	49.7																																																																								
125	47.8	53.1																																																																							
160	47.0																																																																								
200	44.3																																																																								
250	44.9	49.2																																																																							
315	44.2																																																																								
400	43.1																																																																								
500	46.1	48.6																																																																							
630	40.5																																																																								
800	38.1																																																																								
1000	36.8	42.3																																																																							
1250	37.6																																																																								
1600	34.5																																																																								
2000	31.8	37.1																																																																							
2500	28.7																																																																								
3150	26.7																																																																								
4000	26.5	32.5																																																																							
5000	29.4																																																																								
6300	28.6																																																																								
8000	26.3	31.7																																																																							
10000	25.2																																																																								
<p>Sound power level L_w(A): 48.9 dB [re 1pW], Uncertainty σ_{tot}: 1.6 dB</p>																																																																									
Name of test institute: DTI		Date: 20-01-2024																																																																							
No. of test report: 300-KLAB-23-040																																																																									
Measurements are in full conformity with ISO 3743-1																																																																									







Detailed test results of sound power measurement – Test N#3

 	<h3>Sound power levels according to ISO 3743-1:2010</h3>																																																																			
<p>Engineering method for small, movable sources in reverberant fields - Comparison method for hard-walled test rooms</p>																																																																				
<p>Client: Midea Object: Type: Air to water heat pump Model: MHC-V6WD2N8-BE30 Mounting conditions: The outdoor unit is mounted on the supporting metal support frame using six vibration insulators and placed on four pieces of concrete tiles (20x20x2.5 cm). All of these are placed in a water drop tray on two pieces of heavy concrete tiles (90x90x10cm) laying on a vibration damping mat on the floor. The noise radiated by the outdoor unit has been measured in Test room 2.</p>	<p>Date of test: 20-01-2024</p>																																																																			
<p>Operating conditions: A7/W55, Compressor speed: 66[Hz], Fan speed: 550[rpm], Pump speed: 31 [%], EXV1(P): 196, Heating capacity: 6.13 [kW], Power_input: 2.06 [kW], Water flow rate: 668 [l/h]</p>	<p>Reference box: L1: 1.3 m L2: 0.4 m L3: 0.7 m Volume: 0.4 m³</p>																																																																			
<p>Static pressure: 101.7 kPa Air temperature: 7.0 °C Relative air humidity: 84.0 % Test room volume: 102.8 m³ Area, S, of test room: 138.9 m²</p>	<p>Room: Room 2</p>																																																																			
<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th>Frequency f [Hz]</th> <th>L_w 1/3 octave [dB]</th> <th>1/1 oct [dB]</th> </tr> </thead> <tbody> <tr><td>100</td><td>57.8</td><td></td></tr> <tr><td>125</td><td>59.3</td><td>61.9</td></tr> <tr><td>160</td><td>49.2</td><td></td></tr> <tr><td>200</td><td>55.2</td><td></td></tr> <tr><td>250</td><td>58.5</td><td>62.4</td></tr> <tr><td>315</td><td>58.5</td><td></td></tr> <tr><td>400</td><td>60.7</td><td></td></tr> <tr><td>500</td><td>49.3</td><td>61.2</td></tr> <tr><td>630</td><td>48.6</td><td></td></tr> <tr><td>800</td><td>47.8</td><td></td></tr> <tr><td>1000</td><td>47.3</td><td>51.5</td></tr> <tr><td>1250</td><td>44.2</td><td></td></tr> <tr><td>1600</td><td>44.4</td><td></td></tr> <tr><td>2000</td><td>42.7</td><td>47.3</td></tr> <tr><td>2500</td><td>39.0</td><td></td></tr> <tr><td>3150</td><td>36.1</td><td></td></tr> <tr><td>4000</td><td>34.0</td><td>39.4</td></tr> <tr><td>5000</td><td>33.3</td><td></td></tr> <tr><td>6300</td><td>37.0</td><td></td></tr> <tr><td>8000</td><td>35.9</td><td>41.6</td></tr> <tr><td>10000</td><td>37.5</td><td></td></tr> </tbody> </table>	Frequency f [Hz]	L _w 1/3 octave [dB]	1/1 oct [dB]	100	57.8		125	59.3	61.9	160	49.2		200	55.2		250	58.5	62.4	315	58.5		400	60.7		500	49.3	61.2	630	48.6		800	47.8		1000	47.3	51.5	1250	44.2		1600	44.4		2000	42.7	47.3	2500	39.0		3150	36.1		4000	34.0	39.4	5000	33.3		6300	37.0		8000	35.9	41.6	10000	37.5			
Frequency f [Hz]	L _w 1/3 octave [dB]	1/1 oct [dB]																																																																		
100	57.8																																																																			
125	59.3	61.9																																																																		
160	49.2																																																																			
200	55.2																																																																			
250	58.5	62.4																																																																		
315	58.5																																																																			
400	60.7																																																																			
500	49.3	61.2																																																																		
630	48.6																																																																			
800	47.8																																																																			
1000	47.3	51.5																																																																		
1250	44.2																																																																			
1600	44.4																																																																			
2000	42.7	47.3																																																																		
2500	39.0																																																																			
3150	36.1																																																																			
4000	34.0	39.4																																																																		
5000	33.3																																																																			
6300	37.0																																																																			
8000	35.9	41.6																																																																		
10000	37.5																																																																			
<p>Sound power level L_w(A): 60.1 dB [re 1pW], Uncertainty σ_{tot}: 1.6 dB</p>																																																																				
<p>Name of test institute: DTI No. of test report: 300-KLAB-23-040</p>	<p>Date: 20-01-2024</p>																																																																			
<p>Measurements are in full conformity with ISO 3743-1</p>																																																																				






Detailed test results of sound power measurement – Test N# 4

	<h3>Sound power levels according to ISO 3743-1:2010</h3>		TEKNOLOGISK INSTITUT
Engineering method for small, movable sources in reverberant fields - Comparison method for hard-walled test rooms			
Client:	Midea	Date of test:	20-01-2024
Object:	Type: Air to water heat pump Model: MHC-V6WD2N8-BE30		
Mounting conditions:	The outdoor unit is mounted on the supporting metal support frame using six vibration insulators and placed on four pieces of concrete tiles (20x20x2.5 cm). All of these are placed in a water drop tray on two pieces of heavy concrete tiles (90x90x10cm) laying on a vibration damping mat on the floor. The noise radiated by the outdoor unit has been measured in Test room 2.		
Operating conditions:	A7/W55, Compressor speed: 38[Hz], Fan speed: 400[rpm], Pump speed: 31 [%], EXV1(P): 114, Heating capacity: 3.19 [kW], Power_input: 1.14 [kW], Water flow rate: 405 [l/h]		
Static pressure:	101.7 kPa	<u>Reference box:</u>	
Air temperature:	7.0 °C	L1:	1.3 m
Relative air humidity:	84.0 %	L2:	0.4 m
Test room volume:	102.8 m ³	Room:	Room 2
Area, S, of test room:	138.9 m ²	L3:	0.7 m
		Volume:	0.4 m ³

Frequency f [Hz]	L _w 1/3 octave [dB]	1/1 oct [dB]
100	52.5	
125	47.9	55.3
160	50.1	
200	49.0	
250	48.5	53.2
315	47.7	
400	44.2	
500	42.5	47.6
630	41.2	
800	40.9	
1000	42.0	46.0
1250	40.5	
1600	38.4	
2000	33.2	39.9
2500	29.4	
3150	26.9	
4000	24.4	30.0
5000	23.5	
6300	27.4	
8000	26.0	32.1
10000	28.3	



Sound power level L_w(A): 50.7 dB [re 1pW], Uncertainty σ_{tot}: 1.6 dB

Name of test institute:	DTI	Date:	20-01-2024
No. of test report:	300-KLAB-23-040		
Measurements are in full conformity with ISO 3743-1			



Appendix 1 Sound power measurement

Unit specification

Type of unit: Mono air to water heat pump
Manufacturer: Midea
Size of the heat pump: 0.4 x 0.7 x 1.3m (W x L x H)
Year of production: n/a.


Operating conditions and environment

The operating conditions of the unit under test fulfill the requirements for Class A.

The acoustic test chamber is a hard wall reverberant room (103 m³ and equipped with relevant sound diffusing reflector panels. The acoustical test chamber fulfils the requirements of ISO3743-1 accuracy grade 2 (engineering grade).

The measurements of the average sound pressure levels in 1/3 octave frequency bands are carried out using three microphones in the test chamber. During the measurements, the microphones are traversed up and down for one meter in the arc of a quarter circle.

The picture below shows the installation of the unit during test, position of microphones, sound diffusing reflector panels, and the reference sound source.





Measurement instruments

Id nr.	Manufacturer	Description	Calibration company
100864	GRAS	Gras 40AE_26CA, 1/2" free field microphone, Room 1	Norsonic A/S, Norway
100865	GRAS	Gras 40AE_26CA, 1/2" free field microphone, Room 1	Norsonic A/S, Norway
100866	GRAS	Gras 40AE_26CA, 1/2" free field microphone, Room 1	Norsonic A/S, Norway
100867*	GRAS	Gras 40AE_26CA, 1/2" free field microphone, Room 2	Norsonic A/S, Norway
100868*	GRAS	Gras 40AE_26CA, 1/2" free field microphone, Room 2	Norsonic A/S, Norway
100869*	GRAS	Gras 40AE_26CA, 1/2" free field microphone, Room 2	Norsonic A/S, Norway
100870	GRAS	Gras 40AE_26CA, 1/2" free field microphone, Roof monitor	Norsonic A/S, Norway
100873*	Brüel & Kjær	Acoustical calibrator, Brüel & Kjær 4231	Element Metech, Denmark
100859	Norsonic	Reference sound source, Norsonic Nor278 Room 1	RISE, Sweden
100872*	Norsonic	Reference sound source, Norsonic Nor278 Room 2	RISE, Sweden
100620*	Norsonic	Multi-channel measurement system Nor850	Norsonic A/S, Norway

*Instruments are used for the actual measurements for the calculation of the test results.

The other instruments are used for control measurements.
All microphones are equipped with windshields.



Test Procedure

The measurements of the emitted sound power level from the heat pump are carried out according to the following standard:

- DS/EN 14511:2022
- EN 12102-1:2022
- ISO/EN 3743-1:2010

The basic acoustic measurement standard DS/EN 3743-1 is a comparison method using a calibrated reference sound source. Two series of sound pressure measurements are made under exactly the same acoustic conditions, e.g., the same microphone positions, temperature and air humidity. The calibrated sound power levels are known for the reference sound source at each frequency band, and they are used in the estimation of the acoustical correction factor for the calculation of the sound power emitted from the unit under test. The background noise levels are measured and used for relevant corrections.

The final total A-weighted sound power level is based on measurements and calculations in 1/3-octave levels, which then are summed into 1/1-octave levels. The A-weighted total sound power level is determined for the measured frequency range from 100 Hz to 10 kHz.

The actual microphone positions and correction values are saved in data files linked to the complete project documentation according to the DANAK-accreditation.

The complete measurement system is documented and regularly calibrated according to DANAK.

The detailed description of the measurement method is given in Danish in the quality database system "QA Web" at Danish Technological Institute, which is accessible by DANAK.

Measurement uncertainty

The uncertainty of sound power level in decibel is determined in accordance with ISO 3743-1, equation 22 $\sigma_{tot} = \sqrt{\sigma_{RO}^2 + \sigma_{omc}^2}$ where:

- σ_{RO} is the standard deviation of the reproducibility of the method
- σ_{omc} is the standard deviation describing the uncertainty associated with the instability of the operating and mounting conditions for the particular noise source during test.

σ_{RO} expresses the uncertainty in test results delivered by the different accredited test laboratories due to different instrumentation and implementation of measurement procedure as well different radiation characteristics of the noise source during test.

σ_{omc} expresses the uncertainty associated with the instability of the operating and mounting conditions for the particular noise source during test. The mounting and installation conditions in two DTI acoustical test chambers are well defined in the test procedure. Possible instability of the operating conditions is monitored and assessed prior to each noise test.





The test uncertainty σ_{omc} is calculated according to ISO3743-1 Annex C formula C.1 and is typically below 0.5dB. However, the uncertainty is rounded up to the nearest 0.5dB increment in the report. As pr. Table C.1 (accuracy grade 2), the uncertainty σ_{RO} is set to 1.5.

The expanded uncertainty U is calculated according to ISO 3743-1 equation 23:
 $U = k \sigma_{\text{tot}}$ where $k = 2$ for 95% confidence.

EXAMPLE: $\sigma_{\text{tot}}: \sqrt{1.5^2 + 0.5^2} = 1.6 \text{ dB}$ and $U(95\%) = 3.2 \text{ dB}$

Note: The expanded uncertainty does not include the standard deviation of production which is used in ISO4871 for the purpose of making noise declaration for batches of machines.



Appendix 2 Authorization letter

Authorization Letter

This declaration of conformity is issued under the sole responsibility of
Manufacturer's Name: GD Midea HEATING&VENTILATING Equipment Co.,Ltd.
Manufacturer's Address: Midea Industrial City, Shunde, Foshan, Guangdong, P.R. China
We declare that the following product we produced for WIENKRA SP. Z O.O are identical to our following models

Midea model	SEVRA model
MHC-V4W/D2N8-B	SEV-HPMO1-04
MHC-V6W/D2N8-B	SEV-HPMO1-06

Company name: **WIENKRA SP. Z O.O**

Tradename /-mark: **SEVRA**


Address: Biuro Handlowe Krakow, ul. Kotlarska 34A, 31-539 Krakow


Note: This declaration becomes invalid if technical or operational modifications are introduced without the manufacturer's consent.

Production year: 2023


Date : 15/08/2024

Authorization:





Mgr Edyta Winiarska-Stachowicz
Tłumacz przysięgły języka angielskiego
Ul. Kazimierza Wielkiego 4/4, Kraków
tel. 609-570-720
Uwierzytelnione tłumaczenie z języka angielskiego





DANISH
TECHNOLOGICAL
INSTITUTE

Teknologiparken
Kongsvang Allé 29
DK-8000 Aarhus C
+45 72 20 20 00
Info@teknologisk.dk
www.teknologisk.dk

Strona 1 z 42
Znak: KAMA/RTHI/AAS
Nr pliku: 225959
Załączniki: 2

RAPORT Z PRZEPROWADZONEJ PRÓBY

Nr raportu:
300-KLAB-23-040-23

Klient: Firma: GD MIDEA HEATING & VENTILATING EQUIPMENT CO., LTD.
Adres: Penglai Industry Road, Beijiao
Miejscowość: Shunde, Foshan, Guangdong, 528311, Chiny
Tel.: +86 13902810522

Badana jednostka: Marka: Midea
Typ: Pompa ciepła typu powietrze-woda (monoblok)
Model: MHC-V6W/D2N8-B
Nr fabr.: 341H09752012A250100012
Rok prod.: Jedn. zewnętrzna: N/D
Data: Okres wykon. próby: Styczeń 2024

Nazwa marki: Marka: SEVRA
Typ: Pompa ciepła typu powietrze-woda (monoblok)
Model: SEV-HPMO1-06

Procedury W rozdziale Cel przeprowadzenia próby (strona 3) znajduje się wykaz norm.

Uwagi: Urządzenie dostarczył klient. Instalacja i ustawienia testowe zostały wykonane zgodnie z zaleceniami klienta. Pomiedzy każdą próbą klient zmieniał poszczególne parametry, takie jak prędkość sprężarki, zawór rozprężny, prędkość wentylatora, prędkość pompy, czas odszraniania, czas ogrzewania. Raport dla testowanej jednostki nosi nazwę 300-KLAB-23-040; wydano go 12.03.2024. Prosimy zapoznać się również z załącznikiem 2.

Warunki przeprowadzenia próby: Niniejsza próba została przeprowadzona w ramach akredytacji zgodnie z międzynarodowymi wymogami (ISO/IEC 17025:2017) oraz zgodnie z Ogólnymi Warunkami Duńskiego Instytutu Technologicznego. Wyniki próby odnoszą się wyłącznie do testowanego produktu. Niniejszy raport z przeprowadzonej próby można przytaczać we fragmentach wyłącznie za pisemną zgodą Duńskiego Instytutu Technologicznego.

Klient nie może powoływać się na Duński Instytut Technologiczny lub jego pracowników w celach reklamowych lub marketingowych, chyba że Duński Instytut Technologiczny wyrazi na to każdorazowo pisemną zgodę.

Data: 23.08.2024

**Oddział/
Centrum:** Danish Technological Institute
Energy and Climate
Heat Pump Laboratory, Aarhus

Podpis:
Kamalathan Arumugam
B.Sc. Engineer

Współpraca:
Rasmus Thisgaard
B.TecMan & MarEng



Test Reg. nr. 300



Pompy ciepła o identycznej budowie

Według GD MIDEA HEATING & VENTILATING EQUIPMENT CO., LTD. pompy ciepła wyszczególnione w poniższej tabeli są uważane za identyczne wraz z testowaną jednostką. Mają one identyczne:

- wydajność grzewczą
- obieg czynnika chłodniczego (w tym objętość czynnika chłodniczego)
- źródło ciepła i ujścia ciepła
- główne komponenty / zasadę działania i sterownia
- identyczną obudowę

Marka	Model
Midea	MHC-V6W/D2N8-B
Midea	MHC-V6W/D2N8-BE30
Midea	MHC-V6W/D2N8-BE30
Midea	MHC-V6W/D2N8-BE60
Midea	MHC-V6W/D2N8-BER90
Midea	MHC-V6W/D2N8-B1
Midea	MHC-V6W/D2N8-B1E30
Midea	MHC-V6W/D2N8-B1E60
Midea	MHC-V6W/D2N8-B1ER90
Midea	MHG-V6W/D2N8-B2
Midea	MHC-V6W/D2N8-B2E30
Midea	MHC-V6W/D2N8-B2E60
Midea	MHC-V6W/D2N8-B2ER90





Cel przeprowadzenia próby

Celem niniejszego raportu jest udokumentowanie następujących kwestii:

Sezonowy współczynnik wydajności (SCOP) przy zastosowaniu w niskiej i średniej temperaturze dla klimatu umiarkowanego zgodnie z normą EN 14825:2022.

W celu obliczenia SCOP przeprowadzono próby w warunkach obciążenia częściowego podanych w tabelach na stronie 5 i 6.

Próba obciążenia częściowego SCOP w warunkach $SCOP_C$ i $SCOP_{B\&F}$ przy zastosowaniu w niskiej temperaturze dla cieplejszego klimatu zgodnie z normą EN 14825:2022.

Próba obciążenia częściowego SCOP w warunkach $SCOP_A$ i $SCOP_{G\&F}$ przy zastosowaniu w niskiej temperaturze dla cieplejszego klimatu zgodnie z normą EN 14825:2022.

Standardowe warunki znamionowe próby COP (tryb ogrzewania) w niskiej i średniej temperaturze zgodnie z normą EN 14511:2022.

Wymagania eksploatacyjne według normy EN 14511-4:2022

- 4.2.1 Próby rozruchowe i eksploatacyjne
- 4.5 Odcięcie przepływu czynnika przenoszącego ciepło
- 4.6 Całkowite odcięcie zasilania

Pomiary mocy akustycznej według normy EN 12102-1:2022





Warunki prowadzenia próby Warunki próby SCOP dla niskich temperatur - EN 14825


Warunki częściowego obciążenia dla referencyjnego SCOP i referencyjnego SCOPon do obliczania jednostek powietrze-woda dla zastosowań niskotemperaturowych dla referencyjnego sezonu grzewczego;

„A” = umiarkowanie, „W” = cieplej, „C” = chłodniej.

	Współczynnik obciążenia częściowego w %				Zewnętrzny wymiennik ciepła		Wewnętrzny wymiennik ciepła			
					Temperatura termometru suchego (mokrego) °C		Wylot stały °C	Wylot zmienny ^d °C		
	Wzór	War. umiarkow.	Cieplej	Chłodniej	Powietrze zewnętrzne	Powietrze wylotowe	Wsz. war. klimatyczn	War. umiarkow.	Cieplej	Chłodniej
A	$(-7 - 16) / (T_{designh} - 16)$	88,46	n.d.	60,53	-7(-8)	20(12)	a / 35	a / 34	n.d.	a / 30
B	$(+2 - 16) / (T_{designh} - 16)$	53,85	100,00	36,84	2(1)	20(12)	a / 35	a / 30	a / 35	a / 27
C	$(+7 - 16) / (T_{designh} - 16)$	34,62	64,29	23,68	7(6)	20(12)	a / 35	a / 27	a / 31	a / 25
D	$(+12 - 16) / (T_{designh} - 16)$	15,38	28,57	10,53	12(11)	20(12)	a / 35	a / 24	a / 26	a / 24
E	$(TOL^e - 16) / (T_{designh} - 16)$				TOL^e	20(12)	a / 35	a / b	a / b	a / b
F	$(T_{biv} - 16) / (T_{designh} - 16)$				T_{biv}	20(12)	a / 35	a / c	a / c	a / c
G	$(-15 - 16) / (T_{designh} - 16)$	n.d.	n.d.	81,58	-15	20(12)	a / 35	n.d.	n.d.	a / 32

Informacje dodatkowe

Uwarunk. klimatyczne	$T_{designh}$ [°C]	$T_{bivalent}$ [°C]	TOL [°C]	Temperatura zewnętrzna	Natężenie przepływu
War. umiarkow.	-10	-7	-10	Zmienna	Zmienne
Cieplej	2	7	2	Zmienna	Zmienne
Chłodniej	-22	-15	-22	Zmienna	Zmienne





Warunki próby SCOP dla średnich temperatur - EN 14825

Warunki częściowego obciążenia dla referencyjnego SCOP i referencyjnego SCOPon do obliczania jednostek powietrze-woda dla zastosowań średnotemperaturowych dla referencyjnego sezonu grzewczego;

„A” = umiarkowanie, „W” = cieplej, „C” = chłodniej.

	Współczynnik obciążenia częściowego w %				Zewnętrzny wymiennik ciepła		Wewnętrzny wymiennik ciepła			
					Temperatura termometru suchego (mokrego) °C		Wylot stały °C	Wylot zmienny ^d °C		
	Wzór	War. umiarkow.	Cieplej	Chłodniej	Powietrze zewnętrzne	Powietrze wylotowe		Wsz. war. klimatyczne	War. umiarkow.	Cieplej
A	$(-7 - 16) / (T_{designh} - 16)$	88,46	n.d.	60,53	-7(-8)	20(12)	a / 55	a / 52	n.d.	a / 44
B	$(+2 - 16) / (T_{designh} - 16)$	53,85	100	36,84	2(1)	20(12)	a / 55	a / 42	a / 55	a / 37
C	$(+7 - 16) / (T_{designh} - 16)$	34,62	64,29	23,68	7(6)	20(12)	a / 55	a / 36	a / 46	a / 32
D	$(+12 - 16) / (T_{designh} - 16)$	15,38	28,57	10,53	12(11)	20(12)	a / 55	a / 30	a / 34	a / 28
E	$(TOL^e - 16) / (T_{designh} - 16)$				TOL^e	20(12)	a / 55	a / b	a / b	a / b
F	$(T_{biv} - 16) / (T_{designh} - 16)$				T_{biv}	20(12)	a / 55	a / c	a / c	a / c
G	$(-15 - 16) / (T_{designh} - 16)$	n.d.	n.d.	81,58	-15	20(12)	a / 55	n.d.	n.d.	a / 49

Informacje dodatkowe

Uwarunk. klimatyczne	$T_{designh}$ [°C]	$T_{bivalent}$ [°C]	TOL [°C]	Temperatura zewnętrzna	Natężenie przepływu
War. umiarkow.	-10	-7	-10	Zmienne	Zmienne





Warunki próby COP dla niskich temperatur – EN 14511

N [#]	Źródło ciepła		Ujście ciepła	
	Temperatura termometru suchego na wlocie (°C)	Temperatura termometru mokrego na wlocie (°C)	Temperatura wlotowa (°C)	Temperatura wylotowa (°C)
1 ^S	7	6	30	35

S: Standardowy warunek znamionowy

Warunki próby COP dla umiarkowanych temperatur - EN 14511

N [#]	Źródło ciepła		Ujście ciepła	
	Temperatura termometru suchego na wlocie (°C)	Temperatura termometru mokrego na wlocie (°C)	Temperatura wlotowa (°C)	Temperatura wylotowa (°C)
1 ^S	7	6	47	55

S: Standardowy warunek znamionowy

Warunki próby dla wymagań eksploatacyjnych - EN 14511-4

N [#]	Źródło ciepła		Ujście ciepła	Natężenie przepływu wody w wewnętrznym wymienniku ciepła	Próba
	Temperatura termometru suchego na wlocie (°C)	Temperatura termometru mokrego na wlocie (°C)	Temperatura wlotowa (°C)		
1	-25	-	14	415 l/h	Rozpoczęcie
2	-25	-	35	415 l/h	Eksploatacyjna





Warunki prowadzenia próby podczas odcięcia nośnika ciepła - EN 14511-4

N [#]	Źródło ciepła		Ujście ciepła		Wymiennik ciepła
	Temperatura termometru suchego na wlocie (°C)	Temperatura termometru mokrego na wlocie (°C)	Temperatura wlotowa (°C)	Temperatura wylotowa (°C)	
1	7	6	47	55	Wewnętrzny
2	7	6	47	55	Zewnętrzny

Warunki prowadzenia próby w przypadku odcięcia zasilania - EN 14511-4

N [#]	Źródło ciepła		Ujście ciepła	
	Temperatura termometru suchego na wlocie (°C)	Temperatura termometru mokrego na wlocie (°C)	Temperatura wlotowa (°C)	Temperatura wylotowa (°C)
1	7	6	47	55

Warunki prowadzenia prób dla pomiarów mocy akustycznej - EN 12102-1


N [#]	Warunki prowadzenia próby		Ustawienia pompy ciepła			
	Zewnętrzny wymiennik ciepła (termometr suchy/termometr mokry) (°C)	Wewnętrzny wymiennik ciepła (wlot/wylot) (°C)	Prędkość obrotowa sprężarki [®] (Hz)	Prędkość obrotowa wentylatora na zewnątrz (obr./min.)	Wydajność grzewcza (kW)	Moc wejściowa (kW)
1 ^F	7/6	30/35	66	550	6,46	1,23
2 ^P	7/6	30/35	30	400	3,06	0,57
3 ^F	7/6	47/55	66	550	6,13	2,06
4 ^E	7/6	47/55	38	400	3,19	1,14

F) pełne obciążenie, P) częściowe obciążenie, E) etykietowanie ErP



DANAK

Test Reg. nr. 300





Wyniki przeprowadzonej próby Wyniki przeprowadzonej próby SCOP w niskiej temperaturze - średnia sezonu grzewczego - EN 14825

Model (zewnątrzny)	MHC-V6W/D2N8-B
Monoblokowa pompa ciepła powietrze-woda	Y
Niskotemperaturowa pompa ciepła	N
Wyposażona w dodatkowy podgrzewacz	Y
Podgrzewacz kombinowany z pompą ciepła	N
Odwracalna	Y

Znamionowa moc cieplna ¹⁾	P_{rated}	6,8 [kW]
Sezonowa efektywność energetyczna pomieszczeń	η_s SCOP	192,8 [%] 4,89 [-]

Zmierzona wydajność ogrzewania dla częściowego obciążenia przy temperaturze zewnętrznej T_j	Umiark. war. klimatyczne	$T_j = -15^\circ\text{C}$	P_{dh}	- [kW]
		$T_j = -7^\circ\text{C}$	P_{dh}	5,74 [kW]
		$T_j = 2^\circ\text{C}$	P_{dh}	3,72 [kW]
	Aplikacja niskotemperaturowa	$T_j = 7^\circ\text{C}$	P_{dh}	3,21 [kW]
		$T_j = 12^\circ\text{C}$	P_{dh}	3,76 [kW]
		$T_j = \text{temperatura dwuwartościowa}$	P_{dh}	5,74 [kW]
		$T_j = \text{limit operacyjny}$	P_{dh}	5,39 [kW]

Zmierzony współczynnik wydajności przy temperaturze zewnętrznej T_j	Umiark. war. klimatyczne	$T_j = -15^\circ\text{C}$	COPd	- [-]
		$T_j = -7^\circ\text{C}$	COPd	3,02 [-]
		$T_j = 2^\circ\text{C}$	COPd	4,76 [-]
	Aplikacja niskotemperaturowa	$T_j = 7^\circ\text{C}$	COPd	6,79 [-]
		$T_j = 12^\circ\text{C}$	COPd	8,85 [-]
		$T_j = \text{temperatura dwuwartościowa}$	COPd	3,02 [-]
		$T_j = \text{limit operacyjny}$	COPd	2,68 [-]


Temperatura dwuwartościowa	$T_{bivalent}$	-7 [°C]
Limit operacyjny temperatury	TOL	-10 [°C]
Współczynnik utraty energii	C_{dh}	0,95 [-]

Pobór mocy w trybach innych niż tryb aktywny	Tryb wył.	P_{OFF}	0,015 [kW]
	Tryb wył. termostatu	P_{TO}	0,020 [kW]
	Tryb oczekiwania *	P_{SB}	0,015 [kW]
	Tryb grzania skrzyni korbowej ²	P_{CK}	0,015 [kW]
Podgrzewacz dodatkowy ¹⁾	Znamionowa moc cieplna	P_{SUP}	1,41 [kW]
	Rodzaj dostarczanej energii		Elektryczna

Pozostałe elementy	Sterowanie przepustowością		Zmienne
	Sterowanie przepływem wody		Zmienne
	Natężenie przepływu wody		-
	Roczne zapotrzebowanie na energię	Q_{HE}	2870 [kWh]

¹⁾W przypadku ogrzewaczy pomieszczeń z pompą ciepła i wielofunkcyjnych ogrzewaczy z pompą ciepła znamionowa moc cieplna P_{rated} , jest równa projektowemu obciążeniu grzewczemu, $P_{designh}$, a znamionowa moc cieplna dodatkowego ogrzewacza, P_{sup} , jest równa dodatkowej wydajności grzewczej, $sup(T_j)$.

²⁾ Do obliczenia SCOP stosuje się wartość $P_{CK}-P_{SB}$. Zob. str. 15





Wyniki próby SCOP w średnich temperaturach - średnia sezonu grzewczego - EN 14825

Model (zewnątrzny)	MHC-V6W/D2N8-B
Monoblokowa pompa ciepła powietrze-woda	Y
Niskotemperaturowa pompa ciepła	N
Wyposażona w dodatkowy podgrzewacz	Y
Podgrzewacz kombinowany z pompą ciepła	N
Odwracalna	Y

Znamionowa moc cieplna ¹⁾	P _{rated}	5,7 [kW]
Sezonowa efektywność energetyczna ogrzewania pomieszczeń	n _s	140,4 [%]
	SCOP	3,58 [-]

Zmierzona wydajność ogrzewania dla częściowego obciążenia przy temperaturze zewnętrznej T _j	Umiark. war. klimatyczne Aplikacja średnotemperaturowa	T _j = -15°C	P _{dh}	- [kW]
		T _j = -7°C	P _{dh}	5,18 [kW]
		T _j = 2°C	P _{dh}	3,13 [kW]
		T _j = 7°C	P _{dh}	2,94 [kW]
		T _j = 12°C	P _{dh}	3,59 [kW]
		T _j = temperatura dwuwartościowa	P _{dh}	5,18 [kW]
		T _j = limit operacyjny	P _{dh}	4,49 [kW]

Zmierzony współczynnik wydajności przy temperaturze zewnętrznej T _j	Umiark. war. klimatyczne Aplikacja średnotemperaturowa	T _j = -15°C	COP _d	- [-]
		T _j = -7°C	COP _d	2,13 [-]
		T _j = 2°C	COP _d	3,58 [-]
		T _j = 7°C	COP _d	4,74 [-]
		T _j = 12°C	COP _d	6,39 [-]
		T _j = temperatura dwuwartościowa	COP _d	2,13 [-]
		T _j = limit operacyjny	COP _d	1,83 [-]

Temperatura dwuwartościowa	T _{bivalent}	-7 [°C]
Limit operacyjny temperatury	T _{OL}	-10 [°C]
Współczynnik utraty energii	C _{dh}	0,96 [-]

Pobór mocy w trybach innych niż tryb aktywny	Tryb wył.	P _{OFF}	0,015 [kW]
	Tryb wył. termostatu	P _{TO}	0,020 [kW]
	Tryb oczekiwania	P _{SB}	0,015 [kW]
	Tryb grzania skrzyni korbowej ²⁾	P _{CK}	0,015 [kW]
Podgrzewacz dodatkowy ¹⁾	Znamionowa moc cieplna	P _{SUP}	1,21 [kW]
	Rodzaj dostarczanej energii		Elektryczna

Pozostałe element	Sterowanie przepustowością		Zmienne
	Sterowanie przepływem wody		Zmienne
	Natężenie przepływu wody		-
	Roczne zapotrzebowanie na energię	Q _{HE}	3286 [kWh]

¹⁾ W przypadku ogrzewaczy pomieszczeń z pompą ciepła i wielofunkcyjnych ogrzewaczy z pompą ciepła znamionowa moc cieplna P_{rated}, jest równa projektowemu obciążeniu grzewczemu, P_{designh}, a znamionowa moc cieplna dodatkowego ogrzewacza, P_{sup}, jest równa dodatkowej wydajności grzewczej, sup(T_j).

²⁾ Do obliczenia SCOP stosuje się wartość P_{CK}-P_{SB}. Zob. str. 17



OŚWIADCZENIE

Producent SEVRA oświadcza, iż pompy ciepła

- 1) SEV-HPMO1-04
Oznaczenie/typ/identyfikator modelu
- 2) SEV-HPMO1-06
Oznaczenie/typ/identyfikator modelu
- 3) _____
Oznaczenie/typ/identyfikator modelu
- 4) _____
Oznaczenie/typ/identyfikator modelu
- 5) _____
Oznaczenie/typ/identyfikator modelu

Należą do jednego podtypu w danym typoszeregu i spełniają łącznie następujące warunki:

- identyczna konstrukcja obiegu chłodniczego, ten sam czynnik chłodniczy/roboczy;
- ten sam producent, typ i liczba sprężarek;
- ten sam typ elementu rozprężnego;
- ten sam typ skraplacza;
- ten sam typ parownika;
- ten sam typ procesu odszraniania;
- ten sam sterownik i zasada sterowania wydajnością;
- ten sam producent, typ i liczba wentylatorów parownika (w przypadku powietrznych pomp ciepła) i zasada sterowania wydajnością (stała, zmienna lub stopniowana regulacja prędkości obrotowej);
- urządzenia z i bez zaworu czterodrogowego nie mogą być zaliczone do tego samego typoszeregu.

Kraków, 15.10.2024

Miejscowość, data



Podpis osoby upoważnionej