


Dorota Szmaida-Kuberczyk
tłumacz przysięgły języka angielskiego
Rybie, ul. Kasztanowa 33, 05-090 Raszyn
tel. 501 123 253



[Handwritten signature]

POŚWIADCZONE TŁUMACZENIE Z JĘZYKA ANGIELSKIEGO

[Dokument źródłowy, przedstawiony w formie elektronicznej, składa się z 34 numerowanych arkuszy. Na życzenie Klienta przetłumaczono strony jak niżej. Tekst w nawiasach kwadratowych pochodzi od tłumacza.] -----

[nagłówek (na każdym arkuszu oprócz 1)]: logo · **DUŃSKI INSTYTUT TECHNOLOGICZNY** [ang. Danish Technological Institute] · numer strony w formacie [nr strony] z 34 · 300-KLAB-24-020-2 -----

[stopka (na każdym arkuszu)]: logo ilac-MRA · logo DANAK · Test Reg. nr. 300 -----

[arkusz 1]: -----
logo · **DUŃSKI INSTYTUT TECHNOLOGICZNY** [ang. Danish Technological Institute] · Teknologiparken · Kongsvang Allé 29, DK-8000 Aarhus C · +45 72 20 20 00 · Info@teknologisk.dk · www.teknologisk.dk -----

Strona 1 z 34 -----

Inicjały: PRES/RTHI -----

Nr akt: 249417 -----

Załączniki: 1 -----

RAPORT Z BADAŃ -----

Nr raportu: 300-KLAB-24-020-2 -----

Klient: -----

Firma: GUANGDONG PHNIX ECO-ENERGY SOLUTION LTD. -----

Adres: No. 3 Tianyuan Road, Dagang Town, Nansha District, Guangzhou -----

Miasto: Guangdong, 511470, Chiny -----

Tel. + 86 020-39067523 -----

Element: -----

Marka: PHNIX -----


Typ: pompa ciepła powietrze-woda -----

Model: PASRW060S-BP-PS-B -----

Nr serii: B082208260010 -----

Rok produkcji: nie dotyczy -----

Daty: element badany: od maja do czerwca 2024 r. -----



Handwritten signature

Marka:

*Marka: Cooper & Hunter

Typ: pompa ciepła powietrze-woda (monoblok)

Model: CH-HP23-UIPMRM-P

Procedura: zob. cel z wykazem norm (strona 2).

Uwagi: jednostka została dostarczona przez klienta. Instalacji oraz ustawień testowych dokonano zgodnie z instrukcjami producenta.

Warunki: niniejsze badanie zostało przeprowadzone w ramach akredytacji zgodnie z wymogami międzynarodowymi (ISO/IEC 17025:2017) oraz zgodnie z Ogólnymi Warunkami Duńskiego Instytutu Technologicznego. Wyniki badania odnoszą się wyłącznie do badanego urządzenia. Niniejszy raport z badań może być przytaczany w formie wyciągu wyłącznie po uzyskaniu pisemnej zgody Duńskiego Instytutu Technologicznego.

Klient nie może wymieniać ani powoływać się na Duński Instytut Technologiczny ani na pracowników Duńskiego Instytutu Technologicznego w celach marketingowych lub reklamowych bez każdorazowej pisemnej zgody Duńskiego Instytutu Technologicznego.

Dział/Ośrodek: Duński Instytut Technologiczny · Energia i Klimat ·
Laboratorium Pomp Ciepła, Aarhus

Data: 05 sierpnia 2024 r.

Podpis:

Preben Eskerod

B.TecMan & MarEng

Współpraca:

Rasmus Thisgaard

B.TecMan & MarEng

DOKUMENT PODPISANY CYFROWO

06 sierpnia 2024 r.

Duński Instytut Technologiczny


[arkusz 7]:

Wyniki badań SCOP w niskiej temperaturze – dla średniej sezonu grzewczego – EN 14825

Model (jednostka zewnętrzna)

PASRW060S-BP-PS-B

Pompa ciepła powietrze-woda monoblok	T
Niskotemperaturowa pompa ciepła	N
Wypożyczona w dodatkowy ogrzewacz	N
Wielofunkcyjny ogrzewacz z pompą ciepła	N
Obliczenie SCOP wykonane jako odwracalne	T



Znamionowa moc cieplna ¹⁾	P_{RATED}	12,75 [kW]
Sezonowa efektywność	η_s	192,2 [%]
energetyczna ogrzewania pomieszczeń	SCOP	4,88 [-]

Zmierzona wydajność grzewcza przy częściowym obciążeniu w temperaturze zewnętrznej T_j	Klimat umiarkowany - Zastosowanie w niskiej temperaturze	$T_i = 15^\circ\text{C}$	P_{dh}	- [kW]
		$T_i = -7^\circ\text{C}$	P_{dh}	12,11 [kW]
		$T_i = 2^\circ\text{C}$	P_{dh}	7,17 [kW]
		$T_i = 7^\circ\text{C}$	P_{dh}	7,18 [kW]
		$T_i = 12^\circ\text{C}$	P_{dh}	7,90 [kW]
		$T_j = \text{temperatura dwuwartościowa}$	P_{dh}	12,11 [kW]
		$T_i = \text{granica działania}$	P_{dh}	12,26 [kW]

Zmierzony współczynnik wydajności w temperaturze zewnętrznej T_j	Klimat umiarkowany - Zastosowanie w niskiej temperaturze	$T_i = 15^\circ\text{C}$	COPd	- [-]
		$T_i = -7^\circ\text{C}$	COPd	3,36 [-]
		$T_i = 2^\circ\text{C}$	COPd	4,81 [-]
		$T_i = 7^\circ\text{C}$	COPd	5,96 [-]
		$T_i = 12^\circ\text{C}$	COPd	7,88 [-]
		$T_j = \text{temperatura dwuwartościowa}$	COPd	3,36 [-]
		$T_i = \text{granica działania}$	COPd	2,92 [-]

Temperatura dwuwartościowa	Tbivalent	-7 [°C]
Graniczna temperatura robocza	TOL	-10 [°C]
Współczynnik strat	WTOL	- [°C]
	Cdh	0,97 [-]

Pobór mocy w trybach innych niż aktywny	Tryb wyłączenia	P_{OFF}	0,022 [kW]
	Tryb wyłączzonego termostatu	P_{TO}	0,034 [kW]
	Tryb gotowości	P_{SB}	0,022 [kW]
	Tryb włączonej grzałki karteru	P_{CK}	0,022 [kW]
	Znamionowa moc cieplna	P_{SUP}	0,49 [kW]
Ogrzewacz dodatkowy ¹⁾	Rodzaj energii zasilania		elektryczna

Inne pozycje	Regulacja wydajności		zmienna
	Regulacja przepływu wody		zmienna
	Nateżenie przepływu wody		-
	Roczne zużycie energii	Q_{HE}	5398 [kWh]


W przypadku ogrzewaczy pomieszczeń z pompą ciepła i wielofunkcyjnych ogrzewaczy z pompą ciepła znamionowa moc cieplna (P_{rated}) jest równa obciążeniu obliczeniowemu dla trybu ogrzewania ($P_{designh}$), a znamionowa moc grzewcza ogrzewacza dodatkowego (P_{sup}), jest równa dodatkowej wydajności grzewczej ($\sup(T_j)$).

[arkusz 8]: -----

Wyniki badań SCOP w średniej temperaturze – dla średniej sezonu

grzewczego – EN 14825 -----

Model (jednostka zewnętrzna)	PASRW060S-BP-PS-B
Pompa ciepła powietrze-woda monoblok	T
Niskotemperaturowa pompa ciepła	N
Wypożyczona w dodatkowy ogrzewacz	N
Wielofunkcyjny ogrzewacz z pompą ciepła	N
Obliczenie SCOP wykonane jako odwracalne	T



Znamionowa moc cieplna ¹⁾	P _{RATED}	14,44 [kW]
Sezonowa efektywność ogrzewania	η _s	138,2 [%]
Energetyczna pomieszczeń	SCOP	3,53 [-]

Zmierzona wydajność grzewcza przy częściowym obciążeniu w temperaturze zewnętrznej T _j	Klimat umiarkowany - Zastosowanie w średniej temperaturze	T _i = 15°C	P _d	- [kW]
		T _i = -7°C		13,25 [kW]
		T _i = 2°C	P _d	8,16 [kW]
		T _i = 7°C	P _d	7,02 [kW]
		T _i = 12°C	P _d	8,07 [kW]
		T _j = temperatura dwuwartościowa	P _d	13,25 [kW]
		T _i = granica działania	P _d	11,27 [kW]

Zmierzony współczynnik wydajności w temperaturze zewnętrznej T _j	Klimat umiarkowany - Zastosowanie w średniej temperaturze	T _i = 15°C	COP _d	- [-]
		T _i = -7°C	COP _d	2,26 [-]
		T _i = 2°C	COP _d	3,46 [-]
		T _i = 7°C	COP _d	4,49 [-]
		T _i = 12°C	COP _d	6,43 [-]
		T _j = temperatura dwuwartościowa	COP _d	2,26 [-]
		T _i = granica działania	COP _d	1,80 [-]

Temperatura dwuwartościowa	T _{bivalent}	-7 [°C]
Graniczna temperatura robocza	TOL	-10 [°C]
Współczynnik strat	C _{dh}	0,97 [-]

Pobór mocy w trybach innych niż aktywny	Tryb wyłączenia	P _{OFF}	0,022 [kW]
	Tryb wyłączzonego termostatu	P _{TO}	0,034 [kW]
	Tryb gotowości	P _{SB}	0,022 [kW]
	Tryb włączonej grzałki karteru	P _{CK}	0,022 [kW]
	Znamionowa moc cieplna	P _{SUP}	3,17 [kW]
Ogrzewacz dodatkowy ¹⁾	Rodzaj energii zasilania		elektryczna


Inne pozycje	Regulacja wydajności		zmienna
	Regulacja przepływu wody		zmienna
	Natężenie przepływu wody		-
	Roczne zużycie energii	Q _{HE}	8452 [kWh]

W przypadku ogrzewaczy pomieszczeń z pompą ciepła i wielofunkcyjnych ogrzewaczy z pompą ciepła znamionowa moc cieplna (Prated) jest równa obciążeniu obliczeniowemu dla trybu ogrzewania (Pdesignh), a znamionowa moc grzewcza ogrzewacza dodatkowego (Psup), jest równa dodatkowej wydajności grzewczej (sup(T_j)).

[arkusz 9]: -----

Wyniki badań COP w niskiej temperaturze – EN 14511 -----

Nr	Warunki badania	Wydajność grzewcza [kW]	COP
1	A7/W35	16,097	4,325



Wyniki badań COP w średniej temperaturze – EN 14511 -----

Nr	Warunki badania	Wydajność grzewcza [kW]	COP
1	A7/W55	16,208	3,026

Wyniki badań dla rozruchu i działania – EN 14511-4 -----

Nr	Warunki badania Wlot powietrze/woda [C°]	Walidacja badania
rozruch	A-25/W9	pozytywna
działanie	A-25/W50	pozytywna

Wyniki badań przy zamknięciu przepływu czynnika przekazującego ciepło po stronie skraplacza – EN 14511-4 -----

Nr	Wymiennik ciepła	Walidacja badania
1	wewnętrzny	pozytywna
2	zewewnętrzny	pozytywna

[arkusz 10]: -----

Wyniki badań przy całkowitej awarii zasilania energią elektryczną – EN 14511-4 -----

Nr	Walidacja badania
1	pozytywna

Wyniki pomiaru mocy akustycznej – EN 12102-1 -----

Nr	Warunki badania	Poziom mocy akustycznej LW(A) [dB re 1pW]	Niepewność σ_{tot} [dB]
1 ^E	A7/W55	57,2	1,7

E) Oznaczenie ErP -----

Poziom mocy akustycznej odniesionej do A jest oznaczony dla mierzonego zakresu częstotliwości od 100 Hz do 10 kHz. W celu obliczenia niepewności zob. Załącznik 1. -----

Pomiary mocy akustycznej wykonuje Kamalathan Arumugam (KAMA) we współpracy z Patrickiem Gilbertem (PGL), Duński Instytut Technologiczny. ---

[arkusz 34]: -----

Załącznik 2 – Upoważnienie -----

Upoważnienie -----

[ang. Authorization Letter] -----

*Niniejsza deklaracja zgodności zostaje wydana na wyłączną odpowiedzialność:

Nazwa producenta: Guangdong PHNIX ECO-Energy Solution LTD -----

Adres producenta: No. 3 Tianyuan Road, Dagang Town, Nansha District
Guangzhou Guangdong, 511470 Chiny -----

Oświadczamy, iż poniższy produkt, pompy ciepła, który wyprodukowaliśmy
dla firmy COOPER AND HUNTER OVERSEAS LP, są identyczne jak nasze
poniższe modele: -----

Model Cooper&Hunter	CH-HP23-UIMPRM-P
Model PHNIX	PASRW060S-BP-PS-B

Nazwa [firma] Cooper&Hunter: COOPER AND HUNTER OVERSEAS LP ---

Nazwa marki Cooper&Hunter: Cooper&Hunter -----

Adres Cooper&Hunter: SUITE 201, 45B WEST WILMOT STREET,
RICHMOND HILL, ON L4B2P3 KANADA -----

Uwaga: Niniejsza deklaracja traci ważność w przypadku wprowadzenia zmian
technologicznych lub funkcjonalnych bez zgody producenta. -----

Data: 24 maja 2024 r. -----

Podmiot upoważniony: Guangdong PHNIX ECO-Energy Solution LTD -----

[-], nieczytelny podpis -----


[Odcisk pieczęci o treści]: W imieniu Guangdong PHNIX ECO-Energy
Solution LTD · [-], nieczytelny podpis · Podpis osoby upoważnionej -----

[koniec tłumaczenia]

Ja, Dorota Szmajda-Kuberczyk, tłumacz przysięgły języka angielskiego
wpisana na listę tłumaczy przysięgłych Ministra Sprawiedliwości pod
numerem TP/2161/05, stwierdzam zgodność powyższego tłumaczenia z
dokumentem w języku angielskim (dokument elektroniczny pdf, którego
wydruk, opatrzony pieczęcią i podpisem tłumacza, załączono do
niniejszego).

Rybie, 08.08.2024 r.

Nr Repertorium: 543/24



Dorota Szmajda-Kuberczyk

TEST REPORT

Report no.:
300-KLAB-24-020-2



DANISH
TECHNOLOGICAL
INSTITUTE

Teknologiparken
Kongsvang Allé 29
DK-8000 Aarhus C
+45 72 20 20 00
Info@teknologisk.dk
www.teknologisk.dk

Page 1 of 34
Init: PRES/RTHI
File no.: 249417
Enclosures: 1

Customer: Company: GUANGDONG PHNIX ECO-ENERGY SOLUTION LTD.
Address: No. 3 Tianyuan Road, Dagang Town, Nansha District, Guangzhou,
City: Guangdong, 511470, China
Tel.: +86 020-39067523

Component: Brand: PHNIX
Type: Air to water heat pump
Model: PASRW060S-BP-PS-B
Series no.: B082208260010
Prod. Year: N/A

Dates: Component tested: May - June 2024

Brand name: Brand: Cooper & Hunter
Type: Air to water heat pump (mono block)
Model: CH-HP23-UIIMPRM-P

Procedure: See objective (page 2) for list of standards.

Remarks: The unit was delivered by the customer. The installation and test settings were done according to the manufacturer's instructions.

Terms: This test was conducted under accreditation in accordance with international requirements (ISO/IEC 17025:2017) and in accordance with the General Terms and Conditions of Danish Technological Institute. The test results solely apply to the tested item. This test report may be quoted in extract only if Danish Technological Institute has granted its written consent.


The customer may not mention or refer to Danish Technological Institute or Danish Technological Institute's employees for advertising or marketing purposes unless Danish Technological Institute has granted its written consent in each case.

Division/Centre: Danish Technological Institute
Energy and Climate
Heat Pump Laboratory, Aarhus

Date: 2024.08.05

Signature:
Preben Eskerod
B.TecMan & MarEng

Co-reader:
Rasmus Thisgaard
B.TecMan & MarEng




DIGITALLY SIGNED DOCUMENT
6 August 2024
DANISH TECHNOLOGICAL INSTITUTE



 **DANAK**
Test Reg. nr. 300



Test results

Test results of SCOP test at low temperature - heating season average - EN 14825

Model (Outdoor)	PASRW060S-BP-PS-B
Air-to-water heat pump mono bloc	Y
Low-temperature heat pump	N
Equipped with supplementary heater	N
Heat pump combination heater	N
Reversible	Y

Rated heat output ¹⁾	P _{rated}	12.75 [kW]
Seasonal space heating energy efficiency	η_s	192.2 [%]
	SCOP	4.88 [-]

Measured capacity for heating for part load at outdoor temperature T _j	Average Climate - Low temperature application	T _j = -15 °C	P _{dH}	- [kW]
		T _j = -7 °C	P _{dH}	12.11 [kW]
		T _j = 2 °C	P _{dH}	7.17 [kW]
		T _j = 7 °C	P _{dH}	7.18 [kW]
		T _j = 12 °C	P _{dH}	7.90 [kW]
		T _j = bivalent temperature	P _{dH}	12.11 [kW]
		T _j = operation limit	P _{dH}	12.26 [kW]

Measured coefficient of performance at outdoor temperature T _j	Average Climate - Low temperature application	T _j = -15 °C	COP _d	- [-]
		T _j = -7 °C	COP _d	3.36 [-]
		T _j = 2 °C	COP _d	4.81 [-]
		T _j = 7 °C	COP _d	5.96 [-]
		T _j = 12 °C	COP _d	7.88 [-]
		T _j = bivalent temperature	COP _d	3.36 [-]
		T _j = operation limit	COP _d	2.92 [-]

Bivalent temperature	T _{bivalent}	-7 [°C]
Operation limit temperatures	TOL	-10 [°C]
Degradation coefficient	C _{dH}	0.97 [-]


Power consumption in modes other than active mode	Off mode	P _{OFF}	0.022 [kW]
	Thermostat-off mode	P _{TO}	0.034 [kW]
	Standby mode	P _{SB}	0.022 [kW]
	Crankcase heater mode	P _{CK}	0.022 [kW]
Supplementary heater ¹⁾	Rated heat output	P _{SUP}	0.49 [kW]
	Type of energy input		Electrical

Other items	Capacity control		Variable
	Water flow control		Variable
	Water flow rate		
	Annual energy consumption	Q _{HE}	5398 [kWh]

¹⁾ For heat pump space heaters and heat pump combination heaters, the rated heat output, P_{rated}, is equal to the design load for heating, P_{designh}, and the rated heat output of a supplementary heater, P_{sup}, is equal to the supplementary capacity for heating, P_{suph}.



[Signature]





Test results of SCOP test at medium temperature - heating season average - EN 14825

Model (Outdoor)	PASRW060S-BP-PS-B
Air-to-water heat pump mono bloc	Y
Low-temperature heat pump	N
Equipped with supplementary heater	N
Heat pump combination heater	N
Reversible	Y

Rated heat output ¹⁾	P_{rated}	14.44 [kW]
Seasonal space heating energy efficiency	η_s	138.2 [%]
	SCOP	3.53 [-]

Measured capacity for heating for part load at outdoor temperature T_j	Average Climate - Medium temperature application	$T_j = -15\text{ °C}$	P_{dh}	- [kW]
		$T_j = -7\text{ °C}$	P_{dh}	13.25 [kW]
		$T_j = 2\text{ °C}$	P_{dh}	8.16 [kW]
		$T_j = 7\text{ °C}$	P_{dh}	7.02 [kW]
		$T_j = 12\text{ °C}$	P_{dh}	8.07 [kW]
		$T_j = \text{bivalent temperature}$	P_{dh}	13.25 [kW]
		$T_j = \text{operation limit}$	P_{dh}	11.27 [kW]

Measured coefficient of performance at outdoor temperature T_j	Average Climate - Medium temperature application	$T_j = -15\text{ °C}$	COPd	- [-]
		$T_j = -7\text{ °C}$	COPd	2.26 [-]
		$T_j = 2\text{ °C}$	COPd	3.46 [-]
		$T_j = 7\text{ °C}$	COPd	4.49 [-]
		$T_j = 12\text{ °C}$	COPd	6.43 [-]
		$T_j = \text{bivalent temperature}$	COPd	2.26 [-]
		$T_j = \text{operation limit}$	COPd	1.80 [-]

Bivalent temperature	$T_{bivalent}$	-7 [°C]
Operation limit temperatures	TOL	-10 [°C]
	WTOL	- [°C]
Degradation coefficient	C_{dh}	0.97 [-]


Power consumption in modes other than active mode	Off mode	P_{OFF}	0.022 [kW]
	Thermostat-off mode	P_{TO}	0.034 [kW]
	Standby mode	P_{SB}	0.022 [kW]
	Crankcase heater mode	P_{CK}	0.022 [kW]
Supplementary heater ¹⁾	Rated heat output	P_{SUP}	3.17 [kW]
	Type of energy input		Electrical

Other items	Capacity control		Variable
	Water flow control		Variable
	Water flow rate		-
	Annual energy consumption	Q_{HE}	8452 [kWh]

¹⁾For heat pump space heaters and heat pump combination heaters, the rated heat output, P_{rated} , is equal to the design load for heating, $P_{designh}$, and the rated heat output of a supplementary heater, P_{sup} , is equal to the supplementary capacity for heating, $sup(T_j)$.



[Signature]





COP test results - low temperature – EN 14511

N [#]	Test conditions	Heating capacity [kW]	COP
1	A7/W35	16.097	4.325

COP test results - medium temperature – EN 14511


N [#]	Test conditions	Heating capacity [kW]	COP
1	A7/W55	16.208	3.036

Test results for starting and operating test - EN 14511-4

N [#]	Test conditions air/water inlet [°C]	Test validation
Starting	A-25/W9	Passed
Operating	A-25/W50	Passed

Test results for shutting off the heat transfer medium – EN 14511-4

N [#]	Heat exchanger	Test validation
1	Indoor	Passed
2	Outdoor	Passed





Test results for complete power supply failure – EN 14511-4

N [#]	Test validation
1	Passed

Test results of sound power measurements – EN 12102-1

N [#]	Test conditions	Sound power level LW(A) [dB re 1pW]	Uncertainty σ_{tot} [dB]
1 ^E	A7/W55	57.2	1.7

E) ErP labelling


The A-weighted total sound power level is determined for the measured frequency range from 100 Hz to 10 kHz. For the calculation of uncertainty, see appendix 1.

The sound power measurements are carried out by Kamalathasan Arumugam (KAMA) and co-read by Patrick Glibert (PGL), Danish Technological Institut



DANAK

Test Reg. nr. 300





Appendix 2 Authorization Letter

Authorization Letter

This declaration of conformity is issued under the sole responsibility of

Manufacturer's Name: Guangdong PHNIX ECO-Energy Solution LTD

Manufacturer's Address: No. 3 Tianyuan Road, Dagang Town, Nansha District
Guangzhou Guangdong, 511470 China

We declare that the following Heat pump product we produced for COOPER
AND HUNTER OVERSEAS LP are identical to our following models

Cooper&Hunter model	CH-HP23-UIMPRM-P
PHNIX model	PASRW060S-BP-PS-B

Cooper&Hunter company name: COOPER AND HUNTER OVERSEAS LP

Cooper&Hunter brand /-mark: Cooper&Hunter

Cooper&Hunter address: SUITE 201, 45B WEST WILMOT STREET,
RICHMOND HILL, ON L4B2P3 CANADA

Note: This declaration becomes invalid if technical or operational modifications
are introduced without the manufacturer's consent.

For and on behalf of
GUANGDONG PHNIX ECO-ENERGY SOLUTION LTD.
广东芬尼克兹节能设备有限公司


Date: 24 May 2024

刘建 Libian Phnix

Authorised party: Guangdong PHNIX ECO-Energy Solution LTD



[Signature]



DANAK
Test Reg. nr. 300

TEST REPORT

Report no.:
300-KLAB-24-020-2



**DANISH
TECHNOLOGICAL
INSTITUTE**

Teknologiparken
Kongsvang Allé 29
DK-8000 Aarhus C
+45 72 20 20 00
Info@teknologisk.dk
www.teknologisk.dk

Page 1 of 34
Init: PRES/RTHI
File no.: 249417
Enclosures: 1

Customer: Company: GUANGDONG PHNIX ECO-ENERGY SOLUTION LTD.
Address: No. 3 Tianyuan Road, Dagang Town, Nansha District, Guangzhou,
City: Guangdong, 511470, China
Tel.: +86 020-39067523

Component: Brand: PHNIX
Type: Air to water heat pump
Model: PASRW060S-BP-PS-B
Series no.: B082208260010
Prod. Year: N/A

Dates: Component tested: May - June 2024

Brand name: Brand: Cooper & Hunter
Type: Air to water heat pump (mono block)
Model: CH-HP23-UIMPRM-P

Procedure: See objective (page 2) for list of standards.

Remarks: The unit was delivered by the customer. The installation and test settings were done according to the manufacturer's instructions.

Terms: This test was conducted under accreditation in accordance with international requirements (ISO/IEC 17025:2017) and in accordance with the General Terms and Conditions of Danish Technological Institute. The test results solely apply to the tested item. This test report may be quoted in extract only if Danish Technological Institute has granted its written consent.

The customer may not mention or refer to Danish Technological Institute or Danish Technological Institute's employees for advertising or marketing purposes unless Danish Technological Institute has granted its written consent in each case.

Division/Centre: Danish Technological Institute
Energy and Climate
Heat Pump Laboratory, Aarhus

Date: 2024.08.05

Signature:
Preben Eskerod
B.TecMan & MarEng

Co-reader:
Rasmus Thisgaard
B.TecMan & MarEng



Test Reg. nr. 300



Objective

The objective of this report is to document the following:

The Seasonal Coefficient of Performance (SCOP) at low and medium temperature application for average climate according to EN 14825:2022.

In order to calculate the SCOP, tests were carried out at the part load conditions stated in the tables on page 4 and 5.

COP test standard rating conditions A7/W35 and A7/W55 according to EN 14511:2022.

Operating requirements according to EN 14511-4:2022

- 4.2.1 Starting and operating tests
- 4.5 Shutting of the heat transfer medium flows
- 4.6 Complete power supply failure

Sound power measurements according to EN 12102-1:2022.



Contents:

SCOP test conditions for low temperature – EN 14825	4
SCOP test conditions for medium temperature – EN 14825	5
COP test conditions - low temperature – EN 14511	6
COP test conditions - medium temperature – EN 14511	6
Test conditions for sound power measurements – EN 12102-1	6
Test results.....	7
Test results of SCOP test at low temperature - heating season average – EN 14825.....	7
Test results of SCOP test at medium temperature - heating season average – EN 14825	8
COP test results - low temperature – EN 14511	9
COP test results - medium temperature – EN 14511.....	9
Test results for starting and operating test - EN 14511-4	9
Test results for shutting off the heat transfer medium – EN 14511-4	9
Test results for complete power supply failure – EN 14511-4.....	10
Test results of sound power measurements – EN 12102-1	10
Photos	11
SCOP - detailed calculation	13
Detailed SCOP calculation of low temperature and average climate conditions – EN 14825.....	13
Detailed SCOP calculation of medium temperature and average climate conditions – EN 14825	15
Detailed test results	17
Detailed SCOP part load test results - low temperature application - average climate – EN 14825.....	17
Detailed SCOP part load test results - medium temperature application - average climate – EN 14825	22
Detailed COP test results - low temperature – EN 14511	27
Detailed COP test results - medium temperature – EN 14511	28
Detailed test results of sound power measurement – Test N#1	29
Appendix 1 Sound power measurement.....	30
Appendix 2 Authorization Letter	34



Test conditions

SCOP test conditions for low temperature – EN 14825

Part load conditions for reference SCOP and reference SCOP_{on} calculation of air to water units for low temperature application for the reference heating season;

"A" = average, "W" = warmer, and "C" = colder.

	Part load ratio in %				Outdoor heat exchanger		Indoor heat exchanger			
					Dry (wet) bulb temperature °C		Fixed outlet °C	Variable outlet ^d °C		
	Formula	Average	Warmer	Colder	Outdoor air	Exhaust air	All climates	Average	Warmer	Colder
A	$(-7 - 16) / (T_{\text{designh}} - 16)$	88,46	n.a.	60,53	-7(-8)	20(12)	a / 35	a / 34	n.a.	a / 30
B	$(+2 - 16) / (T_{\text{designh}} - 16)$	53,85	100,00	36,84	2(1)	20(12)	a / 35	a / 30	a / 35	a / 27
C	$(+7 - 16) / (T_{\text{designh}} - 16)$	34,62	64,29	23,68	7(6)	20(12)	a / 35	a / 27	a / 31	a / 25
D	$(+12 - 16) / (T_{\text{designh}} - 16)$	15,38	28,57	10,53	12(11)	20(12)	a / 35	a / 24	a / 26	a / 24
E	$(TOL^e - 16) / (T_{\text{designh}} - 16)$				TOL^e	20(12)	a / 35	a / b	a / b	a / b
F	$(T_{\text{biv}} - 16) / (T_{\text{designh}} - 16)$				T_{biv}	20(12)	a / 35	a / c	a / c	a / c
G	$(-15 - 16) / (T_{\text{designh}} - 16)$	n.a.	n.a.	81,58	-15	20(12)	a / 35	n.a.	n.a.	a / 32

Additional information

Climate	T_{designh} [°C]	T_{bivalent} [°C]	TOL [°C]	Outlet temperature	Flow rate
Average	-10	-7	-10	Variable	Fixed



SCOP test conditions for medium temperature – EN 14825

Part load conditions for reference SCOP and reference SCOPon calculation of air to water units for medium temperature application for the reference heating season;

“A” = average, “W” = warmer, and “C” = colder.

	Part load ratio in %				Outdoor heat exchanger		Indoor heat exchanger			
					Dry (wet) bulb temperature °C		Fixed outlet °C	Variable outlet ^d °C		
	Formula	Average	Warmer	Colder	Outdoor air	Exhaust air	All climates	Average	Warmer	Colder
A	$(-7 - 16) / (T_{\text{designh}} - 16)$	88,46	n.a.	60,53	-7(-8)	20(12)	^a / 55	^a / 52	n.a.	^a / 44
B	$(+2 - 16) / (T_{\text{designh}} - 16)$	53,85	100	36,84	2(1)	20(12)	^a / 55	^a / 42	^a / 55	^a / 37
C	$(+7 - 16) / (T_{\text{designh}} - 16)$	34,62	64,29	23,68	7(6)	20(12)	^a / 55	^a / 36	^a / 46	^a / 32
D	$(+12 - 16) / (T_{\text{designh}} - 16)$	15,38	28,57	10,53	12(11)	20(12)	^a / 55	^a / 30	^a / 34	^a / 28
E	$(TOL^e - 16) / (T_{\text{designh}} - 16)$				TOL^e	20(12)	^a / 55	^a / ^b	^a / ^b	^a / ^b
F	$(T_{\text{biv}} - 16) / (T_{\text{designh}} - 16)$				T_{biv}	20(12)	^a / 55	^a / ^c	^a / ^c	^a / ^c
G	$(-15 - 16) / (T_{\text{designh}} - 16)$	n.a.	n.a.	81,58	-15	20(12)	^a / 55	n.a.	n.a.	^a / 49

Additional information

Climate	T_{designh} [°C]	T_{bivalent} [°C]	TOL [°C]	Outlet temperature	Flow rate
Average	-10	-7	-10	Variable	Fixed



COP test conditions - low temperature – EN 14511

N#	Heat source		Heat sink		Heat pump settings
	Inlet dry bulb temperature (°C)	Inlet wet bulb temperature (°C)	Inlet temperature (°C)	Outlet temperature (°C)	Compressor speed/ Fan speed
1 ^S	7	6	30	35	65 Hz / 500 rpm

S: Standard rating condition

COP test conditions - medium temperature – EN 14511

N#	Heat source		Heat sink		Heat pump settings
	Inlet dry bulb temperature (°C)	Inlet wet bulb temperature (°C)	Inlet temperature (°C)	Outlet temperature (°C)	Compressor speed/ Fan speed
1 ^S	7	6	47	55	60 Hz / 500 rpm

S: Standard rating condition

Test conditions for sound power measurements – EN 12102-1

N#	Test condition		Heat pump setting			
	Outdoor heat exchanger (dry bulb/ wet bulb) (°C)	Indoor heat exchanger (inlet/ outlet) (°C)	Compressor speed (Hz)	Fan speed Motor speed 1/2 (rpm)	Heating capacity (kW)	Power input (kW)
1 ^E	7/6	47/55	30	415/420	6.95	3.11

E) ErP labelling



Test results

Test results of SCOP test at low temperature - heating season average - EN 14825

Model (Outdoor)	PASRW060S-BP-PS-B
Air-to-water heat pump mono bloc	Y
Low-temperature heat pump	N
Equipped with supplementary heater	N
Heat pump combination heater	N
Reversible	Y

Rated heat output¹⁾	P_{rated}	12.75 [kW]
Seasonal space heating energy efficiency	η_s	192.2 [%]
	SCOP	4.88 [-]

Measured capacity for heating for part load at outdoor temperature T_j	Average Climate - Low temperature application	$T_j = -15\text{ °C}$	P_{dh}	- [kW]
		$T_j = -7\text{ °C}$	P_{dh}	12.11 [kW]
		$T_j = 2\text{ °C}$	P_{dh}	7.17 [kW]
		$T_j = 7\text{ °C}$	P_{dh}	7.18 [kW]
		$T_j = 12\text{ °C}$	P_{dh}	7.90 [kW]
		$T_j = \text{bivalent temperature}$	P_{dh}	12.11 [kW]
		$T_j = \text{operation limit}$	P_{dh}	12.26 [kW]

Measured coefficient of performance at outdoor temperature T_j	Average Climate - Low temperature application	$T_j = -15\text{ °C}$	COP_d	- [-]
		$T_j = -7\text{ °C}$	COP_d	3.36 [-]
		$T_j = 2\text{ °C}$	COP_d	4.81 [-]
		$T_j = 7\text{ °C}$	COP_d	5.96 [-]
		$T_j = 12\text{ °C}$	COP_d	7.88 [-]
		$T_j = \text{bivalent temperature}$	COP_d	3.36 [-]
		$T_j = \text{operation limit}$	COP_d	2.92 [-]

Bivalent temperature	$T_{bivalent}$	-7 [°C]
Operation limit temperatures	TOL	-10 [°C]
Degradation coefficient	WTOL	- [°C]
	C_{dh}	0.97 [-]

Power consumption in modes other than active mode	Off mode	P_{OFF}	0.022 [kW]
	Thermostat-off mode	P_{TO}	0.034 [kW]
	Standby mode	P_{SB}	0.022 [kW]
	Crankcase heater mode	P_{CK}	0.022 [kW]
Supplementary heater¹⁾	Rated heat output	P_{SUP}	0.49 [kW]
	Type of energy input		Electrical

Other items	Capacity control		Variable
	Water flow control		Variable
	Water flow rate		-
	Annual energy consumption	Q_{HE}	5398 [kWh]

¹⁾For heat pump space heaters and heat pump combination heaters, the rated heat output, P_{rated} , is equal to the design load for heating, $P_{designh}$, and the rated heat output of a supplementary heater, P_{sup} , is equal to the supplementary capacity for heating, $sup(T_j)$.



Test results of SCOP test at medium temperature - heating season average – EN 14825

Model (Outdoor)	PASRW060S-BP-PS-B
Air-to-water heat pump mono bloc	Y
Low-temperature heat pump	N
Equipped with supplementary heater	N
Heat pump combination heater	N
Reversible	Y

Rated heat output¹⁾	P_{rated}	14.44 [kW]
Seasonal space heating energy efficiency	η_s	138.2 [%]
	SCOP	3.53 [-]

Measured capacity for heating for part load at outdoor temperature T_j	Average Climate - Medium temperature application	$T_j = -15\text{ °C}$	P_{dh}	- [kW]
		$T_j = -7\text{ °C}$	P_{dh}	13.25 [kW]
		$T_j = 2\text{ °C}$	P_{dh}	8.16 [kW]
		$T_j = 7\text{ °C}$	P_{dh}	7.02 [kW]
		$T_j = 12\text{ °C}$	P_{dh}	8.07 [kW]
		$T_j = \text{bivalent temperature}$	P_{dh}	13.25 [kW]
		$T_j = \text{operation limit}$	P_{dh}	11.27 [kW]

Measured coefficient of performance at outdoor temperature T_j	Average Climate - Medium temperature application	$T_j = -15\text{ °C}$	COP_d	- [-]
		$T_j = -7\text{ °C}$	COP_d	2.26 [-]
		$T_j = 2\text{ °C}$	COP_d	3.46 [-]
		$T_j = 7\text{ °C}$	COP_d	4.49 [-]
		$T_j = 12\text{ °C}$	COP_d	6.43 [-]
		$T_j = \text{bivalent temperature}$	COP_d	2.26 [-]
		$T_j = \text{operation limit}$	COP_d	1.80 [-]

Bivalent temperature	$T_{bivalent}$	-7 [°C]
Operation limit temperatures	TOL	-10 [°C]
	WTOL	- [°C]
Degradation coefficient	C_{dh}	0.97 [-]

Power consumption in modes other than active mode	Off mode	P_{OFF}	0.022 [kW]
	Thermostat-off mode	P_{TO}	0.034 [kW]
	Standby mode	P_{SB}	0.022 [kW]
	Crankcase heater mode	P_{CK}	0.022 [kW]
Supplementary heater¹⁾	Rated heat output	P_{SUP}	3.17 [kW]
	Type of energy input		Electrical

Other items	Capacity control		Variable
	Water flow control		Variable
	Water flow rate		-
	Annual energy consumption	Q_{HE}	8452 [kWh]

¹⁾For heat pump space heaters and heat pump combination heaters, the rated heat output, P_{rated} , is equal to the design load for heating, $P_{designh}$, and the rated heat output of a supplementary heater, P_{sup} , is equal to the supplementary capacity for heating, $sup(T_j)$.



COP test results - low temperature – EN 14511

N#	Test conditions	Heating capacity [kW]	COP
1	A7/W35	16.097	4.325

COP test results - medium temperature – EN 14511

N#	Test conditions	Heating capacity [kW]	COP
1	A7/W55	16.208	3.036

Test results for starting and operating test - EN 14511-4

N#	Test conditions air/water inlet [°C]	Test validation
Starting	A-25/W9	Passed
Operating	A-25/W50	Passed

Test results for shutting off the heat transfer medium – EN 14511-4

N#	Heat exchanger	Test validation
1	Indoor	Passed
2	Outdoor	Passed



Test results for complete power supply failure – EN 14511-4

N#	Test validation
1	Passed

Test results of sound power measurements – EN 12102-1

N#	Test conditions	Sound power level LW(A) [dB re 1pW]	Uncertainty σ_{tot} [dB]
1 ^E	A7/W55	57.2	1.7

E) ErP labelling

The A-weighted total sound power level is determined for the measured frequency range from 100 Hz to 10 kHz. For the calculation of uncertainty, see appendix 1.

The sound power measurements are carried out by Kamalathan Arumugam (KAMA) and co-read by Patrick Glibert (PGL), Danish Technological Institut



Photos

Rating plate

INTELLIGENT INVERTER HEAT PUMP

MODEL	PASRW060S-BP-PS-B
RATED VOLTAGE/FREQUENCY	380-415V/3N~/50Hz
MOISTURE RESISTANCE	IPX4
ELECTRICAL SHOCKPROOF	I
HEATING CAPACITY(A)	7.00~23.00 kW
HEATING POWER INPUT(A)	1.47~5.90 kW
COOLING CAPACITY(B)	5.30~15.00 kW
COOLING POWER INPUT(B)	2.03~6.59 kW
HOT WATER CAPACITY(C)	8.80~26.20 kW
HOT WATER POWER INPUT(C)	2.10~6.29 kW
*RATED POWER INPUT	8.30 kW
*RATED CURRENT INPUT	15.0 A
WATER HEAD	6.9 m
WATER FLOW	2.9 m ³ /h
WATER PIPE OUTLET/INLET	1 Inch
REFRIGERANT/ PROPER CHARGE	R32/2.0 kg
CO2 EQUIVALENT	1.35 T
NOISE	42-54dB(A)
NET WEIGHT	208 kg
OPERATION PRESSURE(LOW SIDE)	2.1 MPa
OPERATION PRESSURE(HIGH SIDE)	4.4 MPa
MAXIMUM ALLOWABLE PRESSURE	4.4 MPa
FACTORY NUMBER(ON THE BAR CODE)	
MANUFACTURED DATE(ON THE BAR CODE)	
A: AMBIENT TEMP.(DB/WB): 7°C/6°C, WATER TEMP.(IN/OUT): 30°C/35°C	
B: AMBIENT TEMP.(DB/WB): 35°C/24°C, WATER TEMP.(IN/OUT): 12°C/7°C	
C: AMBIENT TEMP.(DB/WB): 20°C/15°C, WATER TANK TEMPERATURE FROM 15°C TO 55°C.	
*According to IEC/EN 60335-1	
BTI GUMKOWSKI Sp. z o.o. Sp. k. ul. Obornicka 71 62-002 Suchy Las	

Model: PASRW060S-BP-PS-B
Product Code: 13130233
Batch No: 0000044485

Serial No. : B082208260010



Outdoor unit





SCOP - detailed calculation

Detailed SCOP calculation of low temperature and average climate conditions – EN 14825

Calculation of reference SCOP

$$SCOP = \frac{P_{designh} \times H_{he}}{\frac{P_{designh} \times H_{he}}{SCOP_{on}} + H_{TO} \times P_{TO} + H_{SB} \times P_{SB} + H_{CK} \times P_{CK} + H_{OFF} \times P_{OFF}}$$

Where

P_{design} =	Heating load of the building at design temperature, kW
H_{he} =	Number of equivalent heating hours, 2066 h
H_{TO} , H_{SB} , H_{CK} , H_{OFF} =	Number of hours for which the unit is considered to work in thermostat off mode, standby mode, crankcase heater mode and off mode, h, respectively
P_{TO} , P_{SB} , P_{CK} , P_{OFF} =	Electricity consumption during thermostat off mode, standby mode, crankcase heater mode and off mode, kW, respectively

Data for SCOP

	Outdoor temperature [°C]	Part load ratio [%]	Part load [kW]	Declared capacity [kW]	Declared COP [-]	cdh [-]	CR [-]	COP _{bin} [-]
A	-7	88	11.28	12.11	3.36	0.99	1.00	3.36
B	2	54	6.87	7.17	4.81	0.98	1.00	4.81
C	7	35	4.41	7.18	5.96	0.97	0.61	5.85
D	12	15	1.96	7.90	7.88	0.97	0.25	7.15
E	-10	100	12.75	12.26	2.92	0.99	1.00	2.92
F - BIV	-7	88	11.28	12.11	3.36	0.99	1.00	3.36

Energy consumption for thermostat off, standby, off mode, crankcase heater mode

	Hours [h]	Power input [kW]	Applied to SCOP calculation [kW]	Energy consumption [kWh]
Off mode	0	0.022	0.022	0
Thermostat off	178	0.034	0.034	6.052
Standby	0	0.022	0.022	0
Crankcase heater	178	0.022	0	0



Calculation Bin for SCOP_{on}

	Bin	Outdoor temperature [°C]	Hours [h]	Heat load [kW]	Heat load covered by heat pump [kW]	Electrical back up heater [kW]	backup heater energy input [kWh]	COP _{bin} [-]	Annual heating demand [kWh]	Annual energy input [kWh]	Net annual heating capacity [kWh]	Net annual power input [kWh]
E	21	-10	1	12.75	12.26	0.49	0.49	2.92	12.75	4.69	12.26	4.20
	22	-9	25	12.26	11.94	0.32	8.09	3.07	306.49	105.42	298.40	97.34
	23	-8	23	11.77	11.61	0.16	3.72	3.21	270.69	86.77	266.97	83.05
A / F - BIV	24	-7	24	11.28	11.28	0.00	0.00	3.36	270.69	80.48	270.69	80.48
	25	-6	27	10.79	10.79	0.00	0.00	3.52	291.29	82.64	291.29	82.64
	26	-5	68	10.30	10.30	0.00	0.00	3.69	700.27	190.00	700.27	190.00
	27	-4	91	9.81	9.81	0.00	0.00	3.85	892.50	232.03	892.50	232.03
	28	-3	89	9.32	9.32	0.00	0.00	4.01	829.24	206.92	829.24	206.92
	29	-2	165	8.83	8.83	0.00	0.00	4.17	1456.44	349.40	1456.44	349.40
	30	-1	173	8.34	8.34	0.00	0.00	4.33	1442.22	333.12	1442.22	333.12
	31	0	240	7.85	7.85	0.00	0.00	4.49	1883.08	419.36	1883.08	419.36
	32	1	280	7.36	7.36	0.00	0.00	4.65	2059.62	442.81	2059.62	442.81
B	33	2	320	6.87	6.87	0.00	0.00	4.81	2196.92	456.53	2196.92	456.53
	34	3	357	6.38	6.38	0.00	0.00	5.02	2275.88	453.29	2275.88	453.29
	35	4	356	5.88	5.88	0.00	0.00	5.23	2094.92	400.61	2094.92	400.61
	36	5	303	5.39	5.39	0.00	0.00	5.44	1634.45	300.57	1634.45	300.57
	37	6	330	4.90	4.90	0.00	0.00	5.65	1618.27	286.61	1618.27	286.61
C	38	7	326	4.41	4.41	0.00	0.00	5.85	1438.79	245.74	1438.79	245.74
	39	8	348	3.92	3.92	0.00	0.00	6.11	1365.23	223.30	1365.23	223.30
	40	9	335	3.43	3.43	0.00	0.00	6.37	1149.95	180.44	1149.95	180.44
	41	10	315	2.94	2.94	0.00	0.00	6.63	926.83	139.75	926.83	139.75
	42	11	215	2.45	2.45	0.00	0.00	6.89	527.16	76.50	527.16	76.50
D	43	12	169	1.96	1.96	0.00	0.00	7.15	331.50	46.36	331.50	46.36
	44	13	151	1.47	1.47	0.00	0.00	7.41	222.14	29.98	222.14	29.98
	45	14	105	0.98	0.98	0.00	0.00	7.67	102.98	13.43	102.98	13.43
	46	15	74	0.49	0.49	0.00	0.00	7.93	36.29	4.58	36.29	4.58

SUM	26336.60	5391.35	26324.31	5379.05
SCOP_{on}		4.88	SCOP_{net}	4.89



Detailed SCOP calculation of medium temperature and average climate conditions – EN 14825

Calculation of reference SCOP

$$SCOP = \frac{P_{design} \times H_{he}}{\frac{P_{design} \times H_{he}}{SCOP_{on}} + H_{TO} \times P_{TO} + H_{SB} \times P_{SB} + H_{CK} \times P_{CK} + H_{OFF} \times P_{OFF}}$$

Where

P_{design} =

Heating load of the building at design temperature, kW

H_{he} =

Number of equivalent heating hours, 2066 h

H_{TO} , H_{SB} , H_{CK} , H_{OFF} =

Number of hours for which the unit is considered to work in thermostat off mode, standby mode, crankcase heater mode and off mode, h, respectively

P_{TO} , P_{SB} , P_{CK} , P_{OFF} =

Electricity consumption during thermostat off mode, standby mode, crankcase heater mode and off mode, kW, respectively

Data for SCOP

	Outdoor temperature [°C]	Part load ratio [%]	Part load [kW]	Declared capacity [kW]	Declared COP [-]	cdh [-]	CR [-]	COPbin [-]
A	-7	88	12.77	13.25	2.26	0.99	1.00	2.26
B	2	54	7.78	8.16	3.46	0.99	1.00	3.46
C	7	35	5.00	7.02	4.49	0.98	0.71	4.45
D	12	15	2.22	8.07	6.43	0.97	0.28	6.01
E	-10	100	14.44	11.27	1.80	0.99	1.00	1.80
F - BIV	-7	88	12.77	13.25	2.26	0.99	1.00	2.26

Energy consumption for thermostat off, standby, off mode, crankcase heater mode

	Hours [h]	Power input [kW]	Applied to SCOP calculation [kW]	Energy consumption [kWh]
Off mode	0	0.022	0.022	0
Thermostat off	178	0.034	0.034	6.052
Standby	0	0.022	0.022	0
Crankcase heater	178	0.022	0	0



Calculation Bin for SCOP_{on}

	Bin	Outdoor temperature [°C]	Hours [h]	Heat load [kW]	Heat load covered by heat pump [kW]	Electrical back up heater [kW]	backup heater energy input [kWh]	COP _{bin} [-]	Annual heating demand [kWh]	Annual energy input [kWh]	Net annual heating capacity [kWh]	Net annual power input [kWh]
	[-]											
E	21	-10	1	14.44	11.27	3.17	3.17	1.80	14.44	9.44	11.27	6.27
	22	-9	25	13.88	11.77	2.11	52.86	1.95	347.12	203.55	294.26	150.69
	23	-8	23	13.33	12.27	1.06	24.32	2.11	306.57	158.17	282.26	133.85
A / F - BIV	24	-7	24	12.77	12.77	0.00	0.00	2.26	306.57	135.37	306.57	135.37
	25	-6	27	12.22	12.22	0.00	0.00	2.40	329.90	137.62	329.90	137.62
	26	-5	68	11.66	11.66	0.00	0.00	2.53	793.09	313.54	793.09	313.54
	27	-4	91	11.11	11.11	0.00	0.00	2.66	1010.80	379.74	1010.80	379.74
	28	-3	89	10.55	10.55	0.00	0.00	2.79	939.16	336.11	939.16	336.11
	29	-2	165	10.00	10.00	0.00	0.00	2.93	1649.49	563.63	1649.49	563.63
	30	-1	173	9.44	9.44	0.00	0.00	3.06	1633.39	533.98	1633.39	533.98
	31	0	240	8.89	8.89	0.00	0.00	3.19	2132.68	668.28	2132.68	668.28
	32	1	280	8.33	8.33	0.00	0.00	3.32	2332.62	701.83	2332.62	701.83
B	33	2	320	7.78	7.78	0.00	0.00	3.46	2488.12	719.94	2488.12	719.94
	34	3	357	7.22	7.22	0.00	0.00	3.65	2577.54	705.32	2577.54	705.32
	35	4	356	6.66	6.66	0.00	0.00	3.85	2372.60	615.81	2372.60	615.81
	36	5	303	6.11	6.11	0.00	0.00	4.05	1851.10	456.92	1851.10	456.92
	37	6	330	5.55	5.55	0.00	0.00	4.25	1832.77	431.27	1832.77	431.27
C	38	7	326	5.00	5.00	0.00	0.00	4.45	1629.50	366.34	1629.50	366.34
	39	8	348	4.44	4.44	0.00	0.00	4.76	1546.19	324.86	1546.19	324.86
	40	9	335	3.89	3.89	0.00	0.00	5.07	1302.38	256.82	1302.38	256.82
	41	10	315	3.33	3.33	0.00	0.00	5.38	1049.68	195.01	1049.68	195.01
	42	11	215	2.78	2.78	0.00	0.00	5.69	597.04	104.85	597.04	104.85
D	43	12	169	2.22	2.22	0.00	0.00	6.01	375.44	62.51	375.44	62.51
	44	13	151	1.67	1.67	0.00	0.00	6.32	251.59	39.83	251.59	39.83
	45	14	105	1.11	1.11	0.00	0.00	6.63	116.63	17.59	116.63	17.59
	46	15	74	0.56	0.56	0.00	0.00	6.94	41.10	5.92	41.10	5.92
SUM									29827.49	8444.25	29747.14	8363.91
SCOP_{on}										3.53	SCOP_{net}	3.56



Detailed test results

Detailed SCOP part load test results - low temperature application - average climate – EN 14825

Detailed result for 'EN14825:2022' Average Low (A) A -7 /W34		
Tested according to:	EN14511:2022 and EN14825:2022	
Climate zone:	Average	
Temperature application:	Low	
Condition name:	A	
Condition temperature:	°C	-7
Part load:	%	88%
Chosen Tbivalent	°C	-10
Tdesign	°C	-10
Pdesign	kW	12.75
Heating demand:	kW	11.28
CR:	-	1.0
Minimum flow reached:	-	No
Measurement type:	Steady State	
Integrated liquid pump:	Yes	
Integrated liquid pump able to generate a positive ext. static pressure difference:	Yes	
Included corrections (Final result)		
Heating capacity	kW	12.114
COP	-	3.364
Power consumption	kW	3.601
Measured		
Heating capacity	kW	12.189
COP	-	3.276
Power consumption	kW	3.721
During heating		
Air_inlet temperature dry bulb	°C	-7.02
Air temperature wet bulb	°C	-8.16
Water_inlet temperature	°C	30.71
water_outlet temperature	°C	34.11
Water_outlet temperature (Time averaged)	°C	34.11
Circulation pump		
Measured external static pressure difference, liquid pump	Pa	50585
Calculated Hydraulic power	W	43
Calculated global efficiency	η	0.36
Calculated Capacity correction	W	76
Calculated Power correction	W	119
Water Flow	m³/s	0.000858



Detailed result for 'EN14825:2022' Average Low (B) A 2 /W30		
Tested according to:	EN14511:2022 and EN14825:2022	
Climate zone:		Average
Temperature application:		Low
Condition name:		B
Condition temperature:	°C	2
Part load:	%	54%
Chosen Tbivalent	°C	-10
Tdesign	°C	-10
Pdesign	kW	12.75
Heating demand:	kW	6.87
CR:	-	1.0
Minimum flow reached:	-	No
Measurement type:		Steady State
Integrated liquid pump:		Yes
Integrated liquid pump able to generate a positive ext. static pressure difference:		Yes
Included corrections (Final result)		
Heating capacity	kW	7.171
COP	-	4.812
Power consumption	kW	1.490
Measured		
Heating capacity	kW	7.246
COP	-	4.503
Power consumption	kW	1.609
During heating		
Air_inlet temperature dry bulb	°C	1.98
Air temperature wet bulb	°C	1.00
Water_inlet temperature	°C	28.07
water_outlet temperature	°C	30.10
Water_outlet temperature (Time averaged)	°C	30.10
Circulation pump		
Measured external static pressure difference, liquid pump	Pa	50585
Calculated Hydraulic power	W	43
Calculated global efficiency	η	0.36
Calculated Capacity correction	W	76
Calculated Power correction	W	119
Water Flow	m ³ /s	0.000858



Detailed result for 'EN14825:2022' Average Low (C) A 7 /W27		
Tested according to:	EN14511:2022 and EN14825:2022	
Climate zone:		Average
Temperature application:		Low
Condition name:		C
Condition temperature:	°C	7
Part load:	%	35%
Chosen Tbivalent	°C	-10
Tdesign	°C	-10
Pdesign	kW	12.75
Heating demand:	kW	4.41
CR:	-	0.6
Minimum flow reached:	-	No
Measurement type:		Steady State
Integrated liquid pump:		Yes
Integrated liquid pump able to generate a positive ext. static pressure difference:		Yes
Included corrections (Final result)		
Heating capacity	kW	7.179
COP	-	5.958
Power consumption	kW	1.205
Measured		
Heating capacity	kW	7.255
COP	-	5.480
Power consumption	kW	1.324
During heating		
Air_inlet temperature dry bulb	°C	6.97
Air temperature wet bulb	°C	5.82
Water_inlet temperature	°C	25.80
water_outlet temperature	°C	27.82
Water_outlet temperature (Time averaged)	°C	27.04
Circulation pump		
Measured external static pressure difference, liquid pump	Pa	50585
Calculated Hydraulic power	W	43
Calculated global efficiency	η	0.36
Calculated Capacity correction	W	76
Calculated Power correction	W	119
Water Flow	m ³ /s	0.000858



Detailed result for 'EN14825:2022' Average Low (D) A 12 /W24		
Tested according to:	EN14511:2022 and EN14825:2022	
Climate zone:		Average
Temperature application:		Low
Condition name:		D
Condition temperature:	°C	12
Part load:	%	15%
Chosen Tbivalent	°C	-10
Tdesign	°C	-10
Pdesign	kW	12.75
Heating demand:	kW	1.96
CR:	-	0.2
Minimum flow reached:	-	No
Measurement type:		Steady State
Integrated liquid pump:		Yes
Integrated liquid pump able to generate a positive ext. static pressure difference:		Yes
Included corrections (Final result)		
Heating capacity	kW	7.898
COP	-	7.885
Power consumption	kW	1.002
Measured		
Heating capacity	kW	7.973
COP	-	7.114
Power consumption	kW	1.121
During heating		
Air_inlet temperature dry bulb	°C	11.87
Air temperature wet bulb	°C	11.00
Water_inlet temperature	°C	23.60
water_outlet temperature	°C	25.83
Water_outlet temperature (Time averaged)	°C	24.15
Circulation pump		
Measured external static pressure difference, liquid pump	Pa	50585
Calculated Hydraulic power	W	43
Calculated global efficiency	η	0.36
Calculated Capacity correction	W	76
Calculated Power correction	W	119
Water Flow	m ³ /s	0.000858



Detailed result for 'EN14825:2022' Average Low (E) A -10 /W35		
Tested according to:	EN14511:2022 and EN14825:2022	
Climate zone:		Average
Temperature application:		Low
Condition name:		E
Condition temperature:	°C	-10
Part load:	%	100%
Chosen Tbivalent	°C	-10
Tdesign	°C	-10
Pdesign	kW	12.75
Heating demand:	kW	12.75
CR:	-	1.0
Minimum flow reached:	-	No
Measurement type:		Transient
Integrated liquid pump:		Yes
Integrated liquid pump able to generate a positive ext. static pressure difference:		Yes
Included corrections (Final result)		
Heating capacity	kW	12.265
COP	-	2.917
Power consumption	kW	4.205
Measured		
Heating capacity	kW	12.340
COP	-	2.854
Power consumption	kW	4.324
During heating		
Air_inlet temperature dry bulb	°C	-10.10
Air temperature wet bulb	°C	-11.19
Water_inlet temperature	°C	31.38
water_outlet temperature	°C	35.06
Water_outlet temperature (Time averaged)	°C	35.06
Circulation pump		
Measured external static pressure difference, liquid pump	Pa	50109
Calculated Hydraulic power	W	43
Calculated global efficiency	η	0.36
Calculated Capacity correction	W	75
Calculated Power correction	W	118
Water Flow	m ³ /s	0.000858



Detailed SCOP part load test results - medium temperature application - average climate – EN 14825

Detailed result for 'EN14825:2022' Average Medium (A) A -7 /W52		
Tested according to:	EN14511:2022 and EN14825:2022	
Climate zone:		Average
Temperature application:		Medium
Condition name:		A
Condition temperature:	°C	-7
Part load:	%	88%
Chosen Tbivalent	°C	-10
Tdesign	°C	-10
Pdesign	kW	14.44
Heating demand:	kW	12.77
CR:	-	1.0
Minimum flow reached:	-	No
Measurement type:		Steady State
Integrated liquid pump:		Yes
Integrated liquid pump able to generate a positive ext. static pressure difference:		Yes
Included corrections (Final result)		
Heating capacity	kW	13.247
COP	-	2.265
Power consumption	kW	5.849
Measured		
Heating capacity	kW	13.335
COP	-	2.226
Power consumption	kW	5.991
During heating		
Air_inlet temperature dry bulb	°C	-7.04
Air temperature wet bulb	°C	-8.22
Water_inlet temperature	°C	45.71
water_outlet temperature	°C	52.21
Water_outlet temperature (Time averaged)	°C	52.21
Circulation pump		
Measured external static pressure difference, liquid pump	Pa	108303
Calculated Hydraulic power	W	53
Calculated global efficiency	η	0.38
Calculated Capacity correction	W	88
Calculated Power correction	W	141
Water Flow	m ³ /s	0.000491



Detailed result for 'EN14825:2022' Average Medium (B) A 2 /W42		
Tested according to:	EN14511:2022 and EN14825:2022	
Climate zone:		Average
Temperature application:		Medium
Condition name:		B
Condition temperature:	°C	2
Part load:	%	54%
Chosen Tbivalent	°C	-10
Tdesign	°C	-10
Pdesign	kW	14.44
Heating demand:	kW	7.78
CR:	-	1.0
Minimum flow reached:	-	No
Measurement type:		Steady State
Integrated liquid pump:		Yes
Integrated liquid pump able to generate a positive ext. static pressure difference:		Yes
Included corrections (Final result)		
Heating capacity	kW	8.162
COP	-	3.456
Power consumption	kW	2.362
Measured		
Heating capacity	kW	8.250
COP	-	3.296
Power consumption	kW	2.503
During heating		
Air_inlet temperature dry bulb	°C	1.95
Air temperature wet bulb	°C	1.01
Water_inlet temperature	°C	38.10
water_outlet temperature	°C	42.12
Water_outlet temperature (Time averaged)	°C	42.12
Circulation pump		
Measured external static pressure difference, liquid pump	Pa	108303
Calculated Hydraulic power	W	53
Calculated global efficiency	η	0.38
Calculated Capacity correction	W	88
Calculated Power correction	W	141
Water Flow	m ³ /s	0.000491



Detailed result for 'EN14825:2022' Average Medium (C) A 7 /W36		
Tested according to:	EN14511:2022 and EN14825:2022	
Climate zone:		Average
Temperature application:		Medium
Condition name:		C
Condition temperature:	°C	7
Part load:	%	35%
Chosen Tbivalent	°C	-10
Tdesign	°C	-10
Pdesign	kW	14.44
Heating demand:	kW	5.00
CR:	-	0.7
Minimum flow reached:	-	No
Measurement type:		Steady State
Integrated liquid pump:		Yes
Integrated liquid pump able to generate a positive ext. static pressure difference:		Yes
Included corrections (Final result)		
Heating capacity	kW	7.024
COP	-	4.487
Power consumption	kW	1.565
Measured		
Heating capacity	kW	7.112
COP	-	4.169
Power consumption	kW	1.706
During heating		
Air_inlet temperature dry bulb	°C	6.92
Air temperature wet bulb	°C	5.99
Water_inlet temperature	°C	33.57
water_outlet temperature	°C	37.04
Water_outlet temperature (Time averaged)	°C	36.04
Circulation pump		
Measured external static pressure difference, liquid pump	Pa	108303
Calculated Hydraulic power	W	53
Calculated global efficiency	η	0.38
Calculated Capacity correction	W	88
Calculated Power correction	W	141
Water Flow	m ³ /s	0.000491



Detailed result for 'EN14825:2022' Average Medium (D) A 12 /W30		
Tested according to:	EN14511:2022 and EN14825:2022	
Climate zone:		Average
Temperature application:		Medium
Condition name:		D
Condition temperature:	°C	12
Part load:	%	15%
Chosen Tbivalent	°C	-10
Tdesign	°C	-10
Pdesign	kW	14.44
Heating demand:	kW	2.22
CR:	-	0.3
Minimum flow reached:	-	No
Measurement type:		Steady State
Integrated liquid pump:		Yes
Integrated liquid pump able to generate a positive ext. static pressure difference:		Yes
Included corrections (Final result)		
Heating capacity	kW	8.068
COP	-	6.434
Power consumption	kW	1.254
Measured		
Heating capacity	kW	8.156
COP	-	5.848
Power consumption	kW	1.395
During heating		
Air_inlet temperature dry bulb	°C	11.90
Air temperature wet bulb	°C	11.07
Water_inlet temperature	°C	28.99
water_outlet temperature	°C	32.97
Water_outlet temperature (Time averaged)	°C	30.09
Circulation pump		
Measured external static pressure difference, liquid pump	Pa	108303
Calculated Hydraulic power	W	53
Calculated global efficiency	η	0.38
Calculated Capacity correction	W	88
Calculated Power correction	W	141
Water Flow	m ³ /s	0.000491



Detailed result for 'EN14825:2022' Average Medium (E) A -10 /W55		
Tested according to:	EN14511:2022 and EN14825:2022	
Climate zone:		Average
Temperature application:		Medium
Condition name:		E
Condition temperature:	°C	-10
Part load:	%	100%
Chosen Tbivalent	°C	-10
Tdesign	°C	-10
Pdesign	kW	14.44
Heating demand:	kW	14.44
CR:	-	1.0
Minimum flow reached:	-	No
Measurement type:		Steady State
Integrated liquid pump:		Yes
Integrated liquid pump able to generate a positive ext. static pressure difference:		Yes
Included corrections (Final result)		
Heating capacity	kW	11.268
COP	-	1.797
Power consumption	kW	6.272
Measured		
Heating capacity	kW	11.356
COP	-	1.771
Power consumption	kW	6.414
During heating		
Air_inlet temperature dry bulb	°C	-9.98
Air temperature wet bulb	°C	-11.14
Water_inlet temperature	°C	49.42
water_outlet temperature	°C	54.96
Water_outlet temperature (Time averaged)	°C	54.96
Circulation pump		
Measured external static pressure difference, liquid pump	Pa	108303
Calculated Hydraulic power	W	53
Calculated global efficiency	η	0.38
Calculated Capacity correction	W	88
Calculated Power correction	W	141
Water Flow	m ³ /s	0.000491



Detailed COP test results - low temperature – EN 14511

Detailed result for 'EN14511:2022' A7/W35		
Tested according to:	EN14511:2022	
Minimum flow reached:	No	
Measurement type:	Transient	
Integrated circulation pump:	Yes	
Included corrections (Final result)		
Heating capacity	kW	16.097
COP	-	4.325
Power consumption	kW	3.722
Measured		
Heating capacity	kW	16.172
COP	-	4.210
Power consumption	kW	3.841
During heating		
Air temperature dry bulb	°C	6.88
Air temperature wet bulb	°C	5.86
Inlet temperature	°C	29.98
Outlet temperature	°C	34.89
Circulation pump		
Measured: Static differential pressure, liquid pump	Pa	50585
Calculated Hydraulic power	W	43
Calculated global efficiency	η	0.36
Calculated Capacity correction	W	76
Calculated Power correction	W	119
Water Flow	m³/s	0.000858




Detailed COP test results - medium temperature – EN 14511

Detailed result for 'EN14511:2022' A7/W55		
Tested according to:	EN14511:2022	
Minimum flow reached:	No	
Measurement type:	Steady State	
Integrated circulation pump:	Yes	
Included corrections (Final result)		
Heating capacity	kW	16.208
COP	-	3.036
Power consumption	kW	5.339
Measured		
Heating capacity	kW	16.295
COP	-	2.974
Power consumption	kW	5.480
During heating		
Air temperature dry bulb	°C	6.95
Air temperature wet bulb	°C	5.95
Inlet temperature	°C	46.97
Outlet temperature	°C	54.91
Circulation pump		
Measured: Static differential pressure, liquid pump	Pa	108303
Calculated Hydraulic power	W	53
Calculated global efficiency	η	0.38
Calculated Capacity correction	W	88
Calculated Power correction	W	141
Water Flow	m³/s	0.000491



Detailed test results of sound power measurement – Test N#1





Appendix 1 Sound power measurement

Unit specification

Type of unit: Mono air to water heat pump

Manufacturer: PHNIX

Size of the heat pump: 0.5x1.2x1.3 m (W x L x H)

Year of production: N/A.


Operating conditions and environment

The operating conditions of the unit under test fulfill the requirements for Class A.

The acoustic test chamber is a hard walled reverberant room (103 m³) and equipped with relevant sound diffusing reflector panels. The acoustical test chamber fulfils the requirements of ISO3743-1 accuracy grade 2 (Engineering grade).

The measurements of the average sound pressure levels in 1/3 octave frequency bands are carried out using three microphones in the test chamber. During the measurements, the microphones are traversed up and down for one meter in the arc of a quarter circle.

The picture below shows the installation of the unit under test, position of microphones, sound diffusing reflector panels and the reference sound source.





Measurement instruments

Id nr.	Manufacturer	Description	Calibration company
100864	GRAS	Gras 40AE_26CA, ½" free field microphone, Room 1	Norsonic A/S, Norway
100865	GRAS	Gras 40AE_26CA, ½" free field microphone, Room 1	Norsonic A/S, Norway
100866	GRAS	Gras 40AE_26CA, ½" free field microphone, Room 1	Norsonic A/S, Norway
100867*	GRAS	Gras 40AE_26CA, ½" free field microphone, Room 2	Norsonic A/S, Norway
100868*	GRAS	Gras 40AE_26CA, ½" free field microphone, Room 2	Norsonic A/S, Norway
100869*	GRAS	Gras 40AE_26CA, ½" free field microphone, Room 2	Norsonic A/S, Norway
100870	GRAS	Gras 40AE_26CA, ½" free field microphone, Roof monitor	Norsonic A/S, Norway
100873*	Brüel & Kjær	Acoustical calibrator, Brüel & Kjær 4231	Element Metech, Denmark
100859	Norsonic	Reference sound source, Norsonic Nor278 Room 1	RISE, Sweden
100872*	Norsonic	Reference sound source, Norsonic Nor278 Room 2	RISE, Sweden
100620*	Norsonic	Multi-channel measurement system Nor850	Norsonic A/S, Norway

*Instruments are used for the actual measurements for the calculation of the test results.

The other instruments are used for control measurements.
All microphones are equipped with windshields.



Test Procedure

The measurements of the emitted sound power level from the heat pump are carried out according to the following standard:

- DS/EN 14511:2022
- EN 12102-1:2022
- ISO/EN 3743-1:2010

The basic acoustic measurement standard DS/EN 3743-1 is a comparison method using a calibrated reference sound source. Two series of sound pressure measurements are made under exactly the same acoustic conditions, e.g., the same microphone positions, temperature and air humidity. The calibrated sound power levels are known for the reference sound source at each frequency band, and they are used in the estimation of the acoustical correction factor for the calculation of the sound power emitted from the unit under test. The background noise levels are measured and used for relevant corrections.

The final total A-weighted sound power level is based on measurements and calculations in 1/3-octave levels, which then are summed into 1/1-octave levels. The A-weighted total sound power level is determined for the measured frequency range from 100 Hz to 10 kHz.

The actual microphone positions and correction values are saved in data files linked to the complete project documentation according to the DANAK-accreditation.

The complete measurement system is documented and regularly calibrated according to DANAK.

The detailed description of the measurement method is given in Danish in the quality database system "QA Web" at Danish Technological Institute, which is accessible by DANAK.



Measurement uncertainty

The uncertainty of sound power level in decibel is determined in accordance with ISO 3743-1, equation 22 $\sigma_{tot} = \sqrt{\sigma_{RO}^2 + \sigma_{omc}^2}$ where:

- σ_{RO} is the standard deviation of the reproducibility of the method and
- σ_{omc} is the standard deviation describing the uncertainty associated with the instability of the operating and mounting conditions for the particular noise source under test.

σ_{RO} expresses the uncertainty in test results delivered by the different accredited test laboratories due to different instrumentation and implementation of measurement procedure as well different radiation characteristic of the noise source under test.

σ_{omc} expresses the uncertainty associated with the instability of the operating and mounting conditions for the particular noise source under test. The mounting and installation conditions in two DTI acoustical test chambers are well defined in the test procedure. Possible instability of the operating conditions is monitored and assessed prior to each noise test.

The test uncertainty σ_{omc} is calculated according to ISO3743-1 Annex C formula C.1 and is typically below 1.0dB, however in the report rounded up to the nearest 0.5dB og 1.0dB increment. As pr. Table C.1 (Accuracy grade 2) the uncertainty σ_{RO} is set to 1.5.

The expanded uncertainty U is calculated according to ISO 3743-1 equation 23:

$U = k \sigma_{tot}$ where $k = 2$ for 95% confidence.

EXAMPLE: $\sigma_{tot}: \sqrt{1.5^2 + 0.5^2} = 1.6 \text{ dB}$ and $U(95\%) = 3.2 \text{ dB}$

Note: The expanded uncertainty does not include the standard deviation of production which is used in ISO4871 for the purpose of making noise declaration for batches of machines.



Appendix 2 Authorization Letter

Authorization Letter

This declaration of conformity is issued under the sole responsibility of

Manufacturer's Name: Guangdong PHNIX ECO-Energy Solution LTD

Manufacturer's Address: No. 3 Tianyuan Road, Dagang Town, Nansha District
Guangzhou Guangdong, 511470 China

We declare that the following Heat pump product we produced for COOPER
AND HUNTER OVERSEAS LP are identical to our following models

Cooper&Hunter model	CH-HP23-UIMPRM-P
PHNIX model	PASRW060S-BP-PS-B

Cooper&Hunter company name: COOPER AND HUNTER OVERSEAS LP

Cooper&Hunter brand /-mark: Cooper&Hunter

Cooper&Hunter address: SUITE 201, 45B WEST WILMOT STREET,
RICHMOND HILL, ON L4B2P3 CANADA

Note: This declaration becomes invalid if technical or operational modifications
are introduced without the manufacturer's consent.

For and on behalf of
GUANGDONG PHNIX ECO-ENERGY SOLUTION LTD.
广东芬尼克兹节能设备有限公司

Date: 24 May 2024

刘建 Lilian Phnix

Authorised party: Guangdong Phnix Eco-Energy Solution LTD

