



**Strojírenský zkušební ústav, s.p.**  
**(Engineering Test Institute, Public Enterprise)**  
**Hudcova 424/56b, Medlánky, 621 00 Brno, Česká republika**  
Testing Laboratory 1045.1 accredited by the CAI pursuant to ČSN EN ISO/IEC 17025:2018

Page 1 / 34



## TEST REPORT 39-17853/T

**Product:** Outdoor Air/Water Heat pump - monobloc

**Type designation:** EUROS ATMO 7

**Customer:** Euros Energy Sp. z o.o  
ul. Macieja Rataja 4F  
05-850 Koprki  
POLAND

**Manufacturer:** Euros Energy Sp. z o.o  
ul. Macieja Rataja 4F  
05-850 Koprki  
POLAND

**Report issue date:** 2024-10-02

**Distribution list:** 1 copy to the Customer  
1 copy to the Engineering Test Institute


## I. Description of product tested

The Heat pump **EUROS ATMO 7** supplied by the company **Euros Energy Sp. z o.o** is structurally adapted to operate in air/water system. Device is designed as monobloc **EUROS ATMO 7 OUT** placed outside and indoor hydrobox **EUROS ATMO 7 IN** hanging on inner wall. Outdoor and indoor units are connected by water hoses and electrical wires. Refrigerant R32 is used with charge 0.9 kg. Power supply is a one-phase. Heat pump is able to work in heating and cooling mode. Heat pump is working with fixed flow rate.


Main components of the outdoor unit **EUROS ATMO 7 OUT**:

Main components of the indoor hydrobox **EUROS ATMO 7 IN**:


Scheme:



Photodocumentation:



Heat pump **EUROS ATMO 7** – outdoor unit  
– Front view –




Heat pump **EUROS ATMO 7** – outdoor unit  
– Back view –

Not recognized



Heat pump **EUROS ATMO 7** – outdoor unit  
– Compressor label –


Heat pump **EUROS ATMO 7** – outdoor unit  
– Label –




Heat pump **EUROS ATMO 7** – outdoor unit  
– Without cover –



Heat pump **EUROS ATMO 7** – indoor hydrobox  
– Label –



Heat pump **EUROS ATMO 7** – indoor hydrobox  
– With cover –



Heat pump **EUROS ATMO 7** – indoor hydrobox  
– Without cover –

## **II. Sample tested**

SZU reg. no.	Product name	Date of submission
1212.24.40352.001	EUROS ATMO 7	2024-08-07

The visual inspection, tests and verification were carried out by Ing. Tomáš Sedláček at the test station of SZU

The tests were performed using measuring and testing equipment with valid calibration.

## **III. Measuring and test equipment:**

No.	Description:	Inventory number:
1.	Electrical energy meter	E2.1
2.	Digital watt meter	1.2.2 ENERGIE ANALYZATOR_2
3.	Flow meter Krohne Optiflux	8.1.2 TECH_K2_V_DN15
4.	Barometer	2.4 MAR18_1_PB
5.	Differential pressure gauge	3.2 MAR18_2_dP
6.	Temperature-humidity meter HF532	3.1.1 K2_VLHKOST_1
7.	Temperature-humidity meter HF532	3.1.3 K2_VLHKOST_2
8.	Thermometers	3.4 MAR18_T

## **IV. Methods, results of tests and verifications**

No.	Test objective	Requirement	Method of test	Documentation	Test evaluation/verification *
1.	Rating conditions	–	ČSN EN 14511-2:2023 ČSN EN 14511-3:2023	Page No. 7	x
2.	Seasonal performance tests and SCOP calculation – Low temperature application	–	ČSN EN 14511-3:2023 ČSN EN 14825:2023	Page No. 8 – 14	x
3.	Seasonal performance tests and SCOP calculation – Medium temperature application	–	ČSN EN 14511-3:2023 ČSN EN 14825:2023	Page No. 15 – 21	x
*) Evaluation / statement of conformity:					
+..... Requirement fulfilled			0 ..... Not applicable		
-..... Requirement not fulfilled			x ..... Not evaluated		

Measured quantity	Unit	Uncertainty measurement of	Evaluation
Liquid - temperature difference ( $dT$ ) - temperature inlet/outlet - volume flow - static pressure difference	[K] [°C] [m³/s] [kPa]	± 0.15 K ± 0.15 K ± 1 % ± 1 kPa ( $\Delta p \leq 20$ kPa) or ± 5 % ( $\Delta p > 20$ kPa)	fulfilled fulfilled fulfilled fulfilled
Air - dry bulb temperature - wet bulb temperature - volume flow - static pressure difference	[°C] [°C] [m³/s] [Pa]	± 0.2 K ± 0.4 K ± 5 % ± 5 Pa ( $\Delta p \leq 100$ Pa) or ± 5 % ( $\Delta p > 100$ Pa)	fulfilled fulfilled not applied not applied
Refrigerant - pressure at compressor outlet - temperature	[kPa] [°C]	± 1 % ± 0.5 K	not applied not applied
Concentration (in volume) - heat transfer medium	[%]	± 2	not related
Electrical quantities - electric power - voltage - current - electric energy	[W] [V] [A] [kWh]	± 1 % ± 0.5 % ± 0.5 % ± 1 %	fulfilled fulfilled fulfilled not applied
Compressor rotational speed	[min⁻¹]	± 0.5 %	not applied
The heating or cooling capacities measured on the liquid side shall be determined within a maximum uncertainty of 5 % independent of the individual uncertainties of measurement including the uncertainties on the properties of fluids.			fulfilled

**Note:**

The stated extended measurement uncertainties are calculated as a factor of the measurement uncertainty and the extension coefficient  $k=2$ , corresponding to the coverage certainty of 95% as regards standard classification.

If a statement of conformity is provided, the decision rule pursuant to ILAC-G8:09/2019, Art. 4.2.1 - binary statement for the simple acceptance rule shall apply.

Comment to abbreviated marking: e.g. A7/W35

A (air) 7 (input air, dry-bulb temperature in °C) / W (water), 35 (output heating water temperature in °C)

<b>Test objective:</b>	Rating conditions		
<b>Exact name of the test procedure:</b>	<b>1.37* - Tests of leakage, pressure resistance, thermal and technical parameters, combustion efficiency, safety functions</b>		
<b>Test method:</b>	ČSN EN 14511-2:2023, ČSN EN 14511-3:2023		
<b>Sample tested:</b>	Heat pump <b>EUROS ATMO 7</b>		
<b>Measuring equipment used:</b>	see Chapter III		

Specification of the assessment condition	A7/W35*	A7/W55
Date of testing	2024-08-19	2024-08-20
Transient test procedure	YES / NO	NO
Average defrost time of 1 cycle	[min]	—
Average time of 1 cycle	[min]	—
Calculation time	[min]	70.0
Output heating water – temperature calculation	[°C]	34.91
Input heating water – temperature calculation	[°C]	29.92
Output heating water temperature	[°C]	34.91
Input heating water temperature	[°C]	29.92
Air temperature – dry bulb temperature	[°C]	7.00
Air temperature – wet bulb temperature	[°C]	6.00
Relative humidity	[%]	86.98
Barometric pressure	[kPa]	98.309
Ambient temperature	[°C]	6.92
Secondary circuit pressure difference	[kPa]	33.259
Efficiency of the secondary liquid pump	[—]	0.185
Volume flow rate of heating water	[m <sup>3</sup> ·h <sup>-1</sup> ]	0.6232
Density of heating water	[kg·m <sup>-3</sup> ]	994.1
Specific heat capacity of heating water	[kJ·kg <sup>-1</sup> ·K <sup>-1</sup> ]	4.175
Voltage	[V]	232.31
Total current	[A]	3.53
Overall power input	[kW]	0.754
Capacity correction of sec. liquid pump	[W]	25.350
Power input correction of sec. liquid pump	[W]	31.10
Heating capacity – heating water	[kW]	3.585
<b>Corrected heating capacity – heating water</b>	<b>[kW]</b>	<b>3.560</b>
Uncertainty of corrected heating capacity	[kW]	± 0.062
<b>Effective electric power input</b>	<b>[kW]</b>	<b>0.723</b>
<b>COP</b>	<b>[—]</b>	<b>4.925</b>
Uncertainty of COP	[—]	± 0.090
<b>Control settings</b>	<b>[—]</b>	<b>4</b>
Circulation pump settings – heating water	[—]	3

\*This condition was measured as a steady state condition even though an oil recovery occurred.

<b>Test objective:</b>	Seasonal performance tests and SCOP calculation – Low temperature application		
<b>Exact name of the test procedure:</b>	<b>1.37* - Tests of leakage, pressure resistance, thermal and technical parameters, combustion efficiency, safety functions</b>		
<b>Test method:</b>	ČSN EN 14511-3:2023, ČSN EN 14825:2023		
<b>Sample tested:</b>	Heat pump <b>EUROS ATMO 7</b>		
<b>Measuring equipment used:</b>	see Chapter III		

Design		Air / water – monobloc						
Conditions specification according ČSN 14825:2023	to EN	Temperature application			Low (reference water temperature 35 °C)			
		Reference heating season			<b>Average</b>			
		Outlet water temperature - indoor heat exchanger			Variable			
		Compressor speed control			Variable			
		Water flow rate – primary circuit			–			
		Water flow rate – secondary circuit			Fixed			
Seasonal space heating energy efficiency		Heating	Average	$\eta_s$	<u>189.8</u>	%		
			Warmer	$\eta_s$	–	%		
			Colder	$\eta_s$	–	%		
Seasonal efficiency according to ČSN 14825:2023	EN	Heating	Average	<b>SCOP</b>	<u>4.82</u>	–		
			Warmer	SCOP	–	–		
			Colder	SCOP	–	–		
Function	Cooling					Yes		
	Heating	Yes	Reference heating season	Average	Yes			
				Warmer	–			
				Colder	–			
Full heating load				Cooling				
	Heating	Average	$P_{designc}$	<u>5.22</u>	kW			
		Warmer	$P_{designh}$	–	kW			
		Colder	$P_{designh}$	–	kW			
Bivalent temperatures		Heating	Average	$T_{bivalent}$	-7	°C		
			Warmer	$T_{bivalent}$	–	°C		
			Colder	$T_{bivalent}$	–	°C		
Operation limit temperatures		Heating	Average	TOL	-10	°C		
			Warmer	TOL	–	°C		
			Colder	TOL	–	°C		
Seasonal power consumption according ČSN EN 14825:2023	to	Cooling		$Q_{CE}$	–	kWh		
		Heating	Average	$Q_{HE}$	2238	kWh		
			Warmer	$Q_{HE}$	–	kWh		
			Colder	$Q_{HE}$	–	kWh		
Modes other than „active mode“					Off mode	$P_{OFF}$ 13.8 W		
					Thermostat off mode	$P_{TO}$ 13.9 W		
					Standby mode	$P_{SB}$ 13.8 W		
					Crankcase heater mode	$P_{CK}$ 0.0 W		

### Calculation of SCOP according to ČSN EN 14825:2023:

Number of hours used for calculation of reference SCOP (Annex B – Table B. 2, B. 3)

- For reversible heat pumps and reference heating season „A“ = average

H <sub>HE</sub>	2066	[h]
H <sub>TO</sub>	178	[h]
H <sub>SB</sub>	0	[h]
H <sub>CK</sub>	178	[h]
H <sub>OFF</sub>	0	[h]

Measured data:

P <sub>TO</sub>	0.0139	[kW]
P <sub>SB</sub>	0.0138	[kW]
P <sub>CK</sub>	0.0000	[kW]
P <sub>OFF</sub>	0.0138	[kW]
P <sub>designh</sub>	5.22	[kW]
SCOP <sub>ON</sub>	4.83	[–]

Coefficient and correction:

F(1)	3	[%]
F(2)	0	[%]
CC	2.5	[–]

### Calculation of SCOP:

#### 7.3 Calculation of the reference annual heating demand (Q<sub>H</sub>)

$$Q_H = P_{\text{designh}} \cdot H_{\text{HE}} \quad [\text{kWh}]$$

$$Q_H = 5.22 \cdot 2066 = 10790 \quad [\text{kWh}]$$

#### 7.4 Calculation of the annual electricity consumption (Q<sub>HE</sub>)

$$Q_{\text{HE}} = Q_H / \text{SCOP}_{\text{on}} + H_{\text{TO}} \cdot P_{\text{TO}} + H_{\text{SB}} \cdot P_{\text{SB}} + H_{\text{CK}} \cdot P_{\text{CK}} + H_{\text{OFF}} \cdot P_{\text{OFF}} \quad [\text{kWh}]$$

$$Q_{\text{HE}} = 10790 / 4.83 + 178 \cdot 0.0139 + 0 \cdot 0.0138 + 178 \cdot 0 + 0 \cdot 0.0138 = 2238 \quad [\text{kWh}]$$

#### 7.2 General formula for calculation of reference SCOP

$$\text{SCOP} = Q_H / Q_{\text{HE}} \quad [-]$$

$$\text{SCOP} = 10790 / 2238 = 4.82 \quad [-]$$

#### 7.1 Calculation of the seasonal space heating efficiency η<sub>s</sub>

$$\Sigma F(i) = F(1) + F(2) \quad [-]$$

$$\Sigma F = 0.03 + 0 = 0.03 \quad [-]$$

$$\eta_s = 1 / CC \cdot \text{SCOP} - \Sigma F(i) \quad [-]$$

$$\eta_s / A = (1 / 2.5) * 4.82 - 0.03 = \underline{\underline{1.898}} \quad [-]$$

Temperature level	Low (reference water temperature 35 °C)		
Reference heating season	„A“ = average ( $T_{designh} = -10 °C$ )		
Assessment condition	A, Tbiv(F)	B	C
Specification of the assessment condition	A-7/W34	A2/W30	A7/W28.05
Date of testing	2024-08-20	2024-08-22	2024-08-23
Transient test procedure	YES / NO	NO	NO
Average defrost time of 1 cycle	[min]	–	–
Average time of 1 cycle	[min]	–	–
Calculation time	[min]	70.0	70.0
Output heating water – temperature calculation	[°C]	33.96	30.00
Input heating water – temperature calculation	[°C]	27.49	25.94
Output heating water temperature	[°C]	33.96	30.00
Input heating water temperature	[°C]	27.49	25.94
Air temperature – dry bulb temperature	[°C]	-7.00	2.00
Air temperature – wet bulb temperature	[°C]	-8.00	1.01
Relative humidity	[%]	74.99	84.04
Barometric pressure	[kPa]	98.139	98.364
Ambient temperature	[°C]	-7.07	1.92
Secondary circuit pressure difference	[kPa]	30.487	32.102
Efficiency of the secondary liquid pump	[–]	0.199	0.183
Volume flow rate of heating water	[m <sup>3</sup> ·h <sup>-1</sup> ]	0.6230	0.6230
Density of heating water	[kg·m <sup>-3</sup> ]	994.4	995.6
Specific heat capacity of heating water	[kJ·kg <sup>-1</sup> ·K <sup>-1</sup> ]	4.175	4.176
Voltage	[V]	232.65	232.17
Total current	[A]	6.88	2.98
Overall power input	[kW]	1.591	0.624
Capacity correction of sec. liquid pump	[W]	24.158	24.869
Power input correction of sec. liquid pump	[W]	29.43	30.42
Heating capacity – heating water	[kW]	4.644	2.917
<b>Corrected heating capacity – heating water</b>	<b>[kW]</b>	<b>4.620</b>	<b>2.892</b>
Uncertainty of corrected heating capacity	[kW]	± 0.071	± 0.066
<b>Effective electric power input</b>	<b>[kW]</b>	<b>1.562</b>	<b>0.594</b>
COP	[–]	2.958	4.869
Uncertainty of COP	[–]	± 0.048	± 0.131
<b>Control settings</b>	<b>[–]</b>	<b>10</b>	<b>3</b>
Circulation pump settings – heating water	[–]	3	3

Temperature level	Low (reference water temperature 35 °C)		
Reference heating season	„A“ = average ( $T_{designh} = -10 \text{ }^{\circ}\text{C}$ )		
Assessment condition	<b>D</b>		<b>TOL(E)</b>
Specification of the assessment condition	<b>A12/W26.93</b>		<b>A-10/W35</b>
Date of testing	<b>2024-08-22</b>		<b>2024-08-21</b>
Transient test procedure	YES / NO	NO	NO
Average defrost time of 1 cycle	[min]	—	—
Average time of 1 cycle	[min]	—	—
Calculation time	[min]	70.0	70.0
Output heating water – temperature calculation	[°C]	26.94	34.96
Input heating water – temperature calculation	[°C]	22.88	29.02
Output heating water temperature	[°C]	26.94	34.96
Input heating water temperature	[°C]	22.88	29.02
Air temperature – dry bulb temperature	[°C]	12.00	-10.00
Air temperature – wet bulb temperature	[°C]	11.00	-10.98
Relative humidity	[%]	88.99	70.49
Barometric pressure	[kPa]	98.635	98.353
Ambient temperature	[°C]	11.92	-10.07
Secondary circuit pressure difference	[kPa]	32.496	31.548
Efficiency of the secondary liquid pump	[–]	0.183	0.199
Volume flow rate of heating water	[m <sup>3</sup> ·h <sup>-1</sup> ]	0.6230	0.6230
Density of heating water	[kg·m <sup>-3</sup> ]	996.4	994.1
Specific heat capacity of heating water	[kJ·kg <sup>-1</sup> ·K <sup>-1</sup> ]	4.177	4.175
Voltage	[V]	230.09	232.45
Total current	[A]	2.09	6.78
Overall power input	[kW]	0.405	1.572
Capacity correction of sec. liquid pump	[W]	25.038	24.629
Power input correction of sec. liquid pump	[W]	30.66	30.09
Heating capacity – heating water	[kW]	2.917	4.257
<b>Corrected heating capacity – heating water</b>	<b>[kW]</b>	<b>2.892</b>	<b>4.232</b>
Uncertainty of corrected heating capacity	[kW]	± 0.066	± 0.070
<b>Effective electric power input</b>	<b>[kW]</b>	<b>0.375</b>	<b>1.542</b>
COP	[–]	7.719	2.745
Uncertainty of COP	[–]	± 0.251	± 0.047
<b>Control settings</b>	<b>[–]</b>	<b>1</b>	<b>10</b>
Circulation pump settings – heating water	[–]	3	3

Data for SCOP calculation

- Low temperature application (reference water temperature 35 °C)
- Reference heating season „A“ – average

	Outdoor heat exchanger	Indoor heat exchanger	Part load ratio	Part load	DC Declared capacity	COPd at declared capacity	Cd <sub>h</sub> degradation coefficient	CR	COPbin (Tj)	Eff. power input of compressor off state
	Outdoor air inlet	Outlet water temperature								
	[°C]	[°C]								
A	-7	34.00	88.46	4.62	4.620	2.958	0.900	1.00	2.958	–
B	2	30.00	53.85	2.81	2.892	4.869	0.900	1.00	4.869	–
C	7	28.05	34.62	1.81	2.552	6.251	0.966	0.71	6.165	0.0139
D	12	26.93	15.38	0.80	2.892	7.719	0.963	0.28	7.040	0.0139
TOL (E)	-10	35.00	100.00	5.22	4.232	2.745	0.900	1.00	2.745	–
Tbiv (F)	-7	34.00	88.46	4.62	4.620	2.958	0.900	1.00	2.958	–

Adaption of water temperature – according to ČSN EN 14825:2023, Annex E

- Low temperature application (reference water temperature 35 °C)
- Reference season „A“ – average
- Condition D
- Fixed water flow rate – secondary circuit

General formulas and derivation:

$$\begin{aligned} t_{\text{outlet, average}} &= t_{\text{inlet, capacity test}} + (t_{\text{outlet, capacity test}} - t_{\text{inlet, capacity test}}) \cdot CR & [\text{°C}] \\ t_{\text{outlet, average}} &= t_{\text{inlet, capacity test}} + (\Delta t) \cdot CR & [\text{°C}] \\ t_{\text{outlet, average}} &= t_{\text{outlet, capacity test}} - \Delta t + \Delta t \cdot CR & [\text{°C}] \\ t_{\text{outlet, capacity test}} &= t_{\text{outlet, average}} + \Delta t - \Delta t \cdot CR & [\text{°C}] \end{aligned}$$

For fixed flow:

$\Delta t = \text{Declared capacity} / \text{Declared capacity}_{\text{standard rating conditions A7W35}} \cdot 5$

$CR \cdot \Delta t = \text{Part load} / \text{Declared capacity} \cdot \text{Declared capacity}_{\text{standard rating conditions A7W35}} \cdot 5$

$CR \cdot \Delta t = \text{Part load} / \text{Declared capacity}_{\text{standard rating conditions A7W35}} \cdot 5$

$t_{\text{outlet, capacity test, fixed flow}} = t_{\text{outlet, average}} + \text{Declared capacity} / \text{Declared capacity}_{\text{standard rating conditions A7W35}} \cdot 5 - \text{Part load} / \text{Declared capacity}_{\text{standard rating conditions A7W35}} \cdot 5$

$t_{\text{outlet, capacity test, fixed flow}} = t_{\text{outlet, average}} + 5 / \text{Declared capacity}_{\text{standard rating conditions A7W35}} \cdot (\text{Declared capacity} - \text{Part load})$

Measured data:

t <sub>outlet, average</sub>	24.00	[\text{°C}]
Declared capacity	2.892	[\text{kW}]
Declared capacity standard rating condition A7/W35	3.560	[\text{kW}]
Part load	0.80	[\text{kW}]

Calculation of water temperature

$$t_{\text{outlet, capacity test, fixed flow}} = 24 + 5 / 3.56 \cdot (2.892 - 0.8) = \underline{\underline{26.93}}$$

[°C]

Calculation SCOP, SCOP<sub>on</sub>, SCOP<sub>net</sub>


- Low temperature application (reference water temperature 35 °C)
- Reference heating season „A“ – average

Bin	Outdoor temp. (dry bulb)	Hours	Part load ratio	Heat load	Capacity of HP	Heat load covered by heat pump	Resistive heat elbu (Tj)	Annual resistive heat	COPbin (Tj)	Annual heating demand	Annual power input including electric back up heating	Net annual heating capacity	Net annual power input without electric back up heating	
j	Tj	hj		Ph(Tj)		elbu(Tj)	hj x elbu(Tj)		COPb in (Tj)	hj x Ph(Tj)		hj x (Ph(Tj) - elbu(Tj))		
[–]	[°C]	[h]	[%]	[kW]	[kW]	[kW]	[kWh]	[–]	[kWh]	[kWh]	[kWh]	[kWh]	[kWh]	
TOL(E)	21	-10	1	100.00	5.22	4.23	4.23	0.99	0.99	2.75	5	3	4	2
	22	-9	25	96.15	5.02	4.36	4.36	0.66	16.51	2.82	126	55	109	39
	23	-8	23	92.31	4.82	4.49	4.49	0.33	7.59	2.89	111	43	103	36
A, Tbiv(F)	24	-7	24	88.46	4.62	4.62	4.62	0.00	0.00	2.96	111	37	111	37
	25	-6	27	84.62	4.42	4.43	4.42	0.00	0.00	3.17	119	38	119	38
	26	-5	68	80.77	4.22	4.24	4.22	0.00	0.00	3.38	287	85	287	85
	27	-4	91	76.92	4.02	4.04	4.02	0.00	0.00	3.60	366	102	366	102
	28	-3	89	73.08	3.82	3.85	3.82	0.00	0.00	3.81	340	89	340	89
	29	-2	165	69.23	3.62	3.66	3.62	0.00	0.00	4.02	597	148	597	148
	30	-1	173	65.38	3.41	3.47	3.41	0.00	0.00	4.23	591	140	591	140
	31	0	240	61.54	3.21	3.28	3.21	0.00	0.00	4.44	771	174	771	174
	32	1	280	57.69	3.01	3.08	3.01	0.00	0.00	4.66	844	181	844	181
B	33	2	320	53.85	2.81	2.89	2.81	0.00	0.00	4.87	900	185	900	185
	34	3	357	50.00	2.61	2.82	2.61	0.00	0.00	5.13	932	182	932	182
	35	4	356	46.15	2.41	2.76	2.41	0.00	0.00	5.39	858	159	858	159
	36	5	303	42.31	2.21	2.69	2.21	0.00	0.00	5.65	669	119	669	119
	37	6	330	38.46	2.01	2.62	2.01	0.00	0.00	5.91	663	112	663	112
C	38	7	326	34.62	1.81	2.55	1.81	0.00	0.00	6.16	589	96	589	96
	39	8	348	30.77	1.61	2.62	1.61	0.00	0.00	6.34	559	88	559	88
	40	9	335	26.92	1.41	2.69	1.41	0.00	0.00	6.51	471	72	471	72
	41	10	315	23.08	1.21	2.76	1.21	0.00	0.00	6.69	380	57	380	57
	42	11	215	19.23	1.00	2.82	1.00	0.00	0.00	6.86	216	31	216	31
D	43	12	169	15.38	0.80	2.89	0.80	0.00	0.00	7.04	136	19	136	19
	44	13	151	11.54	0.60	2.96	0.60	0.00	0.00	7.22	91	13	91	13
	45	14	105	7.69	0.40	3.03	0.40	0.00	0.00	7.39	42	6	42	6
	46	15	74	3.85	0.20	3.10	0.20	0.00	0.00	7.57	15	2	15	2
	$\Sigma$		4910					$\Sigma$	10788	2235	10763	2210		

SCOPon	4.83	SCOPnet	4.87
<b>SCOP</b>	<b>4.82</b>		

Part load performance diagram

- Low temperature application (reference water temperature 35 °C)
- Reference heating season „A“ – average



<b>Test objective:</b>	Seasonal performance tests and SCOP calculation – Medium temperature application		
<b>Exact name of the test procedure:</b>	<b>1.37* - Tests of leakage, pressure resistance, thermal and technical parameters, combustion efficiency, safety functions</b>		
<b>Test method:</b>	ČSN EN 14511-3:2023, ČSN EN 14825:2023		
<b>Sample tested:</b>	Heat pump <b>EUROS ATMO 7</b>		
<b>Measuring equipment used:</b>	see Chapter III		

Design		Air / water – monobloc			
Conditions specification according to ČSN 14825:2023	to EN	Temperature application			
		Reference heating season			
		Outlet water temperature - indoor heat exchanger		Variable	
		Compressor speed control		Variable	
		Water flow rate – primary circuit		–	
		Water flow rate – secondary circuit		Fixed	
Seasonal space heating energy efficiency	Heating	Average	$\eta_s$	<u>131.4</u> %	
		Warmer	$\eta_s$	– %	
		Colder	$\eta_s$	– %	
Seasonal efficiency according to ČSN 14825:2023	EN	Average	<b>SCOP</b>	<u>3.36</u> –	
		Warmer	SCOP	– –	
		Colder	SCOP	– –	
Function	Cooling				
	Heating	Yes	Reference heating season	Average	
				Warmer	
				Colder	
Full heating load	Cooling		$P_{designc}$	– kW	
	Heating	Average		<u>4.81</u> kW	
		Warmer	$P_{designh}$	– kW	
		Colder	$P_{designh}$	– kW	
Bivalent temperatures	Heating	Average	$T_{bivalent}$	-7 °C	
		Warmer	$T_{bivalent}$	– °C	
		Colder	$T_{bivalent}$	– °C	
Operation limit temperatures	Heating	Average	TOL	-10 °C	
		Warmer	TOL	– °C	
		Colder	TOL	– °C	
Seasonal power consumption according to ČSN EN 14825:2023	Cooling		QCE	– kWh	
	Heating	Average		2957 kWh	
		Warmer	QHE	– kWh	
		Colder	QHE	– kWh	
Modes other than „active mode“				Off mode $P_{OFF}$ 13.8 W	
				Thermostat off mode $P_{TO}$ 13.9 W	
				Standby mode $P_{SB}$ 13.8 W	
				Crankcase heater mode $P_{CK}$ 0.0 W	

**Calculation of SCOP according to ČSN EN 14825:2023:**

Number of hours used for calculation of reference SCOP (Annex B – Table B. 2, B. 3)

- For reversible heat pumps and reference heating season „A“ = average

H <sub>HE</sub>	2066	[h]
H <sub>TO</sub>	178	[h]
H <sub>SB</sub>	0	[h]
H <sub>CK</sub>	178	[h]
H <sub>OFF</sub>	0	[h]

Measured data:

P <sub>TO</sub>	0.0139	[kW]
P <sub>SB</sub>	0.0138	[kW]
P <sub>CK</sub>	0.0000	[kW]
P <sub>OFF</sub>	0.0138	[kW]
P <sub>designh</sub>	4.81	[kW]
SCOP <sub>ON</sub>	3.36	[–]

Coefficient and correction:

F(1)	3	[%]
F(2)	0	[%]
CC	2.5	[–]

**Calculation of SCOP:**

7.3 Calculation of the reference annual heating demand (Q<sub>H</sub>)

$$Q_H = P_{\text{designh}} \cdot H_{\text{HE}} \quad [\text{kWh}]$$

$$Q_H = 4.81 \cdot 2066 = 9937 \quad [\text{kWh}]$$

7.4 Calculation of the annual electricity consumption (Q<sub>HE</sub>)

$$Q_{\text{HE}} = Q_H / \text{SCOP}_{\text{on}} + H_{\text{TO}} \cdot P_{\text{TO}} + H_{\text{SB}} \cdot P_{\text{SB}} + H_{\text{CK}} \cdot P_{\text{CK}} + H_{\text{OFF}} \cdot P_{\text{OFF}} \quad [\text{kWh}]$$

$$Q_{\text{HE}} = 9937 / 3.36 + 178 \cdot 0.0139 + 0 \cdot 0.0138 + 178 \cdot 0 + 0 \cdot 0.0138 = 2957 \quad [\text{kWh}]$$

7.2 General formula for calculation of reference SCOP

$$\text{SCOP} = Q_H / Q_{\text{HE}} \quad [-]$$

$$\text{SCOP} = 9937 / 2957 = 3.36 \quad [-]$$

7.1 Calculation of the seasonal space heating efficiency η<sub>s</sub>

$$\Sigma F(i) = F(1) + F(2) \quad [-]$$

$$\Sigma F = 0.03 + 0 = 0.03 \quad [-]$$

$$\eta_s = 1 / CC \cdot \text{SCOP} - \Sigma F(i) \quad [-]$$

$$\eta_s / A = (1 / 2.5) * 3.36 - 0.03 = 1.314 \quad [-]$$

Temperature level	Medium (reference water temperature 55 °C)			
Reference heating season	„A“ = average ( $T_{designh} = -10 °C$ )			
Assessment condition	A, Tbiv(F)	B	C	
Specification of the assessment condition	A-7/W52	A2/W42	A7/W37.84	
Date of testing	2024-08-20	2024-08-22	2024-08-23	
Transient test procedure	YES / NO	NO	NO	NO
Average defrost time of 1 cycle	[min]	–	–	–
Average time of 1 cycle	[min]	–	–	–
Calculation time	[min]	70.0	70.0	70.0
Output heating water – temperature calculation	[°C]	51.81	42.04	37.88
Input heating water – temperature calculation	[°C]	40.36	35.07	31.64
Output heating water temperature	[°C]	51.81	42.04	37.88
Input heating water temperature	[°C]	40.36	35.07	31.64
Air temperature – dry bulb temperature	[°C]	-7.00	2.00	7.00
Air temperature – wet bulb temperature	[°C]	-7.97	1.01	6.02
Relative humidity	[%]	75.70	83.97	87.14
Barometric pressure	[kPa]	98.395	98.316	98.390
Ambient temperature	[°C]	-7.08	1.93	6.94
Secondary circuit pressure difference	[kPa]	30.977	36.837	35.953
Efficiency of the secondary liquid pump	[–]	0.148	0.156	0.155
Volume flow rate of heating water	[m <sup>3</sup> ·h <sup>-1</sup> ]	0.3312	0.3320	0.3320
Density of heating water	[kg·m <sup>-3</sup> ]	988.1	991.8	993.3
Specific heat capacity of heating water	[kJ·kg <sup>-1</sup> ·K <sup>-1</sup> ]	4.178	4.175	4.175
Voltage	[V]	232.40	231.77	232.69
Total current	[A]	9.28	3.68	2.74
Overall power input	[kW]	2.152	0.798	0.563
Capacity correction of sec. liquid pump	[W]	15.981	18.393	18.094
Power input correction of sec. liquid pump	[W]	18.77	21.79	21.41
Heating capacity – heating water	[kW]	4.271	2.664	2.388
<b>Corrected heating capacity – heating water</b>	<b>[kW]</b>	<b>4.255</b>	<b>2.646</b>	<b>2.370</b>
Uncertainty of corrected heating capacity	[kW]	± 0.035	± 0.039	± 0.038
<b>Effective electric power input</b>	<b>[kW]</b>	<b>2.133</b>	<b>0.777</b>	<b>0.541</b>
COP	[–]	1.995	3.407	4.377
Uncertainty of COP	[–]	± 0.017	± 0.054	± 0.079
<b>Control settings</b>	<b>[–]</b>	<b>10</b>	<b>3</b>	<b>1</b>
Circulation pump settings – heating water	[–]	3	3	3

Temperature level	Medium (reference water temperature 55 °C)		
Reference heating season	„A“ = average ( $T_{designh} = -10 \text{ }^{\circ}\text{C}$ )		
Assessment condition	<b>D</b>		<b>TOL(E)</b>
Specification of the assessment condition	<b>A12/W35.36</b>		<b>A-10/W55</b>
Date of testing	<b>2024-08-22</b>		<b>2024-08-21</b>
Transient test procedure	YES / NO	NO	NO
Average defrost time of 1 cycle	[min]	—	—
Average time of 1 cycle	[min]	—	—
Calculation time	[min]	70.0	70.0
Output heating water – temperature calculation	[°C]	35.33	55.09
Input heating water – temperature calculation	[°C]	27.98	45.28
Output heating water temperature	[°C]	35.33	55.09
Input heating water temperature	[°C]	27.98	45.28
Air temperature – dry bulb temperature	[°C]	12.00	-10.00
Air temperature – wet bulb temperature	[°C]	11.00	-10.84
Relative humidity	[%]	88.98	74.53
Barometric pressure	[kPa]	98.509	98.194
Ambient temperature	[°C]	11.92	-10.07
Secondary circuit pressure difference	[kPa]	36.874	34.491
Efficiency of the secondary liquid pump	[—]	0.156	0.153
Volume flow rate of heating water	[m³·h⁻¹]	0.3320	0.3320
Density of heating water	[kg·m⁻³]	994.1	986.6
Specific heat capacity of heating water	[kJ·kg⁻¹·K⁻¹]	4.175	4.179
Voltage	[V]	231.85	232.45
Total current	[A]	2.54	9.69
Overall power input	[kW]	0.513	2.241
Capacity correction of sec. liquid pump	[W]	18.405	17.505
Power input correction of sec. liquid pump	[W]	21.81	20.69
Heating capacity – heating water	[kW]	2.807	3.745
<b>Corrected heating capacity – heating water</b>	<b>[kW]</b>	<b>2.789</b>	<b>3.727</b>
Uncertainty of corrected heating capacity	[kW]	± 0.039	± 0.043
<b>Effective electric power input</b>	<b>[kW]</b>	<b>0.491</b>	<b>2.220</b>
COP	[—]	5.680	1.679
Uncertainty of COP	[—]	± 0.097	± 0.020
<b>Control settings</b>	<b>[—]</b>	<b>1</b>	<b>10</b>
Circulation pump settings – heating water	[—]	3	3

**Data for SCOP calculation**

- Medium temperature application (reference water temperature 55 °C)
- Reference heating season „A“ – average

	Outdoor heat exchanger	Indoor heat exchanger	Part load ratio	Part load	DC Declared capacity	COPd at declared capacity	Cdh degradation coefficient	CR	COPbin (Tj)	Eff. power input of compressor off state
	Outdoor air inlet	Outlet water temperature								
	[°C]	[°C]	[%]	[kW]	[kW]	[–]	[–]	[–]	[–]	[kW]
<b>A</b>	-7	52.00	88.46	4.26	4.255	1.955	0.900	1.00	1.955	–
<b>B</b>	2	42.00	53.85	2.59	2.646	3.407	0.900	1.00	3.407	–
<b>C</b>	7	37.84	34.62	1.67	2.370	4.377	0.974	0.70	4.330	0.0139
<b>D</b>	12	35.36	15.38	0.74	2.789	5.680	0.972	0.27	5.267	0.0139
<b>TOL (E)</b>	-10	55.00	100.00	4.81	3.727	1.679	0.900	1.00	1.679	–
<b>Tbiv (F)</b>	-7	52.00	88.46	4.26	4.255	1.955	0.900	1.00	1.955	–

**Adaption of water temperature – according to ČSN EN 14825:2023, Annex E**

- Medium temperature application (reference water temperature 55 °C)
- Reference season „A“ – average
- Condition D
- Fixed water flow rate – secondary circuit

**General formulas and derivation:**

$$t_{\text{outlet, average}} = t_{\text{inlet, capacity test}} + (t_{\text{outlet, capacity test}} - t_{\text{inlet, capacity test}}) \cdot CR \quad [\text{°C}]$$

$$t_{\text{outlet, average}} = t_{\text{inlet, capacity test}} + (\Delta t) \cdot CR \quad [\text{°C}]$$

$$t_{\text{outlet, average}} = t_{\text{outlet, capacity test}} - \Delta t + \Delta t \cdot CR \quad [\text{°C}]$$

$$t_{\text{outlet, capacity test}} = t_{\text{outlet, average}} + \Delta t - \Delta t \cdot CR \quad [\text{°C}]$$

**For fixed flow:**

$$\Delta t = \text{Declared capacity} / \text{Declared capacity}_{\text{standard rating conditions A7W55}} \cdot 8$$

$$CR \cdot \Delta t = \text{Part load} / \text{Declared capacity} \cdot \text{Declared capacity}_{\text{standard rating conditions A7W55}} \cdot 8$$

$$CR \cdot \Delta t = \text{Part load} / \text{Declared capacity}_{\text{standard rating conditions A7W55}} \cdot 8$$

$$t_{\text{outlet, capacity test, fixed flow}} = t_{\text{outlet, average}} + \text{Declared capacity} / \text{Declared capacity}_{\text{standard rating conditions A7W55}} \cdot 8 - \text{Part load} / \text{Declared capacity}_{\text{standard rating conditions A7W55}} \cdot 8$$

$$t_{\text{outlet, capacity test, fixed flow}} = t_{\text{outlet, average}} + 8 / \text{Declared capacity}_{\text{standard rating conditions A7W55}} \cdot (\text{Declared capacity} - \text{Part load})$$

**Measured data:**

t <sub>outlet, average</sub>	30.00	[\text{°C}]
Declared capacity	2.789	[\text{kW}]
Declared capacity standard rating condition A7/W55	3.061	[\text{kW}]
Part load	0.74	[\text{kW}]

Calculation of water temperature

$$t_{\text{outlet, capacity test, fixed flow}} = 30 + 8 / 3.061 \cdot (2.789 - 0.74) = \underline{\underline{35.36}}$$

[°C]

Calculation SCOP, SCOP<sub>on</sub>, SCOP<sub>net</sub>


- Medium temperature application (reference water temperature 55 °C)
- Reference heating season „A“ – average

Bin	Outdoor temp. (dry bulb)	Hours	Part load ratio	Heat load	Capacity of HP	Heat load covered by heat pump	Resistive heat elbu (T <sub>j</sub> ) elbu(T <sub>j</sub> )	Annual resistive heat	COPbin (T <sub>j</sub> ) COPb in (T <sub>j</sub> )	Annual heating demand	Annual power input including electric back up heating	Net annual heating capacity h <sub>j</sub> × (P h(T <sub>j</sub> ) - elbu(T <sub>j</sub> ))	Net annual power input without electric back up heating	
TOL(E)	21	-10	1	100.00	4.81	3.73	3.73	1.08	1.08	1.68	5	3	4	2
	22	-9	25	96.15	4.63	3.90	3.90	0.72	18.05	1.77	116	73	98	55
	23	-8	23	92.31	4.44	4.08	4.08	0.36	8.30	1.86	102	59	94	50
A, Tbiv(F)	24	-7	24	88.46	4.26	4.26	4.26	0.00	0.00	1.96	102	52	102	52
	25	-6	27	84.62	4.07	4.08	4.07	0.00	0.00	2.12	110	52	110	52
	26	-5	68	80.77	3.89	3.90	3.89	0.00	0.00	2.28	264	116	264	116
	27	-4	91	76.92	3.70	3.72	3.70	0.00	0.00	2.44	337	138	337	138
	28	-3	89	73.08	3.52	3.54	3.52	0.00	0.00	2.60	313	120	313	120
	29	-2	165	69.23	3.33	3.36	3.33	0.00	0.00	2.76	549	199	549	199
	30	-1	173	65.38	3.15	3.18	3.15	0.00	0.00	2.92	544	186	544	186
	31	0	240	61.54	2.96	3.00	2.96	0.00	0.00	3.08	710	230	710	230
	32	1	280	57.69	2.78	2.82	2.78	0.00	0.00	3.25	777	239	777	239
B	33	2	320	53.85	2.59	2.65	2.59	0.00	0.00	3.41	829	243	829	243
	34	3	357	50.00	2.41	2.59	2.41	0.00	0.00	3.59	859	239	859	239
	35	4	356	46.15	2.22	2.54	2.22	0.00	0.00	3.78	790	209	790	209
	36	5	303	42.31	2.04	2.48	2.04	0.00	0.00	3.96	617	156	617	156
	37	6	330	38.46	1.85	2.43	1.85	0.00	0.00	4.15	611	147	611	147
C	38	7	326	34.62	1.67	2.37	1.67	0.00	0.00	4.33	543	125	543	125
	39	8	348	30.77	1.48	2.45	1.48	0.00	0.00	4.52	515	114	515	114
	40	9	335	26.92	1.30	2.54	1.30	0.00	0.00	4.70	434	92	434	92
	41	10	315	23.08	1.11	2.62	1.11	0.00	0.00	4.89	350	71	350	71
	42	11	215	19.23	0.93	2.71	0.93	0.00	0.00	5.08	199	39	199	39
D	43	12	169	15.38	0.74	2.79	0.74	0.00	0.00	5.27	125	24	125	24
	44	13	151	11.54	0.56	2.87	0.56	0.00	0.00	5.45	84	15	84	15
	45	14	105	7.69	0.37	2.96	0.37	0.00	0.00	5.64	39	7	39	7
	46	15	74	3.85	0.19	3.04	0.19	0.00	0.00	5.83	14	2	14	2
	$\Sigma$		4910							$\Sigma$	9936	2954	9908	2926

SCOPon	3.36	SCOPnet	3.39
<b>SCOP</b>	<b>3.36</b>		

Part load performance diagram

- Medium temperature application (reference water temperature 55 °C)
- Reference heating season „A“ – average



Tested by: Ing Tomáš Sedláček  
 Reviewed and approved by: Ing. Michal Faltýnek



Date: 2024-10-02



Signed:   


## V. Graphs

### 1. Rating conditions



A7/W35 (Control settings: 4)





**A7/W55 (Control settings: 4)**




## 2. Seasonal performance tests and SCOP calculation – Low temperature application

A-7W34 (Control settings: 10)





A2W30 (Control settings: 3)





**A7W28.05 (Control settings: 1)**


A12W26.93 (Control settings: 1)





A-10W35 (Control settings: 10)





### 3. Seasonal performance tests and SCOP calculation – Medium temperature application



A-7W52 (Control settings: 10)





A2W42 (Control settings: 3)





A7W37.84 (Control settings: 1)



A12W35.36 (Control settings: 1)



**A-10W55 (Control settings: 10)**


## **VI. A list of referenced documents**

- Order of 2024-06-27 (Order reg. no. B-82537, received on 2024-06-27)
- Contract B-82537/39
- ČSN EN 14511-2:2023 - Air conditioners, liquid chilling packages and heat pumps for space heating and cooling and process chillers, with electrically driven compressors - Part 2: Test conditions
- ČSN EN 14511-3:2023 - Air conditioners, liquid chilling packages and heat pumps for space heating and cooling and process chillers, with electrically driven compressors - Part 3: Test methods
- ČSN EN 14825:2023 - Air conditioners, liquid chilling packages and heat pumps, with electrically driven compressors, for space heating and cooling, commercial and process cooling - Testing and rating at part load conditions and calculation of seasonal performance

Test Report compiled by: Ing. Tomáš Sedláček



Test Report approved by:

Ing. Mario Jankola  
Heating Equipment and Construction Products Manager

– End of Test Report –



**Strojírenský zkušební ústav, s.p.**  
**(Engineering Test Institute, Public Enterprise)**  
**Hudcova 424/56b, Medlánky, 621 00 Brno, Česká republika**  
Testing Laboratory 1045.1 accredited by the CAI pursuant to ČSN EN ISO/IEC 17025:2018

Page 1 / 19



## **TEST REPORT 39-17853/H**

**Product:** Outdoor Air/Water Heat pump - monobloc

**Type designation:** **EUROS ATMO 7**

**Customer:**  
Euros Energy Sp. z o.o  
ul. Macieja Rataja 4F  
05-850 Koprki  
POLAND

**Manufacturer:**  
Euros Energy Sp. z o.o  
ul. Macieja Rataja 4F  
05-850 Koprki  
POLAND

**Report issue date:** 2024-09-11

**Distribution list:**  
1 copy to the Customer  
1 copy to the Engineering Test Institute


### I. Description of product tested

The Heat pump **EUROS ATMO 7** supplied by the company **Euros Energy Sp. z o.o** is structurally adapted to operate in air/water system. Device is designed as monobloc **EUROS ATMO 7 OUT** placed outside and indoor hydrobox **EUROS ATMO 7 IN** hanging on inner wall. Outdoor and indoor units are connected by water hoses and electrical wires. Refrigerant R32 is used with charge 0.9 kg. Power supply is a one-phase. Heat pump is able to work in heating and cooling mode. Heat pump is working with fixed flow rate.


Main components of the outdoor unit **EUROS ATMO 7 OUT**:

Main components of the indoor hydrobox **EUROS ATMO 7 IN**:


Scheme:



Photodocumentation:



Heat pump **EUROS ATMO 7** – outdoor unit  
– Front view –




Heat pump **EUROS ATMO 7** – outdoor unit  
– Back view –

Not recognized



Heat pump **EUROS ATMO 7** – outdoor unit  
– Compressor label –


Heat pump **EUROS ATMO 7** – outdoor unit  
– Label –




# Heat pump **EUROS ATMO 7** – outdoor unit – Without cover –



# Heat pump **EUROS ATMO 7** – indoor hydrobox – Label –



## Heat pump **EUROS ATMO 7** – indoor hydrobox – With cover –



Heat pump **EUROS ATMO 7** – indoor hydrobox  
– Without cover –

## II. Sample tested

SZU reg. no.	Product name	Date of submission
1212.24.40352.001	EUROS ATMO 7	2024-08-07

The visual inspection, tests and verification were carried out by Ing. Ondrej Bilkovič at the test station of SZU. The tests were performed using measuring and testing equipment with valid calibration.

## III. Measuring and test equipment:

No.	Description	Inventory number
1.	Electrical energy meter	E1.1 E2.1
2.	Digital watt meter	1.2.1 ENERGIE ANALYZATOR_1 1.2.2 ENERGIE ANALYZATOR_2
3.	Flow meter Krohne Optiflux	8.1.1 TECH_K1_V_DN15 8.1.2 TECH_K2_V_DN15 8.1.3 TECH_K2_V_DN25
4.	Barometer	2.4 MAR18_1_PB
5.	Differential pressure gauge	2.2 MAR18_1_dP 3.2 MAR18_2_dP
6.	Thermometers	2.4 MAR18_T 3.4 MAR18_T
7.	Thermo-hydro meter 608-H1	117043
8.	Tape measure	ME 475
9.	Multi-analyser SINUS SoundBook MK2	000-000-000-875/1
10.	Microphone pair G.R.A.S. 40 AK, wind deflector	000-000-000-875/2
11.	Calibrator G.R.A.S. 42AG	000-000-000-875/3

#### **IV. Methods, results of tests and verifications**

No.	Test objective	Requirement	Method of test	Documentation	Test evaluation/verification *
1.	Calculation of sound power level	Art. 9	<b>ČSN ISO 9614-2:1997</b>	Page No. 8-18	+
2.	Acoustic measurements – Sound power level	Art. 8	<b>ČSN EN 12102-1:2023</b>	Page No. 7-18	+
<b>*) Evaluation / statement of conformity:</b>					
+..... Requirement fulfilled		0 .....Not applicable			
-..... Requirement not fulfilled		X .....Not evaluated			

**Note:**

The stated extended measurement uncertainties are calculated as a factor of the measurement uncertainty and the extension coefficient k=2, corresponding to the coverage certainty of 95% as regards standard classification.

If a statement of conformity is provided, the decision rule pursuant to ILAC-G8:09/2019, Art. 4.2.1 – binary statement for the simple acceptance rule shall apply.

<b>Test objective:</b>	Heating and cooling equipment
<b>Exact name of the test procedure:</b>	<b>2.136* - Measurement of noise characteristics</b>
<b>Test method:</b>	<b>ČSN EN 12102-1:2023; ČSN ISO 9614-2:1997</b>
<b>Sample tested:</b>	Air/Water Heat pump <b>EUROS ATMO 7</b>
<b>Measuring equipment used:</b>	see Chapter III
<b>Place of test:</b>	Engineering Test Institute, Hudcova 424/56b, 621 00 Brno, CZ

**Measurement uncertainty:**

Measured quantity	Unit	Uncertainty of measurement	Evaluation
Liquid			
- temperature difference (dT) - temperature inlet/outlet - volume flow - static pressure difference	[K] [°C] [m <sup>3</sup> /s] [kPa]	± 0.15 K ± 0.15 K ± 1 % ± 1 kPa ( $\Delta p \leq 20$ kPa) or ± 5 % ( $\Delta p > 20$ kPa)	fulfilled fulfilled fulfilled fulfilled
Air			
- dry bulb temperature - wet bulb temperature - volume flow - static pressure difference	[°C] [°C] [m <sup>3</sup> /s] [Pa]	± 0.2 K ± 0.4 K ± 5 % ± 5 Pa ( $\Delta p \leq 100$ Pa) or ± 5 % ( $\Delta p > 100$ Pa)	fulfilled fulfilled not applied not applied
Refrigerant			
- pressure at compressor outlet - temperature	[kPa] [°C]	± 1 % ± 0.5 K	not applied not applied
Concentration (in volume)			
- heat transfer medium	[%]	± 2	not applied
Electrical quantities			
- electric power - voltage - current - electric energy	[W] [V] [A] [kWh]	± 1 % ± 0.5 % ± 0.5 % ± 1 %	fulfilled fulfilled fulfilled not applied
Compressor rotational speed	[min <sup>-1</sup> ]	± 0.5 %	not applied
The heating or cooling capacities measured on the liquid side shall be determined within a maximum uncertainty of 5 % independent of the individual uncertainties of measurement including the uncertainties on the properties of fluids.			fulfilled

**Note:**

Comment to abbreviated marking: e.g. A7/W55  
 A (air) 7 (input source air temperature in °C) / W (water), 55 (output heating water temperature in °C)


### a) Measurement surface

Tested samples were surrounded by a cuboid-shaped measurement surface set at the distance  $d$  [m].


<b>Test Sample:</b> Air/Water Heat pump <b>EUROS ATMO 7</b>			<b>Outdoor unit</b>	<b>Indoor unit</b>
Distance from the test sample	$d$	[m]	0.20	0.20
Height of measurement surface	$h$	[m]	0.91	0.45
Width of measurement surface	$w$	[m]	1.40	0.95
Depth of measurement surface	$l$	[m]	0.77	0.97
Total measurement surface area	$S$	[m <sup>2</sup> ]	5.03	2.65
Minimal measuring time per surface	$t_M$	[s]	90.00	90.00

Sketch of measurement surface (not to scale):

Air/Water Heat pump **EUROS ATMO 7**  
 – Outdoor unit –



Air/Water Heat pump **EUROS ATMO 7**  
 – Indoor unit –



**b) Acoustic environment**

The device under test was placed inside a climate chamber (dimensions shown below). The chamber was acoustically treated to be compliant with ČSN EN ISO 3745:2012 requirements for hemi-anechoic chambers. The background noise was stable with the main noise source being the air conditioning of the climate chamber which was set to lower power or momentarily turned off for sufficient signal to noise ratio. The device under test was placed in a position offset from the middle of the chamber, at a sufficient distance from the surrounding walls, and was rotated by about  $5\pm10^\circ$ . Care was taken to ensure low air flow at the measurement surface by adjusting the measurement distance and positions.

Climate-acoustic chamber (corresponds to free field over a reflecting plane)	Outdoor Unit	Indoor Unit
Width of testing room	$l_1$ [m]	5.60 3.75
Length of testing room	$l_2$ [m]	4.50 4.50
Height of testing room	$l_3$ [m]	4.25 4.25

c) **Measured and calculated data – General overview:**

Test sample	Air/Water Heat pump <b>EUROS ATMO 7</b> Indoor unit	Air/Water Heat pump <b>EUROS ATMO 7</b> Outdoor unit		
The measured values are in accordance with ČSN EN 12102-1:2023	YES	YES		
The measured values are in accordance with ČSN EN ISO 9614-2:1997	YES	YES		
Operation mode	Heating	Heating		
Specification of the assessment condition	A7/W55*	A7/W55*		
Type of HP capacity regulation	Inverter	Inverter		
Compressor speed settings	Mode 1	Mode 1		
Fan speed settings	Mode 1	Mode 1		
Date of testing (YYYY-MM-DD)	2024-08-23	2024-08-23		
Reference air temperature	$t_{amb}$	[°C]	21.0	7.0
Relative humidity of air	RH	[%]	62.7	86.7
Ambient pressure	$p_{amb}$	[hPa]	986.3	986.3
Overall sound power level (linear)	$L_w$	[dB]	42.1 ± 1.5	62.9 ± 1.5
Overall A-weighted sound power level	$L_{WA}$	[dB(A)]	32.3 ± 1.5	51.2 ± 1.5
Accuracy class	<b>Engineering (grade 2)</b>			

\* Comment to abbreviated marking: i.e. A7/W55  
 A (water), 7 (input source liquid temperature in °C) / W (water), 55 (outlet heating water temperature in °C)

**1A) Measurement results – octave bands**

Air/Water Heat pump <b>EUROS ATMO 7</b> Indoor unit at A7/W55; Compressor at Mode 1; Fan at Mode 1									<b>Engineering (Grade 2)</b>
---	--	--	--	--	--	--	--	--	----------------------------------

<b>f<sub>m</sub></b> [Hz]	Criterion 1			Criterion 2		Criterion 3		<b>All criteria passed?</b>	<b>L<sub>W</sub></b> [dB]	<b>L<sub>WA</sub></b> [dB(A)]	<b>U</b> [dB]	<b>Evaluation</b>
	<b>L<sub>d</sub></b>	<b>F<sub>pl</sub></b>	<b>L<sub>d</sub> &gt; F<sub>pl</sub></b>	<b>F<sub>+/‐</sub></b>	<b>F<sub>+/‐</sub> ≤ 3</b>	<b>L<sub>W(1)</sub>–L<sub>W(2)</sub> ≤ S</b>						
125	20.9	12.4	YES	1.3	YES	YES	YES	YES	38.8	22.1	± 3.0	passed
250	22.2	5.1	YES	0.0	YES	YES	YES	YES	30.3	22.7	± 2.0	c
500	21.4	0.0	YES	0.0	YES	YES	YES	YES	31.7	28.9	± 1.5	passed
1000	22.3	8.4	YES	3.0	YES	YES	YES	YES	26.7	26.1	± 1.5	c
2000	22.1	3.1	YES	0.0	YES	YES	YES	YES	20.0	21.1	± 1.5	c
4000	20.6	25.8	YES	3.0	YES	NO	NO	NO	15.4	16.5	± 1.5	nc
8000**)	19.7	2.2	YES	0.0	YES	NO	NO	NO	18.5	18.4	± 2.5	nc
<b>Total</b>								<b>42.1</b>	<b>32.3</b>	<b>± 1.5</b>		


\*\*) Due to the sound intensity method limitations, the frequency of 6300 Hz was measured only.

Legend:

- passed** Frequency bands with this description are significant for the calculation of A-weighted total sound power level  $L_{WA}$ . Required accuracy class is fulfilled in this band.
- not passed** Frequency bands with this description are significant for the calculation of A-weighted total sound power level  $L_{WA}$ . Required accuracy class is not fulfilled in this band.
- c** Frequency bands with this description are not significant for the calculation of A-weighted total sound power level  $L_{WA}$ . These bands are evaluated in the calculation of  $L_{WA}$ .
- nc** Frequency bands with this description are not significant for the calculation of A-weighted total sound power level  $L_{WA}$ . These bands are not evaluated in the calculation of  $L_{WA}$ .

Spectrum of Sound power level  $L_w$  – octave bands

Air/Water Heat pump <b>EUROS ATMO 7</b> Indoor unit at A7/W55; Compressor at Mode 1; Fan at Mode 1	<b>Engineering (Grade 2)</b>
---	----------------------------------



**1B) Measurement results – one-third octave bands**

Air/Water Heat pump <b>EUROS ATMO 7</b> Indoor unit at A7/W55; Compressor at Mode 1; Fan at Mode 1									<b>Engineering (Grade 2)</b>
---	--	--	--	--	--	--	--	--	----------------------------------


<b>f<sub>m</sub></b> [Hz]	Criterion 1			Criterion 2		Criterion 3	<b>All criteria passed?</b>	<b>L<sub>w</sub></b> [dB]	<b>L<sub>WA</sub></b> [dB(A)]	<b>U</b> [dB]	<b>Evaluation</b>
	<b>L<sub>d</sub></b>	<b>F<sub>pl</sub></b>	<b>L<sub>d</sub> &gt; F<sub>pl</sub></b>	<b>F<sub>+/-</sub></b>	<b>F<sub>+/-</sub> ≤ 3</b>	<b>L<sub>W(1)</sub>-L<sub>W(2)</sub> ≤ S</b>					
100	20.4	17.2	YES	2.9	YES	YES	YES	35.4	16.3	± 3.0	c
125	20.9	12.4	YES	1.3	YES	YES	YES	34.9	18.8	± 3.0	passed
160	21.3	15.2	YES	2.4	YES	YES	YES	29.9	16.5	± 3.0	passed
200	21.8	7.2	YES	0.0	YES	YES	YES	23.5	12.6	± 2.0	c
250	22.2	5.1	YES	0.0	YES	YES	YES	23.5	14.9	± 2.0	c
315	22.5	1.0	YES	0.0	YES	YES	YES	28.0	21.4	± 2.0	passed
400	22.3	0.0	YES	0.0	YES	YES	YES	25.2	20.4	± 1.5	passed
500	21.4	0.0	YES	0.0	YES	YES	YES	26.7	23.5	± 1.5	passed
<b>630</b>	<b>22.8</b>	<b>0.0</b>	<b>YES</b>	<b>0.0</b>	<b>YES</b>	<b>YES</b>	<b>YES</b>	<b>28.4</b>	<b>26.5</b>	<b>± 1.5</b>	<b>passed</b>
800	22.2	0.0	YES	0.0	YES	YES	YES	26.1	25.3	± 1.5	passed
1000	22.3	8.4	YES	3.0	YES	YES	YES	15.9	15.9	± 1.5	c
1250	21.8	8.9	YES	2.9	YES	YES	YES	12.9	13.5	± 1.5	c
1600	21.9	3.2	YES	0.0	YES	YES	YES	17.3	18.3	± 1.5	passed
2000	22.1	3.1	YES	0.0	YES	YES	YES	14.8	16.0	± 1.5	c
2500	21.7	5.4	YES	0.0	YES	NO	NO	12.3	13.6	± 1.5	nc
3150	21.2	4.3	YES	0.0	YES	YES	YES	13.9	15.1	± 1.5	c
4000	20.6	25.8	YES	3.0	YES	NO	NO	9.2	10.2	± 1.5	nc
5000	19.9	19.7	YES	2.4	YES	NO	NO	2.3	2.8	± 1.5	nc
6300	19.7	2.2	YES	0.0	YES	NO	NO	13.8	13.7	± 2.5	nc
<b>Total</b>								<b>42.1</b>	<b>32.3</b>	<b>± 1.5</b>	

Legend:

- passed** Frequency bands with this description are significant for the calculation of A-weighted total sound power level  $L_{WA}$ . Required accuracy class is fulfilled in this band.
- not passed** Frequency bands with this description are significant for the calculation of A-weighted total sound power level  $L_{WA}$ . Required accuracy class is not fulfilled in this band.
- c** Frequency bands with this description are not significant for the calculation of A-weighted total sound power level  $L_{WA}$ . These bands are evaluated in the calculation of  $L_{WA}$ .
- nc** Frequency bands with this description are not significant for the calculation of A-weighted total sound power level  $L_{WA}$ . These bands are not evaluated in the calculation of  $L_{WA}$ .

Spectrum of Sound power level  $L_w$  – one-third octave bands

Air/Water Heat pump <b>EUROS ATMO 7</b> Indoor unit at A7/W55; Compressor at Mode 1; Fan at Mode 1	Engineering (Grade 2)
---	--------------------------



**2A) Measurement results – octave bands**

Air/Water Heat pump <b>EUROS ATMO 7</b> Outdoor unit at A7/W55; Compressor at Mode 1; Fan at Mode 1									<b>Engineering (Grade 2)</b>
--	--	--	--	--	--	--	--	--	----------------------------------

<b>f<sub>m</sub></b> [Hz]	Criterion 1			Criterion 2		Criterion 3		<b>All criteria passed?</b>	<b>L<sub>w</sub></b> [dB]	<b>L<sub>WA</sub></b> [dB(A)]	<b>U</b> [dB]	<b>Evaluation</b>
	<b>L<sub>d</sub></b>	<b>F<sub>pl</sub></b>	<b>L<sub>d</sub> &gt; F<sub>pl</sub></b>	<b>F<sub>+/-.</sub></b>	<b>F<sub>+/-.</sub> ≤ 3</b>	<b>L<sub>W(1)</sub>-L<sub>W(2)</sub> ≤ S</b>						
125	26.8	3.2	YES	0.0	YES	YES	YES	YES	52.1	35.9	± 3.0	c
250	27.5	1.8	YES	0.0	YES	YES	YES	YES	52.5	43.5	± 2.0	passed
500	28.0	2.1	YES	0.0	YES	YES	YES	YES	50.8	47.7	± 1.5	passed
1000	27.9	2.5	YES	0.0	YES	YES	YES	YES	45.2	45.2	± 1.5	passed
2000	27.2	2.8	YES	0.0	YES	YES	YES	YES	39.0	40.1	± 1.5	c
4000	26.3	5.5	YES	0.0	YES	YES	YES	YES	30.1	31.2	± 1.5	c
8000 <sup>**</sup> )	25.6	18.7	YES	0.0	YES	YES	YES	YES	24.6	24.5	± 2.5	c
<b>Total</b>									<b>57.0</b>	<b>51.2</b>	<b>± 1.5</b>	


<sup>\*\*) Due to the sound intensity method limitations, the frequency of 6300 Hz was measured only.</sup>

Legend:

- passed** Frequency bands with this description are significant for the calculation of A-weighted total sound power level  $L_{WA}$ . Required accuracy class is fulfilled in this band.
- not passed** Frequency bands with this description are significant for the calculation of A-weighted total sound power level  $L_{WA}$ . Required accuracy class is not fulfilled in this band.
- c** Frequency bands with this description are not significant for the calculation of A-weighted total sound power level  $L_{WA}$ . These bands are evaluated in the calculation of  $L_{WA}$ .
- nc** Frequency bands with this description are not significant for the calculation of A-weighted total sound power level  $L_{WA}$ . These bands are not evaluated in the calculation of  $L_{WA}$ .

Spectrum of Sound power level  $L_W$  – octave bands

Air/Water Heat pump <b>EUROS ATMO 7</b> Outdoor unit at A7/W55; Compressor at Mode 1; Fan at Mode 1	<b>Engineering</b> (Grade 2)
--	---------------------------------



**2B) Measurement results – one-third octave bands**


Air/Water Heat pump <b>EUROS ATMO 7</b> Outdoor unit at A7/W55; Compressor at Mode 1; Fan at Mode 1									<b>Engineering (Grade 2)</b>
--	--	--	--	--	--	--	--	--	----------------------------------

<b>f<sub>m</sub></b> [Hz]	Criterion 1			Criterion 2		Criterion 3		<b>All criteria passed?</b>	<b>L<sub>w</sub></b> [dB]	<b>L<sub>WA</sub></b> [dB(A)]	<b>U</b> [dB]	<b>Evaluation</b>
	<b>L<sub>d</sub></b>	<b>F<sub>pl</sub></b>	<b>L<sub>d</sub> &gt; F<sub>pl</sub></b>	<b>F<sub>+/‐</sub></b>	<b>F<sub>+/‐</sub> ≤ 3</b>	<b>L<sub>W(1)</sub>-L<sub>W(2)</sub> ≤ s</b>						
100	27.4	3.9	YES	0.0	YES	YES	YES	YES	47.9	28.8	± 3.0	c
125	26.8	3.2	YES	0.0	YES	YES	YES	YES	48.5	32.4	± 3.0	c
160	27.0	3.8	YES	0.0	YES	YES	YES	YES	44.7	31.3	± 3.0	c
200	27.2	2.2	YES	0.0	YES	YES	YES	YES	49.7	38.8	± 2.0	passed
250	27.5	1.8	YES	0.0	YES	YES	YES	YES	46.2	37.6	± 2.0	passed
<b>315</b>	<b>27.7</b>	<b>2.3</b>	<b>YES</b>	<b>0.0</b>	<b>YES</b>	<b>YES</b>	<b>YES</b>	<b>YES</b>	<b>46.0</b>	<b>39.4</b>	<b>± 2.0</b>	<b>passed</b>
400	27.9	2.2	YES	0.0	YES	YES	YES	YES	46.0	41.2	± 1.5	passed
500	28.0	2.1	YES	0.0	YES	YES	YES	YES	46.4	43.2	± 1.5	passed
<b>630</b>	<b>27.7</b>	<b>2.0</b>	<b>YES</b>	<b>0.0</b>	<b>YES</b>	<b>YES</b>	<b>YES</b>	<b>YES</b>	<b>45.9</b>	<b>44.0</b>	<b>± 1.5</b>	<b>passed</b>
800	27.9	2.5	YES	0.0	YES	YES	YES	YES	40.0	39.2	± 1.5	passed
1000	27.9	2.5	YES	0.0	YES	YES	YES	YES	41.0	41.0	± 1.5	passed
1250	27.3	2.6	YES	0.0	YES	YES	YES	YES	40.2	40.8	± 1.5	passed
1600	26.8	2.7	YES	0.0	YES	YES	YES	YES	37.7	38.7	± 1.5	passed
2000	27.2	2.8	YES	0.0	YES	YES	YES	YES	31.3	32.5	± 1.5	c
2500	26.8	2.9	YES	0.0	YES	YES	YES	YES	28.4	29.7	± 1.5	c
3150	26.5	3.8	YES	0.0	YES	YES	YES	YES	25.9	27.1	± 1.5	c
4000	26.3	5.5	YES	0.0	YES	YES	YES	YES	28.0	29.0	± 1.5	c
5000	25.8	14.3	YES	2.5	YES	YES	YES	YES	10.3	10.8	± 1.5	c
6300	25.6	18.7	YES	0.0	YES	YES	YES	YES	19.8	19.7	± 2.5	c
<b>Total</b>									<b>62.9</b>	<b>51.2</b>	<b>± 1.5</b>	

Legend:

- passed** Frequency bands with this description are significant for the calculation of A-weighted total sound power level  $L_{WA}$ . Required accuracy class is fulfilled in this band.
- not passed** Frequency bands with this description are significant for the calculation of A-weighted total sound power level  $L_{WA}$ . Required accuracy class is not fulfilled in this band.
- c** Frequency bands with this description are not significant for the calculation of A-weighted total sound power level  $L_{WA}$ . These bands are evaluated in the calculation of  $L_{WA}$ .
- nc** Frequency bands with this description are not significant for the calculation of A-weighted total sound power level  $L_{WA}$ . These bands are not evaluated in the calculation of  $L_{WA}$ .

Spectrum of Sound power level  $L_W$  – one-third octave bands



Tested by:

Ing. Ondrej Bilkovič

Date:

2024-09-11

Signed:



Reviewed and  
approved by:

Ing. Antonín Kolbábek, Ph.D.

Date:

2024-09-11

Signed:



## V. A list of referenced documents

- Order of 2024-06-27 (Order reg. no. B-82537, received on 2024-06-27)
- Contract B-82537/39
- ČSN EN 12102-1:2023 - Air conditioners, liquid chilling packages, heat pumps, process chillers and dehumidifiers with electrically driven compressors - Determination of the sound power level - Part 1: Air conditioners, liquid chilling packages, heat pumps for space heating and cooling, dehumidifiers and process chillers
- ČSN ISO 9614-2:1997 - Acoustics - Determination of sound power levels of noise sources using sound intensity - Part 2: Measurement by scanning
- ČSN EN 14511-2:2023 - Air conditioners, liquid chilling packages and heat pumps for space heating and cooling and process chillers, with electrically driven compressors - Part 2: Test conditions
- ČSN EN 14511-3:2023 - Air conditioners, liquid chilling packages and heat pumps for space heating and cooling and process chillers, with electrically driven compressors - Part 3: Test methods
- ČSN EN 14511-4:2023 - Air conditioners, liquid chilling packages and heat pumps for space heating and cooling and process chillers, with electrically driven compressors - Part 4: Requirements
- ČSN EN 14825:2023 - Air conditioners, liquid chilling packages and heat pumps, with electrically driven compressors, for space heating and cooling, commercial and process cooling - Testing and rating at part load conditions and calculation of seasonal performance
- Background of the SZU task no. 39-17853
- Record measurement file 39-17853-H.zip

Test Report compiled by:

**Ing. Ondrej Bilkovič**  
Test engineer



Test Report approved by:

**Ing. Antonín Kolbábek, Ph.D.**  
Hydraulic and Pressure Equipment Manager

– End of Test Report –



Instytut Badawczy Przemysłu Maszynowego, przedsiębiorstwo państwowe, Brno, Republika Czeska  
Engineering Test Institute. Public Enterprise. Brno. Czech Republic

## CERTYFIKAT Z BADAŃ TEST CERTIFICATE

Number **O-B-01662-24**

Producent  
*Customer*

Euros Energy Sp. z o.o  
ul. Macieja Rataja 4F  
05-850 Koprki  
POLAND

Produkt  
*Product*

Pompa Ciepła powietrze/woda – monoblok  
*Outdoor Air/Water Heat Pump – monobloc*

Rodzaj oznaczenia / znak towarowy  
*Type designation / Trade mark*

**EUROS ATMO 7**

Metoda testowa  
*Test methods*

ČSN EN 14511-2:2023, ČSN EN 14511-3:2023,  
ČSN EN 12102-1:2023

Podstawy zaświadczenia  
*Basis of certificate*

Raport z badań - *Test reports:*  
39-17853/T z dnia - of 2024-10-02  
39-17853/H z dnia - of 2024-09-11  
Dokumentacja techniczna przedstawiona przez - *Technical documents of Euros Energy Sp. z o.o*

Zastosowanie  
*Temperature application*

**NISKOTEMPERATUROWA - LOW,  
WYSOKOTEMPERATUROWA - MEDIUM**

referencyjna temperatura wody 35 °C i 55 °C - Reference water temperature 35 °C and 55 °C

### Wyniki - Results:

Warunki cieplne*	A7/W35	A7/W55
Temperature conditions*		
Skorygowana moc grzewcza <i>Corrected heat capacity</i>	[kW]	3.560
Efektywny pobór mocy elektrycznej <i>Effective electric power input</i>	[kW]	0.723
Współczynnik efektywności <i>Coefficient of performance</i>	[–]	4.925
Ustawienia sterowania <i>Control settings</i>	[–]	4

(\*) Uwagi do skróconych oznaczeń: np. A7/W35: A (powietrze), 7 (temperatura wejściowa - temperatura termometru suchego) w °C, W (woda), 35 (temperatura wyjściowa) w °C.

Comment to abbreviated marking: e.g. A7/W35: A (air), 7 (input air – dry bulb temperature in °C) / W (water), 35 (output heating water temperature in °C).

**Poziom mocy akustycznej dla danych warunków temperaturowych A7/W55<sup>\*</sup> (Mode 1):**  
**Sound power level at temperature condition A7/W55<sup>\*</sup> (Mode 1):**

Pompa Ciepla Powietrze/Woda –  
monobloc  
*Air/Water Heat Pump – monobloc*

**EUROS ATMO 7 OUT**  
– Jednostka zewnętrzna –  
– outdoor unit –

**EUROS ATMO 7 IN**  
– Jednostka wewnętrzna –  
– indoor unit –

Poziom mocy akustycznej  
*Sound power level*  
Klasa dokładności  
*Accuracy class*

$L_{WA}$   $51.2 \pm 1.5$  dB(A)  
Techniczna (2)  
Engineering (2)

$L_{WA}$   $32.3 \pm 3.0$  dB(A)  
Techniczna (2)  
Engineering (2)

(\*) Uwagi do skróconych oznaczeń: np. A7/W35: A (powietrze), 7 (temperatura wejściowa - temperatura termometru suchego) w °C, W (woda), 35 (temperatura wyjściowa) w °C.

*Comment to abbreviated marking: e.g. A7/W35: A (air), 7 (input air – dry bulb temperature in °C) / W (water), 35 (output heating water temperature in °C).*

**Specyfikacja warunków - Specification of conditions:**

Kontrola prędkości kompresora <i>Compressor speed control</i>	Zmienna <i>Variable</i>	Nominalne natężenie przepływu cieczy (wewnętrzny wymiennik ciepła) - <i>Rated liquid flow rate (indoor heat exchanger)</i>	Stała <i>Fixed</i>
Wylotowa temperatura wody (wewnętrzny wymiennik ciepła) - <i>Outlet water temperature (indoor heat exchanger)</i>	Zmienna <i>Variable</i>	Nominalne natężenie przepływu cieczy (zewnętrzny wymiennik ciepła) - <i>Rated liquid flow rate (outdoor heat exchanger)</i>	–
Funkcja <i>Function</i>	Odwrotna <i>Reversible</i>		

Instytut Badawczy Przemysłu Maszynowego, przedsiębiorstwo państowe potwierdza niniejszym certyfikatem z badań, że badanie produktu, którego dotyczy dalo wyniki wskazane powyżej. Instytut Badawczy Przemysłu Maszynowego, przedsiębiorstwo państowe jest akredytowanym Laboratorium 1045.1.

*Engineering Test Institute, Public Enterprise, confirms by this Test Certificate that the testing of the product in question was performed with the results as stated above. Engineering Test Institute, Public Enterprise, is an accredited Testing Laboratory 1045.1.*

Brno, 2024-10-03

**Ing. Mario Jankola**



Kierownik ds. Urządzeń Grzewczych i Wyrobów Budowlanych  
*Heating Equipment and Construction Products Manager*  
- KONIEC CERTYFIKATU Z BADAŃ -  
- END OF TEST CERTIFICATE -



Instytut Badawczy Przemysłu Maszynowego, przedsiębiorstwo państowe, Brno, Republika Czeska  
Engineering Test Institute. Public Enterprise. Brno. Czech Republic

# CERTYFIKAT Z BADAŃ

## TEST CERTIFICATE

Number **O-B-01663-24**

Producent  
*Customer*

Euros Energy Sp. z o.o  
ul. Macieja Rataja 4F  
05-850 Koprki  
POLAND

Produkt  
*Product*

Pompa Ciepła powietrze/woda – monoblok  
*Outdoor Air/Water Heat Pump – monobloc*

Rodzaj oznaczenia / znak towarowy  
*Type designation / Trade mark*

**EUROS ATMO 7**

Metoda testowa  
*Test methods*

ČSN EN 14511-2:2023, ČSN EN 14511-3:2023,  
ČSN EN 14825:2023, ČSN EN 12102-1:2023

Podstawy zaświadczenia  
*Basis of certificate*

Raport z badań - *Test reports:*  
39-17853/T z dnia - of 2024-10-02  
39-17853/H z dnia - of 2024-09-11  
Dokumentacja techniczna przedstawiona przez - *Technical documents of Euros Energy Sp. z o.o*

Referencyjny okres grzewczy  
*Reference heating season*

**, „A“ = Średni - „A“ = average**  
(Warunki obliczeniowe odniesienia dla ogrzewania  $T_{designh} = -10^{\circ}\text{C}$  - Reference design temperature  $T_{designh} = -10^{\circ}\text{C}$ )

### Wyniki - Results:

#### NISKA TEMPERATURA *LOW TEMPERATURE*

Referencyjna temperatura wody 35 °C - Reference water temperature 35 °C

#### ŚREDNIA TEMPERATURA *MEDIUM TEMPERATURE*

Referencyjna temperatura wody 55 °C - Reference water temperature 55 °C

<b>5.22</b>	$P_{designh}$ [kW] ... Obciążenie obliczeniowe dla trybu ogrzewania - <i>Full load heating</i>	<b>4.81</b>
<b>4.82</b>	$SCOP$ [-] ... Wskaźnik sezonowej efektywności - <i>Seasonal coefficient of performance</i>	<b>3.36</b>

Temperatura zewnętrzna <i>Outdoor temperature</i>	Deklarowana wydajność grzewcza <i>Heating declared capacity</i>	Wskaźnik efektywności dla deklarowanej wydajności <i>Coefficient of performance at the declared capacity</i>	Temperatura zewnętrzna <i>Outdoor temperature</i>	Deklarowana wydajność grzewcza <i>Heating declared capacity</i>	Wskaźnik efektywności dla deklarowanej wydajności <i>Coefficient of performance at the declared capacity</i>
$T_j$ [°C]	$P_{dh}$ [kW]	$COP_d$ [-]	$T_j$ [°C]	$P_{dh}$ [kW]	$COP_d$ [-]
$T_j = -7$	4.620	2.958	$T_j = -7$	4.255	1.955
$T_j = +2$	2.892	4.869	$T_j = +2$	2.646	3.407
$T_j = +7$	2.552	6.251	$T_j = +7$	2.370	4.377
$T_j = +12$	2.892	7.719	$T_j = +12$	2.789	5.680
$T_j = TOL = -10$	4.232	2.745	$T_j = TOL = -10$	3.727	1.679
$T_j = T_{bivalent} = -7$	4.620	2.958	$T_j = T_{bivalent} = -7$	4.255	1.955

O-B-01663-24, strona - page 1 (2)

Strojírenský zkušební ústav, s.p., Hudcová 424/56b, 621 00 Brno, Česká republika  
Engineering Test Institute, public enterprise, Hudcová 424/56b, 621 00 Brno, Czech Republic

**NISKA TEMPERATURA**  
**LOW TEMPERATURE**

Referencyjna temperatura wody 35 °C - Reference water temperature 35 °C

**ŚREDNIA TEMPERATURA**  
**MEDIUM TEMPERATURE**

Referencyjna temperatura wody 55 °C - Reference water temperature 55 °C

**Pobór mocy w trybach innych niż „tryb aktywny” - Power consumption in modes other than „active mode”**

13.8	Tryb wyłączenia Off mode	P <sub>OFF</sub>	[W]	13.8
13.9	Tryb wyłączonego termostatu Thermostat off mode	P <sub>TO</sub>	[W]	13.9
13.8	Tryb czuwania Standby mode	P <sub>SB</sub>	[W]	13.8
0.0	Tryb włączonej grzałki karteru Crankcase heater mode	P <sub>CK</sub>	[W]	0.0

Rocznego zużycie energii elektrycznej na potrzeby ogrzewania wg: - Annual electricity consumption for heating according to:

2238	ČSN EN 14825:2023	Q <sub>HE</sub>	[kWh]	2957
------	-------------------	-----------------	-------	------

**Sezonowa efektywność energetyczna ogrzewania pomieszczeń - Seasonal Space heating energy efficiency**

189.8	ČSN EN 14825:2023	η <sub>s</sub>	[%]	131.4
-------	-------------------	----------------	-----	-------

**Przepływ cieczy w zewnętrzny wymienniku ciepła - Liquid flow rate in outdoor heating exchanger**

-	Ciecz obiegu źródła Source liquid	Min/Max	[m <sup>3</sup> /h]	-
---	--------------------------------------	---------	---------------------	---

**Przepływ cieczy w wewnętrznym wymienniku ciepła - Liquid flow rate in indoor heating exchanger**

0.623	Woda grzewcza Heating water	Min/Max	[m <sup>3</sup> /h]	0.332
-------	--------------------------------	---------	---------------------	-------

**Poziom mocy akustycznej dla warunków - Sound power level at condition A7/W55\* (Mode 1):**

<b>EUROS ATMO 7 OUT</b> - Jednostka zewnętrzna – - outdoor unit –	L <sub>WA</sub>	51.2 ± 1.5	dB(A)	Klasa dokładności 2 (Techniczna) Accuracy class 2 (Engineering)
<b>EUROS ATMO 7 IN</b> - Jednostka wewnętrzna – - indoor unit –	L <sub>WA</sub>	32.3 ± 1.5	dB(A)	Klasa dokładności 2 (Techniczna) Accuracy class 2 (Engineering)

(\*) Uwagi do skróconych oznaczeń: np. A7/W55: A (powietrze), 7 (temperatura wejściowa - temperatura termometru suchego w °C), W (woda), 55 (temperatura wyjściowa w °C).

Comment to abbreviated marking: e.g. A7/W55: A (air), 7 (input air – dry bulb temperature in °C) / W (water), 55 (output heating water temperature in °C).


**Specyfikacja warunków - Specification of conditions:**

Kontrola prędkości kompresora Compressor speed control	Zmienna Variable	Nominalne natężenie przepływu cieczy (wewnętrzny wymiennik ciepła) - Rated liquid flow rate (indoor heat exchanger)	Stała Fixed
Wylotowa temperatura wody (wewnętrzny wymiennik ciepła) - Outlet water temperature (indoor heat exchanger)	Zmienna Variable	Nominalne natężenie przepływu cieczy (zewnętrzny wymiennik ciepła) - Rated liquid flow rate (outdoor heat exchanger)	-
Funkcja Function	Odwrotna Reversible		

Instytut Badawczy Przemysłu Maszynowego, przedsiębiorstwo państowe potwierdza niniejszym certyfikatem z badań, że badanie produktu, którego dotyczy dalo wyniki wskazane powyżej. Instytut Badawczy Przemysłu Maszynowego, przedsiębiorstwo państowe jest akredytowanym Laboratorium 1045.1.

Engineering Test Institute, Public Enterprise, confirms by this Test Certificate that the testing of the product in question was performed with the results as stated above. Engineering Test Institute, Public Enterprise, is an accredited Testing Laboratory 1045.1.

Brno, 2024-10-03

  
**Ing. Mario Jankola**

Kierownik ds. Urządzeń Grzewczych i Wyrobów Budowlanych  
Heating Equipment and Construction Products Manager  
- KONIEC CERTYFIKATU Z BADAN -  
- END OF TEST CERTIFICATE -



## OŚWIADCZENIE

Producent **Euros Energy Sp. z o.o.** oświadcza, iż pompy ciepła

1) **Euros ATMO 7 OUT + Euros ATMO 7 INO**

Oznaczenie/typ/identyfikator modelu

**Euros ATMO 7 OUT + Euros HYDRO 200 A10**

Oznaczenie/typ/identyfikator modelu

2) **Euros ATMO 11 OUT + Euros ATMO 11 INO**

Oznaczenie/typ/identyfikator modelu

**Euros ATMO 11 OUT + Euros HYDRO 200 A10**

Oznaczenie/typ/identyfikator modelu

Należą do jednego podtypu w danym typozzeregu i spełniają łącznie następujące warunki:

- identyczna konstrukcja obiegu chłodniczego, ten sam czynnik chłodniczy/roboczy;
- ten sam producent, typ i liczba sprężarek;
- ten sam typ elementu rozprężnego;
- ten sam typ skraplacza;
- ten sam typ parownika;
- ten sam typ procesu odszraniania;
- ten sam sterownik i zasada sterowania wydajnością;
- ten sam producent, typ i liczba wentylatorów parownika (w przypadku powietrznych pomp ciepła) i zasada sterowania wydajnością (stała, zmenna lub stopniowana regulacja prędkości obrotowej);
- urządzenia z i bez zaworu czterodrogowego nie mogą być zaliczone do tego samego typozzeregu.

**Paweł Kwiatkowski**

**Dyrektor  
Działu Rozwoju Produktu**

**Koprki, 10.10.2024r.**  
Miejscowość, data

**Paweł Maria Kwiatkowski**  
Podpis osoby upoważnionej