

Prüfbedingung  
Test condition

Verbrauch (Consumption)

A12 / Wxx-24 D

Prüfnummer  
Test number

LW-694-24-53

| Messgrößen<br>Measured variables | Einheit<br>Unit | Mittelwert<br>Mean value | abs. Fehler<br>absolute error | rel. Fehler<br>relative error |
|----------------------------------|-----------------|--------------------------|-------------------------------|-------------------------------|
| 1 Pto                            | W               | 16.4                     | ± 0.3                         | ± 2.00%                       |
| 2 Psb                            | W               | 11.4                     | ± 0.2                         | ± 2.00%                       |
| 3 Poff                           | W               | 11.4                     | ± 0.2                         | ± 2.00%                       |
| 4 Pck                            | W               | -                        | ± -                           | ± -                           |
| 5 Prüfdauer (test duration)      | hh:mm:ss        | 4:04:30                  |                               |                               |
| Prüfbeginn (beginning of test)   | hh:mm:ss        | 08:06:10                 | 12.12.2024                    | 2024-12-12                    |
| Prüfende (end of test)           | hh:mm:ss        | 12:10:40                 | 12.12.2024                    | 2024-12-12                    |

6 Bemerkung (remark)

7 Prüfer (supervisor)

C. Schaible

Prüfnorm (test standard)

EN 14825

passed