

TEST REPORT

Report no.: 300-KLAB-24-023-1



**DANISH
TECHNOLOGICAL
INSTITUTE**

Teknologiparken
Kongsvang Allé 29
DK-8000 Aarhus C
+45 72 20 20 00
Info@teknologisk.dk
www.teknologisk.dk

Page 1 of 33
Init: PRES/RTHI/AAS
File no.: 249428
Enclosures: 2

Customer:

Component:

Dates: Component tested: April-June 2024

Brand name: Brand: KOSPEL
Type: Air to water heat pump
Model: HPMO2-16/23

Procedure: See objective (page 2) for list of standards.

Remarks: The unit was delivered by the customer. The installation and test settings were done according to the manufacturer's instructions. The report for the tested unit is named 300-KLAB-24-023 issued 2024.07.24 - Also see appendix 2.

Terms: This test was conducted under accreditation in accordance with international requirements (ISO/IEC 17025:2017) and in accordance with the General Terms and Conditions of Danish Technological Institute. The test results solely apply to the tested item. This test report may be quoted in extract only if Danish Technological Institute has granted its written consent.

The customer may not mention or refer to Danish Technological Institute or Danish Technological Institute's employees for advertising or marketing purposes unless Danish Technological Institute has granted its written consent in each case.

Division/Centre: Danish Technological Institute
Energy and Climate
Heat Pump Laboratory, Aarhus

Date: 2024.08.13

Signature:
Preben Eskerod
B.TecMan & MarEng

Co-reader:
Rasmus Thisgaard
B.TecMan & MarEng



 **DANAK**
Test Reg. nr. 300



Objective

The objective of this report is to document the following:

The Seasonal Coefficient of Performance (SCOP) at low and medium temperature application for average climate according to EN 14825:2022.

In order to calculate the SCOP, tests were carried out at the part load conditions stated in the tables on page 4 and 5.

COP test standard rating conditions A7/W35 and A7/W55 according to EN 14511:2022.

Sound power measurements according to EN 12102-1:2022.




Contents:

Test conditions	4
SCOP test conditions for low temperature – EN 14825	4
SCOP test conditions for medium temperature – EN 14825	5
COP test conditions - low temperature – EN 14511	6
COP test conditions - medium temperature – EN 14511	6
Test conditions for sound power measurements – EN 12102-1	6
Test results	7
Test results of SCOP test at low temperature - heating season average – EN 14825	7
Test results of SCOP test at medium temperature - heating season average – EN 14825	8
COP test results - low temperature – EN 14511	9
COP test results - medium temperature – EN 14511	9
Test results of sound power measurements – EN 12102-1	9
Photos	10
SCOP - detailed calculation	12
Detailed SCOP calculation of low temperature and average climate conditions – EN 14825	12
Detailed SCOP calculation of medium temperature and average climate conditions – EN 14825	14
Detailed test results	16
Detailed SCOP part load test results - low temperature application - average climate – EN 14825	16
Detailed SCOP part load test results - medium temperature application - average climate – EN 14825	21
Detailed COP test results - low temperature – EN 14511	26
Detailed COP test results - medium temperature – EN 14511	27
Detailed test results of sound power measurement – Test N#1	28
Appendix 1 Unit specification	29
Appendix 2 Brand name	33









Test results

Test results of SCOP test at low temperature - heating season average – EN 14825

Model (Outdoor)	
Air-to-water heat pump mono bloc	Y
Low-temperature heat pump	N
Equipped with supplementary heater	N
Heat pump combination heater	N
Reversible	Y

Rated heat output¹⁾	P_{rated}	13.01 [kW]
Seasonal space heating energy efficiency	η_s	185.5 [%]
	SCOP	4.71 [-]

Measured capacity for heating for part load at outdoor temperature T_j	Average Climate	$T_j = -15\text{ °C}$	P_{dh}	- [kW]
		$T_j = -7\text{ °C}$	P_{dh}	11.62 [kW]
	Low temperature application	$T_j = 2\text{ °C}$	P_{dh}	7.56 [kW]
		$T_j = 7\text{ °C}$	P_{dh}	7.40 [kW]
		$T_j = 12\text{ °C}$	P_{dh}	8.21 [kW]
		$T_j = \text{bivalent temperature}$	P_{dh}	11.62 [kW]
		$T_j = \text{operation limit}$	P_{dh}	10.11 [kW]

Measured coefficient of performance at outdoor temperature T_j	Average Climate	$T_j = -15\text{ °C}$	COPd	- [-]
		$T_j = -7\text{ °C}$	COPd	3.04 [-]
	Low temperature application	$T_j = 2\text{ °C}$	COPd	4.64 [-]
		$T_j = 7\text{ °C}$	COPd	6.07 [-]
		$T_j = 12\text{ °C}$	COPd	8.12 [-]
		$T_j = \text{bivalent temperature}$	COPd	3.04 [-]
		$T_j = \text{operation limit}$	COPd	2.43 [-]

Bivalent temperature	$T_{bivalent}$	-7 [°C]
Operation limit temperatures	TOL	-10 [°C]
Degradation coefficient	C_{dh}	0.98 [-]

Power consumption in modes other than active mode	Off mode	P_{OFF}	0.022 [kW]
	Thermostat-off mode	P_{TO}	0.022 [kW]
	Standby mode	P_{SB}	0.022 [kW]
	Crankcase heater mode	P_{CK}	0.022 [kW]
Supplementary heater¹⁾	Rated heat output	P_{SUP}	2.90 [kW]
	Type of energy input		Electrical

Other items	Capacity control		Variable
	Water flow control		Fixed
	Water flow rate		2948 [l/h]
	Annual energy consumption	Q_{HE}	5704 [kWh]

¹⁾For heat pump space heaters and heat pump combination heaters, the rated heat output, P_{rated} , is equal to the design load for heating, $P_{design,h}$, and the rated heat output of a supplementary heater, P_{sup} , is equal to the supplementary capacity for heating, $sup(T_j)$.



Test results of SCOP test at medium temperature - heating season average – EN 14825

Model (Outdoor)	
Air-to-water heat pump mono bloc	Y
Low-temperature heat pump	N
Equipped with supplementary heater	N
Heat pump combination heater	N
Reversible	Y

Rated heat output¹⁾	P_{rated}	14.42 [kW]
Seasonal space heating energy efficiency	η_s	133.2 [%]
	SCOP	3.40 [-]

Measured capacity for heating for part load at outdoor temperature T_j	Average Climate	$T_j = -15\text{ °C}$	P_{dh}	- [kW]
	-	$T_j = -7\text{ °C}$	P_{dh}	13.58 [kW]
	Medium temperature application	$T_j = 2\text{ °C}$	P_{dh}	8.07 [kW]
		$T_j = 7\text{ °C}$	P_{dh}	6.71 [kW]
		$T_j = 12\text{ °C}$	P_{dh}	8.19 [kW]
		$T_j = \text{bivalent temperature}$	P_{dh}	13.58 [kW]
		$T_j = \text{operation limit}$	P_{dh}	14.02 [kW]

Measured coefficient of performance at outdoor temperature T_j	Average Climate	$T_j = -15\text{ °C}$	COPd	- [-]
	-	$T_j = -7\text{ °C}$	COPd	2.28 [-]
	Medium temperature application	$T_j = 2\text{ °C}$	COPd	3.22 [-]
		$T_j = 7\text{ °C}$	COPd	4.34 [-]
		$T_j = 12\text{ °C}$	COPd	6.40 [-]
		$T_j = \text{bivalent temperature}$	COPd	2.28 [-]
		$T_j = \text{operation limit}$	COPd	1.85 [-]

Bivalent temperature	$T_{bivalent}$	-7 [°C]
Operation limit temperatures	TOL	-10 [°C]
Degradation coefficient	WTOL	- [°C]
	C_{dh}	0.98 [-]

Power consumption in modes other than active mode	Off mode	P_{OFF}	0.022 [kW]
	Thermostat-off mode	P_{TO}	0.022 [kW]
	Standby mode	P_{SB}	0.022 [kW]
	Crankcase heater mode	P_{CK}	0.022 [kW]
Supplementary heater¹⁾	Rated heat output	P_{SUP}	0.40 [kW]
	Type of energy input		Electrical

Other items	Capacity control		Variable
	Water flow control		Fixed
	Water flow rate		1510 [l/h]
	Annual energy consumption	Q_{HE}	8750 [kWh]

¹⁾For heat pump space heaters and heat pump combination heaters, the rated heat output, P_{rated} , is equal to the design load for heating, $P_{designh}$, and the rated heat output of a supplementary heater, P_{sup} , is equal to the supplementary capacity for heating, $sup(T_j)$.



COP test results - low temperature – EN 14511

N#	Test conditions	Heating capacity [kW]	COP
1	A7/W35	17.297	4.948

COP test results - medium temperature – EN 14511

N#	Test conditions	Heating capacity [kW]	COP
1	A7/W55	14.312	2.768


Test results of sound power measurements – EN 12102-1


N#	Test conditions	Sound power level LW(A) [dB re 1pW]	Uncertainty σ_{tot} [dB]
1 ^E	A7/W55	59.2	1.6

E) ErP labelling

The A-weighted total sound power level is determined for the measured frequency range from 100 Hz to 10 kHz. For the calculation of uncertainty, see appendix 1.

The sound power measurements are carried out by Kamalathan Arumugam (KAMA) and co-read by Patrick Glibert (PGL), Danish Technological Institut.







SCOP - detailed calculation

Detailed SCOP calculation of low temperature and average climate conditions – EN 14825

Calculation of reference SCOP

$$SCOP = \frac{P_{designh} \times H_{he}}{\frac{P_{designh} \times H_{he}}{SCOP_{on}} + H_{TO} \times P_{TO} + H_{SB} \times P_{SB} + H_{CK} \times P_{CK} + H_{OFF} \times P_{OFF}}$$

Where

P_{design} =

Heating load of the building at design temperature, kW

H_{he} =

Number of equivalent heating hours, 2066 h

H_{TO} , H_{SB} , H_{CK} , H_{OFF} =

Number of hours for which the unit is considered to work in thermostat off mode, standby mode, crankcase heater mode and off mode, h, respectively

P_{TO} , P_{SB} , P_{CK} , P_{OFF} =


Electricity consumption during thermostat off mode, standby mode, crankcase heater mode and off mode, kW, respectively

Data for SCOP

	Outdoor temperature [°C]	Part load ratio [%]	Part load [kW]	Declared capacity [kW]	Declared COP [-]	cdh [-]	CR [-]	COPbin [-]
A	-7	88	11.51	11.62	3.04	0.99	1.00	3.04
B	2	54	7.01	7.56	4.64	0.99	1.00	4.64
C	7	35	4.50	7.40	6.07	0.98	0.61	6.00
D	12	15	2.00	8.21	8.12	0.98	0.24	7.60
E	-10	100	13.01	10.11	2.43	0.99	1.00	2.43
F - BIV	-7	88	11.51	11.62	3.04	0.99	1.00	3.04

Energy consumption for thermostat off, standby, off mode, crankcase heater mode

	Hours [h]	Power input [kW]	Applied to SCOP calculation [kW]	Energy consumption [kWh]
Off mode	0	0.022166	0.02217	0
Thermostat off	178	0.022344	0.02234	3.9772409
Standby	0	0.022166	0.02217	0
Crankcase heater	178	0.022168	1.9E-06	0.0003299





Detailed SCOP calculation of medium temperature and average climate conditions – EN 14825

Calculation of reference SCOP

$$SCOP = \frac{P_{designh} \times H_{he}}{\frac{P_{designh} \times H_{he}}{SCOP_{on}} + H_{TO} \times P_{TO} + H_{SB} \times P_{SB} + H_{CK} \times P_{CK} + H_{OFF} \times P_{OFF}}$$

Where

P_{design} = Heating load of the building at design temperature, kW

H_{he} = Number of equivalent heating hours, 2066 h

H_{TO} , H_{SB} , H_{CK} , H_{OFF} = Number of hours for which the unit is considered to work in thermostat off mode, standby mode, crankcase heater mode and off mode, h, respectively


P_{TO} , P_{SB} , P_{CK} , P_{OFF} = Electricity consumption during thermostat off mode, standby mode, crankcase heater mode and off mode, kW, respectively


Data for SCOP


	Outdoor temperature [°C]	Part load ratio [%]	Part load [kW]	Declared capacity [kW]	Declared COP [-]	cdh [-]	CR [-]	COPbin [-]
A	-7	88	12.76	13.58	2.28	1.00	1.00	2.28
B	2	54	7.76	8.07	3.22	0.99	1.00	3.22
C	7	35	4.99	6.71	4.34	0.99	0.74	4.32
D	12	15	2.22	8.19	6.40	0.98	0.27	6.12
E	-10	100	14.42	14.02	1.85	1.00	1.00	1.85
F - BIV	-7	88	12.76	13.58	2.28	1.00	1.00	2.28


Energy consumption for thermostat off, standby, off mode, crankcase heater mode


	Hours [h]	Power input [kW]	Applied to SCOP calculation [kW]	Energy consumption [kWh]
Off mode	0	0.022166	0.02217	0
Thermostat off	178	0.022344	0.02234	3.9772409
Standby	0	0.022166	0.02217	0
Crankcase heater	178	0.022168	1.9E-06	0.0003299











































Measurement instruments

Id nr.	Manufacturer	Description	Calibration company
100864	GRAS	Gras 40AE_26CA, 1/2" free field microphone, Room 1	Norsonic A/S, Norway
100865	GRAS	Gras 40AE_26CA, 1/2" free field microphone, Room 1	Norsonic A/S, Norway
100866	GRAS	Gras 40AE_26CA, 1/2" free field microphone, Room 1	Norsonic A/S, Norway
100867*	GRAS	Gras 40AE_26CA, 1/2" free field microphone, Room 2	Norsonic A/S, Norway
100868*	GRAS	Gras 40AE_26CA, 1/2" free field microphone, Room 2	Norsonic A/S, Norway
100869*	GRAS	Gras 40AE_26CA, 1/2" free field microphone, Room 2	Norsonic A/S, Norway
100870	GRAS	Gras 40AE_26CA, 1/2" free field microphone, Roof monitor	Norsonic A/S, Norway
100873*	Brüel & Kjær	Acoustical calibrator, Brüel & Kjær 4231	Element Metech, Denmark
100859	Norsonic	Reference sound source, Norsonic Nor278 Room 1	RISE, Sweden
100872*	Norsonic	Reference sound source, Norsonic Nor278 Room 2	RISE, Sweden
100620*	Norsonic	Multi-channel measurement system Nor850	Norsonic A/S, Norway

*Instruments are used for the actual measurements for the calculation of the test results.

The other instruments are used for control measurements.
All microphones are equipped with windshields.

